

# Compton College Administration Building Renovation

tBP Project No. 20987.00

DSA #3 - 119689

File #

Bid No:

Compton College  
Compton, California

## PROJECT MANUAL

Volume 1 of 1  
Divisions 00 - 32  
August 2019

■ **Architect:**

tBP/Architecture  
4611 Teller Ave. Newport Beach, CA 92660-2104  
949. 673. 0300

tBP

Architecture  
Planning  
Interiors  
Management





**SECTION 00 01 01  
PROJECT TITLE PAGE**

**FOR**

**ADMINISTRATION BUILDING RENOVATION**

**PROJECT NUMBER: 20987.00**

**DISTRICT**

**COMPTON COMMUNITY COLLEGE DISTRICT  
1111 E. ARTESIA BOULEVARD, COMPTON CA 90221  
310.900.1600  
WWW.COMPTON.EDU**

**PROJECT LOCATION**

**COMPTON COLLEGE  
1111 E. ARTESIA BOULEVARD  
COMPTON , CALIFORNIA 90221**

**PREPARED BY:**

**ARCHITECT**

**TBP/ARCHITECTURE, INC.**

4611 Teller Avenue, Newport Beach, CA 92660  
949.673.0300  
www.tbparchitecture.com

NOTICE: This Project Manual, is an unpublished instrument of service of the authors. It is prepared for use only on this Project and in conjunction with the authors' interpretations, observations, decisions and administration, as described in the Conditions of the Contract. Desired results without these services cannot be assured. Use in whole or in part, without the authors' services and expressed written consent may violate Act 17 U.S.C. par. 301 (1991).

**SECTION 00 01 07  
SEALS PAGE**

**ARCHITECT**

**TBP/ARCHITECTURE, INC.**

4611 Teller Avenue, Newport Beach, CA 92660

Architect of Record (AOR)



**STRUCTURAL ENGINEER**

**VCA ENGINEERS, INC.**

2151 Michelson Drive, Suite 240, Irvine, California 92612

Structural Engineer of Record (SEOR)



**MECHANICAL ENGINEER**

**CAPITAL ENGINEERING CONSULTANTS, INC.**

11020 Sun Center Drive, Suite 100, Rancho Cordova California 95670

Plumbing Engineer of Record (PEOR)



DATE SIGNED: 02/26/19

**PLUMBING ENGINEER**

**CAPITAL ENGINEERING CONSULTANTS, INC.**

11020 Sun Center Drive, Suite 100, Rancho Cordova California 95670

Plumbing Engineer of Record (PEOR)



DATE SIGNED: 02/26/19

**ELECTRICAL ENGINEER**

**FBA ENGINEERING**

150 Paularino Avenue, Suite A120, Costa Mesa CA 92626

Electrical Engineer of Record (EEOR)



**END OF SECTION**



**SECTION 00 01 10**  
**TABLE OF CONTENTS**

**PROCUREMENT AND CONTRACTING REQUIREMENTS**

**DIVISION 00 -- PROCUREMENT AND CONTRACTING REQUIREMENTS**

- 00 01 01 - Project Title Page
- 00 01 02 - Project Information
- 00 01 07 - Seals Page
- 00 01 10 - Table of Contents
- 00 31 00 - Available Project Information
- The following Division 00 - Procurement and Contracting Requirements documents and Division 01 - General Requirements sections are provided by the Compton Community College District and are under separate cover. These are not produced by the Architect.
- 00 11 13 - Notice Calling for Bids
- 00 21 13 - Instructions for Bidders
- 00 41 00 - Bid Proposal
- 00 43 24 - Pre-Bid Inquiry Form
- 00 43 36 - Subcontractors List
- 00 45 10 - Verification of Contractor & Subcontractor DIR Registration
- 00 45 13 - Statement of Qualifications
- 00 45 19 - Non-Collusion Affidavit
- 00 45 26 - Certificate of Workers Compensation Insurance
- 00 45 27 - Drug-Free Workplace Certification
- 00 52 00 - Agreement
- 00 61 00 - Bid Bond
- 00 61 13 - Performance Bond
- 00 61 14 - Labor and Material Payment Bond
- 00 62 90 - Verification of Certified Payroll Records Submittal to Labor Commissioner
- 00 65 36 - Guarantee Form
- 00 65 37 - Contractor Certification of Subcontractor Claims
- 00 72 00 - General Conditions
- 00 73 00 - Special Conditions

**SPECIFICATIONS**

**DIVISION 01 -- GENERAL REQUIREMENTS**

- 01 21 00 - Allowances
- 01 23 00 - Alternates

- 01 25 00 - Contract Modification Procedures
- 01 29 00 - Payment Procedures
- 01 30 40 - Post Bid Interview
- 01 30 50 - Construction Procedures Manual
- 01 31 00 - Project Coordination
- 01 32 00 - Acceleration of Work
- 01 33 00 - Submittal Procedures
- 01 35 10 - Alteration Project Procedures
- 01 42 00 - References
- 01 43 80 - Work Plan and Milestone Schedule
- 01 45 00 - Quality Control
- 01 50 00 - Temporary Facilities and Controls
- 01 62 00 - Product Options
- 01 63 00 - Product Substitution Procedures
- 01 70 00 - Cleaning
- 01 72 20 - Field Engineering
- 01 73 20 - Cutting and Patching
- 01 74 00 - Warranties and Guarantees
- 01 77 00 - Closeout Procedures
- 01 78 20 - Project Record Documents
- 01 78 50 - Operating and Maintenance Data
- 01 81 00 - Commissioning

**DIVISION 02 -- EXISTING CONDITIONS**

- 02 41 00 - Demolition

**DIVISION 03 -- CONCRETE**

- 03 01 00 - Maintenance of Concrete
- 03 10 00 - Concrete Forming and Accessories
- 03 20 00 - Concrete Reinforcing
- 03 30 00 - Cast-in-Place Concrete
- 03 35 11 - Concrete Floor Finishes
- 03 35 43 - Concrete Floor Polishing

**DIVISION 04 -- MASONRY**

- 04 20 01 - Masonry Veneer

**DIVISION 05 -- METALS**

- 05 05 19 - Post-Installed Concrete Anchors



05 50 00 - Metal Fabrications

**DIVISION 06 -- WOOD, PLASTICS, AND COMPOSITES**

06 10 00 - Rough Carpentry

06 20 00 - Finish Carpentry

06 41 00 - Architectural Wood Casework

06 83 16 - Fiberglass Reinforced Paneling

**DIVISION 07 -- THERMAL AND MOISTURE PROTECTION**

07 01 50.19 - Preparation for Re-Roofing

07 05 53 - Fire and Smoke Assembly Identification

07 21 00 - Thermal Insulation

07 54 00 - Thermoplastic Membrane Roofing

07 62 00 - Sheet Metal Flashing and Trim

07 72 00 - Roof Accessories

07 84 00 - Firestopping

07 92 00 - Joint Sealants

**DIVISION 08 -- OPENINGS**

08 06 71 - Door Hardware Schedule

08 11 13 - Hollow Metal Doors and Frames

08 14 16 - Flush Wood Doors

08 31 00 - Access Doors and Panels

08 42 29 - Automatic Entrances

08 43 13 - Aluminum-Framed Storefronts

08 71 00 - Door Hardware

08 80 00 - Glazing

**DIVISION 09 -- FINISHES**

09 05 61 - Common Work Results for Flooring Preparation

09 21 16 - Gypsum Board Assemblies

09 22 36 - Lath

09 24 00 - Cement Plastering

09 30 00 - Tiling

09 51 00 - Suspended Acoustical Ceilings

09 65 00 - Resilient Flooring

09 68 13 - Tile Carpeting

09 84 30 - Sound-Absorbing Wall and Ceiling Units

09 91 13 - Exterior Painting

09 91 23 - Interior Painting

**DIVISION 10 -- SPECIALTIES**

- 10 14 00 - Signage
- 10 14 53 - Traffic and Parking Signage
- 10 21 13.17 - Phenolic Toilet Compartments
- 10 28 00 - Toilet Accessories
- 10 44 00 - Fire Protection Specialties

**DIVISION 12 -- FURNISHINGS**

- 12 24 00 - Window Shades
- 12 36 00 - Countertops

**DIVISION 22 -- PLUMBING**

- 22 00 50 - Common Work Results for Plumbing Systems
- 22 05 13 - Common Motor Requirements for Plumbing Equipment
- 22 05 17 - Sleeves and Sleeve Seals for Plumbing Piping
- 22 05 18 - Escutcheons for Plumbing Piping
- 22 05 19 - Meters and Gages for Plumbing Piping
- 22 05 23 - General-Duty Valves for Plumbing Piping
- 22 05 29 - Hangers and Supports for Plumbing Piping and Equipment
- 22 05 48 - Vibration and Seismic Controls for Plumbing Piping and Equipment
- 22 05 53 - Identification for Plumbing Piping and Equipment
- 22 07 19 - Plumbing Piping Insulation
- 22 11 16 - Domestic Water Piping
- 22 11 19 - Domestic Water Piping Specialties
- 22 11 23 - Domestic Water Pumps
- 22 13 16 - Sanitary Waste and Vent Piping
- 22 13 19 - Sanitary Waste Piping Specialties
- 22 13 19.13 - Sanitary Drains
- 22 34 00 - Fuel-Fired, Domestic-Water Heaters
- 22 42 13.13 - Commercial Water Closets
- 22 42 13.16 - Commercial Urinals
- 22 42 16.13 - Commercial Lavatories
- 22 42 16.16 - Commercial Sinks

**DIVISION 23 -- HEATING, VENTILATING, AND AIR-CONDITIONING (HVAC)**

- 23 00 50 - Common Work Results for HVAC Systems
- 23 05 13 - Common Motor Requirements for HVAC Equipment
- 23 05 17 - Sleeves and Sleeve Seals for HVAC Piping

- 23 05 18 - Escutcheons for HVAC Piping
- 23 05 29 - Hangers and Supports for HVAC Piping and Equipment
- 23 05 48 - Vibration and Seismic Controls for HVAC
- 23 05 53 - Identification for HVAC Piping and Equipment
- 23 05 93 - Testing, Adjusting, and Balancing for HVAC
- 23 07 13 - Duct Insulation
- 23 07 19 - HVAC Piping Insulation
- 23 09 23 - Direct-Digital Control System for HVAC
- 23 11 23 - Facility Natural-Gas Piping
- 23 23 00 - Refrigerant Piping
- 23 31 13 - Metal Ducts
- 23 33 00 - Air Duct Accessories
- 23 33 46 - Flexible Ducts
- 23 34 23 - HVAC Power Ventilators
- 23 37 13 - Diffusers, Registers, and Grilles
- 23 41 00 - Particulate Air Filtration
- 23 51 23 - Gas Vents
- 23 74 16 - Packaged, Rooftop Air-Conditioning Units
- 23 81 26.13 - Variable Refrigerant Flow Split-System Heat-Pumps

**DIVISION 26 -- ELECTRICAL**

- 26 05 00 - Common Work Results for Electrical
- 26 05 01 - Basic Electrical Materials and Methods
- 26 05 05 - Electrical Demolition
- 26 05 30 - Conduit and Wire
- 26 05 48 - Sound Control
- 26 09 10 - Supplemental Metering and Sub-Metering
- 26 09 43 - Lighting Control Systems
- 26 24 13 - Switchboards
- 26 24 16 - Branch Circuit Panelboards and Terminal Cabinets
- 26 24 19 - Motor Control Equipment
- 26 50 00 - Lighting Fixtures
- 26 52 00 - Emergency Lighting Central Battery

**DIVISION 27 -- COMMUNICATIONS**

- 27 08 00 - Commissioning of Communications Systems
- 27 20 00 - Electronic Network Systems Infrastructure
- 27 41 16 - Audio-Video Systems and Equipment

27 51 26 - Assistive Listening System

27 53 13 - Clock System

**DIVISION 28 -- ELECTRONIC SAFETY AND SECURITY**

28 10 00 - Access Control

28 46 20 - Fire Alarm

**DIVISION 31 -- EARTHWORK**

31 23 16.13 - Trenching

**DIVISION 32 -- EXTERIOR IMPROVEMENTS**

32 01 17 - Asphalt Pavement Repair

32 13 13 - Concrete Paving

32 17 23.13 - Painted Pavement Markings

32 17 26 - Tactile Warning Surfacing

**END OF SECTION**

**SECTION 02 41 00**  
**DEMOLITION**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Selective demolition of building elements for alteration purposes.

**1.02 RELATED REQUIREMENTS**

- A. Section 07 01 50.19 - Preparation for Re-Roofing: Removal of existing roofing, roof insulation, flashing, trim, and accessories.

**1.03 REFERENCE STANDARDS**

- A. 29 CFR 1926 - U.S. Occupational Safety and Health Standards; current edition.
- B. NFPA 241 - Standard for Safeguarding Construction, Alteration, and Demolition Operations; 2013.

**1.04 DEFINITIONS**

- A. Remove: Remove and legally dispose of items, except those identified for use in recycling, re-use, and salvage programs.
- B. Environmental Pollution and Damage: The presence of chemical, physical, or biological elements or agents which adversely affect human health or welfare; unfavorably alter ecological balances of importance to human or animal life; affect other species of importance to humanity; or degrade the utility of the environment for aesthetic, cultural or historical purposes.
- C. Inert Fill: A permitted facility that accepts inert waste such as asphalt and concrete exclusively for the purpose of disposal.
  - 1. Inert Solids/Inert Waste: Non-liquid solid waste including, but not limited to, soil and concrete, that does not contain hazardous substances or soluble pollutants at concentrations in excess of water-quality standards established by a regional water board and does not contain significant quantities of decomposable solid waste.
- D. Class III Landfill: A landfill that accepts non-hazardous materials such as household, commercial, and industrial waste, resulting from construction, remodeling, repair, and demolition operations. A Class III landfill must have a solid waste facilities permit from the State of California.
- E. Demolition Waste: Building materials and solid waste resulting from construction, remodeling, repair, cleanup, or demolition operations that are not hazardous. This term includes, but is not limited to, asphalt concrete, Portland cement concrete, brick, lumber, gypsum wallboard, cardboard and other associated packaging, roofing material, ceramic tile, carpeting, plastic pipe, and steel. The materials may include rock, soil, tree stumps, and other vegetative matter resulting from land clearing and landscaping for construction or land development projects.
- F. Chemical Waste: Includes petroleum products, bituminous materials, salts, acids, alkalis, herbicides, pesticides, organic chemicals and inorganic wastes.

- G. Recycling: The process of sorting, cleansing, treating and reconstituting materials for the purpose of using the altered form in the manufacture of a new product. Recycling does not include burning, incinerating or thermally destroying solid waste.
- H. Reuse: The use, in the same or similar form as it was produced, of a material which might otherwise be discarded.
- I. Solid Waste: All putrescible and nonputrescible solid, semisolid, and liquid wastes, including garbage, trash, refuse, paper, rubbish, ashes, industrial wastes, demolition and construction wastes, abandoned vehicles and parts thereof, discarded home and industrial appliances, dewatered, treated, or chemically fixed sewage sludge which is not hazardous waste, manure, vegetable or animal solid and semisolid wastes, and other discarded solid and semisolid wastes. "Solid waste" does not include hazardous waste, radioactive waste, or medical waste as defined or regulated by State law.

#### **1.05 ADMINISTRATIVE REQUIREMENTS**

- A. Pre-Construction Conference: Conduct a pre-construction conference one week prior to the start of the work of this section; require attendance by all affected trades.
- B. Convene a conference at the Project site 3 days prior to starting demolition to review the Drawings and Specifications, requirements of authorities having jurisdiction, instructions and requirements of serving utilities, sequencing and interface considerations and project conditions.
- C. Conference shall be attended by Construction Manager, supervisory and quality control personnel of Contractor and all subcontractors performing this and directly-related Work.
- D. Submit minutes of meeting to District, Project Inspector and Architect, for Project record purposes.
- E. Sequencing: Ensure that utility connections are achieved in an orderly and expeditious manner.
  - 1. Refer to sequence requirements specified in Section 01 10 00 - Summary; and construction progress schedule requirements specified in Section 01 32 16 - Construction Progress Schedule.

#### **1.06 MATERIALS OWNERSHIP**

- A. Except for items or materials indicated to be reused, salvaged, reinstalled, or otherwise indicated to remain property of Compton Community College District, demolished materials shall become the Contractor's property and shall be removed, recycled, or disposed from Project site in an appropriate and legal manner.
  - 1. Arrange a meeting no less than ten (10) days prior to demolition with the District or Construction Manager and other designated representatives to review any salvagable items to determine if District wants to retain ownership, and discuss Contractor's Waste Management and Recycling Plan.

#### **1.07 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Demolition Plan: Submit demolition plan as specified by OSHA and local authorities.

1. Indicate extent of demolition, removal sequence, bracing and shoring, and location and construction of barricades and fences.
  2. Identify demolition firm and submit qualifications.
- C. Demolition phase:
1. Proposed dust-control measures.
  2. Proposed noise-control measures.
  3. Schedule of demolition activities indicating the following:
    - a. Detailed sequence of demolition and removal work, including start and end dates for each activity.
    - b. Dates for shutoff, capping, and continuation of utility services.
- D. Project Record Documents: Accurately record actual locations of capped and active utilities and subsurface construction.
1. Record drawings: Identify and accurately locate capped utilities and other subsurface structural, electrical, or mechanical conditions.

#### **1.08 SUBMITTALS**

- A. Demolition and Removal Procedures and Schedule: Submit for Project record only.
- B. Project Record Drawings: Submit in accordance with provisions specified in Section 01 78 00 - Closeout Submittals. Indicate verified locations of underground utilities and storm drainage system on project record drawings.

#### **1.09 QUALITY ASSURANCE**

- A. Demolition Firm Qualifications: Company specializing in the type of work required.
  1. Minimum of 5 years of documented experience.

#### **1.10 SCHEDULING**

- A. Schedule Work to precede new construction.
- B. Describe demolition removal procedures and schedule.
- C. Perform work between the hours of 8am and 5pm, subject to noise abatement regulations and District's approval for noise considerations.

### **PART 2 PRODUCTS -- NOT USED**

### **PART 3 EXECUTION**

#### **3.01 GENERAL PROCEDURES AND PROJECT CONDITIONS**

- A. Conform to the relevant Article of the General Conditions, South Coast Air Quality Management District and other applicable regulatory procedures when discovering hazardous or contaminated materials.
- B. Field Measurements and Conditions:
  1. Survey existing conditions and correlate with requirements indicated to determine extent of demolition and recycling required.

2. In addition to provisions of the Conditions of the Contract, verify dimensions and field conditions prior to construction. Verify condition of substrate and adjoining Work before proceeding with demolition Work. If conflict is found notify Construction Manager, Project Inspector and Architect.
- C. Comply with other requirements specified in Section 01 70 00.
- D. Comply with governing EPA notification regulations before starting demolition. Comply with hauling and disposal regulations of authorities having jurisdiction. Obtain and pay for all permits required.
- E. Environmental Controls
1. Comply with federal, state and local regulations pertaining to water, air, solid waste, recycling, chemical waste, sanitary waste, sediment and noise pollution.
  2. Confine demolition activities to areas defined by public roads, easements, and work area limits indicated on the drawings.
  3. Temporary Construction: Remove indications of temporary construction facilities, such as haul roads, work areas, structures, stockpiles or waste areas.
  4. Water Resources: Comply with applicable regulations concerning the direct or indirect discharge of pollutants to underground and natural surface waters.
    - a. Oily Substances: Prevent oily or other hazardous substances from entering the ground, drainage areas, or local bodies of water in such quantities as to affect normal use, aesthetics, or produce a measurable ecological impact on the area.
      - 1) Store and service construction equipment at areas designated for collection of oil wastes.
  5. Dust Control, Air Pollution, and Odor Control: Prevent creation of dust, air pollution and odors.
    - a. Use temporary enclosures and other appropriate methods to limit dust and dirt rising and scattering in air to lowest practical level.
    - b. Store volatile liquids, including fuels and solvents, in closed containers.
    - c. Properly maintain equipment to reduce gaseous pollutant emissions.
  6. Noise Control: Perform demolition operations to minimize noise.
    - a. Repetitive, high level impact noise will be permitted only during the times indicated in Section 01 70 00 - Execution and Closeout Requirements. Repetitive impact noise on the property shall not exceed the following dB limitations:

| Sound Level in dB | Time Duration of Impact Noise    |
|-------------------|----------------------------------|
| 70                | More than 12 minutes in any hour |
| 80                | More than 3 minutes in any hour  |

- b. Provide equipment, sound-deadening devices, and take noise abatement measures that are necessary to comply with the requirements of this Contract.
- c. At least once every five successive working days while work is being performed above 55 dB noise level, measure sound level for noise exposure due to the demolition.



- 1) Measure sound levels on the 'A' weighing network of a General Purpose sound level meter at slow response.
  - 2) To minimize the effect of reflective sound waves at buildings, measurements may be taken three to six feet in front of any building face.
- F. Comply with applicable codes and regulations for demolition operations and safety of adjacent structures and the public.
1. Obtain required permits.
  2. Comply with applicable requirements of NFPA 241.
  3. Use of explosives is not permitted.
  4. Take precautions to prevent catastrophic or uncontrolled collapse of structures to be removed; do not allow worker or public access within range of potential collapse of unstable structures.
    - a. Survey condition of the building to determine whether removing any element might result in a structural deficiency or unplanned collapse of any portion of the structure or adjacent structures during demolition.
      - 1) Retain a licensed and qualified civil or structural engineer to provide analysis, including calculations, necessary to ensure the safe execution of the demolition work.
    - b. Prevent movement or settlement of adjacent structures. Provide bracing and shoring.
    - c. Perform surveys as the Work progresses to detect hazards resulting from demolition activities.
  5. Provide, erect, and maintain temporary barriers and security devices.
    - a. Provide, erect, and maintain temporary barriers, safety and security devices , for protection of streets, sidewalks, curbs, adjacent property and the public.
    - b. Protection: Protect existing construction and adjacent areas with temporary barriers and security devices in accordance with requirements specified in Division 01.
      - 1) Review location and type of construction of temporary barriers with District and/or the Construction Manager.
      - 2) Barriers shall control dust, debris and provide protection for persons occupying and using adjacent facilities.
      - 3) Maintain protected egress and access at all times, in accordance with requirements of authorities having jurisdiction and with permission of DSA (AHJ having jurisdiction).
  6. Use physical barriers to prevent access to areas that could be hazardous to workers or the public.
  7. Conduct operations to minimize effects on and interference with adjacent structures and occupants.
  8. Do not close or obstruct roadways or sidewalks without permit.
  9. Conduct operations to minimize obstruction of public and private entrances and exits; do not obstruct required exits at any time; protect persons using entrances and exits from removal operations.

- 10. Obtain written permission from owners of adjacent properties when demolition equipment will traverse, infringe upon or limit access to their property.
- G. Do not begin removal until receipt of notification to proceed from District.
- H. Do not begin removal until built elements to be salvaged or relocated have been removed.
- I. Protect existing structures and other elements that are not to be removed.
  - 1. Provide bracing and shoring.
  - 2. Prevent movement or settlement of adjacent structures.
  - 3. Stop work immediately if adjacent structures appear to be in danger.
  - 4. Protect existing landscaping materials, appurtenances, structures and items that are not to be demolished, or are on adjacent property.
  - 5. Mark location of utilities.
- J. Minimize production of dust due to demolition operations; do not use water if that will result in ice, flooding, sedimentation of public waterways or storm sewers, or other pollution.
- K. Hazardous Materials: Comply with 29 CFR 1926 and state and local regulations.
- L. Remove materials to be re-installed or retained in manner to prevent damage. Store and protect in accordance with requirements of Division 01.
- M. Perform demolition in a manner that maximizes salvage and recycling of materials.
  - 1. Dismantle existing construction and separate materials.
  - 2. Set aside reusable, recyclable, and salvageable materials; store and deliver to collection point or point of reuse.
- N. Damages: Promptly repair damages to adjacent facilities caused by demolition operations.

### **3.02 SELECTIVE DEMOLITION FOR ALTERATIONS**

- A. Drawings showing existing construction and utilities are based on casual field observation and existing record documents only.
  - 1. Verify that construction and utility arrangements are as indicated.
  - 2. Report discrepancies to Architect before disturbing existing installation.
  - 3. Beginning of demolition work constitutes acceptance of existing conditions that would be apparent upon examination prior to starting demolition.
- B. Maintain weatherproof exterior building enclosure except for interruptions required for replacement or modifications; take care to prevent water and humidity damage.
- C. Remove existing work as indicated and as required to accomplish new work.
  - 1. Remove rotted wood, corroded metals, and deteriorated masonry and concrete; replace with new construction specified.
  - 2. Remove items indicated on drawings.
  - 3. Remove structural framing members and lower to ground by method suitable to avoid free fall and to prevent ground impact or dust generation.
- D. Services (Including but not limited to HVAC, Plumbing, Electrical, and Telecommunications): Remove existing systems and equipment as indicated.

1. Maintain existing active systems that are to remain in operation; maintain access to equipment and operational components.
  2. Where existing active systems serve occupied facilities but are to be replaced with new services, maintain existing systems in service until new systems are complete and ready for service.
  3. Verify that abandoned services serve only abandoned facilities before removal.
  4. Remove abandoned pipe, ducts, conduits, and equipment; remove back to source of supply where possible, otherwise cap stub and tag with identification.
- E. Protect existing work to remain.
1. Prevent movement of structure; provide shoring and bracing if necessary.
  2. Perform cutting to accomplish removals neatly and as specified for cutting new work.
  3. Repair adjacent construction and finishes damaged during removal work.
  4. Patch as specified for patching new work.

### **3.03 DEBRIS AND WASTE REMOVAL**

- A. Remove debris, junk, and trash from site.
- B. Remove from site all materials not to be reused on site; do not burn or bury.
- C. Remove temporary work.
- D. Leave site in clean condition, ready for subsequent work.
- E. Clean up spillage and wind-blown debris from public and private lands.

**END OF SECTION**



**SECTION 03 01 00**  
**MAINTENANCE OF CONCRETE**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Cleaning of existing concrete surfaces.
- B. Repair of exposed structural, shrinkage, and settlement cracks.
- C. Resurfacing of concrete surfaces having spalled areas and other damage.
- D. Repair of deteriorated concrete.
- E. Repair of internal concrete reinforcement.
- F. Scope of Work: As indicated on the drawings and as required as work progresses for hidden conditions after consultation with the Architect.

**1.02 RELATED REQUIREMENTS**

- A. Section 03 30 00 - Cast-in-Place Concrete: Finishing of concrete surface to tolerance; floating, troweling, and similar operations; curing.

**1.03 REFERENCE STANDARDS**

- A. ASTM A996/A996M - Standard Specification for Rail-Steel and Axle-Steel Deformed Bars for Concrete Reinforcement; 2016.
- B. ASTM C33/C33M - Standard Specification for Concrete Aggregates; 2016.
  - 1. Use 2013 as indicated in the 2016 CBC Referenced Standards.
- C. ASTM C150/C150M - Standard Specification for Portland Cement; 2016.
  - 1. Use 2012 as indicated in the 2016 CBC Referenced Standards
- D. ASTM C404 - Standard Specification for Aggregates for Masonry Grout; 2011.
- E. ASTM C881/C881M - Standard Specification for Epoxy-Resin-Base Bonding Systems for Concrete; 2015.
- F. ASTM C928/C928M - Standard Specification for Packaged, Dry, Rapid-Hardening Cementitious Material for Concrete Repairs; 2013.
- G. ASTM C1059/C1059M - Standard Specification for Latex Agents for Bonding Fresh to Hardened Concrete; 2013.
- H. AWS D1.4/D1.4M - Structural Welding Code - Reinforcing Steel; 2011.
  - 1. Use 2011 as indicated in the 2016 CBC Referenced Standards.

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Scheduling: Perform blast cleaning only between the hours of 7 am to 10 pm.

**1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.

- B. Product Data: Indicate product standards, physical and chemical characteristics, technical specifications, limitations, maintenance instructions, and general recommendations regarding each material.
- C. Project Record Documents: Accurately record actual locations of structural reinforcement repairs and type of repair.

#### **1.06 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than three years of documented experience.
- B. Cleaner Qualifications: Company specializing in, and with minimum of 3 years of experience in, the type of cleaning specified.
- C. Installer Qualifications: Company specializing in performing work of the type specified and with minimum of 3 years of documented experience.

#### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Comply with manufacturers' instructions for storage, shelf life limitations, and handling of products.

### **PART 2 PRODUCTS**

#### **2.01 CLEANING MATERIALS**

- A. Degreaser:
  - 1. Manufacturers:
    - a. Euclid Chemical Company; Euco Clean and Strip: [www.euclidchemical.com/#sle](http://www.euclidchemical.com/#sle).
    - b. L&M Construction Chemicals, Inc, a subsidiary of Laticrete International, Inc; CITREX: [www.lmcc.com/#sle](http://www.lmcc.com/#sle).
    - c. SpecChem, LLC; Orange Peel-Citrus Cleaner: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
    - d. W.R. Meadows, Inc: [www.wrmeadows.com](http://www.wrmeadows.com).
    - e. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Detergent: Non-ionic detergent.

#### **2.02 CEMENTITIOUS PATCHING AND REPAIR MATERIALS**

- A. Manufacturers:
  - 1. Adhesives Technology Corporation: [www.atcepoxy.com/#sle](http://www.atcepoxy.com/#sle).
  - 2. ARDEX Engineered Cements: [www.ardexamericas.com/#sle](http://www.ardexamericas.com/#sle).
  - 3. Dayton Superior Corporation: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
  - 4. The QUIKRETE Companies: [www.quikrete.com/#sle](http://www.quikrete.com/#sle).
  - 5. SpecChem, LLC: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
  - 6. W. R. Meadows, Inc: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
  - 7. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

- B. Bonding Slurry: Water-based latex admixture complying with ASTM C1059/C1059M, combined with Portland cement and sand in accordance with admixture manufacturer's instructions.
1. Admixture Manufacturers:
    - a. Dayton Superior Corporation; Acrylic Bonding Agent J40: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - b. The QUIKRETE Companies; QUIKRETE® Concrete Bonding Adhesive: [www.quikrete.com/#sle](http://www.quikrete.com/#sle).
    - c. SpecChem, LLC; Strong Bond - Acrylic Bonder: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
    - d. W. R. Meadows, Inc; Acry-lok: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - e. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- C. Cementitious Resurfacing Mortar: One- or two-component, factory-mixed, polymer-modified cementitious mortar designed for continuous thin-coat application.
1. Mixed with water or latex type bonding agent in proportions as recommended by manufacturer.
  2. Recommended Thickness: Feather edge to 1/8 inch.
  3. Color: Gray.
  4. Manufacturers:
    - a. ARDEX Engineered Cements; ARDEX Feather Finish: [www.ardexamericas.com/#sle](http://www.ardexamericas.com/#sle).
    - b. Dayton Superior Corporation; Architectural Finish: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - c. Dayton Superior Corporation; Thin Resurfacer: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - d. Dayton Superior Corporation; Recrete 20 Minute: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - e. L&M Construction Chemicals, Inc, a subsidiary of Laticrete International, Inc; Duracrete: [www.lmcc.com/#sle](http://www.lmcc.com/#sle).
    - f. The QUIKRETE Companies; QUIKRETE® Concrete Resurfacer: [www.quikrete.com/#sle](http://www.quikrete.com/#sle).
    - g. SpecChem, LLC; Duo Patch: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
    - h. SpecChem, LLC; Final Finish: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
    - i. W. R. Meadows, Inc; Parge-All AF: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - j. W. R. Meadows, Inc; Meadow-Patch T2: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - k. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- D. Cementitious Repair Mortar, Trowel Grade: One- or two-component, factory-mixed, polymer-modified cementitious mortar.
1. Mixed with water or latex type bonding agent in proportions as recommended by manufacturer.
  2. Integral corrosion inhibitor.
  3. Products:
    - a. Adhesives Technology Corporation; HARD-ROK JET PATCH: [www.atcepoxy.com/#sle](http://www.atcepoxy.com/#sle).
    - b. Dayton Superior Corporation; Civil/Structural VO: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).

- c. Five Star Products, Inc; Five Star Structural Concrete V/O:  
www.fivestarproducts.com/#sle.
  - d. The QUIKRETE Companies; QUIKRETE® FastSet Repair Mortar:  
www.quikrete.com/#sle.
  - e. SpecChem, LLC; RepCon V/O: www.specchemllc.com/#sle.
  - f. SpecChem, LLC; Duo Patch: www.specchemllc.com/#sle.
  - g. W. R. Meadows, Inc; Meadow-Crete GPS: www.wrmeadows.com/#sle.
  - h. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- E. Cementitious Repair Mortar, Form and Pour/Pump Grade: Flowable, one- or two-component, factory-mixed, polymer-modified cementitious mortar; in-place material resistant to freeze/thaw conditions.
- 1. Mixed with water in proportions as recommended by manufacturer.
  - 2. Integral corrosion inhibitor.
  - 3. Manufacturers:
    - a. ARDEX Engineered Cements; ARDEX FDM: www.ardexamericas.com/#sle.
    - b. Dayton Superior Corporation; Civil/Structural FPX : www.daytonsuperior.com/#sle.
    - c. Five Star Products, Inc; Five Star Structural Concrete:  
www.fivestarproducts.com/#sle.
    - d. SpecChem, LLC; Duo Patch; www.specchemllc.com/#sle.
    - e. SpecChem, LLC; RepCon H-350; www.specchemllc.com/#sle.
    - f. W. R. Meadows, Inc; Meadow-Crete FNP: www.wrmeadows.com/#sle.
    - g. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- F. Cementitious Pavement Repair Mortar: Fast hardening, flowable; composed of cement, sand, and additives; capable of setting in cold weather conditions without the aid of chloride- or gypsum-based accelerators; in-place material resistant to freeze/thaw conditions.
- 1. Dry Material: Complies with ASTM C928/C928M.
  - 2. Manufacturers:
    - a. Dayton Superior Corporation; HD 50 : www.daytonsuperior.com/#sle.
    - b. Dayton Superior Corporation; Pave Patch 3000: www.daytonsuperior.com/#sle.
    - c. Prospec; Premium Patch 100: www.prospec.com.
    - d. Prospec; Premium Patch 200: www.prospec.com.
    - e. SpecChem, LLC; RepCon 928: www.specchemllc.com/#sle.
    - f. SpecChem, LLC; RepCon 928 FS: www.specchemllc.com/#sle.
    - g. W. R. Meadows, Inc; Futura-15: www.wrmeadows.com/#sle.
    - h. W. R. Meadows, Inc; Futura-45 or Futura-45 Extended:  
www.wrmeadows.com/#sle.
    - i. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

### **2.03 EPOXY PATCHING AND REPAIR MATERIALS**

- A. Manufacturers:
- 1. Adhesives Technology Corporation: www.atcepoxy.com/#sle.



2. Dayton Superior Corporation: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
  3. SpecChem, LLC: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
  4. W. R. Meadows, Inc: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
  5. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Epoxy Repair Mortar: Epoxy resin mixed with aggregate and other materials in accordance with manufacturer's instructions for purpose intended; comply with pot life and workability limits.
1. Manufacturers:
    - a. Adhesives Technology Corporation; Crackbond LR-321: [www.atcepoxy.com/#sle](http://www.atcepoxy.com/#sle).
    - b. Dayton Superior Corporation; Sure Patch: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - c. Dayton Superior Corporation; Sure Fil J52: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - d. Dayton Superior Corporation; Sure Seal LV/LM: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - e. Dayton Superior Corporation; Pro-Flex: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - f. The QUIKRETE Companies; QUIKRETE® FastSet Anchoring Epoxy: [www.quikrete.com/#sle](http://www.quikrete.com/#sle).
    - g. SpecChem, LLC; SpecPoxy 1000, SpecPoxy 2000, SpecPoxy 3000 or SpecPoxy 3000 FS: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
    - h. W. R. Meadows, Inc; Rezi-Weld Gel Paste, Rezi-Weld Gel Paste State, Rezi-Weld 1000, Rezi-Weld LV, or Rezi-Weld LV State: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - i. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- C. Epoxy Injection Adhesive:
1. Manufacturers:
    - a. Adhesives Technology Corporation; Crackbond LR-321: [www.atcepoxy.com/#sle](http://www.atcepoxy.com/#sle).
    - b. Dayton Superior Corporation; Sure Inject J56: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - c. Dayton Superior Corporation; Sure Inject J56 SLV: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - d. Dayton Superior Corporation; Pro-Poxy 50 : [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - e. Dayton Superior Corporation; Pro-Poxy 100 : [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - f. SpecChem, LLC; SpecPoxy 1000; [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
    - g. W. R. Meadows, Inc; Rezi-Weld LV, Rezi-Weld LV State, Rezi-Weld (IP), or Rezi-Weld Gel Paste: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - h. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- D. Epoxy Bonding Adhesive: Non-sag, two-part, 100 percent solids; recommended by manufacturer for purpose and conditions under which used.
1. Non-Load-Bearing Applications: ASTM C881/C881M Type I, II, III, IV, or V, whichever is appropriate to application.
  2. Load-Bearing Applications: ASTM C881/C881M Type IV or V, whichever is appropriate to application.
  3. Other Applications: ASTM C881/C881M Type as appropriate to application.
  4. Manufacturers:
    - a. Adhesives Technology Corporation; Crackbond LR-321: [www.atcepoxy.com/#sle](http://www.atcepoxy.com/#sle).
    - b. Adhesives Technology Corporation; Crackbond SLV-302: [www.atcepoxy.com/#sle](http://www.atcepoxy.com/#sle).

- c. Adhesives Technology Corporation; Ultrabond 2100: [www.atcepoxy.com/#sle](http://www.atcepoxy.com/#sle).
- d. SpecChem, LLC; SpecPoxy 2000: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
- e. SpecChem, LLC; SpecPoxy 3000: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
- f. SpecChem, LLC; SpecPoxy 3000 FS: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
- g. W. R. Meadows, Inc; Rezi-Weld Gel Paste: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
- h. W. R. Meadows, Inc; Rezi-Weld Gel Paste State: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
- i. W. R. Meadows, Inc; Rezi-Weld 1000: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
- j. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## 2.04 ACCESSORIES

- A. Anchoring Adhesive: Self-leveling or non-sag as applicable.
  - 1. Self-Leveling Polyester-Based Products:
    - a. W. R. Meadows, Inc; Poly-Grip: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
  - 2. Self-Leveling Epoxy Products:
    - a. SpecChem, LLC; SpecPoxy 2000; [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
    - b. W. R. Meadows, Inc; Rezi-Weld 1000, Rezi-Weld (IP), or Rezi-Weld 3/2: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
  - 3. Non-Sag Epoxy Products:
    - a. Dayton Superior Corporation; Sure Anchor J50, Sure Anchor I J51, All Weather J51 AW, Pro-Poxy 300, Pro-Poxy 300 FAST, Pro-Poxy 400, or Pro-Poxy 500 : [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - b. SpecChem, LLC; SpecPoxy 3000 or SpecPoxy 3000 FS: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
    - c. W. R. Meadows, Inc; Rezi-Weld Gel Paste or Rezi-Weld Gel Paste State: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - d. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Portland Cement: ASTM C150/C150M, Type I, grey.
- C. Sand: ASTM C33/C33M or ASTM C404; uniformly graded, clean.
- D. Water: Clean and potable.
- E. Reinforcing Steel: ASTM A615/A615M Grade 60 (60,000 psi) billet-steel deformed bars, unfinished.
- F. Reinforcing Steel: Deformed bars, ASTM A996/A996M Grade 60 (420), Type A.

## PART 3 EXECUTION

### 3.01 EXAMINATION

- A. Verify that surfaces are ready to receive work.
- B. Beginning of installation means acceptance of substrate.

### **3.02 CLEANING EXISTING CONCRETE**

- A. Provide enclosures, barricades, and other temporary construction as required to protect adjacent work from damage.
- B. Clean concrete surfaces of dirt or other contamination using the gentlest method that is effective.
  - 1. Try the gentlest method first, then, if not clean enough, use a less gentle method taking care to watch for impending damage.
  - 2. Clean out cracks and voids using same methods.
- C. The following are acceptable cleaning methods, in order from gentlest to less gentle:
  - 1. Water washing using low-pressure, maximum of 100 psi, and, if necessary, brushes with natural or synthetic bristles.
  - 2. Increasing the water washing pressure to maximum of 400 psi.
  - 3. Adding detergent to washing water; with final water rinse to remove residual detergent.
  - 4. Steam-generated low-pressure hot-water washing.
- D. Do not use any of the following cleaning methods, unless otherwise indicated:
  - 1. Brushes with wire bristles, grinding with abrasives, solvents, hydrochloric or muriatic acid, sodium hydroxide, caustic soda, or lye.
  - 2. Soap or detergent that is not non-ionic.
  - 3. Alkaline cleaning agents.
  - 4. Acidic cleaning agents.
  - 5. Abrasive blasting.

### **3.03 CONCRETE STRUCTURAL MEMBER REPAIR**

- A. See the drawings for known specific areas to be repaired (if any).
- B. Remove broken and soft concrete at least 1/4 inch deep.
- C. Mechanically cut away damaged portions of reinforcement.
- D. Remove corrosion from steel and clean mechanically.
- E. Blast clean remaining exposed reinforcement surfaces.
- F. Repair by welding new bar reinforcement to existing reinforcement using sleeve splices.
  - 1. Perform welding work in accordance with AWS D1.4/D1.4M.
  - 2. Make welded sleeve splices to achieve strength to exceed strength of new reinforcement.
- G. Cover exposed steel reinforcement with epoxy mortar.
- H. Work epoxy mortar into broken surface and build up patch to match original.
- I. Feather edges of repairs flush to sound surface and trowel surface to match surrounding area.

### **3.04 CRACK REPAIR USING EPOXY ADHESIVE INJECTION**

- A. Repair exposed cracks.

- B. Provide temporary entry ports spaced to accomplish movement of fluids between ports; no deeper than the depth of the crack to be filled or port size diameter no greater than the thickness of the crack. Provide temporary seal at concrete surface to prevent leakage of adhesive.
- C. Inject adhesive into ports under pressure using equipment appropriate for particular application.
- D. Begin injection at lower entry port and continue until adhesive appears in adjacent entry port. Continue from port to port until entire crack is filled.
- E. Remove temporary seal and excess adhesive.
- F. Clean surfaces adjacent to repair and blend finish.

### **3.05 CONCRETE SURFACE REPAIR USING CEMENTITIOUS MATERIALS**

- A. Clean concrete surfaces, cracks, and joints of dirt, laitance, corrosion, and other contamination using method(s) specified above and allow to dry.
- B. Apply coating of bonding agent to entire concrete surface to be repaired.
- C. Fill voids with cementitious mortar flush with surface.
- D. Apply repair mortar by steel trowel to a minimum thickness of 1/4 inch over entire surface, terminating at a vertical change in plane on all sides.
- E. Trowel finish to match adjacent concrete surfaces.

### **3.06 FIELD QUALITY CONTROL**

- A. An independent testing agency, as specified in Section 01 45 00, will perform field inspection and testing.

**END OF SECTION**

**SECTION 03 10 00**  
**CONCRETE FORMING AND ACCESSORIES**

**PART 1 - GENERAL**

**1.01 SECTION INCLUDES**

- A. Forms for all cast-in-place concrete indicated on the Drawings and subsequent removal of forms, except those earth forms described in this Section.

**1.02 RELATED SECTIONS**

- A. Section 03 20 00 - Concrete Reinforcing.
- B. Section 03 30 00 - Cast-in-Place Concrete.

**1.03 QUALITY ASSURANCE**

- A. Qualifications of workmen: All workmen shall be experienced mechanics. Provide one person who shall be present at all time during execution of this portion of the work who shall be thoroughly familiar with the type of material being installed, the referenced standards and the requirement of this Work and shall direct all Work performed under this Section.
- B. Codes and Standards: In addition to complying with all pertinent codes and regulations, comply with all pertinent recommendations contained in "Recommended Practice for Concrete Formwork," publication ACI 347R and ACI 318, Section 6.1.
- C. Where provisions of pertinent codes and standards conflict with the requirement of this Section, the more stringent provision shall govern.
- D. All Structural Concrete foundations, walls, floors, beams, roofs, columns, and any other structural component requiring structural forming or shoring shall be Engineer Designed Systems with calculations and erection drawings provided by the Contractor. Contractor is to secure the services of a California Registered Structural Engineer for the design of Forming Systems.

**1.04 PRODUCT HANDLING**

- A. Protection: Contractor is to protect all formwork materials before, during and after installation.
- B. Damaged Forms: In the event of damage or misalignment, immediately make all repairs and replacement necessary at no additional cost to the Owner.

**PART 2 - PRODUCTS**

**2.01 MATERIALS**

- A. Form lumber: All form lumber shall be new except as allowed for re-use of forms in Part 3 of this Specification, and all form lumber shall be one of the following, a combination thereof, or an equal approved in advance by the Architect.
  - 1. Plywood forms may be Plyform, Plyron, and bearing the label of the Douglas Fir Plywood Association.

2. Form-lumber may be; fir, larch, hemlock, or approved equal seasoned lumber and surfaced on all four sides.
  3. Form sealers shall be liquid form oil.
- B. Pan Joist Concrete Forming and Shoring System: Forming and shoring for Concrete joist and slabs shall be an Engineered system. Contractor shall engage a Structural Engineer experienced in forming design for the type of construction shown on the drawings. Structural calculations and forming and shoring design erection drawings shall be provided.
- C. Other form materials and/or forming systems may be used if approved by the Owner, Architect and Structural Engineer. A complete list of materials, manufacturers and methods of application are to be submitted to the Architect, in accordance with Division 01.

## **2.02 TIES AND SPREADERS**

- A. Form ties shall be of proven types and shall be a type which does not leave an open hole through the concrete and which permits patching at every hole.
- B. When forms are removed, all metal ties shall be removed and shall be flush with the concrete surface. No metal ties shall be exposed on the exterior of the walls.

## **2.03 ALTERNATE FORMING SYSTEMS**

- A. Alternate forming systems may be used if approved by the Structural Engineer

## **2.04 OTHER MATERIALS**

- A. All other form materials, not specifically described herein, but required for proper completion of concrete formwork, shall be as selected by the Contractor subject to approval by the Owner or Architect.

# **PART 3 - EXECUTION**

## **3.01 INSPECTION**

- A. Contractor shall verify and be responsible for all-existing dimensions and elevations before any Work is done.
- B. Inspect the installed Work of all other trades; verify that all such Work is complete, and that the installation of Formwork may begin.
- C. Verify that forms have been constructed in accordance with all pertinent codes and regulations, referenced standards and the design.
- D. Discrepancies: Do not proceed with installation in areas of discrepancy. Notify the Architect of all discrepancies. All discrepancies are to be fully resolved before proceeding with installation.

## **3.02 CONSTRUCTION FORMS**

- A. Forms are to be constructed sufficiently tight to prevent leakage of concrete, and able to withstand excessive deflection when filled with wet concrete. Forms shall be braced, anchored and properly aligned.
- B. Layout and form all required cast-in-place concrete to the required dimensions indicated on the Drawings.

- C. Care shall be exercised in the layout of forms to avoid the necessity for cutting, patching, or repair of concrete after it is in place.
- D. Make provisions for all openings, offsets, recesses, anchorage, blocking and other requirements of the Work.
- E. Perform all forming required for Work of other trades and do all cutting and repairing of forms required to permit such installations.
- F. Carefully examine the Drawing and Specifications and verify with other trades for openings, reglets, chases, and other items that are required in the forms.
- G. Forms for pre-cast concrete shall be constructed to provide for shrinkage of the concrete, and shall be adequately braced. All edges shall have chamfer strips except as noted on Drawings.
- H. Construct all forms true, plumb, and square within a tolerance of 1/8" in 12 feet.

### **3.03 EMBEDDED ITEMS**

- A. Provide, install and check all required steel frames, angles, grilles, bolts, inserts and other such items required to be anchored in the forms before the concrete is placed.

### **3.04 BRACING**

- A. Properly brace and tie the forms together so as to maintain size, shape, and alignment, and to provide safety to personnel.
- B. Construct all bracing and supporting members of ample size and strength to safely support, without excessive deflection, all dead and live loads to which they may be subjected.

### **3.05 PLYWOOD FORMS**

- A. Plywood forms shall be designed for loads imposed. Nail the plywood panels directly to studs and apply in a manner to minimize the number of joints.
- B. Make all panel joints tight butt joints with all edges true and square, if necessary, use tape to prevent excessive leakage.

### **3.06 FOOTING FORMS**

- A. Foundation forms are to be wood forms.
- B. Earth forms may be used for footings provided the soil will stand without caving, as determined by the Architect (Structural Engineer) and the sides of the bank are made with a neat cut to the minimum dimensions indicated.

### **3.07 REUSE OF FORMS**

- A. Reuse of forms shall be subject to approval of the I.O.R.
- B. Reuse of forms shall not delay or change the schedule for placement of concrete from the schedule if all forms were new.
- C. Reuse of forms shall not affect the structural stability of the forms or the appearance of the finished concrete.

### **3.08 REMOVAL OF FORMS**

- A. Side forms of foundations may be removed 48 hours after placement of concrete. Where foundations are supporting lateral loads, forms shall not be removed until approved by the I.O.R.
- B. Use care and diligence, and protect workmen, passers-by, and the installed work and materials of other trades. Forms shall not be removed until the concrete can support all loads.
- C. Cut nails, tie wires and form ties off flush, leave all surfaces smooth and clean.
- D. Remove metal spreader ties and fill in the resulting pockets to match the surrounding areas with grout or dry pack. Sack all exposed faces.
- E. Fill all holes resulting from the use of bolts, ties, spreaders and sleeve nuts with cement grout applied under pressure by means of a grouting gun; grout shall be one part Portland cement, to two parts sand; apply grout immediately after removing forms.

### **3.09 CLEANING**

- A. Remove all forming material from the site and dispose of in approved dumps.
- B. Clean area of all left over debris including stakes, ties, form boards, wires, concrete spills, etc., and leave area in a neat clean condition.

**END OF SECTION**



**SECTION 03 20 00**  
**CONCRETE REINFORCING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Concrete steel reinforcement as indicated.
- B. Related Sections:
  - 1. Section 03 10 00 - Concrete Forming and Accessories.
  - 2. Section 03 30 00 - Cast-in-Place Concrete.

**1.02 SYSTEM DESCRIPTION**

- A. Regulatory Requirements: Fabrication and placement of reinforcing shall be in accordance with requirements of CBC, Chapter 19A.

**1.03 SUBMITTALS**

- A. Shop Drawings: Submit steel reinforcement Shop Drawings in accordance with ACI 315. Include assembly diagrams, bending charts and slab plans. Indicate lengths and location of splices, size and lengths of reinforcing steel.
- B. Closeout Submittals: Record exact locations of reinforcing that vary from Shop Drawings.

**1.04 QUALITY ASSURANCE**

- A. Comply with the following as a minimum requirement:
  - 1. Concrete Reinforcing Steel Institute (CRSI) Manual of Standard Practice.
  - 2. American Welding Society (AWS).
  - 3. American Concrete Institute (ACI).
  - 4. CBC, Chapter 19A, Concrete.
- B. Source Quality Control: Refer to Division 01 Sections for general requirements and to following paragraphs for specific procedures. Testing laboratory retained by the Owner shall perform following conformance testing, select test Samples of bars, ties, and stirrups from the material at the Project site or from the place of distribution, with each Sample consisting of not less than two 18 inch long pieces, and perform the following tests according to ASTM A 615.
  - 1. Identified Bars: If Samples are obtained from bundles as delivered from the mill, identified as to heat number, accompanied by mill analyses and mill test reports, and properly tagged with the identification certificate so as to be readily identified, perform one tensile and one bend test for each 10 tons or fraction thereof of each size of bars. Submit mill reports when Samples are selected.
  - 2. Unidentified Bars: When positive identification of reinforcing bars cannot be performed and when random Samples are obtained, perform tests for each 2.5 tons or fraction thereof, one tensile and one bend test from each size of bars.

- C. Certification of Welders: Shop and Project site welding shall be performed by certified welding operators.

### **1.05 DELIVERY, STORAGE AND HANDLING**

- A. Avoid exposure to dirt, moisture or conditions harmful to reinforcing.
- B. Reinforcing steel bars, wire, and wire fabric shall be stored on the Project site to permit easy access for examination and identification of each shipment. Material of each shipment shall be separated for size and shape.

## **PART 2 - PRODUCTS**

### **2.01 GENERAL**

- A. Provide reinforcing of sizes, gages and lengths indicated, bent to indicated shapes.

### **2.02 MATERIALS**

- A. Steel Reinforcing Bars: ASTM A 615 and A 706 for welding, grade 60 billet steel unless otherwise specified or indicated.
- B. Bars or Rod Mats: ASTM A 184.
- C. Wire Fabric for Reinforcement: ASTM A 185.
- D. Tie Wire: ASTM A 82, fully annealed, copper-bearing steel wire, 16 gage minimum.
- E. Chairs, Spacers, Supports, and Other Accessories: Standard manufacture conforming to ACI-315 fabricated from steel wire of required types and sizes. For reinforcement supported from grade, provide properly sized dense precast blocks of concrete.

### **2.03 FABRICATION OF REINFORCING BARS**

- A. Comply with CRSI Manual of Standard Practice for Reinforced Concrete Construction for fabrication of reinforcing steel.
- B. Bending and Forming: Fabricate bars of the indicated sizes and bend and form to required shapes and lengths by methods not injurious to materials. Do not heat reinforcement for bending. Bend bars No. 6 size and larger in the shop only. Bars with unscheduled kinks or bends are not permitted. Provide only tested and permitted bar materials.
- C. Welding: Provide only ASTM A 706 steel where welding is indicated. Perform welding by the direct electric arc process in accordance with AWS D1.4 and specified low-hydrogen electrodes. Preheat 6 inches each side of joint. Protect joints from drafts during the cooling process; accelerated cooling is not permitted. Do not tack weld bars. Clean metal surfaces to be welded of loose scale and foreign material. Clean welds each time electrode is changed and chip burned edges before placing welds. When wire brushed, the completed welds must exhibit uniform section, smooth welded metal, feather edges without undercuts or overlays, freedom from porosity and clinkers, and good fusion and penetration into the base metal. Cut out welds or parts of welds deemed defective, using chisel, and replace with proper welding. Prequalification of welds shall be in accordance with CBC requirements.

## **PART 3 - EXECUTION**

### **3.01 INSTALLATION**

- A. Bars shall be bent cold. Bars partially embedded in concrete shall not be field bent except as indicated on reviewed Shop Drawings. Before installation, clean reinforcing of loose scale, rust, oil, dirt and any coating that could reduce bond.
- B. Accurately position, install, and secure reinforcing to prevent displacement during the placement of concrete.
- C. Provide metal chairs to hold reinforcement the required distance above form bottoms. In beams and slab construction, provide chairs under top slab reinforcement as well as under bottom reinforcement. Space chairs so that reinforcement will not be displaced during installation. Provide metal spacers to secure proper spacing. Stirrups shall be accurately and securely wired to bars at both top and bottom. At slabs, footings, and beams in contact with earth, provide concrete blocks to support reinforcement at required distance above grade.
- D. Install and secure reinforcement to maintain required clearance between parallel bars and between bars and forms. Lapped splices shall be installed wherever possible in a manner to provide required clearance between sets of bars. Stagger lapped splices. Dowels and bars extending through construction joints shall be secured in position against displacement before concrete is installed and subsequently cleaned of concrete encrustation's while they are still soft.
- E. Do not install reinforcing in supported slabs and beams until walls and columns have been installed to underside of slabs and beams or until construction joints have been thoroughly cleaned. Reinforcing shall be inspected before placement of concrete and cleaned as required.
- F. Use deformed bars unless otherwise indicated, except for spiral reinforcement.

### **3.02 CLEAN UP**

- A. Remove rubbish, debris and waste materials and legally dispose of off the Project site.

### **3.03 PROTECTION**

- A. Protect the Work of this section until Substantial Completion.

**END OF SECTION**



**SECTION 03 30 00**  
**CAST-IN-PLACE CONCRETE**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Cast-in-place concrete placement and finishing.
  - 2. Related Sections:
    - a. Section 03 10 00 - Concrete Forming and Accessories.
    - b. Section 03 20 00 - Concrete Reinforcing.

**1.02 SUBMITTALS**

- A. Shop Drawings: Submit Shop Drawings indicating locations of cast-in-place concrete Work and accessory items such as vapor barriers. Include details and locations of reinforcing, embedded items, and interfacing with other Work.
- B. Product Data:
  - 1. Mix Design: Submit a concrete mix design for each mix that will be provided for the Work. Include water/ cement ratio, size of coarse aggregate and amount of any admixture. Predict minimum compressive strength, maximum slump and air content percentage.
  - 2. Manufacturer of ready-mixed concrete shall deliver to the job for a certificate with each mixer truck. Certificate shall bear the signature of representative of the testing laboratory, and shall state quantity of cement, water, fine and coarse aggregate and admixtures.
- C. Material Samples: Submit Samples illustrating concrete finishes, minimum 12 inches x 12 inches in size.
- D. Certificates: Submit a notarized certificate that each of following conforms to standards indicated:
  - 1. Aggregates - ASTM Standards C33
  - 2. Admixtures - ASTM Standards C260
  - 3. Curing materials - ASTM Standards C171

**1.03 QUALITY ASSURANCE**

- A. Comply with the following as a minimum requirement.
- B. American Concrete Institute (ACI) Publication:
  - 1. ACI 211 - Recommended Practice for Selecting Proportions of Concrete.
  - 2. ACI 304 - Recommended Practice for Measuring, Mixing, Transporting and Placing Concrete.
  - 3. ACI 305 - Recommended Practice for Hot Weather Concreting.
  - 4. ACI 306 - Recommended Practice for Cold Weather Concreting.

5. ACI 308 - Recommended Practice for Curing Concrete.
  6. ACI 309 - Recommended Practice for Consolidation of Concrete.
- C. American Society for Testing and Materials (ASTM) Standards:
1. ASTM A 185 - Welded Steel Wire Fabric For Concrete Reinforcement.
  2. ASTM C 31 - Making and Curing Concrete Test Specimens in the Field.
  3. ASTM C 33 - Concrete Aggregates.
  4. ASTM C 39 - Compressive Strength of Cylindrical Concrete Specimens.
  5. ASTM C 88 - Soundness of Aggregates by use of Sulphate or Magnesium Sulphate.
  6. ASTM C 94 - Ready-Mixed Concrete.
  7. ASTM C 143 - Slump of Hydraulic Cement Concrete.
  8. ASTM C 150 - Portland Cement.
  9. ASTM C 171 - Sheet Materials for Curing Concrete.
  10. ASTM C 172 - Sampling Freshly Mixed Concrete.
  11. ASTM C 173 - Air Content of Freshly Mixed Concrete by the Volumetric Method.
  12. ASTM C 227 - Potential Alkali Reactivity of Cement-Aggregate Combinations (Mortar-Bar Method).
  13. ASTM C 231 - Air Content of Freshly Mixed Concrete by the Pressure Method.
  14. ASTM C 260 - Air-Entraining Admixtures for Concrete.
  15. ASTM C 289 - Potential Reactivity of Aggregates (Chemical Method).
  16. ASTM D 1751 - Preformed Expansion Joint Fillers for Concrete Paving and Structural Construction (Non-extruding and Resilient Bituminous Types).
- D. Continuous inspection shall be provided at the batch plant and for transit-mixed concrete to run check sieve analysis of aggregate, check moisture content of fine aggregate, check design of mix, check cement being used with test reports, check loading of mixer trucks, and certify to quantities of materials placed in each mixer truck.
- E. Inspection shall be performed by a representative of a testing laboratory selected by the Owner. Owner will pay for inspection costs. Notify the laboratory 24 hours in advance of time concrete is to be mixed. Notify the laboratory of postponement or cancellation of mixing within at least 24 hours of scheduling time.
- F. Continuous batch plant inspection requirement may be waived in accordance with CBC Section 1929A. 5. Waiver shall be in writing, including DSA approval.
- G. Strength Test of Concrete: Refer to Section 01 45 33 - Code-Required Special Inspections.

#### **1.04 DELIVERY, STORAGE AND HANDLING**

- A. Mixing and Placing Concrete: Refer to Section 01 45 33 - Code-Required Special Inspections.
- B. Ready-mix concrete shall be mixed and delivered in accordance with ASTM C 94 and CBC Standard 19-3 and 19-4. Each batch of concrete delivered to the Project site shall be accompanied by a time slip bearing departure time and signature of batch plant supervisor. Concrete shall be placed within 90 minutes after start of mixing.

- C. Store cement and aggregate materials so as to prevent their deterioration or intrusion by foreign matter. Deteriorated or contaminated materials shall not be furnished.

**1.05 JOB CONDITIONS**

- A. Cold Weather Requirements:
  1. Adequate equipment shall be provided for heating concrete materials and protecting concrete during freezing or near-freezing weather. Surfaces, in which concrete is to come in contact with, shall be free from frost or ice. No frozen materials or materials containing ice shall be furnished.
  2. When placing concrete during freezing or near-freezing weather the mix shall have a temperature of at least 50 degrees F., but not more than 90 degrees F. when cement is added. Concrete shall be maintained at a temperature of at least 50 degrees F. for at least 72 hours after placing or until it has thoroughly hydrated. When necessary, concrete materials shall be heated before mixing. Special precautions shall be provided for protection of transit-mixed concrete.
- B. Hot Weather Requirements:
  1. During hot weather, proper attention shall be provided for ingredients, production methods, handling, placing, protection and curing, to prevent excessive concrete temperatures or water evaporation which could impair required strength or durability.

**PART 2 - PRODUCTS**

**2.01 GENERAL**

- A. Ready-Mixed Concrete: Mix and deliver in accordance with requirements of CBC Chapter 1905A.
- B. Strength of Concrete: Concrete, unless otherwise indicated or specified, shall be provided with a minimum ultimate 28-day strength of 3000 psi (f'c). For high-early-strength concrete, age for reaching the f'c shall be as indicated on Drawings.

**2.02 MATERIALS**

- A. Cement: ASTM C 150 Type II Portland Cement. Furnished cement shall be as selected and reviewed for concrete proportioning.
- B. Aggregates: Aggregates shall conform to ASTM C 33 and C 227 except as modified herein. Any suitable individual grading of coarse aggregate may be furnished, provided Grading of Combined Aggregate indicated in following table is obtained. Refer to Section 01 45 23: Testing and Inspection.

**GRADING OF COMBINED**

**AGGREGATE**

| Sieve Sumer or<br>Size in inches | 1-1/2"  | 1"      | 3/4"    |
|----------------------------------|---------|---------|---------|
|                                  | Maximum | Maximum | Maximum |
| Passing a 2"                     | -----   | -----   | -----   |
| Passing a 1-1/2"                 | 95-100  | -----   | -----   |
| Passing a 1"                     | 70-90   | 90-100  | -----   |
| Passing a 3/4"                   | 50-80   | 70-95   | 90-100  |

|                   |       |       |       |
|-------------------|-------|-------|-------|
| Passing a 3/8"    | 40-60 | 45-70 | 55-75 |
| Passing a No. 4   | 35-55 | 35-55 | 40-60 |
| Passing a No. 8   | 25-40 | 27-45 | 30-46 |
| Passing a No. 16  | 16-34 | 20-38 | 23-40 |
| Passing a No. 30  | 12-25 | 12-27 | 13-28 |
| Passing a No. 50  | 2-12  | 5-15  | 5-15  |
| Passing a No. 100 | 0-3   | 0-5   | 0-5   |

- C. Water: Water shall be potable and free from deleterious matter.
- D. Admixtures: CBC Chapter 19A, Section 1903A.6, Type A or D.
- E. Expansion Joint Fillers: Preformed strips, non-extruding and resilient bituminous type, of thickness indicated, conforming to ASTM D 1751.
- F. Curing Paper and Liquid Curing Compounds:
  - 1. Curing Paper: A standard brand conforming to ASTM C 171, Type 1 - Regular, Kure-N-Seal.
  - 2. Liquid Curing Compounds: A standard brand, clear liquid conforming to ASTM C 309, Master Builders, Grace, Antihydro.
- G. Abrasive Aggregate: Norton Alundum, Union Carbide Carborundum, or equal, graded #12 through #30 sizes, color as selected by Architect.
- H. Underlayment: Latex underlayment for filling low spots in concrete shall be Tile-Tex by Flintkote Co., Webtex #60 or Fixallatex by Dowman Products Co.
- I. Vapor Retarder: See Section 07 26 16 - Under-Slab Vapor Retarder.
- J. Stair Strips and Nosing:
  - 1. Fabricated from 6063-T5 extruded aluminum, mill finish. Anti-slip filler shall contain at least 60 percent virgin grain aluminum oxide abrasive. Binder shall be fully cured resilient type epoxy, with binder-to-filler ratio of 13 percent. The epoxy-abrasive filler shall extend over the curved front edge of the nosing and shall be securely bonded to the extruded aluminum base.
  - 2. Manufactured by Wooster Products Inc. American Safety Tread Co. Inc., or equal.
  - 3. Nosing and strips for concrete casting shall be provided with Sure-Hold anchors, chevron shaped continuous full length of nosing or strip.
  - 4. Nosings and anchors for attachment to hydrated concrete stairs and wood stairs shall be similar to those specified below, except they shall be provided with countersunk holes for screws and fasteners.
  - 5. Colors: As selected by Architect to contrast with stair color. Colors shall extend uniformly through the filler.
  - 6. Strip and Nosing Types:
    - a. Nosings for sloped riser steel pan stairs: Type WP4J, 4-1/16 inches wide, 3/8 inch thick.
    - b. Nosings for new concrete stairs: Type WP4C, 4-1/16 inches wide, 3/8 inch thick, nose projects down 1/4 inch.



- c. Nosings for square edged steel pan stairs: Type WP4SP, 4-1/16 inches wide, 3/8 inch thick nose.
- d. Strips for recessing into concrete stairs: Type WP1A, except 2-1/4 inches wide, 3/8 inch thick. American Safety Tread Co., Type 24, or equal.
- e. Strips for adhering to existing or hydrated concrete: Flex-Tred anti-safety strips, minimum 2-1/4 inches wide. Cut from rolls and round corners.
- f. Strips for anchoring into wood or stone: American Safety Tread Co., Type 24H, or equal, with holes for fasteners, 2-1/4 inches wide.

## **PART 3 - EXECUTION**

### **3.01 GENERAL**

- A. Time of Placing: Do not place concrete until reinforcement, conduits, outlet boxes, anchors, hangers, sleeves, bolts, and other embedded materials are securely fastened in place. Contact the IOR at least 24 hours before placing concrete; do not place concrete until inspected by the IOR.
- B. Pouring Record: A record shall be kept on the Project site of time and date of placing concrete in each portion of structure. Such record shall be maintained on the Project site until Substantial Completion and shall be available for examination by the Architect and DSA.

### **3.02 PREPARATION**

- A. Vapor Retarder: See Section 07 26 16 - Under-Slab Vapor Retarder.
- B. Reglets and Rebates:
  - 1. Form reglets and rebates in concrete to receive flashing, frames and other equipment as detailed and required. Coordinate dimensions and locations required with other related Work.
  - 2. If concrete slabs on grade adjoin a wall or other perpendicular concrete surface, form a reglet in wall to receive and carry horizontal concrete Work. Reglet shall be full thickness of the slab and shall be 3/4 inch wide, unless otherwise indicated. Requirement does not apply to exterior walks, unless specifically indicated.
- C. Anchor Slots: Dove-tail anchor slots at concrete walls to receive masonry veneer shall be set vertically in forms, 24 inches maximum on centers measured horizontally. Anchor slots shall be No. 24 gage galvanized sheet steel with removable fiber filler to prevent seepage of cement in slot.
- D. Screeds: Install screeds accurately and maintain at required grade or slab elevations after steel reinforcement has been installed, but before starting to place concrete. Install screeds adjacent to walls and in parallel rows not to exceed 8 feet on centers.

### **3.03 INSTALLATION**

- A. Conveying and Placing:
  - 1. Concrete shall be placed only under direct observation of the IOR. Do not place concrete outside of regular working hours, unless the IOR has been notified at least 48 hours in advance.

2. Concrete shall be conveyed from mixer to location of final placement by methods, which will prevent separation or loss of materials.
  3. Concrete shall be placed as nearly as practicable to its final position to avoid segregation due to re-handling or flowing. No concrete that has partially hydrated or has been contaminated by foreign materials shall be placed, nor shall re-tempered concrete or concrete which has been remixed after initial set be placed.
  4. In placing concrete in thin sections, provide openings in forms, elephant trunks, tremies or other recognized devices, to prevent segregation and accumulation of partially hydrated concrete on forms or metal reinforcement above level of concrete being placed. Such devices shall be installed so that concrete will be dropped vertically. Unconfined vertical drop of concrete from end of such devices to final placement surface shall not exceed 6 feet.
  5. Concrete shall be placed as a continuous operation until placing of panel or section is completed. Top surfaces of vertically formed lifts shall be level.
  6. Concrete shall be thoroughly consolidated during placement, and shall be worked around reinforcement and embedded fixtures with mechanical vibrators.
  7. Where conditions make consolidation difficult, or where reinforcement is congested, batches of mortar containing same proportions of cement, sand, and water as provided in the concrete, shall first be deposited in the forms to a depth of at least one inch.
- B. Compaction and Screeding:
1. Tamp freshly placed concrete with a heavy tamper until at least 3/8 inch of mortar is brought to surface. Concrete shall then be tamped with a light tamper and screeded with a heavy straightedge until depressions and irregularities are eliminated, and surface is true to finish grades or elevations. Remove excess water and debris.
  2. Where slabs are to receive separate cement finish or mortar setting bed, continued tamping to raise mortar to surface is not performed. Laitance shall be removed by brushing with a stiff brush or by light sandblasting to expose clean top surface of coarse aggregate.
- C. Floating and Troweling:
1. When concrete has hydrated sufficiently, it shall be floated to a compact and smooth surface. After floating, wait until concrete has reached proper consistency before troweling. Top surfaces shall receive at least 2 troweling operations with steel hand trowel. Prior to and during final troweling, apply a fine mist of water frequently with an atomizing type fog sprayer. Omit troweling for slabs to receive a separate cement finish.
  2. For interior finish slabs, final troweling shall provide a hard, impervious, and non-slip surfaces, free from defects and blemishes. Finished surface shall be within a tolerance of 1/8 inch in 10 feet. Avoid burnishing. Do not add cement or sand to absorb excess moisture.
  3. Exterior Paving and Cement Walks: Finish as specified above, except surface shall be given a non-slip broom finish to match Sample reviewed by the Architect.
  4. Vertical concrete surfaces shall be finished smooth and free from marks or other surface defects.
- D. Curing:

1. Concrete shall be maintained above 50 degrees F., and in a moist condition for 7 days after placing, except that high early strength concrete shall be maintained in a moist condition for 3 days.
  2. Before applying curing paper, interior floor treated with colored hardener shall be given a heavy protective coat of colored wax left unpolished, and then immediately covered with paper. If wax is not applied within two hours after final troweling, concrete shall be sprayed with a fine water mist and maintained continuously moist until wax is applied, unless spraying is not recommended by hardener manufacturer. After other Work such as plastering and painting has been completed, curing paper shall be removed and waxed floors cleaned of protective wax coating.
  3. Forms containing concrete, top of concrete between forms, and exposed concrete surfaces after removal of forms shall be maintained in a thoroughly wet condition for at least 7 consecutive days after placing.
  4. If weather is hot or surface has dried out, spray surface of concrete slabs and paving with fine mist of water, starting not later than 2 hours after final troweling and continuing until sunset. Surface of finish shall be kept continuously wet until curing medium has been installed.
  5. Immediately after finishing, roof slabs and monolithic floor finish to receive resilient floor covering shall be uniformly and completely coated with liquid curing compound.
    - a. Install compound in a manner and quantity sufficient to produce a uniform continuous thin film of water-impervious membrane. Compound shall be installed in accordance with manufacturer's directions.
    - b. Protect adjoining surfaces from damage during installation. If curing compound is not applied immediately, cover finished concrete with wet burlap or curing paper and keep concrete surface wet for a period not to exceed thirty hours following finishing of concrete. At end of that time, burlap or paper shall be removed and curing compound installed as specified above.
    - c. Immediately after finishing, monolithic floor slabs not scheduled to receive resilient floor covering shall be covered with curing paper. Paper shall be lapped 3 inches at joints and sealed with waterproof sealer. Edges shall be cemented to finish. Repair or replace paper damaged during construction operations.
    - d. Within 24 hours after finishing, exterior slabs and paving, and interior slabs to receive cement topping or mortar setting beds, shall be covered with sand to a depth of 2 inches and kept thoroughly wet for 7 days.
      - 1) Instead of sand covering, exterior walks and paving where no other surface treatment is specified, may be cured with clear liquid curing compound immediately installed in accordance with manufacturer's directions.
- E. Filling, Leveling and Patching:
1. Concrete slabs exhibiting high or low spots and indicated to receive resilient floor covering or soft floor covering, shall have surfaces repaired. High spots shall be honed, or ground with power-driven machines to required tolerances. Low spots shall be filled with latex underlayment, installed in strict accordance with manufacturer's written recommendations.

2. Holes resulting from form ties or sleeve nuts shall be solidly packed, through exterior walls, by pressure grouting with cement grout, as specified. Grouted holes on exposed surfaces shall be screeded flush and finished to match adjoining surfaces.
- F. Cement Base: Cement base shall be of the height, thickness, and shape detailed. Base shall be reinforced with one inch mesh, 18 gage, zinc-coated wire fabric. Base finish mixture shall be one part Portland cement, 2 parts of fine aggregate and one part pea gravel. Colored cement base shall include a chemically inert mineral oxide pigment in the mix.

### 3.04 FINISHING

- A. Soda and Acid Wash: Concrete surfaces to receive plaster, paint or other finish, and which have been formed by oil coated forms, shall be scrubbed with a solution of 1-1/2 pounds of caustic soda to one gallon of water. Surfaces where smooth wood or waste molds have been furnished shall be scrubbed with a solution of 20 percent muriatic acid. Wash with clean water after scrubbing.
- B. Sacking: Exposed concrete curbs, walls, and other surfaces shall be sacked by an application of Portland cement grout, floated, and rubbed. Sacking shall not be performed until patching and filling of holes has been completed. Entire sacking operation for any continuous area shall be started and completed within the same day.
1. Mix one part Portland cement and 1-1/2 parts fine sand with sufficient water to produce a grout having consistency of thick paint. Wet surface of concrete sufficiently to prevent absorption of water from grout. Apply grout uniformly with a brush or spray gun, then immediately float surface with a cork or other suitable float, scouring wall vigorously.
  2. While grout is still plastic, finish surface with a sponge-rubber float, removing excess grout. Allow surface to dry thoroughly, then rub vigorously with dry burlap to completely remove dried grout. No visible film or grout shall remain after rubbing with burlap.
- C. Sandblasting: Exterior concrete surfaces to receive stucco dash coat finish, where plywood or other smooth forms have been furnished, shall be uniformly sand-blasted with sharp quartz sand under sufficient air pressure to remove dirt, form oil and other foreign materials, and roughen surface to provide a proper bond. Such surfaces shall be thoroughly washed with clean water after sandblasting.
- D. Abrasive: Concrete stair treads, landings, ramps and steps on interior and exterior of buildings, and interior exposed concrete floors in shop buildings shall receive an abrasive finish. Abrasive grains in amount of 30 pounds per 100 square feet shall be evenly installed by dust-on method and embedded into surface during first troweling operation. Additional abrasive grains, in amount of 30 pounds per 100 square feet, shall then be evenly installed and embedded into surface during final troweling operation.
- E. Floor Hardener: Exposed interior concrete floors throughout shall be treated with floor hardener, as specified. Install hardener after surface of concrete has reached the point where no excess moisture is present, but while it is still plastic. Hardener shall be installed as follows:
1. Colored Hardener: Install at rate of 40 pounds per 100 square feet of surface for initial application.
  2. Gray (natural) Hardener: Install at rate of 20 pounds per 100 square feet of surface for initial application.

3. Hardener shall be evenly distributed and thoroughly floated into surface mortar with a wood float. An additional 20 pounds of hardener, colored or gray, specified as above, shall be installed over each 100 square feet, and troweled to an even surface having uniform color and texture.
- F. Cement Grout and Dry-Pack Concrete: Cement grout shall be mixed at the Project site and shall be composed of one volume of Portland cement and 2-1/2 volumes of fine aggregate. Materials shall be mixed dry with sufficient water added to make mixture flow under its own weight. When grout is used as a dry pack concrete, add sufficient water to provide a stiff mixture, which can be molded into a sphere.
- G. Broom Finish: Exterior stair treads and landings shall be provided with a non-slip broom finish in addition to abrasive finish specified.
- H. Abrasive Stair Nosing: Nosing shall be installed according to manufacturers written recommendations.

### **3.05 EXPANSION AND CONSTRUCTION JOINTS**

- A. Construction Joints: Details and proposed location of construction joints shall be as indicated on the Drawings, located to least impair strength of structure, in accordance with the following:
  1. Thoroughly clean contact surface by sand blasting entire surface not earlier than 5 days after initial placement.
  2. A mix containing same proportion of sand and cement provided in concrete plus a maximum of 50 percent of coarse aggregate shall be placed to a depth of at least one inch on horizontal joints. Vertical joints shall be wetted and coated with a neat cement grout immediately before placing of new concrete.
  3. Should contact surface become coated with earth, sawdust, or deleterious material of any kind after being cleaned, entire surface shall be re-cleaned before applying mix.
- B. Expansion Joints: Provide expansion joints where indicated in walks and exterior slabs. Space approximately 20 feet apart, unless otherwise indicated. Joints shall extend entirely through slab with joint filler in one piece for width of walk or slab. Joint filler shall be 3/8 inch thick, unless otherwise indicated.
- C. Tooled Joints: Slabs, walks and paving shall be marked into areas as indicated with markings made with a V-grooving tool. Marks shall be round-edged, free from burrs or obstructions, with clean cut angles and shall be straight and true. Walks, if not indicated, shall be marked off into rectangles of not more than 12 square feet and shall have a center marking where more than 5 feet wide.

### **3.06 TESTING**

- A. Molded Cylinder Tests:
  1. Owner Consultant will prepare cylinders. Each cylinder shall be dated, given a number, point in structure from which sample was obtained, mix design number, mix design strength and result of accompanying slump test noted.
  2. Separate tests of molded concrete cylinders obtained at same place and time shall be made at age of 3 days, 7 days, and 28 days. A strength test shall be the average of the

compressive strength of 2 cylinders, obtained from the same sample of concrete and tested at 28 days or at test age designated for determination of f'c.

3. Test cylinders shall be prepared at the Project site and stored in testing laboratory in accordance with ASTM C 31, and tested in accordance with ASTM C 39.
- B. Core Test: At request of the Architect, cores of hardened concrete shall be cut from portions of hydrated structures for testing, in accordance with CBC and ASTM C 42.
1. Provide 4 inch diameter cores at representative places throughout the structure as designated by the Architect.
  2. In general, provide sufficient cores to represent concrete placed with at least one core for each 4,000 square feet of building area, and at least 3 cores total for each Project.
  3. Where cores have been removed, fill voids with drypack, and patch the finish to match the adjacent existing surfaces.
- C. Concrete Consistency: Measure consistency according to ASTM C 143. Test twice each day or partial day's run of the mixer.
- D. Adjustment of Mix: If the strength of any grade of concrete for any portion of Work, as indicated by molded test cylinders, fall below minimum 28 days compressive strength specified or indicated, adjust mix design for remaining portion of construction so that resulting concrete meets minimum strength requirements.
- E. Defective Concrete:
1. Should strength of any grade of concrete, for any portion of Work indicated by tests of molded cylinders and core tests, fall below minimum 28 days strength specified or indicated, concrete will be deemed defective Work and shall be replaced or adequately strengthened in a manner acceptable to the Architect and DSA.
  2. Concrete Work that is not formed as indicated, is not true within 1/250 of span, not true to intended alignment, not plumb or level where so intended, not true to intended grades and levels, contains sawdust shavings, wood or embedded debris, or does not fully conform to Contract provisions, shall be deemed to be defective Work and shall be removed and replaced.
- F. Concrete for Equipment Pads, Mechanical and Electrical Work: Unless otherwise indicated, strength shall be 3,000 psi concrete. Exposed concrete shall be provided with a hand trowel finish with radius corners and edges. Form and place concrete where necessary as described in Section 30 10 00: Concrete Forms and Accessories, and reinforced as described in Section 03 20 00: Concrete Reinforcement. Calcium chloride shall not be furnished in any concrete mix provided for the installation of underground electrical conduits. For concrete encasement of more than one conduit, furnish 3/4 inch to 1 inch aggregate as specified for concrete mix.

### **3.07 CLEAN UP**

- A. Remove rubbish, debris and waste materials and legally dispose of off the Project site.

### **3.08 PROTECTION**

- A. Protect the Work of this section until Substantial Completion.

**END OF SECTION**

**SECTION 03 35 11**  
**CONCRETE FLOOR FINISHES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Surface treatments for concrete floors and slabs.

**1.02 RELATED REQUIREMENTS**

- A. Section 03 30 00 - Cast-in-Place Concrete: Finishing of concrete surface to tolerance; floating, troweling, and similar operations; curing.
- B. Section 03 35 43 - Concrete Floor Polishing.

**1.03 ADMINISTRATIVE REQUIREMENTS**

- A. Coordinate the work with concrete floor placement and concrete floor curing.
- B. Pre-Concrete Placement Meeting:
  - 1. Prior to the start of concrete placement Contractor shall conduct a meeting to review the required methods and procedures to achieve the required finish. Contractor shall send a meeting agenda to all attendees 20 days prior to the scheduled date of the meeting
  - 2. The Contractor shall require responsible representatives of every party concerned with the concreting work to attend the meeting, including but not limited to the following: Contractor's superintendent, ready-mix company, testing lab, topping and coating applicator, and Construction Manager.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Manufacturer's published data on each finishing product, including information on compatibility of different products and limitations.
- C. Maintenance Data: Provide data on maintenance and renewal of applied finishes.
- D. Certification: Submit manufacturer's certificate that all materials supplied conform to applicable Federal regulations and to applicable State and Local air pollution emission ordinances and regulations.

**1.05 MOCK-UP**

- A. For coatings, construct mock-up area under conditions similar to those that will exist during application, with coatings applied.
- B. Mock-Up Size: 6 feet square.
  - 1. Demonstrate typical joints, surface finish, texture, color, and standard of workmanship.
- C. Locate where directed.
- D. Acceptable mock-up may remain as part of the work.

## **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver materials in manufacturer's sealed packaging, including application instructions.

## **1.07 FIELD CONDITIONS**

- A. Maintain light level equivalent to a minimum 200 W light source at 8 feet above the floor surface over each 20 foot square area of floor being finished.
- B. Do not finish floors until interior heating system is operational.
- C. Maintain ambient temperature of 50 degrees F minimum.

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. All products used shall meet VOC requirements Content Restrictions.
- B. Requirements for Physically Disabled: Provide flooring meeting slip-resistant requirements of California Code of Regulations (CCR), Title 24, Part 2, Chapter 11B and ADA Standards.
  - 1. Flooring demonstrating a coefficient of friction of at least wet SCOF 0.6 per ASTM C1028 will be accepted as meeting the intent of slip resistance; CBC 11B-302 Floor or Ground Surfaces, 11B-403 Walking Surfaces, and ADA Standards.
    - a. Also acceptable: A dynamic coefficient of friction of at least 0.42 per DCOF AcuTest ANSI A137.1 Section 9.6.
  - 2. Flooring surface shall be stable, firm, and slip resistant. CBC Section 11B-302.1 General.
  - 3. Flooring surface demonstrating a dynamic coefficient of friction of at least 0.42 wet per DCOF AcuTest ANSI A137.1 Section 9.6 and ANSI/NFSI B101.3 (using a BOT-3000 testing unit) will be accepted as meeting the intent of slip resistance; CBC 11B-302 Floor or Ground Surfaces and ADA Standards.
    - a. Ramp surface: Provide DCOF value of 0.46 wet.

### **2.02 CONCRETE FLOOR FINISH APPLICATIONS**

- A. Unless otherwise indicated, all concrete floors are to be finished using high gloss sealer.
- B. Liquid Densifier/Hardener:
  - 1. Use at following locations: concrete floors on grade.
- C. Penetrating Clear Sealer:
  - 1. Use at following locations: C-2.
- D. Polished Finish:
  - 1. Use at following locations: C-1.

### **2.03 DENSIFIERS AND HARDENERS**

- A. Liquid Densifier/Hardener: Penetrating chemical compound that reacts with concrete, filling the pores and dustproofing; for application to concrete after set.
  - 1. Composition: Lithium silicate.



2. Abrasion Resistance to Revolving Disks: At least a 32.5% improvement over untreated samples when tested in accordance with ASTM C779.
3. Surface Adhesion: At least a 22% increase in adhesion for epoxy when tested in accordance with ASTM D3359.
4. Hardening: As follows when tested in accordance with ASTM C39:
  - a. After 7 Days: An increase of at least 40% over untreated samples.
  - b. After 28 Days: An increase of at least 38% over untreated samples.
5. Coefficient of Friction: 0.86 dry, 0.69 wet when tested in accordance with ASTM C1028.
6. Rebound Number: An increase of at least 13.3% over untreated samples when tested in accordance with ASTM C805.
7. Light Exposure Degradation: No evidence of adverse effects on treated samples when tested in accordance with ASTM G23.
8. Products:
  - a. Dayton Superior Corporation; Pentra-Hard® Densifier: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
  - b. L&M Construction Chemicals, Inc, a subsidiary of Laticrete International, Inc; SEAL HARD: [www.lmcc.com/#sle](http://www.lmcc.com/#sle).
  - c. Nox-Crete Products Group; Duro-Nox: [www.nox-crete.com/#sle](http://www.nox-crete.com/#sle).
  - d. SpecChem, LLC; Cure Hard: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
  - e. Euclid Chemical Corporation; Eucosil: [www.euclidchemical.com](http://www.euclidchemical.com).
  - f. Paul M. Wolff Co.; SHUR-HARD: [www.paulwolffco.com](http://www.paulwolffco.com).
  - g. W. R. Meadows, Inc; Liqui-Hard: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
  - h. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

#### **2.04 COATINGS**

- A. Plastic Aggregate: Finely ground polymer for addition to coatings for slip resistance.
  1. Products:
    - a. Dayton Superior Corporation; Grip Aid: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - b. SpecChem, LLC; Surface Grip: [www.specchemllc.com/#sle](http://www.specchemllc.com/#sle).
    - c. W. R. Meadows, Inc; Sure-Step: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - d. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

#### **2.05 POLISHED CONCRETE SYSTEM**

- A. Polished Concrete System: Materials, equipment, and procedures designed and furnished by a single manufacturer to produce dense polished concrete of the specified sheen.
  1. See Section 03 35 43 - Concrete Floor Polishing.

#### **2.06 JOINT FILLER**

- A. Two component, semi-rigid, epoxy joint filler with minimum compressive strength at 72 hours of 3000 psi per ASTM D 695, minimum elongation of 55% per ASTM D 638, and minimum Shore A Hardness of 100 per ASTM D 2240.
- B. Color(s): As selected by Architect from manufacturer's standard range.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that floor surfaces are acceptable to receive the work of this section.
  - 1. Concrete substrate shall be structurally sound.
- B. Concrete shall be minimum 28 days old.
- C. Verify that flaws in concrete have been patched and joints filled with methods and materials suitable for further finishes.

### **3.02 PREPARATION**

- A. Blow clean using unoiled air or vacuum clean.
- B. Surface profile shall be CSP 2-5 per ICRI 310.2R.

### **3.03 GENERAL**

- A. Apply materials in accordance with manufacturer's instructions.

### **3.04 JOINT FILLER APPLICATION**

- A. All joint facings shall possess an open surface texture. Run a saw blade or grinder down each side of the joint to expose fresh concrete.
- B. Do not use backer rod, sand, or other fill material. Joint filler shall be full depth. A very thin sand layer is acceptable to help prevent the joint filler from flowing into the substrate.
- C. Blow joints clean using un-oiled air.
- D. Prepare joint filler per manufacturer's recommendations.
- E. Fill to 2/3 of the full depth of the joint.
- F. Allow the joint filler to settle and then within 1 hour complete the filling and slightly overfill the joint.
- G. Within 24 hours cut flush with a razor knife or grind flush.

### **3.05 COATING APPLICATION**

- A. Verify that surface is free of previous coatings, sealers, curing compounds, water repellents, laitance, efflorescence, fats, oils, grease, wax, soluble salts, residues from cleaning agents, and other impediments to adhesion.
- B. Verify that water vapor emission from concrete and relative humidity in concrete are within limits established by coating manufacturer.
- C. Protect adjacent non-coated areas from drips, overflow, and overspray; immediately remove excess material.
- D. Apply coatings in accordance with manufacturer's instructions, matching approved mock-ups for color, special effects, sealing and workmanship.
- E. Broadcast system:
  - 1. Apply first layer of coating with non-slip aggregate as recommended by manufacturer.
  - 2. Apply topcoat as recommended by manufacturer.

**3.06 CONCRETE POLISHING**

- A. Execute using materials, equipment, and procedures specified by manufacturer, using manufacturer approved installer.

**3.07 PROTECTION**

- A. Prevent trades from walking and driving through uncured Joint Filler.

**END OF SECTION**



**SECTION 03 35 43**  
**CONCRETE FLOOR POLISHING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. (C-1) Cleaning, application of liquid surface treatment and floor grinding, polishing to specified finish and appearance level.

**1.02 RELATED REQUIREMENTS**

- A. Section 03 30 00 - Cast-in-Place Concrete: Prepared concrete floors ready to receive finish.
- B. Section 07 92 00 - Joint Sealants.

**1.03 REFERENCE STANDARDS**

- A. 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines; current edition.
- B. 24 CFR 51 - Guide to Concrete Floor and Slab Construction; 2015.
- C. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- D. ANSI A137.1 - American National Standard Specifications for Ceramic Tile; 2012.
- E. ANSI/NFSI B101.3 - Test Method for Measuring Wet DCOF of Common Hard Surface Floor Materials; 2012.
- F. ASTM C171 - Standard Specification for Sheet Materials for Curing Concrete; 2016.
- G. ASTM C309 - Standard Specification for Liquid Membrane-Forming Compounds for Curing Concrete; 2011.
- H. ASTM C779/C779M - Standard Test Method for Abrasion Resistance of Horizontal Concrete Surfaces; 2012.
- I. ASTM D2047 - Standard Test Method for Static Coefficient of Friction of Polish-Coated Flooring Surfaces as Measured by the James Machine; 2011.
- J. Reunion Internationale des Laboratoires D'Essais et de Recherches sur les Matériaux et les Constructions (RILEM): RILEM Test Method 11.4 Standard Measurement of Reduction of Moisture Penetration Through Horizontal Concrete Surfaces.

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Coordination: Coordinate the installation of polished concrete with size, location and installation of service utilities.
- B. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by all affected installers.
  - 1. Agenda: Verify project requirements, manufacturer's installation instructions and manufacturer's warranty requirements. Comply with Section 01 33 00 - Submittal Procedures.
    - a. All parties that influence the results of the polishing process must attend including Polishing/Processing Installer, Concrete Subcontractor, District, Architect, Contractor and Parties responsible for assuring concrete mix design.

- b. Determine at what stage in construction floors are to be finished.
- c. Review how all parties are to work together and how each influences final results.
- d. Review the following:
  - 1) Environmental requirements.
  - 2) Scheduling and phasing of work.
  - 3) Coordinating with other work and personnel.
  - 4) Protection of adjacent surfaces.
  - 5) Surface preparation.
  - 6) Repair of defects and defective work prior to installation.
  - 7) Cleaning.
  - 8) Installation of polished floor finishes.
  - 9) Application of liquid hardener, densifier.
  - 10) Protection of finished surfaces after installation.

### **1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures for submittal procedures.
- B. Product Data: Submit manufacturer's complete and most current technical data sheets for the following:
  - 1. Preparation and concrete grinding procedures.
  - 2. Colored Concrete Surface, Dye Selection Guides.
  - 3. Liquid Surface Treatment.
  - 4. Floor Polish.
- C. Shop Drawings: Indicate information on shop drawings as follows:
  - 1. Typical layout including dimensions and floor grinding schedule.
  - 2. Plan view of floor and joint pattern layout.
  - 3. Areas to receive colored surface treatment.
  - 4. Hardener, sealer, densifier in notes.
- D. Test Reports: Certified test reports showing compliance with specified performance characteristics and physical properties.
- E. Certificates:
  - 1. Product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements.
  - 2. Letter of certification from an independent test confirming the system has been tested and passed slip resistance requirements.
  - 3. Current contractor's certificate signed by manufacturer declaring contractor as an approved installer of polishing system.
- F. Manufacturer's Instructions: Manufacturer's installation instructions.
- G. Warranty: Submit warranty documents specified.
- H. Operation and Maintenance Data: Submit operation and maintenance data for installed products in accordance with Section 01 77 00 - Closeout Procedures.
  - 1. Manufacturer's instructions on maintenance renewal of applied treatments.

2. Protocols and product specifications for joint filing, crack repair and/or surface repair.
3. Extra Materials:
  - a. Contractor to provide maintenance materials in accordance with Section 01 77 00 - Closeout Procedures.

#### **1.06 QUALITY ASSURANCE**

- A. Liquid Surface Treatment Applicator Qualifications:
  1. Provide letter of certification from manufacturer stating that the applicator is an approved applicator of the product system, is in good standing, and is familiar with the proper manufacturer's procedures and installation requirements.
  2. Provide a list of a minimum of five (5) projects performed of similar type, size and complexity.
- B. The approved applicator shall provide proof of quantity of material used, and batch/lot numbers. Material shall be stored in accordance with the Manufacturer's instructions.
- C. Applicator Qualifications: Provide an adequate number of skilled workers who are trained and experienced in the necessary craft.

#### **1.07 MOCK-UP**

- A. Construct mock-up area under conditions similar to those which will exist during actual placement, 100 sq. ft.. Produce using specifications for areas to receive concrete processing or polishing.
  1. Provide multiple finish mock-ups as indicated on Drawings.
- B. Place and finish by the same concrete flat work installer responsible for pouring and placing permanent flatwork.
- C. Concrete processing to be performed with the same abrasives, equipment, hardeners/densifiers, dye and personnel to be used in processing permanent flatwork.
- D. Notify Architect 14 days prior to mock-up construction.
- E. Locate where directed.
- F. Contractor is to maintain mock-ups during construction and will be used as a general reference to the finished product.
- G. Mock-up may remain as part of the Work.
- H. Allow minimum 2 business days for inspection of mock-up before proceeding with work.

#### **1.08 FIELD CONDITIONS**

- A. The Contractor is to accommodate the needs of the concrete polisher subcontractor and keep the immediate work areas clear of other trades, pedestrian traffic and disturbances.
- B. The Contractor must coordinate the work so as not to delay other work in progress.
- C. Environmental Limitations:
  1. Refer to Manufacturer's written instructions for environmental limitations.
  2. Dispose of used or diluted liquid surface treatment chemicals and wash water according to applicable Governmental standards.

- D. Protection prior to installation:
  - 1. The following is required to protect the floor slab from stains.
    - a. Inspect and diaper all hydraulic powered equipment to avoid staining of the concrete.
    - b. Allow no trade to park vehicles on the inside slab. If necessary to complete their scope of work, place drop cloths under vehicles at all times.
    - c. Do not allow pipe cutting/threading machines to be used on the inside floor slab.
    - d. Do not allow steel placed on interior slab to cause rust stains.
    - e. Do not allow acids and acidic detergents to come into contact with slab.
    - f. Do not allow paint to come into contact with slab.
    - g. Ensure vehicles and equipment used on slabs have tires that will not leave marks.
      - 1) Ensure slab surface is protected from equipment scrapes, impact abrasions, etc.
      - 2) Contractor is to inform and enforce to all trades that the slab must be protected at all times.
- E. Close areas to traffic during floor application and after application, for time period recommended in writing by manufacturer.

## **1.09 SEQUENCING**

- A. Sequence With Other Work: Comply with manufacturer's written recommendations for sequencing construction operations.

## **1.10 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver materials in manufacturer's original containers, with seals unbroken, bearing manufacturer's labels indicating brand name, batch/lot numbers and directions for storage.
- B. Dispense special concrete finish materials from factory numbered and sealed containers. Maintain record of batch/lot numbers.
- C. Submit record of batch/lot numbers to liquid surface treatment manufacturer for validation and issuance of warranties at the conclusion of the applications.

## **1.11 WARRANTY**

- A. Project Warranty: Refer to Contract Conditions for project warranty provisions.
- B. Manufacturer's Warranty: Submit, for Owner's acceptance, manufacturer's standard warranty document executed by authorized company official. Manufacturer's warranty is in addition to, and does not limit, other rights Owner may have under Contract Documents.
- C. Warranty: Commencing on date of Substantial Completion.

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. Requirements for Physically Disabled: Provide flooring meeting slip-resistant requirements of California Code of Regulations (CCR), Title 24, Part 2, Chapter 11B and ADA Standards.
  - 1. Flooring surface shall be stable, firm, and slip resistant. CBC Section 11B-302.1 General.



2. Flooring demonstrating a coefficient of friction of at least 0.6 per ASTM D2047 will be accepted as meeting the intent of slip resistance; CBC 11B-302 Floor or Ground Surfaces, 11B-403 Walking Surfaces, and ADA Standards.
  - a. Also acceptable: A dynamic coefficient of friction of at least 0.42 per DCOF AcuTest ANSI A137.1 Section 9.6.
- B. 36 CFR 1191 - Americans with Disabilities Act Accessibility Guidelines for Buildings and Facilities; Final Rule; current edition; (ADA Standards).

## 2.02 MANUFACTURERS

- A. Systems:
  1. Ameripolish, Inc; Ameripolish Polished Concrete System: [www.ameripolish.com/#sle](http://www.ameripolish.com/#sle).
  2. ARDEX Engineered Cements; ULTRAFLOOR Polished Concrete System; ARDEX PC-T Concrete Topping; ARDEX PC Finish sealer: [www.ardexamericas.com](http://www.ardexamericas.com).
  3. Euclid Chemical Company; DOUBLE DIAMOND POLISHED CONCRETE FLOOR SYSTEMS: [www.euclidchemical.com/#sle](http://www.euclidchemical.com/#sle).
  4. L&M Construction Chemicals, Inc., a subsidiary of Laticrete International, Inc.; FGS Permashine Concrete Polishing System: [www.lmcc.com](http://www.lmcc.com).
  5. L.M. Scofield Company; SCOFIELD® Formula One™ Ground & Polished Concrete Systems: [www.scofield.com](http://www.scofield.com).
  6. PROSOCO, Inc; Consolideck Polished Concrete System: [www.prosoco.com/consolideck/#sle](http://www.prosoco.com/consolideck/#sle).
  7. W.R. Meadows, Inc; Induroshine and Bellatrix Concrete Enhancer: [www.wrmeadows.com](http://www.wrmeadows.com).
  8. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## 2.03 SYSTEM DESCRIPTION

- A. Concrete Requirements:
  1. Hardened Concrete Properties:
    - a. Minimum Concrete Compressive Strength: 3,500 psi, not to be less than indicated by Structural Drawings or Section 03 30 00 - Cast-in-Place Concrete.
    - b. Normal Weight Concrete: No lightweight aggregate.
    - c. Non-air entrained.
  2. Placement Properties:
    - a. Natural concrete slump of 4 1/2 to 5 inches. Admixtures may be used.
    - b. Flatness Requirements:
      - 1) Overall FF 40.
      - 2) Local FL 20.
  3. Hard-Steel Troweled (3 passes) Concrete: No burn marks. Finish to 24 CFR 51, Class 5 floor.
  4. Curing Options:
    - a. Membrane forming curing compounds (ASTM C309, Type 1, Class B, all resin, dissipating cure).

- 1) Acrylic curing and sealing compounds not recommended.
  - b. Sheet membrane (ASTM C171); polyethylene film not recommended.
  - c. Damp Curing: Seven day cure.
- B. Performance Requirements: Provide polished concrete flooring installed to achieve the following:
1. Minimum Static Coefficient of Friction: as noted in Regulatory Requirements.
    - a. Static Coefficient of Friction, measured in accordance with ASTM D2047.
    - b. High Traction Rating: ANSI/NFSI B101.3-A, non-slip properties.
  2. Abrasion Resistance: ASTM C779/C779M, Method A, high resistance, no more than 0.008 inch wear in 30 minutes.
  3. Reflectivity: Increase of 35% as determined by standard gloss meter.
  4. Waterproof Properties: Rilem Test Method 11.4, 70% or greater reduction in absorption.
- C. It is recognized that floor polishing systems are proprietary in nature. The system products and techniques employed shall be approved by the single manufacturer selected.
1. Ensure concrete finishing components and materials are from single manufacturer.

## 2.04 MATERIALS

- A. Basis of Design Proprietary Products/Systems:
1. Hardener, Sealer, Densifier: Proprietary, water based, odorless liquid, VOC compliant, environmentally safe chemical hardening solution leaving no surface film.
  2. Joint Filler: Semi-rigid, 2-component, self-leveling, 100% solids, rapid curing, polyurea control joint and crack filler with Shore A 80 or higher hardness.
  3. Oil Repellent Sealer: Ready to use, silane, siloxane and fluoropolymers blended water based solution sealer, quick drying, low-odor, oil and water repellent, VOC compliant and compatible with chemically hardened floors.
  4. Concrete Dyes: Fast-drying dye, packaged in premeasured units ready for mixing with VOC exempt solvent; formulated for application to polished cementitious surfaces.
  5. Cleaning Solution: Proprietary, mild, highly concentrated liquid concrete cleaner and conditioner containing wetting and emulsifying agents; biodegradable, environmentally safe and certified High Traction by National Floor Safety Institute (NFSI).
- B. Finish:
1. Standard: High gloss (HG-1), 1500 grit.
- C. Aggregate:
1. Cream finish (little to no aggregates)
  2. Color: As selected by Architect.
- D. Refer to manufacturer's data sheet for specific instructions regarding correct dilution ratios, application techniques, and application rates.
- E. Recommended compatible cleaner for preparation.
- F. Recommended compatible maintenance cleaner.

## **2.05 RELATED MATERIALS**

- A. Scrubbing and Burnishing Machines: Equipment used for scrubbing and burnishing operations shall be Clark, Advance, Tennant, PowerBuff, Tornado or similar equipment as required to produce the specified results.
- B. Water: Potable.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Site Verification of Conditions:
  - 1. The Contractor shall examine slab surface prior to starting work, with Liquid Surface Treatment Applicator present, for any conditions affecting the Applicator's ability to properly apply the liquid surface or polishing treatment.
    - a. Do not proceed until unsatisfactory conditions are corrected.
  - 2. Verify that concrete substrate conditions, which have been previously installed under other sections or contracts, are acceptable for product installation in accordance with manufacturer's instructions prior to installation of concrete finishing materials.
- B. Verify Concrete Slab Performance Requirements:
  - 1. Verify concrete is cured to 28 day, 3,500 psi strength.
  - 2. Verify concrete surfaces received a hard steel-trowel finish (3 passes) during placement.
- C. When wet cure method is used, clean the floor immediately after the removal of the wet curing sheet to remove all residue, alkalis, etc. Do not permit the floor surface to dry between wet curing sheet removal and initial scrubbing.
- D. Prior to application, verify that floor surfaces are free of laitance.
- E. Coordinate with joint filling operations. Do not perform wet cleaning within 72 hours prior to joint filling.

### **3.02 PREPARATION**

- A. Ensure surfaces are clean and free of dirt latent salts, curing membrane, bond- breaker, laitance, and any other residues or other foreign matter harmful to performance of concrete finishing material system.
- B. Examine surface to determine soundness of concrete for polishing.
- C. Remove surface contamination.
- D. Vacuum and clean saw cut joints and surrounding area so that no dust remains to react with liquid surface treatment material.
- E. Beginning of system treatment application indicates acceptance of existing conditions.

### **3.03 APPLICATION**

- A. Floor Surface Polishing and Treatment:
  - 1. Provide polished concrete floor treatment in entirety of slab indicated by drawings. Provide consistent finish in all contiguous areas.

2. Apply floor finish prior to installation of equipment, fixtures and accessories.
  3. Diamond polish concrete floor surfaces with power disc machine recommended by floor finish manufacturer. Sequence with coarse to fine grit using dry method.
    - a. Comply with manufacturer's recommended polishing grits for each sequence to achieve desired finish level. Level of sheen shall match that of approved mock-up.
    - b. Expose aggregate in concrete surface only as determined by approved mock-up.
    - c. All concrete surfaces shall be as uniform in appearance as possible.
  4. Dyed and Polished Concrete:
    - a. Locate demarcation line between dyed surfaces and other finishes.
    - b. Polish concrete to final finish level.
    - c. Apply diluted dyes to polished concrete surface.
    - d. Allow dye to dry.
    - e. Remove residue with dry buffer; reapply as necessary for desired result.
  5. Apply Hardener and Densifier as follows:
    - a. First coat at 250 sq.ft./gal.
    - b. Second coat at 350 sq.ft./gal.
    - c. Follow manufacturer's recommendations for drying time between successive coats.
  6. Remove defects and repolish defective areas.
  7. Finish edges of floor finish adjoining other materials in a clean and sharp manner.
- B. Whitening of concrete by over-application or inadequate removal of liquid surface treatment may be cause for rejection.

### **3.04 ADJUSTMENTS**

- A. Polish to higher gloss those areas not meeting specified gloss levels per mock-up.
- B. Fill joints flush to surface.

### **3.05 FINAL CLEANING**

- A. Do cleanup in accordance with Section 01 70 00 - Execution and Closeout Requirements.
- B. Mechanically scrub treated floors for seven days with soft to medium pads with approved cleaning solution.
- C. Upon completion, remove surplus and excess materials, rubbish, tools and equipment.

### **3.06 WORKMANSHIP AND CLEANING**

- A. The premises shall be kept clean and free of debris at all times.
- B. Remove debris from jobsite.
  1. Dispose of materials in separate, closed containers in accordance with local regulations and per the Storm Water Protection Procedures Plan (SWPPP).

### **3.07 PROTECTION**

- A. The floor should then be protected, and ensured that it is not to come into contact with water for 72 hours following the application of the floor polish system.

- B. Protect installed product from damage during construction in accordance with Section 01 70 00 - Execution and Closeout Requirements.
- C. Protect with EZ Cover™ by McTech Corp., or comparable product.
  - 1. Contact: Phone: (866) 913-8363; website: www.ezform.net.

**3.08 SCHEDULE**

- A. Standard Finish High Gloss HG-1, Color Medium Grey: Student Life, Servery/Dining, Captains Table.

**END OF SECTION**



**SECTION 04 20 01**  
**MASONRY VENEER**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Clay facing brick.
- B. Mortar and grout.
- C. Reinforcement and anchorage.
- D. Flashings.
- E. Installation of lintels.
- F. Accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 06 10 00 - Rough Carpentry: Wood stud backup for masonry veneer.
- B. Section 07 62 00 - Sheet Metal Flashing and Trim: Through-wall masonry flashings.
- C. Section 07 92 00 - Joint Sealants: Sealing control and expansion joints.

**1.03 REFERENCE STANDARDS**

- A. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2016a.
- B. ASTM C91/C91M - Standard Specification for Masonry Cement; 2012.
- C. ASTM C150/C150M - Standard Specification for Portland Cement; 2018.
- D. ASTM C207 - Standard Specification for Hydrated Lime for Masonry Purposes; 2018.
- E. ASTM C216 - Standard Specification for Facing Brick (Solid Masonry Units Made From Clay or Shale); 2017a.
- F. ASTM C270 - Standard Specification for Mortar for Unit Masonry; 2014a.
- G. ASTM C404 - Standard Specification for Aggregates for Masonry Grout; 2018.
- H. BIA Technical Notes No. 7 - Water Penetration Resistance – Design and Detailing; 2017.
- I. BIA Technical Notes No. 28B - Brick Veneer/Steel Stud Walls; 2005.
- J. BIA Technical Notes No. 46 - Maintenance of Brick Masonry; 2017.
- K. TMS 402/602 - Building Code Requirements and Specification for Masonry Structures; 2016.

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Preinstallation Meeting: Convene one week before starting work of this section.

**1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide data for masonry units, fabricated wire reinforcement, and mortar.
- C. Samples: Submit four samples of decorative block units to illustrate color, texture, and extremes of color range.

- D. Manufacturer's Certificate: Certify that masonry units meet or exceed specified requirements.
- E. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.

### **1.06 QUALITY ASSURANCE**

- A. Comply with provisions of TMS 402/602, except where exceeded by requirements of Contract Documents.
  - 1. Maintain one copy of each document on project site.
- B. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section with minimum three years of documented experience.
- C. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years of documented experience.

### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver, handle, and store masonry units by means that will prevent mechanical damage and contamination by other materials.
- B. Handle and store ceramic glazed masonry units in protective cartons or trays. Do not remove from protective packaging until ready for installation.

### **1.08 FIELD CONDITIONS**

- A. Cold and Hot Weather Requirements: Comply with requirements of TMS 402/602 or applicable building code, whichever is more stringent.

## **PART 2 PRODUCTS**

### **2.01 BRICK UNITS**

- A. Facing Brick: ASTM C216, Type FBS Smooth, Grade MW.
  - 1. Color and Texture: Match existing.
  - 2. Nominal Size: Match existing.
  - 3. Special Shapes: Molded units as required by conditions indicated, unless standard units can be sawn to produce equivalent effect.
  - 4. Compressive Strength: As indicated on drawings, measured in accordance with ASTM C67.

### **2.02 MORTAR AND GROUT MATERIALS**

- A. Masonry Cement: ASTM C91/C91M Type N.
  - 1. Colored Mortar: Premixed cement as required to match Architect's color sample.
- B. Portland Cement: ASTM C150/C150M, Type I; color as required to produce approved color sample.
- C. Hydrated Lime: ASTM C207, Type S.
- D. Grout Aggregate: ASTM C404.



- E. Water: Clean and potable.

### **2.03 REINFORCEMENT AND ANCHORAGE**

- A. Masonry Veneer Anchors: 2-piece anchors that permit differential movement between masonry veneer and structural backup, hot dip galvanized to ASTM A 153/A 153M, Class B.
  - 1. Anchor plates: Not less than 0.075 inch thick, designed for fastening to structural backup through sheathing by two fasteners; provide design with legs that penetrate sheathing and insulation to provide positive anchorage.
  - 2. Wire ties: Manufacturer's standard shape, 0.1875 inch thick.
  - 3. Vertical adjustment: Not less than 3-1/2 inches.
  - 4. Seismic Feature: Provide lip, hook, or clip on end of wire ties to engage or enclose not less than one continuous horizontal joint reinforcement wire of 0.1483 inch diameter.
  - 5. Basis of Design Product: HFA Fleming Anchor System as manufactured by Halfen; [www.halfen.com](http://www.halfen.com), or approved equal.

### **2.04 FLASHINGS**

- A. Metal Flashing Materials: Galvanized Steel, as specified in Section 07 62 00.

### **2.05 ACCESSORIES**

- A. Preformed Control Joints: Neoprene material. Provide with corner and tee accessories, fused joints.
  - 1. Manufacturers:
    - a. Blok-Lok Limited: [www.blok-lok.com/#sle](http://www.blok-lok.com/#sle).
    - b. Hohmann & Barnard, Inc: [www.h-b.com/#sle](http://www.h-b.com/#sle).
    - c. WIRE-BOND: [www.wirebond.com/#sle](http://www.wirebond.com/#sle).
    - d. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Joint Filler: Closed cell polyvinyl chloride; oversized 50 percent to joint width; self expanding; in maximum lengths available.
- C. Weeps:
  - 1. Type: Extruded propylene with honeycomb design.
  - 2. Color(s): As selected by Architect from manufacturer's full range.
  - 3. Manufacturers:
    - a. Advanced Building Products, Inc: [www.advancedbuildingproducts.com/#sle](http://www.advancedbuildingproducts.com/#sle).
    - b. Blok-Lok Limited: [www.blok-lok.com/#sle](http://www.blok-lok.com/#sle).
    - c. Hohmann & Barnard, Inc: [www.h-b.com/#sle](http://www.h-b.com/#sle).
    - d. Mortar Net Solutions: [www.mortarnet.com/#sle](http://www.mortarnet.com/#sle).
    - e. WIRE-BOND: [www.wirebond.com/#sle](http://www.wirebond.com/#sle).
    - f. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- D. Drainage Fabric: Polyester mesh bonded to a water and vapor-permeable fabric.

- E. Cavity Mortar Control: Semi-rigid polyethylene or polyester mesh panels, sized to thickness of wall cavity, and designed to prevent mortar droppings from clogging weeps and cavity vents and allow proper cavity drainage.
  - 1. Mortar Diverter: Panels installed at flashing locations.
    - a. Manufacturers:
      - 1) Advanced Building Products, Inc: [www.advancedbuildingproducts.com/#sle](http://www.advancedbuildingproducts.com/#sle).
      - 2) Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- F. Cleaning Solution: Non-acidic, not harmful to masonry work or adjacent materials.

## **2.06 MORTAR AND GROUT MIXING**

- A. Mortar for Unit Masonry: ASTM C270, Proportion Specification.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that field conditions are acceptable and are ready to receive masonry.
- B. Verify that related items provided under other sections are properly sized and located.
- C. Verify that built-in items are in proper location, and ready for roughing into masonry work.

### **3.02 COURSING**

- A. Establish lines, levels, and coursing indicated. Protect from displacement.
- B. Maintain masonry courses to uniform dimension. Form vertical and horizontal joints of uniform thickness.
- C. Brick Units:
  - 1. Bond: Match existing.
  - 2. Coursing: Three units and three mortar joints to equal 8 inches.
  - 3. Mortar Joints: Concave.

### **3.03 PLACING AND BONDING**

- A. Lay solid masonry units in full bed of mortar, with full head joints, uniformly jointed with other work.
- B. Battering corners of joints or excessive furrowing of mortar joints is not permitted.
- C. Remove excess mortar as work progresses.
- D. Interlock intersections and external corners, except for units laid in stack bond.
- E. Do not shift or tap masonry units after mortar has achieved initial set. Where adjustment must be made, remove mortar and replace.
- F. Perform job site cutting of masonry units with proper tools to provide straight, clean, unchipped edges. Prevent broken masonry unit corners or edges.
- G. Isolate top joint of masonry veneer from horizontal structural framing members or support angles with compressible joint filler.

### **3.04 WEEPS/CAVITY VENTS**

- A. Install weeps in veneer walls at 24 inches on center horizontally on top of through-wall flashing above shelf angles and lintels and at bottom of walls.
- B. Install cavity vents in veneer walls at 32 inches on center horizontally below shelf angles and lintels and at top of walls.

### **3.05 CAVITY MORTAR CONTROL**

- A. Do not permit mortar to drop or accumulate into cavity air space or to plug weep/cavity vents.
- B. For cavity walls, build inner wythe ahead of outer wythe to accommodate accessories.
- C. Install cavity mortar control panels continuously throughout full height of exterior masonry cavities during construction of exterior wythe, complying with manufacturer's installation instructions.
  - 1. Verify that airspace width is no more than 3/8 inch greater than panel thickness.
  - 2. Hold cavity mortar control panel tight to face wythe.
  - 3. Install horizontally between joint reinforcement.
  - 4. Stagger end joints in adjacent rows.
  - 5. Fit to perimeter construction and penetrations without voids.
- D. Install cavity mortar diverter at base of cavity and at other flashing locations as recommended by manufacturer to prevent mortar droppings from blocking weep/cavity vents.

### **3.06 REINFORCEMENT AND ANCHORAGE - MASONRY VENEER**

- A. Install horizontal joint reinforcement 16 inches on center.
- B. Place masonry joint reinforcement in first and second horizontal joints above and below openings. Extend minimum 16 inches each side of opening.
- C. Embed longitudinal wires of joint reinforcement in mortar joint with at least 5/8 inch mortar cover on each side.
- D. Lap joint reinforcement ends minimum 6 inches.
- E. Stud Back-Up: Secure veneer anchors to stud framed back-up and embed into masonry veneer at maximum 16 inches on center vertically and 24 inches on center horizontally. Place additional anchors at perimeter of openings and ends of panels, so maximum spacing of anchors is 8 inches on center.
- F. Seismic Reinforcement: Connect veneer anchors with continuous horizontal wire reinforcement before embedding anchors in mortar.

### **3.07 MASONRY FLASHINGS**

- A. Whether or not specifically indicated, install masonry flashing to divert water to exterior at all locations where downward flow of water will be interrupted.
  - 1. Extend flashings full width at such interruptions and at least 6 inches, minimum, into adjacent masonry or turn up at least 1 inch, minimum, to form watertight pan at non-masonry construction.

2. Remove or cover protrusions or sharp edges that could puncture flashings.
  3. Seal lapped ends and penetrations of flashing before covering with mortar.
- B. Terminate flashing up 8 inches minimum on vertical surface of backing:
1. Install vertical leg of flashing behind water-resistive barrier sheet over backing.
- C. Install flashing in accordance with manufacturer's instructions and BIA Technical Notes No. 7.
- D. Extend metal flashings through exterior face of masonry and terminate in an angled drip with hemmed edge. Install joint sealer below drip edge to prevent moisture migration under flashing.
- E. Lap end joints of flashings at least 6 inches, minimum, and seal watertight with flashing sealant/adhesive.

### **3.08 LINTELS**

- A. Install loose steel lintels over openings.

### **3.09 CONTROL AND EXPANSION JOINTS**

- A. Do not continue horizontal joint reinforcement through control or expansion joints.
- B. Install preformed control joint device in continuous lengths. Seal butt and corner joints in accordance with manufacturer's instructions.
- C. Size control joints as indicated on drawings; if not indicated, 3/4 inch wide and deep.
- D. Form expansion joint as detailed on drawings.

### **3.10 TOLERANCES**

- A. Install masonry within the site tolerances found in TMS 402/602.
- B. Maximum Variation From Unit to Adjacent Unit: 1/16 inch.
- C. Maximum Variation from Plane of Wall: 1/4 inch in 10 ft and 1/2 inch in 20 ft or more.
- D. Maximum Variation from Plumb: 1/4 inch per story non-cumulative; 1/2 inch in two stories or more.
- E. Maximum Variation from Level Coursing: 1/8 inch in 3 ft and 1/4 inch in 10 ft; 1/2 inch in 30 ft.
- F. Maximum Variation of Mortar Joint Thickness: Head joint, minus 1/4 inch, plus 3/8 inch.

### **3.11 CUTTING AND FITTING**

- A. Cut and fit for pipes and conduit. Coordinate with other sections of work to provide correct size, shape, and location.
- B. Obtain approval prior to cutting or fitting masonry work not indicated or where appearance or strength of masonry work may be impaired.

### **3.12 CLEANING**

- A. Remove excess mortar and mortar smears as work progresses.
- B. Replace defective mortar. Match adjacent work.
- C. Clean soiled surfaces with cleaning solution.

- D. Use non-metallic tools in cleaning operations.

### **3.13 PROTECTION**

- A. Without damaging completed work, provide protective boards at exposed external corners that are subject to damage by construction activities.

**END OF SECTION**



**SECTION 05 05 19**  
**POST-INSTALLED CONCRETE ANCHORS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Requirements for materials and equipment for post-installed mechanical and adhesive anchors in concrete.

**1.02 RELATED REQUIREMENTS**

- A. Section 01 33 00 - Submittal Procedures: Submittal procedures.
- B. Section 01 45 33 - Code-Required Special Inspections: Test reporting.
- C. Section 01 63 00 - Product Substitution Procedures: Requirements for material and product quality.
- D. Section 03 30 00 - Cast-in-Place Concrete: Placement of anchors in concrete.
- E. Section 05 50 00 - Metal Fabrications.
- F. Divisions 10 - Specialties, 22 - Plumbing, and 26 - Electrical: Mounting of equipment and components.
- G. Other miscellaneous sections, where indicated.

**1.03 REFERENCE STANDARDS**

- A. ASTM A193/A193M - Standard Specification for Alloy - Steel and Stainless Steel Bolting for High Temperature or High Pressure Service and Other Special Purpose Applications; 2016.
- B. ASTM A615/A615M - Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement; 2016.
- C. ASTM B633 - Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel; 2015.
- D. ASTM E329 - Standard Specification for Agencies Engaged in Construction Inspection, Testing, or Special Inspection; 2014a.
- E. ASTM E488/E488M - Standard Test Methods for Strength of Anchors in Concrete Elements; 2015.
- F. ASTM F594 - Standard Specification for Stainless Steel Nuts; 2009 (Reapproved 2015).

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: If requested, manufacturer's product literature and installation instructions for each type of anchor indicated.
- C. Samples: If requested, representative length and diameters of each type of anchor shown on the drawings.
- D. ICC ES Reports: If requested, ICC Evaluation Service report indicating conformance with ICC-ES Acceptance Criteria.
- E. Field quality-control test and inspection reports.

### **1.05 QUALITY ASSURANCE**

- A. Testing Agency Qualifications: An independent agency qualified according to ASTM E329 and Division 01 for testing indicated.
- B. Installer Training: Prior to beginning the work, manufacturer or manufacturer's representative shall provide on-site training for all contractor's personnel who will be installing anchors.

### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver materials to project site in manufacturer's or distributor's original packaging undamaged, and with printed installation instructions.
- B. Store and handle all materials in accordance with manufacturer's recommendations.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Manufacturers: Provide products as indicated on the approved Structural Drawings.
- B. Substitutions: Substitutions of products from manufacturer's not listed are not permitted..

### **2.02 MATERIALS**

- A. Interior Use: For use in conditioned environments free from potential moisture, provide zinc plated carbon steel anchors.
- B. Exterior Use:
  - 1. In exposed or potentially wet environments, and for attachment of exterior cladding materials, provide stainless steel anchors.
  - 2. Stainless steel nuts and washers shall be of matching alloy group of equal or greater strength than the rod.
  - 3. Avoid installing stainless steel anchors in contact with galvanically dissimilar metals.
- C. Deformed Reinforcing Bars: Deformed steel rebar conforming to ASTM A615/A615M Grade 60. Permissible sizes as described in each adhesive products ICC report.

### **2.03 MECHANICAL ANCHORS**

- A. Expansion, screw or undercut anchors having current ICC approval for use in cracked and uncracked concrete, with a published ICC Evaluation Service report.
  - 1. Type and size as indicated on drawings.
  - 2. If products are not indicated, then provide anchors as directed by the Architect.
- B. Basis of Design Approved Products conforming to this specification are acceptable for anchoring to concrete are as indicated on Drawings:
  - 1. Hilti, Inc. Tulsa, OK; Hilti Kwik Bolt TZ Carbon and Stainless Steel Anchors in Cracked and Uncracked Concrete (ICC Report ESR-1917); [www.us.hilti.com](http://www.us.hilti.com).
  - 2. Substitutions: See Section 01 63 00 - Product Substitution Procedures.



## 2.04 ADHESIVE ANCHORS

- A. Cartridge Injection Adhesive Anchors: Threaded carbon steel rod, inserts, or reinforcing dowels complete with required nuts, washers, adhesive system and manufacturer's installation instructions.
  - 1. Type and size as indicated on drawings.
  - 2. Current ICC approval for use in cracked and uncracked concrete with a published ICC Evaluation Service report required.
- B. Interior Use: Unless otherwise indicated on the Drawings, provide:
  - 1. Carbon steel threaded rods conforming to specification as indicated on structural drawings. Where no specification and grade are indicated, provide: ASTM A193/A193M Type B7 with zinc plating in accordance with ASTM B633, Type III Fe/Zn 5 (SC1).
- C. Exterior Use: As indicated on the Drawings, provide stainless steel anchors.
  - 1. Stainless steel anchors shall be AISI Type 304 and Type 316 stainless steel provided with stainless steel nuts and washers of matching alloy group and minimum proof stress equal to or greater than the specified minimum full-size tensile strength of the externally threaded fastener.
  - 2. All nuts shall conform to ASTM F594, unless otherwise specified.
- D. Basis of Design Approved Products conforming to this specification are acceptable for anchoring to concrete are as indicated on Drawings:
  - 1. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- E. Basis of Design Approved Products conforming to this specification are acceptable for anchoring to grouted masonry are as indicated on Drawings:
  - 1. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## 2.05 CONCRETE AND MASONRY SCREW ANCHORS

- A. Anchors shall be manufactured from carbon steel which is then heat-treated.
  - 1. Anchors shall be zinc-plated in accordance with ASTM B633, Class SC1, Type III.
  - 2. Current ICC approval for use in cracked and uncracked concrete with a published ICC Evaluation Service report required.
  - 3. Provide anchors with a diameter and anchor length marking on the head.
  - 4. If products are not indicated, then provide anchors as directed by the Architect.
- B. Basis of Design Approved Products conforming to this specification are acceptable for anchoring to concrete are as follows:
  - 1. Simpson Strong-Tie Company, Inc.; Simpson Titen HD anchor, (ICC Report ER-2713) heavy duty screw anchor for concrete; [www.simpsonanchors.com](http://www.simpsonanchors.com).
  - 2. Hilti, Inc.; Hilti KWIK HUS-EZ (KH-EZ) and KWIK HUS-EZ I (KH-EZ I) Carbon Steel Screw Anchors For Use In Cracked and Uncracked Concrete (ICC Report ESR-3027); [www.hilti.com](http://www.hilti.com).
  - 3. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## **2.06 POWDER-DRIVEN FASTENERS**

- A. Use only if approved by Architect, generally not permitted where not specifically indicated or in load-bearing installations; Fed Spec FF-P-395 or Fed Spec GGG-D-777; as follows.
  - 1. Hilti, Inc.; Hilti Low Velocity Powder Driven Fasteners (ICC Report ESR-1663); [www.us.hilti.com](http://www.us.hilti.com).
  - 2. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verification of Conditions
  - 1. Base Material Strength: Unless otherwise specified, do not drill holes in concrete until concrete has achieved full design strength.
    - a. Adhesive anchors shall be installed in concrete having a minimum concrete compressive strength equal to or greater than the specified minimum 28-day compressive strength or a minimum age of 21 days at time of anchor installation. Whichever are more restrictive.
  - 2. Temperature of concrete surface and ambient air temperature must meet manufacturer's requirements prior to use of adhesive anchor products.
  - 3. Embedded Items:
    - a. Identify position of reinforcing steel and other embedded items prior to drilling holes for anchors.
    - b. Exercise care in coring or drilling to avoid damaging existing reinforcing or embedded items.
    - c. Take precautions as necessary to avoid damaging anything embedded in the concrete including electrical/telecommunications conduit, gas pipes, and plumbing pipes.
    - d. Notify the Architect if reinforcing steel or other embedded items are encountered during drilling.
  - 4. Beginning of installation indicates acceptance of existing conditions.

### **3.02 INSTALLATION**

- A. Installation shall comply with all manufacturer's instructions and current ICC ESR report.
- B. Post-Installed Anchors in Hardened Concrete.
  - 1. Drilled-in anchors and/or powder driven pins in existing non-prestressed reinforced concrete: use care and caution to avoid cutting or damaging the existing reinforcing bars.
  - 2. Maintain a minimum clearance of one inch between the reinforcement and the drilled-in anchor and/or pin.
- C. Manufacturer shall provide on-site training for all personnel who will be installing post-installed adhesive anchors at the beginning of the work. Installation of anchors must be performed by a certified installer.

- D. Where manufacturer recommends use of special tools for installation of anchors, such tools shall be used, unless otherwise permitted specifically by the Engineer.
- E. Drill holes with rotary impact hammer drills using carbide-tipped bits. Bits must be of type required and permitted by ICC ESR report.
  - 1. Drill holes with rotary impact hammer drills using carbide-tipped bits or core drills using diamond core bits.
  - 2. Drill bits shall be of diameters as specified by the anchor manufacturer.
  - 3. Unless otherwise shown on the Drawings, all holes shall be drilled perpendicular to the concrete surface.
  - 4. Where anchors are to be installed in cored holes, use core bits with matched tolerances as specified by the manufacturer.
  - 5. Cored holes may only be used if acceptable to the Engineer and in compliance with ICC ECR report.
- F. Holes shall be cleared of debris after holes are drilled per manufacturer's instructions.
  - 1. For adhesive installations, at a minimum, holes shall be blown out with oil-free compressed air and shall be brushed with a wire or nylon brush.
  - 2. Holes shall than be blown out one additional time with oil-free compressed air.
  - 3. Additional hole cleaning requirements may be required by manufacturer and ICC ESR Report.
- G. During adhesive curing time period, the temperature of the substrate shall be kept above the minimum substrate temperature as defined by the manufacturer. Contractor shall determine the appropriate means and methods to ensure that the temperature is kept above the required minimum temperature required before adhesive installation is begun.

### 3.03 FIELD QUALITY CONTROL

- A. An independent testing agency will perform field quality control tests.
- B. Inspection: Special inspection of post-installed anchors shall be provided as required by the ICC-ES report for that anchor and not less than the requirements of the Structural Drawings and the following (whichever is the most restrictive):
  - 1. Continuously observe the installation of all anchors, or as specified in the ICC report.
    - a. Minimum anchor embedments, proof loads and torques shall be as shown on the Drawings.
    - b. Load Testing: Per Structural General Notes on Drawings and CBC 1913A.7.
    - c. Post-Installed Anchor Load Testing: CBC Section 1910A.5.3
      - 1) As indicated on Structural Drawings, minimum 10 % of drilled-in sill plate bolting anchor applications shall be proof loaded by the independent testing laboratory.
      - 2) 100 % of each type and size of drilled-in anchor shall be proof loaded by the independent testing laboratory.
      - 3) Adhesive anchors and capsule anchors shall not be torque tested unless otherwise directed by the Architect.
      - 4) Tension testing should be performed in accordance with ASTM E488/E488M.
      - 5) Torque shall be applied with a calibrated torque wrench.

- 6) Proof loads shall be applied with a calibrated hydraulic ram, as required and indicated on the Structural Drawings. Comply with CBC 1913A.7.2.
  - 7) If any of the tested anchors fail to achieve the specified torque or proof load within the limits as defined on the Drawings, all anchors of the same diameter and type as the failed anchor shall be tested, unless otherwise instructed by the Architect.
- d. Verify anchor type, anchor dimensions, hole dimensions, anchor spacing, edge distances, anchor embedment and adherence to the manufacturer's published installation instructions.
  - e. For adhesive anchors also verify hole cleaning technique, adhesive expiration date and proper mixing and dispensing.
2. Subsequent inspection of installation will be required when there is a change of personnel doing the installation. Change is defined as any one or more persons drilling or preparing holes, or installing anchors.
  3. Visually inspect 100% of all installed anchors.
- C. Reporting:
1. Daily reports shall reference the applicable ICC-ES report number, indicate that all specified criteria were complied with and provide itemized verification of all inspected items.
  2. Special Inspector shall immediately report any deviations from the requirements to the Architect.
- D. Defective Work:
1. Installations that are not accepted by the Special Inspector shall be considered defective.
  2. Provide additional testing and inspection to determine acceptability of defective work, as directed by the Architect at Contractor's expense.

### **3.04 REPAIR OF DEFECTIVE WORK**

- A. Remove and replace misplaced, defective or malfunctioning anchors at Contractor's expense. Replacement of anchors requires signed structural detail, unless otherwise noted.
- B. Fill empty anchor holes and patch failed anchor locations with high-strength, non-shrink non-metallic grout.

**END OF SECTION**

**SECTION 05 50 00**  
**METAL FABRICATIONS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Shop fabricated steel items.
- B. Steel framing and supports for applications where framing and supports are not specified in other sections.
- C. Ladder safety systems.

**1.02 RELATED REQUIREMENTS**

- A. Section 03 30 00 - Cast-in-Place Concrete: Placement of metal fabrications in concrete.
- B. Section 09 91 23 - Interior Painting: Paint finish.

**1.03 REFERENCE STANDARDS**

- A. 29 CFR 1910.23 - Ladders; current edition.
- B. 29 CFR 1910.28 - Duty to have Fall Protection and Falling Object Protection; Current Edition.
- C. 29 CFR 1910.29 - Fall Protection Systems and Falling Object Protection - Criteria and Practices; Current Edition.
- D. ALI A14.3 - Ladders - Fixed - Safety Requirements; 2014.
- E. ANSI A14.3 - American National Standard for Ladders -- Fixed -- Safety Requirements; 2008.
- F. ANSI/ASSP Z359.11 - Safety Requirements for Full Body Harnesses; 2014.
- G. ANSI/ASSP Z359.12 - Connecting Components for Personal Fall Arrest Systems; 2009.
- H. ANSI/ASSP Z359.15 - Safety Requirements for Single Anchor Lifelines and Fall Arresters for Personal Fall Arrest Systems; 2014.
- I. ANSI/ASSP Z359.16 - Safety Requirements for Climbing Ladder Fall Arrest Systems; 2016.
- J. ASME B18.2.1 - Square, Hex, Heavy Hex, and Askew Head Bolts and Hex, Hex Flange, Lobed Head, and Lag Screws (Inch Series); 2012, Including July 2013 Errata.
- K. ASTM A36/A36M - Standard Specification for Carbon Structural Steel; 2014.
  - 1. Use 2008 as indicated in 2016 CBC Referenced Standards.
- L. ASTM A53/A53M - Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless; 2018.
- M. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products; 2017.
- N. ASTM A283/A283M - Standard Specification for Low and Intermediate Tensile Strength Carbon Steel Plates; 2018.
  - 1. Use 2012a as indicated in 2016 CBC Referenced Standards.
- O. ASTM A307 - Standard Specification for Carbon Steel Bolts, Studs, and Threaded Rod 60 000 PSI Tensile Strength; 2014, with Editorial Revision (2017).

- P. ASTM A500/A500M - Standard Specification for Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes; 2018.
- Q. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2018.
  - 1. Use 2011 as indicated in 2016 CBC Referenced Standards.
- R. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength; 2018a.
- S. ASTM A780/A780M - Standard Practice for Repair of Damaged and Uncoated Areas of Hot-Dip Galvanized Coatings; 2009 (Reapproved 2015).
- T. ASTM A992/A992M - Standard Specification for Structural Steel Shapes; 2011 (Reapproved 2015).
- U. ASTM F3125/F3125M - Standard Specification for High Strength Structural Bolts and Assemblies, Steel and Alloy Steel, Heat Treated, Inch Dimensions 120 ksi and 150 ksi Minimum Tensile Strength, and Metric Dimensions 830 MPa and 1040 MPa Minimum Tensile Strength; 2018.
- V. ASTM D1187/D1187M - Standard Specification for Asphalt-Base Emulsions for Use as Protective Coatings for Metal; 1997 (Reapproved 2018).
- W. AWS A2.4 - Standard Symbols for Welding, Brazing, and Nondestructive Examination; 2012.
- X. AWS D1.1/D1.1M - Structural Welding Code - Steel; 2015, with Errata (2016).
  - 1. Use 2010 w/Errata as indicated in 2016 CBC Referenced Standards.
- Y. IAS AC172 - Accreditation Criteria for Fabricator Inspection Programs for Structural Steel; 2017.
- Z. SSPC-PA 1 - Shop, Field, and Maintenance Painting of Steel; 2016.
- AA. SSPC-Paint 15 - Steel Joist Shop Primer/Metal Building Primer; 1999 (Ed. 2004).
- AB. SSPC-Paint 20 - Zinc-Rich Primers (Type I, "Inorganic," and Type II, "Organic"); 2002 (Ed. 2004).
- AC. SSPC-SP 10 - Near-White Blast Cleaning; 2007.
- AD. SSPC-SP 2 - Hand Tool Cleaning; 2018.
- AE. SSPC-SP 3 - Power Tool Cleaning; 1982, with Editorial Revision (2004).
- AF. SSPC-SP 5 - White Metal Blast Cleaning; 2007.
- AG. SSPC-SP 6 - Commercial Blast Cleaning; 2007.

#### **1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide manufacturer's data sheets on each ladder safety system product to be used, including installation instructions.
- C. Shop Drawings: Indicate profiles, sizes, connection attachments, reinforcing, anchorage, size and type of fasteners, and accessories. Include erection drawings, elevations, and details where applicable.
  - 1. Indicate welded connections using standard AWS A2.4 welding symbols. Indicate net weld lengths.

- D. Certificate: Provide documentation that ladder safety system products of this section meet or exceed cited 1, 1, 1, and 1 requirements.
- E. Welders' Certificates: Submit certification for welders employed on the project, verifying AWS qualification within the previous 12 months.
- F. Fabricator's Qualification Statement: Provide documentation showing steel fabricator is accredited.

#### **1.05 QUALITY ASSURANCE**

- A. Regulatory Requirements: Conform to applicable requirements of California Building Code (CBC), Title 24, Part 2, as amended and adopted by authorities having jurisdiction.
  - 1. Comply with Title 24, Part 9, California Fire Code Chapter 35 "Welding and Other Hot Work."
- B. Coordination: Provide templates and sleeves for incorporation of embedded items into the Work specified in other Sections.
- C. Field-Verified Dimensions: Prior to fabrication, field verify dimensions and details of construction. Immediately report variances in writing to Construction Manager and Architect.
- D. Design indicated items under direct supervision of a Professional Structural Engineer experienced in design of this Work and licensed in California.
- E. Fabricator's Qualifications: Fabricator of light structural steel framing members and other miscellaneous metal fabrications of structural character shall be approved by the authorities having jurisdiction in accordance with applicable Code provisions.
- F. Fabricator Qualifications: A qualified steel fabricator that is accredited by the International Accreditation Service (IAS) Fabricator Inspection Program for Structural Steel or equal.
- G. Welder's Qualifications:
  - 1. Welding shall be performed by certified welders qualified in accordance with procedures specified in applicable referenced AWS standard, using materials, procedures and equipment of the type required for the Work.
  - 2. Certify that each welder has satisfactorily passed AWS qualification tests for welding processes involved and, if pertinent, has undergone re-certification.

#### **1.06 PACKAGING, DELIVERY, STORAGE AND HANDLING**

- A. Storage, General: Store products in enclosed, well-ventilated spaces, not in contact with soil or vegetation and not subject to inclement weather.
- B. Delivery, Storage and Handling, Galvanized Products:
  - 1. Stack and bundle during transport and store to allow air flow between galvanized surfaces.
  - 2. Load for transport to permit continuous drainage should wetting occur.
  - 3. Do not rest galvanized products on cinders or clinkers.

#### **1.07 PROJECT CONDITIONS**

- A. Field Inspection of Fabricated Products: Prior to installation, inspect products for damage and verify markings and dimensions against reviewed submittals.

- B. Environmental Conditions: Do not install products intended for interior locations when spaces are uncovered and unprotected from inclement weather.
- C. Coordination: Coordinate metal fabrications Work with Work specified in other Sections so that related Work shall be accurately and properly joined.

## **PART 2 PRODUCTS**

### **2.01 MATERIALS - STEEL**

- A. Steel Sections: Steel plates, bars, angles, channels, and H-sections; ASTM A 36/A 36M.
  - 1. Galvanized Steel: Structural shapes, plates and bars: From fully killed or semi-killed steel, ASTM A992/A992M, except silicon content in the range 0 to 0.4 percent or 0.15 to 0.25 percent, as applicable, only.
- B. Steel Tubing: ASTM A500/A500M, Grade B cold-formed structural tubing.
- C. Plates: ASTM A283/A283M.
- D. Pipe: ASTM A 53/A 53M, Grade B Schedule 40, black finish.
- E. Slotted Channel Framing: ASTM A653/A653M, Grade 33.
- F. Slotted Channel Fittings: ASTM A1011/A1011M.
- G. Fasteners: See Article Anchors, Fasteners and Accessory Materials below.
- H. Bolts, Nuts, and Washers: ASTM A307, Grade A, plain.
- I. Bolts, Nuts, and Washers: ASTM F3125/F3125M, Type 1, plain.
- J. Welding Materials: AWS D1.1/D1.1M; type required for materials being welded.
- K. Shop and Touch-Up Primer: SSPC-Paint 15, complying with VOC limitations of authorities having jurisdiction.
- L. Touch-Up Primer for Galvanized Surfaces: SSPC-Paint 20, Type I - Inorganic, complying with VOC limitations of authorities having jurisdiction.

### **2.02 ACCESSORIES**

- A. Anchors and Fasteners, General: Same material, color and finish as the metal to which applied, unless otherwise indicated.
- B. Exterior Exposure: Provide stainless steel.
- C. Type, Size and Spacing: Unless otherwise indicated, provide fasteners of type, grade and class required for intended use and sized and spaced as required for loads and substrate.
- D. Screw Head, Typical: Unless otherwise noted, exposed screws shall be phillips oval or flat head, countersunk.
- E. Standard Bolts and Nuts, Steel: ASTM A307, Grade A, hexagonal head.
- F. Lag Screws and Bolts, Steel: 1, type and grade best suited for the purpose, hexagonal or square head.
- G. Plain Steel Screws: FS FF-S-85, FS FF-S-92 and FS FF-S-111; type and grade best suited for the purpose.
- H. Self-Drilling Metal Screw Fasteners: TEKS by Buildex Division, Illinois Tool works, Inc.; ICC Report ESR-1976; [www.itwbuildex.com](http://www.itwbuildex.com).



- I. Plain Steel Washers: FS FF-W-92, round, carbon steel.
- J. Lock Washers: FS FF-W-84, helical spring, carbon steel.
- K. Fiber Plugs, Lead Expansion Shields and Screws: Not permitted.
- L. Anchors and/or Dowels Installed with Adhesives: See notes on Structural Drawings.
- M. Welding Rods and Bare Electrodes: Select according to AWS specifications for the metal alloy to be welded.
- N. Shop Primer Paint:
  - 1. Shop primer, general: Coordinate primer with finish paint and coating, as applicable, to provide sound foundation for field-applied topcoats despite prolonged exposure during construction.
  - 2. Shop primer for ferrous metal at exposed exterior locations: Fabricator's standard zinc-rich two-part catalyzed epoxy coating.
  - 3. Shop primer for ferrous metal at concealed exterior locations and for interior locations: Manufacturer's or fabricator's standard, fast-curing, lead-free, universal modified alkyd primer, complying with performance requirements of FS TT-P-645.
  - 4. Shop primer for galvanized steel, for exposed exterior locations: Fabricator's standard two-part catalyzed epoxy coating, compatible with specified finish paints.
- O. Field Primer and Finish Paints: As specified in Section 09 91 23 - Interior Painting.
- P. Bituminous Coating: High-build mineral-filled coal tar pitch coating, or a cold-applied asphalt mastic complying with ASTM D1187/D1187M, except containing no asbestos fibers.
  - 1. Basis of Design Product: H.B. Tnemecol Series 46-465 as manufactured by Tnemec, Inc., [www.tnemec.com](http://www.tnemec.com), or approved equal.
  - 2. Acceptable Manufacturers:
    - a. BASF (24 g/L).
    - b. Chemmasters.
    - c. Euclid Chemical.
    - d. Henry.
    - e. Polyguard.
    - f. W.R. Meadows, Inc.; Sealmatic Type II (Brush-on/Spray Grade): [www.wrmeadows.com](http://www.wrmeadows.com)
    - g. Substitutions: See Section 01 60 00 - Product Requirements.
- Q. Bond Breaker Tape: Isolate dissimilar metals with Pecora 531 Bond Breaker Tape or equal.

## 2.03 FABRICATION

- A. Ferrous Metal Surfaces, General:
  - 1. For metal fabrications exposed to view upon completion of the Work: Provide ferrous metals materials selected for their surface flatness, smoothness, and freedom from surface blemishes.
  - 2. Do not use materials whose exposed surfaces exhibit pitting, seam marks, roller marks, rolled trade names, roughness, and, for steel sheet, variations in flatness exceeding those permitted by reference standards for stretcher-leveled sheet.

- B. Preparation Before Fabrication: Remove loose mill scale and rust and remove twists and bends in manners not injurious to materials and finishes.
- C. Fabrication: Fabricate and finish metal items in accordance with the Drawings and reviewed shop drawings.
  - 1. Contractor shall verify measurements before fabrication.
  - 2. Galvanize all exterior steel members to comply with ASTM A123/A123M. Provide minimum 1.7 oz/sq ft galvanized coating.
  - 3. Hot-dip galvanize fabricated ferrous items, indicated as remaining unpainted, after fabrication. Field connections shall be bolted or screwed where possible. Avoid field cutting and welding which damage galvanized coating.
  - 4. Fit and shop assemble items in largest practical sections, for delivery to site.
  - 5. Prepare and reinforce fabrications as required to receive applied items and transport to site.
- D. Cutting and Fitting: Fabricate with accurate angles and surfaces, true to the required lines and levels and as required to suit installation conditions.
  - 1. Fabricate items with joints tightly fitted and secured.
  - 2. Continuously seal joined members by intermittent welds and plastic filler.
  - 3. Grind exposed joints flush and smooth with adjacent finish surface. Make exposed joints butt tight, flush, and hairline. Ease exposed edges to small uniform radius.
  - 4. Punch, drill and reaming in manner to leave clean, true lines and surfaces.
    - a. Oversize hole 1/16 inch by punching, when material thickness is equal to or less than bolt diameter plus 1/8 inch.
    - b. Sub-punch 1/16 inch smaller than bolt and drill or ream to oversize by 1/16 inch, when material thickness is thicker than bolt diameter plus 1/8 inch.
  - 5. Gas cutting of non-structural steel items may be acceptable where stress is not transmitted through flame-cut surfaces.
    - a. Make cuts clean and to contour.
    - b. Deduct 1/8 inch from effective width of members cut by torch.
- E. Connections, General:
  - 1. Component parts of built-up members shall be well-pinned with closely-fitted contact.
  - 2. Conceal connections where possible.
  - 3. Otherwise, make countersinks for concealment after fabrication, except where noted.
- F. Bolted and Screwed Connections:
  - 1. Provide holes and connections for work specified in other Sections.
  - 2. Use bolts for field connections only.
  - 3. Provide washers under heads and nuts bearing on wood.
  - 4. Draw all nuts tight and nick threads of permanent connections.
  - 5. Use beveled washers where bearing is on sloped surfaces.

- 6. Where screws must be used for permanent connections in ferrous metal, use flat head type, countersunk, with screw slots filled and finished smooth and flush.
- G. Exposed Mechanical Fastenings: Flush countersunk screws or bolts; unobtrusively located; consistent with design of component, except where specifically noted otherwise.
- H. Supply components required for anchorage of fabrications. Fabricate anchors and related components of same material and finish as fabrication, except where specifically noted otherwise.
- I. Welding: Conform to AWS D1.1/D1.1M recommendations.
  - 1. Do not field weld galvanized components to remain unfinished.
  - 2. Provide continuous welds at welded corners and seams.
  - 3. Grind exposed welds smooth and flush with base material.
  - 4. Re-weld to fill holes. Putties and fillers are not acceptable.
- J. Joints on Finished Surfaces: Provide welds ground smooth and filled.
- K. Joints Exposed to Weather or Water: Fabricate to keep water out, or provide adequate drainage of water that penetrates.
- L. Steel Tubing and Piping Fabrication: Unless otherwise indicated, close ends with plate stock so no exposed ends of tubing and piping. Grind all edges.
- M. Mechanical Finishes: Complete finishing prior to fabrication wherever possible.
  - 1. After fabrication, finish all joints, bends, abrasions, and other surface blemishes to match finish.
  - 2. Protect finish on exposed surfaces by using temporary protective covering.
- N. Coordination: Make provisions to connect metal fabrications with or to receive work specified in other Sections.

## **2.04 FABRICATED ITEMS**

- A. Rough Hardware
  - 1. Provide bent or otherwise custom fabricated bolts, plates, anchors, hangers, dowels, and other miscellaneous steel and iron shapes as indicated on Drawings.
  - 2. Fabricate items to sizes, shapes, and dimensions required. Provide malleable-iron washers for heads and nuts which bear on wood structural connections; elsewhere, furnish steel washers.
- B. Ladders: Steel; in compliance with ANSI A14.3; with mounting brackets and attachments; prime paint finish.
  - 1. Provide roof access ladder, as indicated on Drawings, fabricated of steel bar sides and brackets, mounted to building wall, configured and dimensioned in conformance to OSHA Regulation 1910.27, with round bar stock rungs.
    - a. Hot-dip galvanize ladder all ladder components after fabrication.
    - b. Unless otherwise shown or required by governing authorities, fabricate ladder in accordance with NAAMM standards and recommended details.
  - 2. Side Rails: 3/8 x 3 inches members with eased edges, spaced at 24 inches.

3. Rungs: one inch diameter solid round bar spaced 12 inches on center. Let rungs into side rails.
  - a. Provide 13 ga. three row non-slip surfaces on top of each rung mechanically pressure punched/stamped.
    - 1) Basis of Design Product: Buttonhole type as manufactured by McNichols Company, or approved equal.
4. Anchor brackets:
  - a. As indicated on Drawings.
  - b. Angle: 3-1/4 by 7-1/4 inch by 2-1/2 inches wide;
  - c. Minimum two per stringer, maximum spacing 60 inches on center and within 24 inches of unsupported or unanchored ends.
5. Where indicated on Drawings, provide lockable standard door.
  - a. Top of door shall be cover the first rung to minimum 7 feet above finish floor unless indicated otherwise on Drawings.
  - b. Padlock, OFOI by District.
- C. Slotted Channel Framing: Fabricate channels and fittings from structural steel complying with the referenced standards; factory-applied, rust-inhibiting thermoset acrylic enamel finish.
- D. Other Products and Fabrications
  1. Other Products and Fabrications: Provide all materials not specifically described but required for a complete and proper installation, as selected by the Contractor, subject to review and acceptance by Construction Manager and Architect.

## 2.05 LADDER SAFETY SYSTEMS

- A. Climbing Ladder Fall Arrest System (CLAFS): Comply with 29 CFR 1910.29, 29 CFR 1926.1053, Section 7 of ALI A14.3 and ANSI/ASSP Z359.16; climbing ladder fall arrest system allows worker to climb up and down using both hands; does not require employee continuously, hold, push, or pull any part of system while climbing.
  1. Install on new fixed ladders over 24 feet in height.
  2. Anchorage: Fixed ladder meeting requirements of 29 CFR 1910.23.
  3. Flexible Carrier: Fixed 3/8 inch diameter stainless steel wire rope lifeline with shock absorber and top, bottom and intermediate supports; meeting requirements of ANSI/ASSP Z359.16.
  4. Rigid Carrier: Fixed 304 stainless steel U-shaped slotted track with top, bottom and intermediate supports; meeting requirements of ANSI/ASSP Z359.16.
  5. Fall Arrester: Stainless steel and aluminum automatic pass-through carrier sleeve fall arrester meeting requirements of ANSI/ASSP Z359.15 and ANSI/ASSP Z359.16; compatible with carrier.
- B. Personal Fall Arrest System Components; 29 CFR 1910.140:
  1. Body Support: Full body harness meeting requirements of ANSI/ASSP Z359.11; equipped with front or hip D-rings for attachment to climbing ladder fall arrest system.

2. Connecting Means: Connecting hardware, such as a locking carabiner, meeting requirements of ANSI/ASSP Z359.12; compatible with fall arrester and body support harness.

## 2.06 FINISHES - STEEL

- A. Prime paint all steel items. Conform to SSPC Painting Manual. Shop primer paint after fabrication all metal fabrications.
  1. Exceptions: Galvanize items to be embedded in concrete.
  2. Exceptions: Do not prime surfaces in direct contact with concrete, where field welding is required, and items to be covered with sprayed fireproofing.
  3. Exceptions:
    - a. Do not prime stainless steel, plated steel, and anodized aluminum fabrications, unless specifically noted.
    - b. Do not shop prime galvanized fabrications, unless specifically noted.
    - c. Do not shop prime fabrications for which an entirely field-applied coating system is indicated.
- B. Prepare surfaces to be primed in accordance with minimum SSPC-SP2.
  1. Exterior fabrications: Clean in accordance with SSPC-SP 5, SSPC-SP 6, 8, or SSPC-SP 10.
  2. Interior fabrications: Clean in accordance with SSPC-SP 2, SSPC-SP 3, SSPC-SP 5, SSPC-SP 6, 8, or SSPC-SP 10.
- C. Clean surfaces of rust, scale, grease, and foreign matter prior to finishing.
- D. Prime Painting: One coat where finish painting is to be applied.
  1. Shop Priming: Comply with SSPC-PA 1. Coordinate with requirements specified in Section 09 91 23 - Interior Painting .
    - a. Coordinate primer with finish paint and coating, as applicable, to provide sound foundation for field-applied topcoats despite prolonged exposure during construction.
      - 1) Shop primer for ferrous metal at exposed exterior locations: Tnemec 90E-92, ethyl silicate zinc primer, or equal.
      - 2) Tnemec Series V10, or approved equal, modified alkyd rust-inhibitive primer, or manufacturer's or fabricator's standard, fast-curing, lead-free, universal modified alkyd primer, complying with performance requirements of FS TT-P-645.
    - b. Apply primer immediately following surface preparation.
    - c. Do not prime surfaces to be welded.
    - d. Do not prime surfaces in direct contact bond with concrete or mortar.
    - e. Spray apply shop prime without holidays, drips, runs.
    - f. Provide two coats where product is not to be finish painted or is to be concealed in completed work.
    - g. Apply an additional coat to corners, welds, edges, and fasteners.
    - h. Allow primer to dry and cure before handling.
- E. Shop Painting

1. Shop Painting: Comply with SSPC-PA 1. Shop paint fabrications where feasible.
    - a. Apply thermosetting enamel paint, gloss or semi-gloss, of a type and color as selected and approved by Architect, if not otherwise specified.
    - b. Shop applied finish paint shall be baked to set and cure.
    - c. Allow finish paint to thoroughly dry and cure before handling.
  2. Steel Embedded in Concrete: Coat concealed faces with bituminous coating.
  3. Galvanized Pre-Treatment: Where zinc-coated surfaces are specified to be shop primed, chemically treat surfaces to provide bond for paint before applying primer.
- F. Galvanizing of All Exterior Structural Steel Members: Galvanize after fabrication to ASTM A123/A123M requirements. Provide minimum 1.7 oz/sq ft galvanized coating.
- G. Galvanizing of Non-structural Items: Galvanize after fabrication to ASTM A123/A123M requirements.

## **2.07 FABRICATION TOLERANCES**

- A. Squareness: 1/8 inch maximum difference in diagonal measurements.
- B. Maximum Offset Between Faces: 1/16 inch.
- C. Maximum Misalignment of Adjacent Members: 1/16 inch.
- D. Maximum Bow: 1/8 inch in 48 inches.
- E. Maximum Deviation From Plane: 1/16 inch in 48 inches.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that field conditions are acceptable and are ready to receive work.
- B. Confirm that the ladder structure to which the ladder safety system is installed is capable of withstanding the loads applied by the system in the event of a fall.

### **3.02 PREPARATION**

- A. Obtain Architect's review prior to site cutting or making adjustments not indicated on Drawings and reviewed shop drawings.
- B. Clean and strip primed steel items to bare metal where site welding is required.
- C. Supply setting templates to the appropriate entities for steel items required to be cast into concrete.
- D. Make provision for erection loads with temporary bracing. Keep work in alignment.
- E. Clean and prime field welds. Touch up galvanized steel with cold galvanizing compound.

### **3.03 INSTALLATION**

- A. Install items plumb and level, accurately fitted, free from distortion or defects.
- B. Install ladder safety system in accordance with manufacturer's instructions.
- C. Provide for erection loads, and for sufficient temporary bracing to maintain true alignment until completion of erection and installation of permanent attachments.

- D. Field weld components as indicated on drawings.
- E. Perform field welding in accordance with AWS D1.1/D1.1M.
- F. Obtain approval prior to site cutting or making adjustments not scheduled.
- G. After erection, prime welds, abrasions, and surfaces not shop primed or galvanized, except surfaces to be in contact with concrete.

### **3.04 TOLERANCES**

- A. Maximum Variation From Plumb: 1/4 inch per story, non-cumulative.
- B. Maximum Offset From True Alignment: 1/4 inch.
- C. Maximum Out-of-Position: 1/4 inch.

### **3.05 CLEANING AND TOUCH-UP**

- A. Cleaning: Perform initial cleaning immediately after completion of installation. Prepare surfaces for finish painting.
- B. Galvanizing Touch-Up: Touch up galvanizing immediately after installation, including field welding.
  - 1. Prepare surface and apply cold galvanizing compound in compliance with ASTM A780/A780M and the manufacturer's instructions and recommendations.
- C. Primer Paint Touch-Up: Touch up shop paint immediately after erection. Use products compliant with Section(s) 09 91 23 - Interior Painting.
  - 1. Clean exposed areas of rust, field welds, bolted joints, and areas where primer is damaged by SSPC-SP 2 hand tool cleaning or SSPC-SP 3 power-tool cleaning.
  - 2. Paint with SSPC-Paint 15 (interior) or SSPC-Paint 20 (exterior) compliant material used for shop painting, minimum 3 mils dry film thickness.

**END OF SECTION**





**SECTION 06 10 00**  
**ROUGH CARPENTRY**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Structural dimension lumber framing.
- B. Non-structural dimension lumber framing.
- C. Rough opening framing for doors, windows, and roof openings.
- D. Roof-mounted curbs.
- E. Roofing nailers.
- F. Preservative treated wood materials.
- G. Miscellaneous framing and sheathing.
- H. Communications and electrical room mounting boards.
- I. Concealed wood blocking, nailers, and supports.
- J. Miscellaneous wood nailers, furring, and grounds.

**1.02 RELATED REQUIREMENTS**

- A. Section 05 50 00 - Metal Fabrications: Miscellaneous steel connectors and support angles for wood framing.
- B. Section 07 62 00 - Sheet Metal Flashing and Trim: Sill flashings.
- C. Section 09 21 16 - Gypsum Board Assemblies: Gypsum-based sheathing.

**1.03 REFERENCE STANDARDS**

- A. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2009.
- B. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2015.
  - 1. Use 2011 as indicated in 2016 CBC Referenced Standards.
- C. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2016.
  - 1. Use 2013a as indicated in 2016 CBC Referenced Standards.
- D. AWPA U1 - Use Category System: User Specification for Treated Wood; 2012.
- E. PS 1 - Structural Plywood; 2009.
- F. PS 20 - American Softwood Lumber Standard; 2010.
  - 1. Use 2005 as indicated in 2016 CBC Referenced Standards.
- G. WCLIB (GR) - Standard Grading Rules for West Coast Lumber No. 17; 2004, and supplements.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.

- B. Product Data: Provide technical data on insulated sheathing, wood preservative materials, and application instructions.
- C. Structural Composite Lumber: Submit manufacturer's published structural data including span tables, marked to indicate which sizes and grades are being used; if structural composite lumber is being substituted for dimension lumber or timbers, submit grading agency structural tables marked for comparison.
- D. Evaluation Service Reports: Show compliance with specified requirements.
- E. Manufacturer's Certificate: Certify that wood products supplied for rough carpentry meet or exceed specified requirements.

### **1.05 DELIVERY, STORAGE, AND HANDLING**

- A. General: Cover wood products to protect against moisture. Support stacked products to prevent deformation and to allow air circulation.

### **1.06 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. Correct defective Work within a five year period after Date of Substantial Completion.

## **PART 2 PRODUCTS**

### **2.01 GENERAL REQUIREMENTS**

- A. Dimension Lumber: Comply with PS 20 and requirements of specified grading agencies.
  - 1. Species: Douglas Fir-Larch, unless otherwise indicated.
  - 2. If no species is specified, provide any species graded by the agency specified; if no grading agency is specified, provide lumber graded by any grading agency meeting the specified requirements.
  - 3. Grading Agency: Any grading agency whose rules are approved by the Board of Review, American Lumber Standard Committee ([www.alsc.org](http://www.alsc.org)) and who provides grading service for the species and grade specified; provide lumber stamped with grade mark unless otherwise indicated.
  - 4. Lumber of other species or grades is acceptable provided structural and appearance characteristics are equivalent to or better than products specified.
- B. Lumber fabricated from old growth timber is not permitted.

### **2.02 DIMENSION LUMBER FOR CONCEALED APPLICATIONS**

- A. Grading Agency: West Coast Lumber Inspection Bureau; WCLIB (GR).
- B. Sizes: Nominal sizes as indicated on drawings, S4S.
- C. Moisture Content: S-dry or MC19. Maximum 19%.
- D. Stud Framing (2 by 2 through 2 by 6 ):
  - 1. Species: Douglas Fir-Larch.
  - 2. Grade: No. 1 & Better.
- E. Miscellaneous Framing, Blocking, Nailers, Grounds, and Furring:

1. Lumber: S4S, No. 1 or Construction Grade.
2. Boards: No. 2 or Standard Grade.

### **2.03 STRUCTURAL COMPOSITE LUMBER**

- A. Structural Composite Lumber: Factory fabricated beams, headers, and columns, of sizes and types indicated on drawings; structural capacity as published by manufacturer.
  1. Columns: Use laminated veneer lumber, laminated strand lumber, or parallel strand lumber with manufacturer's published E (modulus of elasticity): 2,000,000 psi, minimum.
  2. Beams: Use laminated veneer lumber, laminated strand lumber, or parallel strand lumber with manufacturer's published E (modulus of elasticity): 2,000,000 psi, minimum.
  3. Headers Not Longer Than 48 inches: Use laminated veneer lumber, laminated strand lumber, or parallel strand lumber.
  4. Manufacturers:
    - a. Boise Cascade Company: [www.bc.com/#sle](http://www.bc.com/#sle).
    - b. Georgia-Pacific Corp.: [www.buildgp.com](http://www.buildgp.com).
    - c. RedBuilt; RedLam LVL: [www.redbuilt.com](http://www.redbuilt.com)
    - d. Weyerhaeuser Company: [www.weyerhaeuser.com/#sle](http://www.weyerhaeuser.com/#sle).
    - e. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

### **2.04 CONSTRUCTION PANELS**

- A. Communications and Electrical Room Mounting Boards: PS 1 A-D plywood, or medium density fiberboard; 3/4 inch thick; flame spread index of 25 or less, smoke developed index of 450 or less, when tested in accordance with ASTM E84.

### **2.05 ACCESSORIES**

- A. Fasteners and Anchors:
  1. Metal and Finish: Hot-dipped galvanized steel complying with ASTM A153/A153M for high humidity and preservative-treated wood locations, unfinished steel elsewhere.
  2. Drywall Screws: Bugle head, hardened steel, power driven type, length three times thickness of sheathing.
  3. Anchors: Expansion shield and lag bolt type for anchorage to solid masonry or concrete.
- B. Die-Stamped Connectors: Hot dipped galvanized steel, sized to suit framing conditions. Provide connectors manufactured by Simpson Strong-Tie.
  1. For contact with preservative treated wood in exposed locations, provide minimum G185 galvanizing complying with ASTM A653/A653M.

### **2.06 FACTORY WOOD TREATMENT**

- A. Treated Lumber and Plywood: Comply with requirements of AWPA U1 - Use Category System for wood treatments determined by use categories, expected service conditions, and specific applications.

1. Preservative-Treated Wood: Provide lumber and plywood marked or stamped by an ALSC-accredited testing agency, certifying level and type of treatment in accordance with AWWPA standards.
- B. Preservative Treatment:
  1. Manufacturers:
    - a. Arch Wood Protection, Inc: [www.wolmanizedwood.com](http://www.wolmanizedwood.com).
    - b. Koppers Performance Chemicals, Inc: [www.koppersperformancechemicals.com](http://www.koppersperformancechemicals.com).
    - c. Viance, LLC: [www.treatedwood.com/#sle](http://www.treatedwood.com/#sle).
    - d. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
  2. Preservative Pressure Treatment of Lumber Above Grade: AWWPA U1, Use Category UC3B, Commodity Specification A using waterborne preservative.
    - a. Kiln dry lumber after treatment to maximum moisture content of 19 percent.
    - b. Treat lumber in contact with roofing, flashing, or waterproofing.
    - c. Treat lumber in contact with concrete.
    - d. Treat lumber in other locations as indicated.
  3. Preservative Pressure Treatment of Plywood Above Grade: AWWPA U1, Use Category UC2 and UC3B, Commodity Specification F using waterborne preservative.
    - a. Kiln dry plywood after treatment to maximum moisture content of 19 percent.
    - b. Treat plywood in contact with roofing, flashing, or waterproofing.
    - c. Treat plywood in other locations as indicated.

## **PART 3 EXECUTION**

### **3.01 INSTALLATION - GENERAL**

- A. Select material sizes to minimize waste.
- B. Reuse scrap to the greatest extent possible; clearly separate scrap for use on site as accessory components, including: shims, bracing, and blocking.
- C. Where treated wood is used on interior, provide temporary ventilation during and immediately after installation sufficient to remove indoor air contaminants.

### **3.02 FRAMING INSTALLATION**

- A. Set structural members level, plumb, and true to line. Discard pieces with defects that would lower required strength.
- B. Make provisions for temporary construction loads, and provide temporary bracing sufficient to maintain structure in true alignment and safe condition until completion of erection and installation of permanent bracing.
- C. Install structural members full length without splices unless otherwise specifically detailed.
- D. Comply with member sizes, spacing, and configurations indicated, and fastener size and spacing indicated, but not less than required by applicable codes.
- E. Install horizontal spanning members with crown edge up and not less than 1-1/2 inches of bearing at each end.

- F. Construct double joist headers at floor and ceiling openings and under wall stud partitions that are parallel to floor joists; use metal joist hangers unless otherwise detailed.
- G. Provide bridging at joists in excess of 8 feet span as detailed. Fit solid blocking at ends of members.
- H. Frame wall openings with two or more studs at each jamb; support headers on cripple studs.

### **3.03 BLOCKING, NAILERS, AND SUPPORTS**

- A. Provide framing and blocking members as indicated or as required to support finishes, fixtures, specialty items, and trim.
- B. In framed assemblies that have concealed spaces, provide solid wood fireblocking as required by applicable local code, to close concealed draft openings between floors and between top story and roof/attic space; other material acceptable to code authorities may be used in lieu of solid wood blocking.
  - 1. Comply with CBC Section 718.2 Fireblocking.
- C. In walls, provide blocking attached to studs as backing and support for wall-mounted items, unless item can be securely fastened to two or more studs or other method of support is explicitly indicated.
- D. Where ceiling-mounting is indicated, provide blocking and supplementary supports above ceiling, unless other method of support is explicitly indicated.
- E. Provide the following specific non-structural framing and blocking:
  - 1. Cabinets and shelf supports.
  - 2. Wall brackets.
  - 3. Handrails.
  - 4. Grab bars.
  - 5. Towel and bath accessories.
  - 6. Wall-mounted door stops.
  - 7. Chalkboards and marker boards.
  - 8. Wall paneling and trim.
  - 9. Joints of rigid wall coverings that occur between studs.

### **3.04 ROOF-RELATED CARPENTRY**

- A. Coordinate installation of roofing carpentry with deck construction, framing of roof openings, and roofing assembly installation.
- B. Provide wood curb at all roof openings except where specifically indicated otherwise. Form corners by alternating lapping side members.

### **3.05 INSTALLATION OF CONSTRUCTION PANELS**

- A. Communications and Electrical Room Mounting Boards: Secure with screws to studs with edges over firm bearing; space fasteners at maximum 24 inches on center on all edges and into studs in field of board.

1. At fire-rated walls, install board over wall board indicated as part of the fire-rated assembly.
2. Where boards are indicated as full floor-to-ceiling height, install with long edge of board parallel to studs.
3. Install adjacent boards without gaps.
4. Size and Location: As indicated on drawings.

### **3.06 SITE APPLIED WOOD TREATMENT**

- A. Apply preservative treatment compatible with factory applied treatment at site-sawn cuts, complying with manufacturer's instructions.
- B. Allow preservative to dry prior to erecting members.

### **3.07 TOLERANCES**

- A. Framing Members: 1/4 inch from true position, maximum.
- B. Variation from Plane (Other than Floors): 1/4 inch in 10 feet maximum, and 1/4 inch in 30 feet maximum.

### **3.08 FIELD QUALITY CONTROL**

- A. See Section 01 45 00 - Quality Control, for additional requirements.

### **3.09 CLEANING**

- A. Waste Disposal: Comply with the requirements of Section 01 74 19 - Construction Waste Management and Disposal.
  1. Comply with applicable regulations.
  2. Do not burn scrap on project site.
  3. Do not burn scraps that have been pressure treated.
  4. Do not send materials treated with pentachlorophenol, CCA, or ACA to co-generation facilities or "waste-to-energy" facilities.
- B. Do not leave any wood, shavings, sawdust, etc. on the ground or buried in fill.
- C. Prevent sawdust and wood shavings from entering the storm drainage system.

**END OF SECTION**

**SECTION 06 20 00**  
**FINISH CARPENTRY**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Finish carpentry items.
- B. Hardware and attachment accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 06 10 00 - Rough Carpentry: Support framing, grounds, and concealed blocking.
- C. Section 06 41 00 - Architectural Wood Casework: Shop fabricated custom cabinet work.
- D. Section 08 14 16 - Flush Wood Doors.
- E. Section 06 41 00 - Architectural Wood Casework: Cabinet hardware.
- F. Section 09 91 23 - Interior Painting: Painting of finish carpentry items.

**1.03 REFERENCE STANDARDS**

- A. ANSI A135.4 - American National Standard for Basic Hardboard; 2012.
- B. ANSI A208.1 - American National Standard for Particleboard; 2009.
- C. AWI/AWMAC/WI (AWS) - Architectural Woodwork Standards; 2014.
- D. AWMAC/WI (NAAWS) - North American Architectural Woodwork Standards, U.S. Version 3.0; 2016.
- E. AWPA U1 - Use Category System: User Specification for Treated Wood; 2012.
  - 1. Use 2014 as indicated in 2016 CBC Ch. 5 Referenced Standards.
- F. BHMA A156.9 - American National Standard for Cabinet Hardware; 2010.
- G. HPVA HP-1 - American National Standard for Hardwood and Decorative Plywood; 2009.
  - 1. Use 2013 as indicated in 2016 CBC Ch. 5 Referenced Standards.
- H. NEMA LD 3 - High-Pressure Decorative Laminates; 2005.
- I. PS 1 - Structural Plywood; 2009.
- J. WDMA I.S. 4 - Industry Specification for Preservative Treatment for Millwork; 2013.
- K. WI (MCP) - Monitored Compliance Program (MCP); current edition at [www.woodworkinstitute.com](http://www.woodworkinstitute.com).

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Coordinate the work with plumbing rough-in, electrical rough-in, and installation of associated and adjacent components.
- B. Sequence installation to ensure utility connections are achieved in an orderly and expeditious manner.

### **1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures for submittal procedures.
- B. Product Data:
  - 1. Provide instructions for attachment hardware and finish hardware.
- C. Shop Drawings: Indicate materials, component profiles, fastening methods, jointing details, and accessories.
  - 1. Scale of Drawings: 1-1/2 inch to 1 foot, minimum.
  - 2. Provide the information required by AWMAC/WI (NAAWS).
  - 3. Include certification program label.
- D. Samples: Submit two samples of finish plywood, 6 by 8 inch in size illustrating wood grain and specified finish.
- E. Samples: Submit two samples of wood trim 6 inch long.
- F. Certificate: Submit labels and certificates required by quality assurance and quality control programs.

### **1.06 QUALITY ASSURANCE**

- A. Fabricator Qualifications: Company specializing in fabricating the products specified in this section with minimum five years of documented experience.
  - 1. Accredited participant in the specified certification program prior to the commencement of fabrication and throughout the duration of the project.
- B. Quality Certification:
  - 1. Comply with WI (MCP) woodwork association quality certification service/program in accordance with requirements for work specified in this section [www.woodworkinstitute.com/#sle](http://www.woodworkinstitute.com/#sle).
  - 2. Provide labels or certificates indicating that the work complies with AWMAC/WI (NAAWS) requirements for grade or grades specified.
  - 3. Provide designated labels on shop drawings as required by certification program.
  - 4. Provide designated labels on installed products as required by certification program.
  - 5. Submit certifications upon completion of installation that verifies this work is in compliance with specified requirements.

### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Protect work from moisture damage.

## **PART 2 PRODUCTS**

### **2.01 FINISH CARPENTRY ITEMS**

- A. Quality Standard: Custom Grade, in accordance with AWMAC/WI (NAAWS), unless noted otherwise.
- B. Surface Burning Characteristics: Provide materials having fire and smoke properties as required by applicable code.



- C. Interior Woodwork Items:
  - 1. Moldings, Bases, Casings, and Miscellaneous Trim: Clear white Maple; prepare for paint finish.
  - 2. Loose Shelving: Birch plywood; prepare for paint finish.

## **2.02 WOOD-BASED COMPONENTS**

- A. Wood fabricated from old growth timber is not permitted.
- B. Provide sustainably harvested wood, certified or labeled as specified in Section 01 63 00 - Product Substitution Procedures.
- C. Wood fabricated from timber recovered from riverbeds or otherwise abandoned is permitted, unless indicated otherwise, and provided it is clean and free of contamination, identify source; provide lumber re-graded by an inspection service accredited by the American Lumber Standard Committee, Inc. (ALSC).

## **2.03 SHEET MATERIALS**

- A. Softwood Plywood, Not Exposed to View: Any face species, medium density fiberboard core; PS 1 Grade A-B, glue type as recommended for application.
- B. Softwood Plywood, Exposed to View: Face species as indicated, plain sawn, medium density fiberboard core; PS 1 Grade A-B, glue type as recommended for application.
- C. Hardwood Plywood: Face species as indicated, plain sawn, book matched, medium density fiberboard core; HPVA HP-1, Front Face Grade AA, Back Face Grade 1, glue type as recommended for application.
- D. Particleboard: ANSI A208.1; Composed of wood chips, sawdust, or flakes of medium density, made with waterproof resin binders; of grade to suit application; sanded faces.
- E. Hardboard: ANSI A135.4; Pressed wood fiber with resin binder, Class 1 - Tempered, 1/4 inch thick, smooth one side (S1S).

## **2.04 PLASTIC LAMINATE MATERIALS**

- A. Plastic Laminate: NEMA LD 3, HGS; color as selected by Architect; textured, low gloss finish.
- B. Laminate Backing Sheet: NEMA LD 3, BKL; undecorated plastic laminate.
- C. Laminate Adhesive: Type recommended by laminate manufacturer to suit application; not containing formaldehyde or other volatile organic compounds.

## **2.05 UPHOLSTERY**

- A. Polyurethane Foam: Density not less than 2.2 lb/cu ft, fire retardant, non-hardening and non-oxidizing, with high resistance to alkalis, oils, moisture, and mildew.
- B. Upholstery Fabric: Manufacturer, fabric designation, color, and pattern; as indicated on Drawings.

## **2.06 FASTENINGS**

- A. Adhesive for Purposes Other Than Laminate Installation: Suitable for the purpose; not containing formaldehyde or other volatile organic compounds.
- B. Concealed Joint Fasteners: Threaded steel.

## **2.07 ACCESSORIES**

- A. Lumber for Shimming and Blocking: Softwood lumber of indicated species.
- B. Primer: Alkyd primer sealer.
- C. Wood Filler: Oil base, tinted to match surface finish color.

## **2.08 HARDWARE**

- A. Hardware: Comply with BHMA A156.9.

## **2.09 WOOD TREATMENT**

- A. Factory-Treated Lumber: Comply with requirements of AWPA U1 - Use Category System for pressure impregnated wood treatments determined by use categories, expected service conditions, and specific applications.
- B. Wood Preservative by Pressure Treatment (PT Type): Provide AWPA U1 treatment using waterborne preservative with 0.25 percent retainage.
- C. Water Repellent Preservative Treatment by Dipping Method: WDMA I.S. 4, with 0.25 percent retainage.
- D. Wood Preservative (Surface Application): Clear, Wodlife Classic type, Tris-2,4,6-(Dimethylaminomethyl) Phenol manufactured by Rust-Oleum Corporation.
- E. Shop pressure treat wood materials requiring preservatives to concealed wood blocking.
- F. Redry wood after pressure treatment to maximum 19 percent moisture content.

## **2.10 FABRICATION**

- A. Shop assemble work for delivery to site, permitting passage through building openings.
- B. Cap exposed plastic laminate finish edges with material of same finish and pattern.
- C. When necessary to cut and fit on site, provide materials with ample allowance for cutting. Provide trim for scribing and site cutting.
- D. Apply plastic laminate finish in full uninterrupted sheets consistent with manufactured sizes. Fit corners and joints hairline; secure with concealed fasteners. Slightly bevel arises. Locate counter butt joints minimum 2 feet from sink cut-outs.
- E. Apply laminate backing sheet to reverse face of plastic laminate finished surfaces.

## **2.11 SHOP FINISHING**

- A. Sand work smooth and set exposed nails and screws.
- B. Apply wood filler in exposed nail and screw indentations.
- C. On items to receive transparent finishes, use wood filler that matches surrounding surfaces and is of type recommended for the applicable finish.
- D. Finish work in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), Section 5 - Finishing for grade specified and as follows:
  - 1. Transparent:
    - a. System - 12, Polyurethane, Water-based.
    - b. Stain: As selected by Architect.

- c. Sheen: Flat.
- 2. Opaque:
  - a. System - 4, Latex Acrylic, Water-based.
  - b. Color: As selected by Architect.
  - c. Sheen: Flat.
- E. Back prime woodwork items to be field finished, prior to installation.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify adequacy of backing and support framing.
- B. Verify mechanical, electrical, and building items affecting work of this section are placed and ready to receive this work.

### **3.02 INSTALLATION**

- A. Install work in accordance with AWMAC/WI (NAAWS) requirements for grade indicated.
- B. Set and secure materials and components in place, plumb and level.
- C. Carefully scribe work abutting other components, with maximum gaps of 1/32 inch. Do not use additional overlay trim to conceal larger gaps.
- D. Install hardware in accordance with manufacturer's written instructions.

### **3.03 SITE APPLIED WOOD TREATMENT**

- A. Apply preservative treatment in accordance with manufacturer's instructions.
- B. Brush apply one coats of preservative treatment on wood in contact with cementitious materials. Treat site-sawn cuts.
- C. Allow preservative to dry prior to erecting members.

### **3.04 PREPARATION FOR SITE FINISHING**

- A. Set exposed fasteners. Apply wood filler in exposed fastener indentations. Sand work smooth.
- B. Site Finishing: See Section 09 91 23.
- C. Before installation, prime paint surfaces of items or assemblies to be in contact with cementitious materials.

### **3.05 TOLERANCES**

- A. Maximum Variation from True Position: 1/16 inch.
- B. Maximum Offset from True Alignment with Abutting Materials: 1/32 inch.

**END OF SECTION**



**SECTION 06 41 00**  
**ARCHITECTURAL WOOD CASEWORK**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Specially fabricated cabinet units.
- B. Hardware.
- C. Factory finishing.
- D. Preparation for installing utilities.

**1.02 RELATED REQUIREMENTS**

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 06 10 00 - Rough Carpentry: Support framing, grounds, and concealed blocking.
- C. Section 06 20 00 - Finish Carpentry: Wood trim unrelated to casework.
- D. Section 12 36 00 - Countertops.

**1.03 REFERENCE STANDARDS**

- A. AWMAC/WI (NAAWS) - North American Architectural Woodwork Standards, U.S. Version 3.0; 2016.
  - 1. Certified Seismic Casework Installation, OPM-0092-13.
- B. BHMA A156.9 - American National Standard for Cabinet Hardware; 2010.
- C. NEMA LD 3 - High-Pressure Decorative Laminates; 2005.
- D. UL (DIR) - Online Certifications Directory; current listings at database.ul.com.
- E. WI (MCP) - Monitored Compliance Program (MCP); current edition at [www.woodworkinstitute.com](http://www.woodworkinstitute.com).

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Preinstallation Meeting: Convene a preinstallation meeting not less than one week before starting work of this section; require attendance by all affected installers.

**1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Shop Drawings: Indicate materials, component profiles, fastening methods, jointing details, and accessories.
  - 1. Scale of Drawings: 1-1/2 inch to 1 foot, minimum.
  - 2. Provide the information required by AWMAC/WI (NAAWS).
  - 3. Include certification program label.
    - a. Affix a Woodwork Institute Certified Compliance Label WI (CCP) on the first page of the shop drawings.
- C. Product Data: Provide data for hardware accessories.

- D. Samples: Submit actual samples of architectural cabinet construction, minimum 12 inches square, illustrating proposed cabinet, countertop, and shelf unit substrate and finish.
- E. Samples: Submit actual sample items of proposed pulls, hinges, shelf standards, and locksets, demonstrating hardware design, quality, and finish.
- F. Certificate: Submit labels and certificates required by quality assurance and quality control programs.
- G. Maintenance Materials: Furnish the following for District's use in maintenance of project:
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.
  - 2. Spare Parts: One of each kind of lock.
  - 3. Extra Stock Materials: six keys of each kind of lock.

### 1.06 QUALITY ASSURANCE

- A. Fabricator Qualifications: Company specializing in fabricating the products specified in this section with minimum five years of documented experience.
  - 1. Company with at least one project in the past 5 years with value of woodwork within 20 percent of cost of woodwork for this Project.
  - 2. Accredited participant in the specified certification program prior to the commencement of fabrication and throughout the duration of the project.
  - 3. A Licensee of the Woodwork Institute's Certified Compliance Program.
- B. Quality Certification:
  - 1. Comply with WI (MCP) woodwork association quality certification service/program in accordance with requirements for work specified in this section:  
<https://woodworkinstitute.com/#sle>.
  - 2. Provide labels or certificates indicating that the installed work complies with AWMAC/WI (NAAWS) requirements for grade or grades specified.
  - 3. Certified Seismic Casework Installation:
    - a. All wood or metal frame wall construction shall be constructed with continuous in wall blocking of either 3x6 flat Douglas Fir, 16 ga. x 6 inch wide, or as indicated on the AHJ approved structural drawings, 50 KSI sheet metal provided in accordance with the location requirements included on the cabinet fabricator/installer's shop drawings. Responsibility for blocking installation shall be that of the wall fabricator.
    - b. All casework installation shall be certified by the Woodwork Institute in accordance with their Certified Seismic Installation Program (CSIP) and their DSA Pre-approvals, including:
      - 1) A CSIP Certificate indicating that all of the casework installation fully meets the requirements of the NAAWS, CSIP and WI's OSHPD Pre-approvals.
    - c. It is the responsibility of the installer to include within their bid, any and all costs for WI's CSIP certification. Certification is a prerequisite for final acceptance. For further information, please visit [www.woodworkinstitute.com](http://www.woodworkinstitute.com)
  - 4. Provide designated labels on shop drawings as required by certification program.
  - 5. Provide designated labels on installed products as required by certification program.

- a. Before delivery to the jobsite the woodwork supplier shall provide a Woodwork Institute Certified Compliance Certificate indicating the millwork products being supplied and Certifying that these products fully meet the requirements of the Grade or Grades specified.
  - b. Each elevation of casework, each laminated plastic top, and each solid surface top shall bear a Woodwork Institute Certified Compliance Label.
6. Submit certifications upon completion of installation that verifies this work is in compliance with specified requirements.
- a. At completion of installation the woodwork installer shall provide a Woodwork Institute Certified Compliance Certificate indicating the products installed, and Certifying that the installation of these products fully meets the requirements of the Grade or Grades specified.
7. All fees charged by the Woodwork Institute for their Certified Compliance program are the responsibility of the millwork manufacturer and/or installer and shall be included in the bid.
8. Replace, repair, or rework all work for which certification is refused.

#### **1.07 MOCK-UP**

- A. Provide mock-up of typical base cabinet, wall cabinet, and countertop, including hardware, finishes, and plumbing accessories.
- B. See Section 01 45 00 - Quality Control for additional requirements.
- C. Locate where directed.
- D. Mock-up may remain as part of the Work, if approved.

#### **1.08 DELIVERY, STORAGE, AND HANDLING**

- A. Protect units from moisture damage.

#### **1.09 FIELD CONDITIONS**

- A. During and after installation of custom cabinets, maintain temperature and humidity conditions in building spaces at same levels planned for occupancy.

### **PART 2 PRODUCTS**

#### **2.01 REGULATORY REQUIREMENTS:**

- A. Wall hung cabinets and floor supported cabinets over 5 feet high shall be braced and anchored in accordance with the California Building Code (CBC) Title 24 Part 2, Table 1607A.1.
  - 1. Comply with OHSPD Pre-Approval OPM-0092-13.
- B. Requirements for Persons with Disabilities: Provide products meeting requirements of California Code of Regulations (CCR), Title 24, Part 2, Chapter 11B and ADA Accessibility Guidelines for Buildings and Facilities, latest amendment.
  - 1. Operable parts for all accessible casework shall comply with CBC Section 11B-309 Operable Parts.

2. Pull hardware shall be U-shaped wire pulls or equally accessible at all accessible casework; CBC 11B-811.4 Operable Parts.

## 2.02 CABINETS

- A. Quality Standard: Custom Grade, in accordance with AWMAC/WI (NAAWS), unless noted otherwise.
- B. Plastic Laminate Faced Cabinets: Custom grade.
- C. Cabinets:
  1. Finish - Exposed Exterior Surfaces: Decorative laminate.
  2. Finish - Exposed Interior Surfaces: Solid phenolic.
  3. Finish - Semi-Exposed Surfaces: Solid phenolic
  4. Finish - Concealed Surfaces: Manufacturer's option. All surfaces to be sealed against checking.
  5. Finish - Semi-Exposed Surfaces: Cabinet interiors (other than exposed interior surfaces of open or glass front cabinets) including faces of shelving therein, and interior door faces: Finish with cabinet liner as specified herein, color as selected by the Architect.
  6. Shelf, Door, Drawer Front and False Front Edge Profiles: Square edge with thick applied band.
    - a. Provide with subfronts and applied finish fronts securely fastened, with square corners, edges finished with 3 mm purified PVC.
    - b. Doors, Drawer Fronts, and False Fronts: 3mm purified PVC edge band, color and pattern to match exposed laminate, hot-melt applied.
    - c. All other exposed and semi exposed edges: 1mm PVC edge band, color and pattern to match exposed laminate.
  7. Door and Drawer Front Retention Profiles: Fixed panel.
  8. Casework Construction Type: Type A - Frameless.
  9. Interface Style for Cabinet and Door: Style 1 - Overlay; flush overlay.
    - a. Hinged to swing flat against the face of adjoining cabinet or the side of cabinet
    - b. Do not notch door or cabinet ends, or divisions to receive hinge.
  10. Layout for Cabinet and Door Fronts: Flush panel.
    - a. Custom Grade: Doors, drawer fronts and false fronts wood grain to run and match vertically within each cabinet unit.
  11. Cabinet Design Series: As indicated on drawings.
    - a. Base Cabinets without drawers: 100 series.
    - b. Base Cabinets with drawers: 200 series.
    - c. Wall hung Cabinets: 300 series.
    - d. Tall Storage Cabinets: 400 series.
    - e. Wardrobe Cabinets: 500 series.
    - f. Library Cabinets: 600 series.
  12. Adjustable Shelf Loading: 50 lbs. per sq. ft.
    - a. Deflection: L/144.



- b. In-line bored holes with locking adjustable shelf clips.
- 13. Cabinet Style: Flush overlay.
- 14. Cabinet Doors and Drawer Fronts: Flush style.
- 15. Drawer Side Construction: Multiple-dovetailed.
- 16. Drawer Construction Technique: As recommended by fabricator.
- 17. Toe Kick Base: Resilient base at toe kick provided under Section 09 65 00 - Resilient Flooring.

### **2.03 WOOD-BASED COMPONENTS**

- A. Lumber shall be sound, kiln dried softwood and/or hardwood meeting the requirements of the NAAWS Grade specified for its intended purpose.
- B. Panels shall contain no added urea-formaldehyde resins and shall be in accordance with the NAAWS requirements for the grade specified.
  - 1. Veneer: HPVA grade to meet the AWS requirements for type of surface and grade.
  - 2. Core: Comply with AWS.
    - a. Basis of Design Material: Combination Core, PureBond Classic Core, [www.columbiaforestproducts.com](http://www.columbiaforestproducts.com), or approved equal.

### **2.04 LAMINATE MATERIALS**

- A. Manufacturers:
  - 1. Abet - Laminati: [www.abetlaminati.com](http://www.abetlaminati.com)
  - 2. Formica Corporation: [www.formica.com/#sle](http://www.formica.com/#sle).
  - 3. Lamin-Art: [www.laminart.com](http://www.laminart.com).
  - 4. Panolam Industries International, Inc; Nevamar: [www.nevamar.com](http://www.nevamar.com).
  - 5. Wilsonart LLC: [www.wilsonart.com/#sle](http://www.wilsonart.com/#sle).
  - 6. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Thermally Fused Laminate (TFL): Melamine resin, NEMA LD 3, Type VGL laminate panels.
  - 1. Manufacturers:
    - a. Wilsonart LLC: [www.wilsonart.com/#sle](http://www.wilsonart.com/#sle).
    - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- C. High Pressure Decorative Laminate (HPDL): NEMA LD 3, types as recommended for specific applications.
- D. Provide specific types as indicated.
  - 1. Horizontal Surfaces: HGS, 0.048 inch nominal thickness, color as selected, finish as scheduled.
  - 2. Vertical Surfaces: VGS, 0.028 inch nominal thickness, color as selected, finish as scheduled.
  - 3. Post-Formed Horizontal Surfaces: HGP, 0.039 inch nominal thickness, color as selected, finish as indicated.

4. Post-Formed Vertical Surfaces: VGP, 0.028 inch nominal thickness, color as selected, finish as indicated.
5. Cabinet Liner: CLS, 0.020 inch nominal thickness, color as selected, finish as scheduled.
  - a. Low Pressure Decorative Laminate: color as selected by Architect from the manufacturers full range, melamine surfacing.
6. Laminate Backer: BKL, 0.020 inch nominal thickness, undecorated; for application to concealed backside of panels faced with high pressure decorative laminate.

## **2.05 COUNTERTOPS**

- A. Countertops are specified in Section 12 36 00.

## **2.06 ACCESSORIES**

- A. Adhesive: Type recommended by fabricator to suit application.
  1. Urea Formaldehyde adhesives shall not be used.
  2. Contact cement shall have a VOC content of less than 80 g/l.
  3. Construction adhesive shall have a VOC content compliant with Section 01 61 16.
- B. Fasteners: Size and type to suit application.
- C. Bolts, Nuts, Washers, Lags, Pins, and Screws: Of size and type to suit application; galvanized or chrome-plated finish in concealed locations and stainless steel or chrome-plated finish in exposed locations.
- D. Concealed Joint Fasteners: Threaded steel.
- E. Grommets: Standard plastic, painted metal, or stainless steel / chrome plated grommets for cut-outs, in color to match adjacent surface.
  1. Basis of Design Product: TG Flip-Top® Series as manufactured by Doug Mocket & Company, Inc., or approved equal.
    - a. Application: desk, countertop, or worksurface grommets.
    - b. Hole Diameter: 3 inches.
    - c. Type: Flip Top.
    - d. Color as selected by Architect.
    - e. Location as directed by Architect or District. Final location and color to be indicated on shop drawing submittal.

## **2.07 HARDWARE**

- A. Hardware: BHMA A156.9, types as recommended by fabricator for quality grade specified.
- B. Adjustable Shelf Supports: Standard side-mounted system using multiple holes for pin supports and coordinated self rests, satin chrome or nickel finish, for nominal 1 inch spacing adjustments.
  1. Locking 3/4-inch plastic shelf supports for 5mm hole diameter.: Knappe & Vogt Manufacturing Company; Product No. 339: [www.knappeandvogt.com](http://www.knappeandvogt.com).
  2. Substitutions: See Section 01 60 00 - Product Requirements.
- C. Drawer and Door Pulls: "U" shaped wire pull, steel with satin finish, 4 inch centers.

1. Comply with CBC 11B-811.4.
  2. Amerock: BP76312-G10, 4 inch Pull, Allison Value Hardware
  3. Rockler: Satin Nickel 4 inch Wire Pull.
  4. Top Knob: M338 - Wire Pull 4 inch - Brushed Satin Nickel - Somerset Collection
  5. Substitutions: See Section 01 60 00 - Product Requirements.
- D. Cabinet Locks: Keyed cylinder, two keys per lock, master keyed, steel with chrome finish.
1. Provide locks on all cabinet doors and drawers in classrooms, except accessible sink bases, and as follows:
    - a. A.V. Cabinets.
    - b. Tall Storage Cabinets.
    - c. Display Cabinets.
    - d. Teacher's Wardrobe.
    - e. Teacher's Work Area.
    - f. Teacher's "Personal" Drawers.
    - g. Filing Cabinets.
    - h. Workrooms to have locks on all doors and drawers.
    - i. Nurse's office to have locks on all doors and drawers.
  2. Locks for doors and drawers shall be keyed alike for each room and master keyed.
  3. Metal Strike Plates: Provide cabinet door and drawer locks with metal strike plates to protect against particle board rip out.
  4. Door and drawer locks shall be of pin tumbler design and include working cylinder slides and forwardly removable cylinder to re-key without totally disassembling lock body and passed by ANSI Grade 1 testing.
  5. Locks shall be easily rekeyable pin tumbler with working top slide and retainer staple.
  6. Cabinet Locks:
    - a. Olympus Lock; Product 500DR: [www.olympus-lock.com](http://www.olympus-lock.com).
    - b. Corbin Cabinet Lock; Product 0737 Drawer Lock: [www.cclsecurity.com](http://www.cclsecurity.com).
    - c. Substitutions: See Section 01 60 00 - Product Requirements.
  7. Drawer Locks:
    - a. Olympus Lock; Product 600DW: [www.olympus-lock.com](http://www.olympus-lock.com).
    - b. Corbin Cabinet Lock; Product 0738 Drawer Lock: [www.cclsecurity.com](http://www.cclsecurity.com).
    - c. Substitutions: See Section 01 60 00 - Product Requirements.
- E. Catches: Magnetic.
1. Catches for Doors Without Locks: Magnetic with aluminum case.
    - a. Amerock; Product No. 145: [www.amerock.com](http://www.amerock.com).
    - b. The Engineered Products Co.; Product EP591: [www.epcohardwaresecurity.com](http://www.epcohardwaresecurity.com).
    - c. Stanley Architectural Hardware; Product CD46.
    - d. Substitutions: See Section 01 60 00 - Product Requirements.
  2. Catches for Inactive Leaf of Pairs of Doors With Locks: Elbow catch.

- a. Amerock; Product E.Z. Flex No. 3675-2G: [www.amerock.com](http://www.amerock.com).
  - b. The Engineered Products Co.; Product No. 1016: [www.epcohardwaresecurity.com](http://www.epcohardwaresecurity.com).
  - c. Ives; Product 2-A92: [www.iveshinges.com](http://www.iveshinges.com).
  - d. Substitutions: See Section 01 60 00 - Product Requirements.
- F. Drawer Slides:
- 1. Type: Full extension with no deflection.
  - 2. Static Load Capacity: As required by drawer size.
    - a. For drawers up to 18 inches wide and less than 4 inches in depth, provide slides with 100 pound capacity.
    - b. For drawers over 18 inches in width and over 4 inches in depth, provide slides with 150 pound capacity.
      - 1) Drawer slide capacity with paper storage: 200 pounds.
  - 3. Mounting: Side mounted.
  - 4. Stops: Positive type.
    - a. Provide mechanical stops designed to prevent accidental removal of the drawer.
  - 5. Features: Provide self closing/stay closed type with rolling balls, steel rollers and self-lubricating bearings.
  - 6. Manufacturers:
    - a. Accuride International, Inc; Light-Duty Drawer Slides: [www accuride.com/#sle](http://www accuride.com/#sle).
    - b. Grant Hardware Company, Division of Hettich International: [www.hettichamerica.com](http://www.hettichamerica.com).
    - c. Hettich America, LP: [www.hettich.com/#sle](http://www.hettich.com/#sle).
    - d. Knappe & Vogt Manufacturing Company; Light-Duty Drawer Slides: [www.knapeandvogt.com/#sle](http://www.knapeandvogt.com/#sle).
    - e. Knappe & Vogt Manufacturing Company; Medium-Duty Drawer Slides: [www.knapeandvogt.com/#sle](http://www.knapeandvogt.com/#sle).
    - f. Knappe & Vogt Manufacturing Company; Heavy-Duty Drawer Slides: [www.knapeandvogt.com/#sle](http://www.knapeandvogt.com/#sle).
    - g. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- G. Hinges: Semiconcealed type, BHMA No. B01521-3, steel with satin finish.
- 1. Provide two hinges for doors up to 48 inches in height. Provide minimum three hinges for doors over 48 inches in height. Comply with WI certification requirements.
  - 2. Wrap around style offset for overlay doors with non-removable pin.
  - 3. Five- knuckle hinge.
  - 4. ANSI/BHMA A156.9 level: Grade 1.
  - 5. Manufacturers:
    - a. Grass America Inc; Institutional Hinges: [www.grassusa.com/#sle](http://www.grassusa.com/#sle).
    - b. Hafele America Co.; : [www.hafele.com](http://www.hafele.com).
    - c. Hardware Resources: [www.hardwareresources.com](http://www.hardwareresources.com).
    - d. Hettich America, LP: [www.hettich.com/#sle](http://www.hettich.com/#sle).

- e. Blum, Inc: [www.blum.com](http://www.blum.com).
- f. Stanley Hardware Div.; Product No. 1592: [www.stanleycommercialhardware.com](http://www.stanleycommercialhardware.com).
- g. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## **2.08 SHOP TREATMENT OF WOOD MATERIALS**

- A. Provide UL (DIR) listed and approved identification on fire retardant treated material.
- B. Deliver fire retardant treated materials cut to required sizes. Minimize field cutting.

## **2.09 SITE FINISHING MATERIALS**

- A. Stain, Shellac, Varnish, and Finishing Materials: In compliance with AWMAC/WI (NAAWS), unless noted otherwise.

## **2.10 FABRICATION**

- A. Assembly: Shop assemble cabinets for delivery to site in units easily handled and to permit passage through building openings.
- B. Edging: Fit shelves, doors, and exposed edges with specified edging. Do not use more than one piece for any single length.
- C. Fitting: When necessary to cut and fit on site, provide materials with ample allowance for cutting. Provide matching trim for scribing and site cutting.
- D. Plastic Laminate: Apply plastic laminate finish in full uninterrupted sheets consistent with manufactured sizes. Fit corners and joints hairline; secure with concealed fasteners. Slightly bevel arises. Locate counter butt joints minimum 2 feet from sink cut-outs.
  - 1. Apply laminate backing sheet to reverse side of plastic laminate finished surfaces.
  - 2. Cap exposed plastic laminate finish edges with material of same finish and pattern.
- E. Mechanically fasten back splash to countertops with steel brackets at 16 inches on center.
- F. Provide cutouts for plumbing fixtures. Verify locations of cutouts from on-site dimensions. Seal cut edges.

## **2.11 SHOP FINISHING**

- A. Sand work smooth and set exposed nails and screws.
- B. For opaque finishes, apply wood filler in exposed nail and screw indentations and sand smooth.
- C. On items to receive transparent finishes, use wood filler matching or blending with surrounding surfaces and of types recommended for applied finishes.
- D. Finish work in accordance with AWMAC/WI (NAAWS), Section 5 - Finishing for grade specified and as follows:
  - 1. Transparent:
    - a. System - 12, Polyurethane, Water-based.
    - b. Stain: As selected by Architect.
    - c. Sheen: Satin.
  - 2. Opaque:
    - a. System - 4, Latex Acrylic, Water-based.

- b. Color: As selected by Architect.
- c. Sheen: Semigloss.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify adequacy of backing and support framing.
- B. Verify location and sizes of utility rough-in associated with work of this section.

### **3.02 INSTALLATION**

- A. Install work in accordance with AWMAC/WI (NAAWS) requirements for grade indicated.
  - 1. Provide a WI Certified Compliance Certificate for installation as specified herein.
  - 2. Install in accordance and comply with WI Certified Seismic Installation Program (CSIP).
- B. Set and secure custom cabinets in place, assuring that they are rigid, plumb, and level.
  - 1. Install plumb, level, true and straight with no distortions. Shim as required using concealed shims. Scribe and cut for accurate fit.
  - 2. Base Cabinets: Set cabinets straight, plumb, and level. Adjust sub-tops within 1/16 inch of a single plane. Fasten each individual cabinet to floor at toe space, with fasteners spaced 12 inches on center. Bolt continuous cabinets together. Secure individual cabinets with not less than 2 fasteners into floor, where they do not adjoin other cabinets.
    - a. Where required, assemble units into one integral unit with joints flush, tight, and uniform. Align similar adjoining doors and drawers to a tolerance of 1/16 inch.
  - 3. Wall Cabinets: Securely fasten woodwork per Division of the State Architect Standards (as adopted by WI) to solid supporting wall framing material, not plaster, lath, or gypsum board. Anchor, adjust, and align wall cabinets as specified for base cabinets.
    - a. Reinforcement of stud walls to support wall-mounted cabinets specified in appropriate section, but responsibility for accurate location and sizing of reinforcement shall be coordinated with applicable trade.
- C. Use fixture attachments in concealed locations for wall mounted components.
  - 1. Secure to ground, stripping, blocking with countersunk, concealed fasteners.
- D. Use concealed joint fasteners to align and secure adjoining cabinet units.
  - 1. Install without distortion so that doors and drawers fit openings and are accurately aligned.
- E. Carefully scribe casework abutting other components, with maximum gaps of 1/32 inch. Do not use additional overlay trim for this purpose.
- F. Secure cabinets to floor using appropriate angles and anchorages.
- G. Countersink anchorage devices at exposed locations. Conceal with solid wood plugs of species to match surrounding wood; finish flush with surrounding surfaces.
- H. Install finish hardware after all finish work has been completed. Inspect drilling operations for surface splinters or delaminations. Pieces bearing such imperfections will be rejected.

### **3.03 ADJUSTING**

- A. Test installed work for rigidity and ability to support loads.
- B. Adjust moving or operating parts to function smoothly and correctly.
  - 1. Adjust casework and hardware so that doors and drawers operate smoothly without warp or bind. Lubricate operating hardware as recommended by manufacturer.

### **3.04 CLEANING**

- A. Take necessary action to keep this work clean and free of dirt, trash, obstruction and equipment, except that necessary for the proper completion of this work. Remove materials not used.
- B. Clean casework, counters, shelves, hardware, fittings, and fixtures.

**END OF SECTION**





**SECTION 06 64 60**  
**TRANSLUCENT RESIN PANEL SYSTEM**

**PART 1 GENERAL**

**1.01 SUMMARY**

- A. This Section includes the Plastic Fabrication as shown and specified in the described system(s):
  - 1. Privacy Screens (DWP-1)
- B. The extent of Solid Polymer Fabrication is shown on the drawings.
  - 1. Additional fabrication and installation details can be found on the 3form Partner Preliminary Project Review, if applicable

**1.02 REFERENCE STANDARDS**

- A. ASTM D1929 - Standard Test Method for Determining Ignition Temperature of Plastics; 2016.
- B. ASTM D2843 - Standard Test Method for Density of Smoke from the Burning or Decomposition of Plastics; 2016.
- C. ASTM D635 - Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position; 2014.

**1.03 ADMINISTRATIVE REQUIREMENTS**

- A. Project Pre-installation Meeting
  - 1. Owner, Architect, Contractor, Installer to meet at project site within one week of scheduled installation.
  - 2. Review mounting conditions, installation and storage instructions, fabrication requirements, seaming and protection measures.

**1.04 SUBMITTALS**

- A. General: Submit in accordance with Section 01 30 00 - Administrative Requirements.
- B. Product List: Minimum of 3 completed 3form Chroma installations or 3 installations of similar materials and complexity. Include contact name and email address for each product.
- C. Product Data: Submit manufacturer's product data; include product description, fabrication information, and compliance with specified performance requirements.
- D. Submit product test reports from a qualified independent 3rd party testing agency indicating each type and class of panel system complies with the project performance requirements, based on comprehensive testing of current products. Previously completed test reports will be acceptable if for current manufacturer and indicative of products used on this project.
  - 1. Test reports required are:
    - a. Rate of Burning (ASTM D635)
    - b. Self-Ignition Temperature (ASTM D1929)
    - c. Density of Smoke (ASTM D2843)

- E. Shop Drawings: Include plans, elevations, sections, panel dimensions, details, and attachments to other work.
- F. Samples for Initial Selection:
  - 1. Submit minimum 2-inch by 2-inch samples. Indicate full color, texture and pattern variation.
- G. Samples for Verification:
  - 1. Submit minimum 4-inch by 4-inch sample for each type, texture, pattern and color of solid plastic fabrication.
- H. Mockups:
  - 1. Build mockups to verify selections made under sample Submittals and to demonstrate aesthetic effects.
  - 2. Build mockup of [each type of] Plastic Fabrication.
  - 3. Approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.
- I. Maintenance Data: Submit manufacturer's care and maintenance data, including care, repair and cleaning instructions. Include in Project closeout documents.

#### **1.05 QUALITY ASSURANCE**

- A. Manufacturers Qualifications
  - 1. Materials and systems shall be manufactured by a company continuously and regularly employed in the manufacture of specified materials for a period of at least three (3) consecutive years and which can show evidence of those materials being satisfactorily used on at least three (3) projects of similar size, scope and location. At least one (1) of the projects shall have been successful for use one year or longer.
  - 2. Manufacturer must offer a documented reclaim process that will take back, at the manufacturers cost, panels that are at their end-of life cycle. Return process is preceded by following requirements highlighted in Section 02 41 00 - Demolition.
  - 3. Manufacturer must have documented training and qualification program for fabrication and installation of plastic fabrications.

#### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver Plastic Fabrications, systems and specified items in manufacturer's standard protective packaging.
- B. Do not deliver Plastic Fabrications, system, components and accessories to Project site until areas are ready for installation.
- C. Store materials in a flat orientation in a dry place that is not exposed to exterior elements. Materials are to be protected against damage from moisture and direct sunlight.
- D. Store 3form Chroma in area of installation minimum of 24 hours prior to installation.
- E. Handle materials to prevent damage to finished surfaces. Provide protective coverings to prevent damage or staining following installation for duration of project.
- F. Before installing Plastic Fabrications, permit them to reach room temperature.

## **1.07 PROJECT CONDITIONS**

- A. Environmental Limitations: Do not install Solid Polymer Fabrications until spaces are enclosed and weatherproof, and ambient temperatures and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.

## **1.08 WARRANTY**

- A. Manufacturer's Special Warranty on Plastic Fabrications: Manufacturer's standard form agreeing to repair or replace units that fail in material or workmanship within the specified warranty period.
- B. Warranty Period: 1 year after ship date.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURER**

- A. Manufacturer: 3form, Inc., Salt Lake City, Utah, USA / telephone 801-649-2500

### **2.02 MATERIALS**

- A. 3form Chroma
  - 1. Engineered acrylic resin
  - 2. Sheet Size: Maximum 4' x 10'
  - 3. Thickness: As indicated on Drawings
  - 4. Basis of Design Product: The design of Plastic Fabrications is based on Chroma as provided by 3form, Inc.; or equal. Products from other manufacturers must be approved by the Architect or Designer prior to bidding in accordance with the Instructions to Bidders and Section 01 63 00 - Product Substitution Procedures.
- B. Sheet minimum performance attributes:
  - 1. Rate of Burning (ASTM D 635). Material must attain CC2 Rating for a nominal thickness of 1.5 mm (0.060 in.) and greater.
  - 2. Self-Ignition Temperature (ASTM D 1929). Material must have a Self-ignition temperature greater than 850°F.
  - 3. Density of Smoke (ASTM D 2843). Material must have a smoke density less than 10%.
  - 4. Color infusion must use water soluble dyes and penetrate at least 150 microns into material.
  - 5. Applied coatings must be low-VOC, contain non-toxic pigments, not contain any heavy metals and be approved for exterior use.
  - 6. Matte surface should be completely renewable onsite.

### **2.03 FABRICATION**

- A. Fabricate Plastic Fabrications to designs, sizes and thicknesses indicated and to comply with indicated standards. Sizes, profiles and other characteristics are indicated on the drawings, additional fabrication and installation details can be found on the 3form Partner Preliminary Project Review, if applicable.

- B. Comply with manufacturer's written recommendations for fabrication.
- C. Machining: Acceptable means of machining are listed below. Ensure that material is not chipped or warped by machining operations.
  - 1. Sawing: Select equipment and blades suitable for type of cut required.
  - 2. Drilling: Drills specifically designed for use with plastic products.
  - 3. Routing
  - 4. Tapping
- D. Forming: Form products to shapes indicated using the appropriate method listed below. Comply with manufacturer's written instructions.
  - 1. Cold Bending
  - 2. Hot Bending
  - 3. Thermoforming: Acceptable only on uncoated material.
  - 4. Drape Forming
  - 5. Matched Mold Forming
  - 6. Mechanical Forming
- E. Laminating: Laminate to substrates indicated using adhesives and techniques recommended by manufacturer.

#### **2.04 MISCELLANEOUS MATERIALS**

- A. Provide products of material, size, and shape required for application indicated, and with a proven record of compatibility with surfaces contacted in installation.
- B. Cleaner: Type recommended by manufacturer.
- C. Fasteners: Use screws designed specifically for plastics. Provide threaded metal inserts for applications requiring frequent disassembly such as light fixtures.
- D. Bonding Cements: May be achieved with solvents or adhesives, suitable for use with product and application.

### **PART 3 EXECUTION**

#### **3.01 EXAMINATION**

- A. Examine substrates, areas, and conditions where installation of Plastic Fabrications will occur, with Installer present, for compliance with manufacturer's requirements. Verify that substrates and conditions are satisfactory for installation and comply with requirements specified.

#### **3.02 INSTALLATION**

- A. Comply with manufacturer's written instructions for the installation of Plastic Fabrications. Sizes, profiles and other characteristics are indicated on the drawings, additional installation details can be found on the 3form Partner Preliminary Project Review, if applicable.
- B. Manufacturer's shop to fabricate items to the greatest degree possible.
- C. Installation should be performed by an authorized 3form Partner, if available.

- D. Utilize fasteners, adhesives and bonding agents recommended by manufacturer for type of installation indicated. Material that is chipped, warped, hazed or discolored as a result of installation or fabrication methods will be rejected.
- E. Install components plumb, level and rigid, scribed to adjacent finishes, in accordance with approved shop drawings and product data.
- F. Form field joints using manufacturer's recommended procedures. Locate seams in panels so that they are not directly in line with seams in substrates.

### **3.03 CLEANING AND PROTECTION**

- A. Protect surfaces from damage until date of substantial completion. Repair work or replace damaged work, which cannot be repaired to Architect's satisfaction.

**END OF SECTION**



**SECTION 06 83 16**  
**FIBERGLASS REINFORCED PANELING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Glass fiber reinforced plastic panels, FRP-1.
- B. Trim.

**1.02 RELATED SECTIONS**

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.

**1.03 REFERENCE STANDARDS**

- A. ASTM D256 - Standard Test Methods for Determining the Izod Pendulum Impact Resistance of Plastics; 2010 (Reapproved 2018).
- B. ASTM D2583 - Standard Test Method for Indentation Hardness of Rigid Plastics by Means of Barcol Impressor; 2013a.
- C. ASTM D3273 - Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber; 2016.
- D. ASTM D5319 - Standard Specification for Glass-Fiber Reinforced Polyester Wall and Ceiling Panels; 2017.
- E. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2018b.
  - 1. Use 2007 as indicated in CBC 2013 Referenced Standards.
- F. FDA Food Code - Chapter 6 - Physical Facilities; Current Edition.
- G. ISO 846 - Plastics -- Evaluation of the action of microorganisms; 1997.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; including sizes, patterns and colors available; and installation instructions.
- C. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.

**1.05 DELIVERY, STORAGE, AND HANDLING**

- A. Store panels flat, indoors, on a clean, dry surface. Remove packaging and allow panels to acclimate to room temperature for 48 hours prior to installation.

**PART 2 PRODUCTS**

**2.01 MANUFACTURERS**

- A. FRP-1 Basis of Design Product: Standard FRP as manufactured by Marlite, or approved equal.

- B. FRP-2 Basis of Design Product: Symmetrix FRP as manufactured by Marlite, or approved equal.
- C. FRP-3 Basis of Design Product: Envue FRP as manufactured by Marlite, or approved equal.
- D. Fiberglass Reinforced Plastic Panels:
  - 1. Crane Composites, Inc: [www.cranecomposites.com](http://www.cranecomposites.com).
  - 2. Marlite: [www.marlite.com](http://www.marlite.com).
  - 3. Nudo: [www.nudo.com](http://www.nudo.com).
  - 4. Parkland Performance; Plas-Tex PolyWall; [www.parklandplastics.com](http://www.parklandplastics.com).
  - 5. Substitutions: See Section 01 60 00 - Product Requirements.

## 2.02 PANEL SYSTEMS

- A. FRP-1 Wall Panels at General use in labs, kitchens & foodservice classrooms:
  - 1. Panel Size: 4 by 8 feet.
  - 2. Panel Thickness: 0.10 inch.
  - 3. Surface Design: Pebbled.
  - 4. Color: P 199 Bright White Color.
  - 5. Attachment Method: Adhesive only, with trim and sealant in joints.
- B. FRP-2 Wall Panels at Captains Table Kitchen:
  - 1. Panel Size: 4 by 8 feet.
  - 2. Panel Thickness: 0.10 inch.
  - 3. Surface Design: Subway Tile Pattern.
  - 4. Color: C 100-G63 White.
  - 5. Attachment Method: Adhesive only, with trim and sealant in joints.
- C. FRP-3 Wall Panels at Area behind Beverage Bar in Servery:
  - 1. Panel Size: 4 by 8 feet.
  - 2. Panel Thickness: 0.10 inch.
  - 3. Surface Design: Image to be supplied by architect/int. designer.
  - 4. Attachment Method: Adhesive only, with trim and sealant in joints.

## 2.03 MATERIALS

- A. Panels: Fiberglass reinforced plastic (FRP), complying with ASTM D5319.
  - 1. Surface Burning Characteristics: Flame Spread Index of 25 (Class A), maximum; Smoke Developed Index of 450, maximum; when whole system is tested in accordance with ASTM E84.
  - 2. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
  - 3. Scratch Resistance: Barcol hardness score greater than 35, when tested in accordance with ASTM D2583.
  - 4. Impact Strength: Greater than 6 ft lb force per inch, when tested in accordance with ASTM D256.



- 5. Surface Characteristics and Cleanability: Provide products that are smooth, durable, and easily cleanable, in compliance with FDA Food Code, Chapter 6 - Physical Facilities.
- 6. Biological Resistance: Rating of 0, when tested in accordance with ISO 846.
- B. FRPT-1 Trim: Aluminum; color coordinating with panel.
- C. FRPT-2 Trim: Stainless Steel; brushed
- D. Fasteners: Nylon rivets.
- E. Adhesive: Type recommended by panel manufacturer.
- F. Sealant: Type recommended by panel manufacturer; white.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions and substrate flatness before starting work.
- B. Verify that substrate conditions are ready to receive the work of this section.

### **3.02 INSTALLATION - WALLS**

- A. Install panels in accordance with manufacturer's instructions.
- B. Cut and drill panels with carbide tipped saw blades, drill bits, or snips.
- C. Pre-drill fastener holes in panels, 1/8 inch greater in diameter than fastener, spaced as indicated by panel manufacturer.
- D. Apply adhesive to the back side of the panel using trowel as recommended by adhesive manufacturer.
- E. Apply panels to wall with seams plumb and pattern aligned with adjoining panels.
- F. Install panels with manufacturer's recommended gap for panel field and corner joints.
- G. Drive fasteners to provide snug fit, and do not over-tighten.
- H. Place trim on panel before fastening edges, as required.
- I. Fill channels in trim with sealant before attaching to panel.
- J. Install trim with adhesive and screws or nails, as required.
- K. Seal gaps at floor, ceiling, and between panels with applicable sealant to prevent moisture intrusion.
- L. Remove excess sealant after paneling is installed and prior to curing.

**END OF SECTION**



**SECTION 07 01 50.19**  
**PREPARATION FOR RE-ROOFING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Removal of existing roofing system in preparation for a new roof membrane system.
- B. Removal of existing flashing and counterflashings.
- C. Temporary roofing protection.

**1.02 RELATED REQUIREMENTS**

- A. Section 07 54 00 - Thermoplastic Membrane Roofing.
- B. Section 07 62 00 - Sheet Metal Flashing and Trim: Replacement of flashing and counterflashings.

**1.03 PRICE AND PAYMENT PROCEDURES**

- A. See Division 01, for additional unit price requirements.
  - 1. Provide the following work using the unit price method.
- B. Repair Existing Roof Wood Decking:
  - 1. Basis of Measurement: By the square foot.
  - 2. Basis of Payment: Includes replacing decking with new material of same thickness.

**1.04 REFERENCE STANDARDS**

- A. ASTM C1177/C1177M - Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing; 2013.
- B. PS 1 - Structural Plywood; 2009.
- C. PS 2 - Performance Standard for Wood-Based Structural-Use Panels; 2010.

**1.05 ADMINISTRATIVE REQUIREMENTS**

- A. Coordinate with affected mechanical and electrical work associated with roof penetrations.
- B. Preinstallation Meeting: Convene one week before starting work of this section.
  - 1. Attendees:
    - a. Architect.
    - b. Contractor.
    - c. District.
    - d. Installer.
    - e. Roofing system manufacturer's field representative.
    - f. Inspection and Testing Agency Representatives.
  - 2. Meeting Agenda: Provide agenda to participants prior to meeting in preparation for discussions on the following:
    - a. Removal and installation schedule.

- b. Necessary preparatory work.
  - c. Protection before, during, and after roofing system installation.
  - d. Removal of existing roofing system.
  - e. Installation of new roofing system.
  - f. Temporary roofing and daily terminations.
  - g. Transitions and connection to and with other work.
  - h. Inspections and testing of installed systems.
- 3. Attendance is mandatory at conference required in section specifying new roofing installation.
  - 4. Establish at pre-bid job walk, number of layers to be removed and reconfirm at pre-installation conference.
- C. Schedule work to coincide with commencement of installation of new roofing system.

### **1.06 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Submit for each type of material.
- C. Shop Drawings: Indicate size, configuration, and installation details.
- D. Preconstruction Test Reports.
- E. Materials Removal Company Qualification Statement.
- F. Installer's Qualification Statement.
- G. Preconstruction Testing Agency Qualification Statement.

### **1.07 QUALITY ASSURANCE**

- A. Regulatory Requirements: Comply with governing EPA notification regulations before beginning membrane roofing removal. Comply with hauling and disposal regulations of authorities having jurisdiction.
- B. Materials Removal Company Qualifications: Company specializing in performing work of type specified with at least three years of documented experience.
  - 1. Comply with EPA notification regulations prior to start of roofing removal work.
  - 2. Comply with removal and disposal regulations of local authorities having jurisdiction (AHJ).
- C. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years of documented experience.
  - 1. When same installer as new roofing system, comply with related requirements of section indicated for new roofing system.
- D. Preconstruction Testing: Conduct testing by an independent test agency, in accordance with provisions of Section 01 45 00 - Quality Control.
  - 1. Provide required testing to locate hazardous materials, such as asbestos, by licensed agency as required for project location.
- E. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years of documented experience.

### **1.08 DELIVERY, STORAGE, AND HANDLING**

- A. Ensure storage and staging of materials does not exceed static and dynamic load-bearing capacities of roof decking.

### **1.09 SCHEDULING**

- A. Schedule work to coincide with commencement of installation of new roofing system.
- B. Remove only existing roofing materials that can be replaced with new materials as the weather will permit.

### **1.10 FIELD CONDITIONS**

- A. Existing Roofing System: Built-up asphalt roofing.
- B. Do not remove existing roofing membrane when weather conditions threaten the integrity of building contents or intended continued occupancy.
- C. Maintain continuous temporary protection prior to and during installation of new roofing system.
- D. Provide notice at least three days before starting activities that will affect normal building operations.
- E. Verify that occupants have been evacuated from building areas when work on structurally impaired roof decking is scheduled to begin.

### **1.11 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.

## **PART 2 PRODUCTS**

### **2.01 COMPONENTS**

- A. Refer to following sections for additional information on components relating to this work:
  - 1. Replacement and removal of existing roofing system in preparation for entire new roofing system, refer to Section 07 54 00.
  - 2. Remove existing flashing and counterflashings in preparation for replacement of these materials as part of this work, refer to Section 07 62 00 for material requirements.

### **2.02 SYSTEM DESCRIPTION**

- A. Indicated Roof Areas: Remove existing roofing, perimeter flashings, base flashings, counter flashings, vent stack flashings, roofing membrane, insulation, vapor retarder.

### **2.03 MATERIALS**

- A. Patching Materials: Provide necessary materials in accordance with requirements of existing roofing system.
- B. Temporary Roofing Protection Materials:
  - 1. Contractor's responsibility to select appropriate materials for temporary protection of roofing areas as determined necessary for this work.

2. Plastic Sheeting: Provide polyethylene sheets; use weights to retain sheeting in position.
3. OSB Sheathing: Oriented strand board (OSB) wood structural panel; PS 2.
  - a. Grade: Sheathing.
  - b. Bond Classification: Exposure 1 OSB.
  - c. Edges: Square.
4. Plywood Sheathing: PS 1, Grade C-D, Exposure I.
5. Provide thickness sufficient to prevent tearing or damage during use.
- C. Glass Mat Gypsum Substrate: ASTM C1177/C1177M, Type X (special fire-resistant) and moisture resistant.
  1. Board Size: 4 feet by 8 feet.
  2. Board Thickness: 1/2 inch.
  3. Board Edges: Square.

#### **2.04 ACCESSORIES**

- A. Fasteners: Type and size as required and compatible with existing and new roofing system to resist local wind uplift.
- B. Sheathing Paper: Red rosin paper type, at least 3 lbs per 100 sq ft.

### **PART 3 EXECUTION**

#### **3.01 EXAMINATION**

- A. Verify existing site conditions.
- B. Verify that existing roof surface has been cleared of materials being removed from existing roofing system and ready for next phase of work as required.
- C. Document existing conditions of adjoining construction and site improvements, including exterior and interior finish surfaces, that might be misconstrued as having been damaged by re-roofing operations.
  1. Submit before work begins.
  2. Use high-resolution digital photographs or video tape supplemented by written commentary for preparing reports.

#### **3.02 PREPARATION**

- A. Sweep roof surface clean of loose matter.
- B. Remove loose refuse and dispose of properly off-site.
  1. Free Fall Maximum: 8 feet, provide enclosed chutes for higher fall.
  2. Do not use District's disposal system.

#### **3.03 MATERIAL REMOVAL**

- A. Remove only existing roofing materials that can be replaced with new materials as the weather will permit.
- B. Remove metal counter flashings.

- C. Remove damaged portions of roofing membrane, perimeter base flashings, flashings around roof protrusions, pitch pans and pockets.
- D. Cut and lay flat any membrane blisters.
- E. Remove damaged insulation and fasteners, cant strips, blocking.
- F. Remove vapor retarder.
- G. Repair existing wood deck surface to provide smooth working surface for new roof system.

### **3.04 INSTALLATION**

- A. Coordinate scope of this work with requirements for installation of new roofing system, refer to Section 07 54 00 for additional requirements.

### **3.05 TEMPORARY PROTECTION**

- A. Provide temporary protective sheeting over uncovered deck surfaces.
- B. Turn sheeting up and over parapets and curbing. Retain sheeting in position with weights.
- C. Provide for surface drainage from sheeting to existing drainage facilities.
- D. Do not permit traffic over unprotected or repaired deck surface.

### **3.06 FIELD QUALITY CONTROL**

- A. Independent agency inspection and testing will be provided under provisions of Section 01 45 00.
- B. Inspection firm will identify the exact limits to material removal.
- C. Testing will identify the condition of existing materials and their reuse, repair or removal.
- D. Test Reports: Indicate existing insulation moisture content and existing bitumen quality.

### **3.07 PROTECTION**

- A. Provide temporary protective sheeting over uncovered deck surfaces.
- B. Turn sheeting up and over parapets and curbing. Retain sheeting in position with weights.
- C. Provide for surface drainage from sheeting to existing drainage facilities.
- D. Do not permit traffic over unprotected or repaired deck surface.

### **3.08 SCHEDULES**

- A. Entire Roofing Area: Remove existing roofing gravel, perimeter flashings, base flashings, counter flashings, vent stack flashings, roofing membrane, insulation, and vapor retarder.
- B. Remove roof mounted mechanical equipment and electrical equipment.

**END OF SECTION**





**SECTION 07 05 53**  
**FIRE AND SMOKE ASSEMBLY IDENTIFICATION**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Identification markings for fire and smoke rated partitions, and fire rated walls.

**1.02 RELATED REQUIREMENTS**

- A. Section 09 91 23 - Interior Painting: Paint finish.

**1.03 REFERENCE STANDARDS**

- A. CBC - California Building Code; 2016.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Manufacturer's printed product literature for each type of marking, indicating font, foreground and background colors, wording, and overall dimensions.
- C. Schedule: Completely define scope of proposed marking, and indicate location of affected walls and partitions, and number of markings.
- D. Samples: Submit two samples of each type of marking proposed for use, of size similar to that required for project, illustrating font, wording, and method of application.

**1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years of documented experience.

**1.06 FIELD CONDITIONS**

- A. Do not install adhered markings when ambient temperature is lower than recommended by label or sign manufacturer.
- B. Do not install painted markings when ambient temperature is lower than recommended by coating manufacturer.

**PART 2 PRODUCTS**

**2.01 MANUFACTURERS**

- A. Partition Identification Labels:
  - 1. Fire Wall Signs, Inc: [www.firewallsigns.com](http://www.firewallsigns.com).
  - 2. Safety Supply Warehouse, Inc: [www.safetysupplywarehouse.com](http://www.safetysupplywarehouse.com).
  - 3. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## **2.02 FIRE AND SMOKE ASSEMBLY IDENTIFICATION**

- A. Regulatory Requirements: Comply with "Marking and Identification" requirements of "Fire-Resistance Ratings and Fire Tests" chapter of the building code.
- B. Adhered Fire and Smoke Assembly Identification Signs: Printed vinyl or paper sign with factory applied adhesive backing.
- C. Applied Fire and Smoke Assembly Identification: Identification markings applied to partition with paint and a code compliant stencil. See Section 09 91 23 for products.
- D. Languages: Provide sign markings in English.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that substrate surfaces are ready to receive work.

### **3.02 PREPARATION**

- A. See Section 09 91 23 for substrate preparation for painted markings.

### **3.03 INSTALLATION**

- A. Locate markings as required by CBC Section 703.7.
- B. Install adhered markings in accordance with manufacturer's instructions.
- C. Install applied markings in accordance with Section 09 91 23.
- D. Install neatly, with horizontal edges level.
- E. Protect from damage until Date of Substantial Completion; repair or replace damaged markings.

**END OF SECTION**

**SECTION 07 21 00**  
**THERMAL INSULATION**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Batt insulation in exterior wall and ceiling construction.
- B. Batt insulation for filling perimeter window and door shim spaces and crevices in exterior wall and roof.
- C. Batt insulation for acoustic applications in interior walls.

**1.02 RELATED REQUIREMENTS**

- A. Section 07 54 00 - Thermoplastic Membrane Roofing: Insulation specified as part of roofing system.
- B. Section 07 84 00 - Firestopping: Insulation as part of fire-rated through-penetration assemblies.
- C. Section 09 21 16 - Gypsum Board Assemblies: Acoustic insulation inside walls and partitions.

**1.03 REFERENCE STANDARDS**

- A. ASTM C552 - Standard Specification for Cellular Glass Thermal Insulation; 2016a.
  - 1. Use 2012b as indicated in 2016 CBC Referenced Standards.
- B. ASTM C665 - Standard Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing; 2012.
- C. ASTM E119 - Standard Test Methods for Fire Tests of Building Construction and Materials; 2016a.
  - 1. Use 2012a as indicated in 2016 CBC Referenced Standards.
- D. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2016.
  - 1. Use 2013a as indicated in 2016 CBC Referenced Standards.
- E. ASTM E136 - Standard Test Method for Behavior of Materials in a Vertical Tube Furnace At 750 Degrees C; 2016.
  - 1. Use 2012 as indicated in 2016 CBC Referenced Standards.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide data on product characteristics, performance criteria, and product limitations.
  - 1. Materials List: Submit materials list, stating manufacturer and product identification for each product specified, including R-Value and fire resistance and surface burning characteristics specified herein.
- C. Compliance Certification: Upon completion of installation of building envelope insulation, a card certifying compliance with requirements of California Code of Regulations (CCR) Title 24

for installation of insulation shall be completed, executed and delivered to local building officials, and one copy conspicuously posted at Project site.

- D. Manufacturer's Installation Instructions: Include information on special environmental conditions required for installation and installation techniques.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.

### **1.05 FIELD CONDITIONS**

- A. Do not install insulation adhesives when temperature or weather conditions are detrimental to successful installation.

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. Fire Performance Characteristics: Where insulation is used within a fire rated wall assembly, provide insulation materials which are identical to those whose fire performance characteristics, as listed for each material or assembly of which insulation is a part, have been determined by testing, in accordance with methods specified below, by UL or other testing and inspecting agency acceptable to State Fire Marshal.
  - 1. Surface Burning Characteristics: ASTM E84. Maximum flame-spread and smoke developed indices are 25 and 450 respectively.
  - 2. Fire Resistance Ratings: ASTM E119.
  - 3. Combustibility: ASTM E136.
- B. Comply with Chapter 12-13 Standards for Insulating Materials, 1998 California Reference Standards Code (Part 12, Title 24. CCR) as published by Department of Consumer Affairs, Bureau of Home Furnishings and Thermal Insulation.
- C. Certificate: As required by the California Building Code (CBC), Title 24, post a certificate containing the building permit number and the insulation manufacturer's name, material identification and R-value and stating that the insulation has been installed in accordance with the plans and specifications.
- D. Performance: Materials shall conform to Section 719, California Building Code.

### **2.02 APPLICATIONS**

- A. Insulation in Wood Framed Walls: Batt insulation with no vapor retarder.
- B. Insulation in Wood Framed Ceiling Structure: Batt insulation with no vapor retarder.
- C. Acoustic Insulation in Wood Framed Interior Walls: Batt insulation with no vapor retarder.

### **2.03 BATT INSULATION MATERIALS**

- A. Glass Fiber Batt Insulation: Flexible preformed batt or blanket, complying with ASTM C665; friction fit.
  - 1. Flame Spread Index: 25 or less, when tested in accordance with ASTM E84.
  - 2. Smoke Developed Index: 450 or less, when tested in accordance with ASTM E84.
  - 3. Combustibility: Non-combustible, when tested in accordance with ASTM E136, except for facing, if any.

4. Formaldehyde Content: Zero.
  5. Exterior Walls:
    - a. Thermal Resistance: R-value of 19.
    - b. Thickness: 5-1/2 inch.
  6. Facing: Aluminum foil, flame spread 25 rated; one side.
  7. Manufacturers:
    - a. CertainTeed Corporation: [www.certainteed.com](http://www.certainteed.com).
    - b. Johns Manville: [www.jm.com](http://www.jm.com).
    - c. Knauf Insulation: [www.knauf.com](http://www.knauf.com).
    - d. Owens Corning Corporation; EcoTouch PINK FIBERGLAS Insulation: [www.ocbuildingspec.com/#sle](http://www.ocbuildingspec.com/#sle).
  8. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Mineral Fiber Batt Insulation: Flexible or semi-rigid preformed batt or blanket, complying with ASTM C665; friction fit; unfaced flame spread index of 0 (zero) when tested in accordance with ASTM E84.
1. Typical at interior walls.
  2. Smoke Developed Index: 0 (zero), when tested in accordance with ASTM E84.
  3. Thickness: 2 inch.
  4. Manufacturers:
    - a. Johns Manville; MinWool Sound Attenuation Fire Batts: [www.jm.com/#sle](http://www.jm.com/#sle).
    - b. Knauf Insulation; EcoBatt Insulation: [www.knaufinsulation.com/#sle](http://www.knaufinsulation.com/#sle).
    - c. ROCKWOOL (ROXUL, Inc); COMFORTBATT: [www.rockwool.com/#sle](http://www.rockwool.com/#sle).
    - d. Thermafiber, Inc; SAFB: [www.thermafiber.com/#sle](http://www.thermafiber.com/#sle).
- C. Flexible Blanket Insulation: Thin profile insulation that complies with complex shapes, unfaced; flame spread index of 5 (five) and smoke development index of 10 (ten) or less when tested in accordance with ASTM E84.
1. Color: Gray.
  2. Thickness: 3/8 inch.
  3. Manufacturers:
    - a. Dow Chemical Company; DOWSIL HPI-1000 Insulation Blanket: [consumer.dow.com/en-us/industry/ind-building-construction.html/#sle](http://consumer.dow.com/en-us/industry/ind-building-construction.html/#sle).

#### **2.04 ACCESSORIES**

- A. Insulation Fasteners: Lengths of unfinished, 13 gage, 0.072 inch high carbon spring steel with chisel or mitered tips, held in place by tension, length to suit insulation thickness and substrate, capable of securely supporting insulation in place.
- B. Nails or Staples: Steel wire; electroplated or galvanized; type and size to suit application.
- C. Wire Mesh: Galvanized steel, hexagonal wire mesh.
- D. Adhesive: Type recommended by insulation manufacturer for application.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that substrate, adjacent materials, and insulation materials are dry and that substrates are ready to receive insulation.
- B. Verify substrate surfaces are flat, free of irregularities.

### **3.02 BATT INSTALLATION**

- A. Install insulation and vapor retarder in accordance with manufacturer's instructions.
- B. Install in exterior wall spaces without gaps or voids. Do not compress insulation.
- C. Trim insulation neatly to fit spaces. Insulate miscellaneous gaps and voids.
- D. Fit insulation tightly in cavities and tightly to exterior side of mechanical and electrical services within the plane of the insulation.

### **3.03 PROTECTION**

- A. Do not permit installed insulation to be damaged prior to its concealment.

**END OF SECTION**

**SECTION 07 54 00**  
**THERMOPLASTIC MEMBRANE ROOFING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Adhered system with thermoplastic roofing membrane.
  - 1. Membrane is OFCI, to be provided by a CMAS contract. Other components are by installing contractor. See Attachment A following this section.
- B. Cover Board
- C. Flashings.
  - 1. Clad Metal Flashing
- D. Roofing cant strips, stack boots, roofing expansion joints, and walkway pads.

**1.02 RELATED REQUIREMENTS**

- A. Section 06 10 00 - Rough Carpentry: Wood nailers and curbs.
- B. Section 07 01 50.19 - Preparation for Re-Roofing.
- C. Section 07 62 00 - Sheet Metal Flashing and Trim: Counterflashings, reglets.
- D. Section 07 72 00 - Roof Accessories: Roof-mounted units; prefabricated curbs.
- E. Division 22 - Plumbing: Roof drains, plumbing penetrating roofing membrane.
- F. Division 26 - Electrical.
  - 1. Conduit penetrating roofing membrane.

**1.03 REFERENCE STANDARDS**

- A. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures; Most Recent Edition Cited by Referring Code or Reference Standard.
- B. ASTM C1177/C1177M - Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing; 2013.
  - 1. Use 2008 as indicated in 2016 CBC Referenced Standards.
- C. ASTM D4434/D4434M - Standard Specification for Poly(Vinyl Chloride) Sheet Roofing; 2015.
  - 1. Use 2012 as indicated in 2016 CBC Referenced Standards.
- D. ASTM E1980 - Standard Practice for Calculating Solar Reflectance Index of Horizontal and Low-Sloped Opaque Surfaces; 2011.
- E. FM (AG) - FM Approval Guide; current edition.
- F. FM DS 1-28 - Wind Design; 2016.
- G. NRCA (RM) - The NRCA Roofing Manual; 2018.
- H. NRCA (WM) - The NRCA Waterproofing Manual; 2005.
- I. UL (FRD) - Fire Resistance Directory; Current Edition.

#### 1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene minimum two weeks before starting work of this section.
1. Review preparation and installation procedures and coordinating and scheduling required with related work.
  2. Notification: Two weeks prior to pre-application conference, inform District and Architect of scheduled roofing beginning and completion dates, such that District may arrange for independent inspection of roofing Work, and presence of independent testing and inspection agency at pre-application conference.
  3. Attendance: Require attendance by Contractor's superintendent and other supervisory and quality control personnel having responsibility for roofing, supervisory personnel of roofing applicator and, if required for warranty provisions, representative of roofing products manufacturer.
    - a. Construction Manager, Architect's insurer, independent testing and inspection agency and Architect, if authorized by District, will attend.
    - b. Require attendance of installers of each component of related Work, including deck or substrate construction, rigid insulation, metal flashing, rooftop equipment, penetrations of roof deck, and other Work integral with or adjacent to roofing may attend.
    - c. If required, attendance shall include authorities having jurisdiction. Contractor shall verify requirement with authorities having jurisdiction and arrange for attendance.
    - d. Agenda:
      - 1) Meeting purpose is to review Drawings and Specifications for suitability for application of roofing system.
      - 2) Review application procedures and coordination required with related Work. Discuss changes and deviations from Drawings and Specifications, if any, recommended or required.
      - 3) Walk roof areas to review and discuss substrate preparation including repair of unacceptable surfaces, roof drainage, penetrations, equipment curbs, and work performed by other trades, which require coordination with roofing system.
      - 4) Review contract document requirements and submittals for roofing system, including roofing schedule, inspection and testing, and environmental conditions. Identify which governing regulations or insurance requirements will affect roofing system installation.
      - 5) Discuss anticipated weather, as well as procedures for responding to unacceptable weather, including using temporary roofing. Temporary roofing, if necessary, will be added to scope of the Work by contract modification (change order or construction change directive), with acceptable adjustment in Contract Time and Contract Sum.
      - 6) Document discussions in writing, including actions required, and distribute copy of report to each meeting participant.
      - 7) Attendance by Construction Manager, Architect and independent testing and inspection agency shall not relieve Contractor of sole responsibility for means, methods, techniques and sequence of construction, in accordance with provisions of the Conditions of the Contract.



## 1.05 SUBMITTALS

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide data indicating physical properties of membrane materials, flashing materials, adhesives, and cover board.
- C. Applicator's(Contractor) Specimen Warranty: For approval.
- D. Shop Drawings: Submit drawings that indicate joint or termination detail conditions, conditions of interface with other materials, and paver layout.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- F. Certification required for existing buildings to be re-roofed per Chapter 3 of Part 1 of Division 2 of the Public Contract Code Section 1 Section 3006(b):
  - 1. I, \_\_\_\_\_ (Name), \_\_\_\_\_ (Name of Employer), certify that I have not offered, given, or agreed to give, received, accepted, or agreed to accept, any gift, contribution, or any financial incentive whatsoever to or from any person in connection with the roof project contract. As used in this certification, "person" means any natural person, business, partnership, corporation, union, committee, club, or other organization, entity, or group of individuals. Furthermore, I \_\_\_\_\_ (Name), \_\_\_\_\_ (Name of Employer), certify that I do not have, and throughout the duration of the contract, I will not have, any financial relationship in connection with the performance of this contract with any architect, engineer, roofing consultant, materials manufacturer, distributor, or vendor that is not disclosed below.
  - 2. I \_\_\_\_\_ (Name), \_\_\_\_\_ (Name of Employer), have the following financial relationships with an architect, engineer, roofing consultant, materials manufacturer, distributor, or vendor, or other person in connection with the following roof project contract:  
  
\_\_\_\_\_ Name and Address of Building, Contract Date and Number
  - 3. I certify that to the best of my knowledge, the contents of this disclosure are true, or are believed to be true.  
  
\_\_\_\_\_ (Signature) \_\_\_\_\_ (Date)  
  
\_\_\_\_\_ (Print Name)  
  
\_\_\_\_\_ (Print Name of Employer)
  - 4. Submit this certification to District, Construction Manager, and Architect.
- G. Manufacturer's Installation Instructions: Indicate membrane seaming precautions and perimeter conditions requiring special attention.
  - 1. Instructions and recommendations for application of roofing system, for each substrate and condition of the Project, with specific directions and recommendations for conditions of the Project for specified guarantee by manufacturer.
- H. Manufacturer's Field Reports: Indicate procedures followed, ambient temperatures, humidity, wind velocity during application, and supplementary instructions given.
- I. Installer's Qualification Statement.
- J. Specimen Warranty: For approval.

1. Applicator's(Contractor) Specimen Warranty: For approval.
- K. Installer's qualification data.
  1. Applicator's Certification: Written documentation that applicator is certified by roofing manufacturer to install roofing systems to be provided for the Project as specified in this Section.
- L. Applicator Warranty: Submit applicators/ contractor's warranty and ensure forms have been completed in District's name and registered with manufacturer.
- M. Material Safety Data Sheet: For all products submitted. For Contractor's use only.

#### **1.06 QUALITY ASSURANCE**

- A. Comply with Title 24 Part 2 - California Building Code Sections 1504 Performance Requirements, 1505 Fire Classification and 1507 Requirements for Roof Coverings; and Part 6 - California Energy Code requirements
- B. Roofing System shall be Energy Star Certified.
- C. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum twenty-five years of documented experience.
- D. Installer Qualifications: Company specializing in performing the work of this section with at least five years of documented experience and approved by manufacturer.
- E. Industry Standards:
  1. Work specified in this Section shall conform to manufacturer's product data and application instructions.
  2. Work shall also conform to the more stringent of recommended practices and details published in NRCA Roofing and Waterproofing Manual and Western States Roofing Contractors Association (WSRCA).
  3. Perform work in accordance with NRCA (RM) and NRCA (WM).
    - a. Maintain one copy on site.
- F. Testing and Inspection:
  1. District's independent inspection and testing agency will perform inspections and tests of roofing work.
  2. Costs of this service will be paid for by District.
  3. Contractor shall cooperate with independent testing and inspection agency.
  4. Refer to general requirements specified in Section 01 45 00 - Quality Control.

#### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver materials in manufacturer's original containers, dry and undamaged, with seals and labels intact.
- B. Store materials in weather protected environment, clear of ground and moisture.
  1. Place all materials on pallets and fully protect from moisture.
- C. Ensure storage and staging of materials does not exceed static and dynamic load-bearing capacities of roof decking.
- D. Protect foam insulation from direct exposure to sunlight.

- E. All materials which are determined to be damaged by the Construction Manager or the manufacturer are to be removed from the job site and replaced at no cost to the District.

### **1.08 FIELD CONDITIONS**

- A. Do not apply roofing membrane during unsuitable weather. Consult with the Manufacturer, as installation time and system integrity may be affected.
- B. Do not apply roofing membrane when ambient temperature is below 40 degrees F or above 95 degrees F.
  - 1. Do not apply roofing membrane when environmental conditions are outside the ranges recommended by manufacturer.
- C. Do not apply roofing membrane to damp or frozen deck surface or when precipitation is expected or occurring.
- D. Do not expose materials vulnerable to water or sun damage in quantities greater than can be weatherproofed the same day.
  - 1. All seams shall be cleaned and heat welded before leaving the job site that day.
- E. Schedule applications so that no partially completed sections of roof are left exposed at end of workday.
- F. Temporary Roofing: Provide temporary roof membrane if necessary to protect portions of the Work before final roofing can be installed.
  - 1. Record by way of change order the District's agreement to proceed with temporary roofing, along with additional costs and other changes (if any) to Contract Documents.
  - 2. Remove temporary roofing before starting installation of final roofing system.
- G. Arrange work sequence to avoid use of newly constructed roofing as a walking surface or for equipment movement and storage.
  - 1. Where such access is absolutely required, the General Contractor or Construction Manager shall provide all necessary protection and barriers to segregate the work area and to prevent damage to adjacent areas.
  - 2. A substantial protection layer consisting of plywood over felt or plywood over insulation board shall be provided for all new and existing roof areas that receive rooftop traffic during construction.

### **1.09 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. System Warranty: Provide manufacturer's system warranty agreeing to repair or replace roofing that leaks or is damaged due to wind within the limits specified.
  - 1. Warranty shall also include insulation and flashing as part of the roofing system and all other manufacturer supplied system components to be used as part of the roofing assembly..
  - 2. Warranty Term: 20 years, Non-Prorated and no dollar limit (NDL).
  - 3. Provide a written guarantee signed by the manufacturer's authorized official, agreeing to correct failures in product and installation, with no dollar limit on such corrections, for the noted warranty term from date established in Notice of Completion.

4. For repair and replacement include costs of both material and labor in warranty.
5. Exceptions Not Permitted:
  - a. Damage due to roof traffic or storage.
  - b. Damage due to wind speed greater than 56 mph but less than 90 mph.
  - c. Damage due to "bird baths," or ponding water during the warranty period.
- C. Applicator/Roofing Contractor Warranty:
  1. The Applicator shall supply the District with a separate five-year workmanship warranty.
  2. In the event any work related to roofing, flashing, or associated metal is found to be within the Applicator warranty term, defective or otherwise not in accordance with the Contract Documents, the Applicator shall repair that defect at no cost to the District.
  3. The Applicator's warranty obligation shall run directly to the District, and a copy shall be sent to the manufacturer.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. CMAS Contract Campus Standard Basis of Design Product: TPA FB as manufactured by Tremco.
  1. Tremco Contact: Steve Tolsma, 714.443.1744, stolsma@tremcoinc.com

### **2.02 PERFORMANCE REQUIREMENTS**

- A. General: Provide installed roofing membrane and base flashings that remain watertight; do not permit the passage of water; and resist specified uplift pressures, thermally induced movement, and exposure to weather without failure.
- B. Material Compatibility: Provide roofing materials that are compatible with one another under conditions of service and application required, as demonstrated by roofing manufacturer based on testing and field experience.
- C. Roofing System Design: Provide a roofing system that is identical to systems that have been successfully tested by a qualified testing and inspecting agency to resist uplift pressure calculated according to ASCE 7.
  1. Safety Factor: As required by code; minimum 2.0
  2. Factory Mutual Research Corporation (FM) - Norwood, MA: Class 1-90 (Attachment Criteria)

### **2.03 ROOFING**

- A. Thermoplastic Membrane Roofing: One ply membrane, fully adhered.
  1. Roof Assembly: (from the top down)
    - a. Roofing Membrane
    - b. Cover Board - Glass mat gypsum panel.
    - c. Wood roof deck.
- B. Roofing Assembly Requirements:

1. Solar Reflectance Index (SRI): 108, minimum, calculated in accordance with ASTM E1980.
  - a. Field applied coating may not be used to achieve specified SRI.
2. Roof Covering External Fire Resistance Classification: UL (FRD) Class A.
3. Factory Mutual Classification: Class 1 and windstorm resistance of 1-90, in accordance with FM DS 1-28. FM Certification is not required.

#### **2.04 MEMBRANE ROOFING AND ASSOCIATED MATERIALS**

- A. Membrane Roofing Materials: (OFCl)
  1. PVC: Polyvinyl chloride (PVC) conforming to ASTM D4434/D4434M, Type IV, sheet contains reinforcing fibers or reinforcing fabrics.
    - a. Thickness: 80 mil, 0.080 inch, minimum.
    - b. Backing: Non-woven polyester fleece.
  2. Sheet Width: Factory fabricated into largest sheets possible.
  3. Solar Reflectance: 0.86, minimum, initial, and 0.65, minimum, 3-year, certified by Cool Roof Rating Council.
  4. Thermal Emissivity: 0.86, minimum, initial, and 0.79, minimum, 3-year, certified by Cool Roof Rating Council.
  5. Color: White, integral.
- B. Seaming(Welding) Materials: As recommended by membrane manufacturer.
- C. Insulation and Cover Board Fasteners and Plates: As recommended and approved by membrane manufacturer.
- D. Flexible Flashing Material: Material recommended by membrane manufacturer.

#### **2.05 COVER BOARD**

- A. Cover Board: Glass mat faced gypsum panels, ASTM C1177/C1177M, fire resistant type, 1/4 inch thick.
  1. Application: Over insulation and at parapet wall studs.
  2. Manufacturers:
    - a. Georgia-Pacific; DensDeck Prime: [www.densdeck.com/#sle](http://www.densdeck.com/#sle).
    - b. National Gypsum Company; DEXcell Glass Mat Roof Board: [www.nationalgypsum.com/#sle](http://www.nationalgypsum.com/#sle).
    - c. USG Corporation; Securock Ultralight Glass-Mat Roof Board: [www.usg.com/#sle](http://www.usg.com/#sle).
    - d. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

#### **2.06 ACCESSORIES**

- A. Clad Metal Flashing:
  1. Description: PVC-coated, heat-weldable sheet metal capable of being formed into a variety of shapes and profiles.
  2. Materials: 24 gauge, G90 galvanized metal sheet with a 20 mil (0.5 mm) unsupported roofing membrane laminated on one side.

3. Clad Metal Color: Match roofing membrane.
- B. Stack Boots: Prefabricated flexible boot and collar for pipe stacks through membrane; same material as membrane.
- C. Butyl Tape: Two-sided rubber type, width as required, self adhering.
  1. Basis of Design Product: TremFlash (TF) Tape as manufactured by Tremco, or approved equal.
- D. Membrane Adhesive: As recommended by membrane manufacturer.
- E. Surface Conditioner for Adhesives: Compatible with membrane and adhesives.
- F. Thinners and Cleaners: As recommended by adhesive manufacturer, compatible with membrane.
- G. Insulation Adhesive: As recommended by insulation manufacturer.
- H. Strip Reglet Devices: Galvanized steel, maximum possible lengths per location, with attachment flanges.
- I. Termination Bar: 1.34 inch wide extruded aluminum, pre-punched strip.
- J. Sealants: As recommended by membrane manufacturer.
- K. Walkway Pads: Suitable for maintenance traffic, contrasting color or otherwise visually distinctive from roof membrane. Used as a protection layer from rooftop traffic.
  1. Composition: Roofing membrane manufacturer's standard.
  2. Size: Manufacturer's standard size(s).
  3. Surface Color: Light Gray.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that surfaces and site conditions are ready to receive work.
  1. Wood Deck:
    - a. Non-FM approved wood deck - The roof deck shall be minimum 1-1/2 inch thick lumber or 15/32 inch thick plywood.
      - 1) Deck shall be installed according to local code requirements.
      - 2) Contact Manufacturer's Technical support for fastening patterns and methods.
- B. Verify deck is supported and secure.
  1. The roof deck and existing roof construction must be structurally sound to provide support for the new roof system.
    - a. Applicator shall load materials on the rooftop in such a manner to eliminate risk of deck overload due to concentrated weight.
    - b. Contractor shall ensure that the roof deck is secured to the structural framing according to local building code and in such a manner as to resist all anticipated wind loads in that location.
- C. Verify deck is clean and smooth, flat, free of depressions, waves, or projections, properly sloped and suitable for installation of roof system.
- D. Verify deck surfaces are dry and free of snow or ice.

- E. Verify that roof openings, curbs, and penetrations through roof are solidly set, and nailing strips and reglets are in place.

### **3.02 WOOD DECK PREPARATION**

- A. Verify flatness and tightness of joints of wood decking. Fill knot holes with latex filler.
- B. Confirm dry deck by moisture meter with 12 percent moisture maximum.

### **3.03 INSTALLATION - GENERAL**

- A. Perform work in accordance with manufacturer's instructions, NRCA (RM), and NRCA (WM) applicable requirements.
- B. Do not apply roofing membrane during unsuitable weather.
- C. Do not apply roofing membrane when ambient temperature is outside the temperature range recommended by manufacturer.
- D. Do not apply roofing membrane to damp or frozen deck surface or when precipitation is expected or occurring.
- E. Do not expose materials vulnerable to water or sun damage in quantities greater than can be weatherproofed the same day.
- F. Coordinate this work with installation of associated counterflashings installed by other sections as the work of this section proceeds.

### **3.04 COVER BOARD INSTALLATION - UNDER MEMBRANE**

- A. Cover Boards: Mechanically fasten cover boards in accordance with roofing manufacturer's instructions and FM (AG) Factory Mutual requirements.
- B. Lay boards with edges in moderate contact without forcing. Cut to fit neatly to perimeter blocking and around penetrations through roof.
- C. At roof drains, use boards cut to slope to slope down to roof drains over a distance of 18 inches.

### **3.05 MEMBRANE APPLICATION**

- A. Roll out membrane, free from wrinkles or tears. Place sheet into place without stretching.
- B. Shingle joints on sloped substrate in direction of drainage.
- C. Fully Adhered Application: Apply adhesive to substrate at rate of no less than 0.69 gal/square. Fully embed membrane in adhesive except in areas directly over or within 3 inches of expansion joints. Fully adhere one roll before proceeding to adjacent rolls.
- D. Overlap edges and ends and seal seams by contact adhesive, minimum 3 inches. Seal permanently waterproof. Apply uniform bead of sealant to joint edge.
- E. Mechanical Attachment: Apply membrane and mechanical attachment devices in accordance with manufacturer's instructions.
  - 1. Install mechanical fasteners at terminations, penetrations, and perimeter of roofing.
- F. At intersections with vertical surfaces:
  - 1. Extend membrane up base angles a minimum of 8 inches onto vertical surfaces.
  - 2. Fully adhere flexible flashing over membrane and up to nailing strips.

3. Secure flashing to nailing strips at 4 inches on center.
  4. Insert flashing into reglets and secure.
- G. Around roof penetrations, seal flanges and flashings with flexible flashing.
- H. Coordinate installation of roof drains and sumps and related flashings.
- I. Over the completed roof membrane system, install a perimeter bar at 4 feet, and 8 feet. spacing from the base angle of the parapet wall or building's edge and cover with a membrane cove strip welded to the field sheet on both sides of the perimeter bar.
1. This securement is an assembly and application requirement.
- J. 4 inch wide, 24 gauge metal strap shall be applied to the parapet wall studs to receive the intermediate fastening required for wall flashing membrane securement to the parapet wall.
1. Straps shall be applied 30 inches from the base angle of the wall and repeated at this same spacing interval.

### **3.06 FINISHING UNBALLASTED SURFACES**

- A. Install walkway pads. Space pad joints to permit drainage.

### **3.07 FIELD QUALITY CONTROL**

- A. See Section 01 45 00 - Quality Control, for general requirements for field quality control and inspection.
- B. Require site attendance of roofing material manufacturers daily during installation of the Work.
1. Roofing system manufacturer shall provide to Architect a written on site approval and sign off on pre-roofing deck, insulation installation, membrane installation, flashing details and completed assembly.
  2. Roofing system manufacturer shall provide to Architect a Project Closeout Report upon delivery of the project warranty. This report shall include the following sections:
    - a. Project Specifications
    - b. Project Summary
    - c. Progress reports as a result of roof inspections
    - d. Job progress photos
    - e. Warranty document with Maintenance Manual describing maintenance and emergency repair.
- C. Regular daily written reports shall be provided to the Contractor and Architect for every day of roofing installation work.
- D. Roofing Inspection and Testing Services by Independent Agency: District's independent agency will provide inspection and testing services during application of roofing system.
1. Unless otherwise directed, inspection, including test cuts and evaluation procedures, will be performed in accordance with Chapter V, "Quality Control," of The NRCA Low-Slope Roofing Manual.
  2. Independent agency will provide reports of inspections and tests to Construction Manager and Architect. Copies of reports will also be provided to Contractor.



3. Water Test: Conduct simulated rain storm test by indirect spray of water for 15 minutes over entire roof surface. Check area below roofing for leaks and check top surface for standing water.
  - a. Record test and inspection by video tape or digital recording.
4. Remedial Work: Correct all defects and irregularities reported from inspections and tests, at no change in Contract Sum or Contract Time.

### **3.08 CLEANING**

- A. See Section 01 74 19 - Construction Waste Management and Disposal, for additional requirements.
- B. Remove bituminous markings from finished surfaces.
- C. In areas where finished surfaces are soiled by work of this section, consult manufacturer of surfaces for cleaning advice and comply with their documented instructions.
- D. Repair or replace defaced or damaged finishes caused by work of this section.

### **3.09 PROTECTION**

- A. Protect installed roofing and flashings from construction operations.
- B. Where traffic must continue over finished roof membrane, protect surfaces using durable materials.

**END OF SECTION**



**Attachment A**

**Owner Purchased Material List for Roofing Project at the Following Site:**

**Compton Community College – Administration Building**

The following material list is to be included in the bid form and signed/dated by the Contractor. Failure to provide this information will render your bid unresponsive. The owner is purchasing the following list of materials from the CMAS contract #4-18-00-118A, quote #5038955. Only these materials, in the quantities listed, will be supplied.

The Contractor is responsible for purchasing any additional material directly from the roofing material manufacturer and/or other supplier at the Contractor's cost. The contractor is also responsible for ALL other items not on this list necessary for the completion of work specified. This includes, but is not limited to, fasteners, adhesives insulation, tapered insulation, cants and taper edge, metal components, warranty charges, inspections, and other consumable materials.

The unloading of material and the storage of said material in a secure area is the sole responsibility of the Contractor. Any unused material will become the property of the Owner at the completion of the project.

| <u>Material</u>             | <u>Quantity</u> | <u>Roll Size</u> |
|-----------------------------|-----------------|------------------|
| TPA 80 Mil Fleece Back..... | 18 Rolls.....   | 76" X 75' Roll   |

Bidding Contractor: \_\_\_\_\_

Contractor Signature: \_\_\_\_\_

Date: \_\_\_\_\_

**SECTION 07 62 00**  
**SHEET METAL FLASHING AND TRIM**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Fabricated sheet metal items, including flashings, counterflashings, gutters, and downspouts.
- B. Sealants for joints within sheet metal fabrications.

**1.02 RELATED REQUIREMENTS**

- A. Section 06 10 00 - Rough Carpentry: Wood nailers for sheet metal work.
- B. Section 06 10 00 - Rough Carpentry: Field fabricated roof curbs.
- C. Section 07 25 00 - Weather Barriers: Flexible flashing.
- D. Division 7 - Thermal and Moisture Protection: Roofing system.
- E. Section 07 62 70 - Exterior Penetration Flashing Panels: Prefabricated flashing sleeves and collars for electrical, mechanical and plumbing items protruding through exterior walls.
- F. Section 07 72 00 - Roof Accessories: Manufactured metal roof curbs.
- G. Section 07 92 00 - Joint Sealants: Sealing non-lap joints between sheet metal fabrications and adjacent construction.
- H. Section 09 91 13 - Exterior Painting: Field painting.

**1.03 REFERENCE STANDARDS**

- A. AATCC Test Method 134 - Voluntary Specification, Performance Requirements and Test Procedures for Superior Performing Organic Coatings on Aluminum Extrusions and Panels (with Coil Coating Appendix); 2013.
- B. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2015.
  - 1. Use 2011 as indicated in 2016 CBC Referenced Standards.
- C. ASTM C920 - Standard Specification for Elastomeric Joint Sealants; 2014a.
- D. ASTM D1970/D1970M - Standard Specification for Self-Adhering Polymer Modified Bituminous Sheet Materials Used as Steep Roofing Underlayment for Ice Dam Protection; 2015a.
- E. ASTM D3161/D3161M - Standard Test Method for Wind-Resistance of Steep Slope Roofing Products (Fan-Induced Method); 2016.
- F. ASTM D4586/D4586M - Standard Specification for Asphalt Roof Cement, Asbestos-Free; 2007 (Reapproved 2012).
- G. SMACNA (ASMM) - Architectural Sheet Metal Manual; 2012.

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Preinstallation Meeting: Convene one week before starting work of this section.

### **1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Shop Drawings: Indicate material profile, jointing pattern, jointing details, fastening methods, flashings, terminations, and installation details.
- C. Samples: Submit two samples 6 x 6 inch in size illustrating metal finish color.

### **1.06 QUALITY ASSURANCE**

- A. Perform work in accordance with SMACNA (ASMM) requirements and standard details, except as otherwise indicated.
- B. Maintain one copy of each document on site.
- C. Fabricator and Installer Qualifications: Company specializing in sheet metal work with five years of documented experience.

### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Stack material to prevent twisting, bending, and abrasion, and to provide ventilation. Slope metal sheets to ensure drainage.
- B. Prevent contact with materials that could cause discoloration or staining.

## **PART 2 PRODUCTS**

### **2.01 SHEET MATERIALS**

- A. Galvanized Steel: ASTM A653/A653M, with G90/Z275 zinc coating; minimum 24 gage, (0.0239 inch) thick base metal.
- B. Pre-Finished Galvanized Steel: ASTM A653/A653M, with G90/Z275 zinc coating; minimum 24 gage, (0.0239) inch thick base metal, shop pre-coated with PVDF coating.
  - 1. PVDF (Polyvinylidene Fluoride) Coating: Superior Performance Organic Finish, AATCC Test Method 134; multiple coat, thermally cured fluoropolymer finish system.
  - 2. Color: As selected by Architect from manufacturer's custom colors.

### **2.02 FABRICATION**

- A. Form sections true to shape, accurate in size, square, and free from distortion or defects.
  - 1. Coping and Cap Flashing:
    - a. Coping and caps of type and profile indicated on Drawings, 20 gage galvanized sheet metal, with integral expansion.
  - 2. Drips at Doors and Windows:
    - a. Provide 20 gage galvanized sheet metal drips at head of all exterior doors and windows where no roof or overhang protection occurs.
    - b. Extend drips 2 inches beyond jambs, unless noted otherwise.
- B. Fabricate cleats of same material as sheet, minimum 4 inches wide, except at continuous strips, interlocking with sheet.
  - 1. Typically use continuous strips.

- C. Form pieces in longest possible lengths.
- D. Hem exposed edges on underside 1/2 inch; miter and seam corners.
- E. Form material with flat lock seams, except where otherwise indicated; at moving joints, use sealed lapped, bayonet-type or interlocking hooked seams.
  - 1. Typical Seams: Overlapped and sealed seams.
  - 2. Coping Seams: Lock seams, flattened.
  - 3. Seams, Horizontal to Vertical Transitions: Solder joints.
  - 4. Soldered seams: Tin edges to be seamed, form seams, and solder.
- F. Fabricate corners from one piece with minimum 18 inch long legs; seam for rigidity, seal with sealant.
- G. Fabricate vertical faces with bottom edge formed outward 1/4 inch and hemmed to form drip.
- H. Fabricate flashings to allow toe to extend 2 inches over roofing gravel. Return and brake edges.

### **2.03 GUTTER AND DOWNSPOUT FABRICATION**

- A. Gutters: SMACNA (ASMM), Rectangular profile.
- B. Downspouts: Rectangular profile.
- C. Scuppers and Overflows: 24 gage galvanized sheet metal, as indicated on Drawings and complying with referenced SMACNA Manual Figure number. Fabricate with minimum 6 inch flanges.
- D. Gutters and Downspouts: Size indicated.
- E. Accessories: Profiled to suit gutters and downspouts.
  - 1. Anchorage Devices: In accordance with SMACNA (ASMM) requirements.
  - 2. Gutter Supports: Straps.
  - 3. Downspout Supports: Straps.
  - 4. Strainers 10 gage galvanized steel wire basket type, riveted and soldered into place.
- F. Splash Pans: Same metal type as downspouts, formed to 12 x 18 inches size; rolled sides of 1 inch high for inverted pan placement.
- G. Downspout Boots: Steel.
- H. Downspout Extenders: Same material and finish as downspouts.
- I. Seal metal joints.

### **2.04 ACCESSORIES**

- A. Fasteners: Galvanized steel, with soft neoprene washers.
- B. Miscellaneous Metal Accessories: Provide sheet metal clips, straps, anchoring devices, and similar accessory units as required for installation of the Work, matching or compatible with material being installed, non-corrosive, size and gage required for performance.
- C. Underlayment: Self-adhesive sheet flexible flashing complying with ASTM D1970/D1970M.

1. Adhesives: Type recommended by flexible flashing sheet manufacturer for waterproof/weather-resistant seaming and adhesive application of flashing sheet.
- D. Slip Sheet: Rosin sized building paper.
- E. Primer: Zinc chromate type.
- F. Concealed Sealants: Non-curing butyl sealant.
- G. Exposed Sealants: ASTM C920; elastomeric sealant, with minimum movement capability as recommended by manufacturer for substrates to be sealed; color to match adjacent material.
  1. Epoxy Seam Sealer: 2-part non-corrosive metal seam cementing compound, recommended by metal manufacturer for exterior/interior non-moving joints including riveted joints.
- H. Plastic Cement: ASTM D4586/D4586M, Type I.
- I. Reglets: Surface mounted type, galvanized steel; face and ends covered with plastic tape.
  1. Performance Requirements
    - a. Reglet and flashing manufacturer shall certify that the system to be installed has been tested to resist 110 MPH wind loads when tested in accordance with ASTM D3161/D3161M for a minimum period of two hours.
  2. Specified Manufacturer: Fry Reglet Corporation, [www.fryreglet.com](http://www.fryreglet.com).
  3. Acceptable Manufacturers:
    - a. O'Keefes, Inc., [www.okeefes.com](http://www.okeefes.com).
    - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
  4. Accessories:
    - a. Corners: Factory-manufactured, mitered inside and outside corners.
    - b. Splices: Factory-manufactured, integral component of reglet and flashing system.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify roof openings, curbs, pipes, sleeves, ducts, and vents through roof are solidly set, reglets in place, and nailing strips located.
- B. Verify roofing termination and base flashings are in place, sealed, and secure.

### **3.02 PREPARATION**

- A. Install starter and edge strips, and cleats before starting installation.
- B. Install surface mounted reglets true to lines and levels, and seal top of reglets with sealant.
- C. Back paint concealed metal surfaces with protective backing paint to a minimum dry film thickness of 15 mil.

### **3.03 INSTALLATION**

- A. Conform to drawing details and the following:
  1. Scuppers: SMACNA Architectural Sheet Metal Manual, Detail 1-26 through 1-28, 1-30B.
  2. Downspouts: SMACNA Architectural Sheet Metal Manual, Detail 1-32B, 1-32F, 1-35B.

3. Parapet Coping/Cap: SMACNA Architectural Sheet Metal Manual, Detail 3-1, 3-3(18 Butt Seam w/ backing plates).
  4. Roof - Penetration Flashing: SMACNA Architectural Sheet Metal Manual, Detail 4-13 through 4-16.
- B. Insert flashings into reglets to form tight fit; secure in place with lead wedges; pack remaining spaces with lead wool; seal flashings into reglets with sealant.
  - C. Secure flashings in place using concealed fasteners, and use exposed fasteners only where permitted..
  - D. Apply plastic cement compound between metal flashings and felt flashings.
  - E. Fit flashings tight in place; make corners square, surfaces true and straight in planes, and lines accurate to profiles.
    1. Counterflashings Installation: Install counterflashing in reglets to form tight fit, either by snap-in seal arrangement or by securing in place with lead wedges spaced 18 inches on center maximum. Pack remaining spaces with lead wool.
      - a. Except where indicated or specified otherwise, insert counterflashing in reglets, extending down vertical surfaces over upturned vertical leg of base flashings not less than 3 inches.
      - b. Form counterflashings to required shapes before installation.
      - c. Lengths of metal counterflashings shall not exceed 120 inches.
      - d. Where stepped counterflashings are required, counterflashing may be installed in short lengths or may be of the preformed one-piece type.
      - e. Provide factory- or shop-form corners not less than 12 inches from the angle.
      - f. Provide end laps in counterflashings not less than 3 inches and make laps weathertight with sealant.
      - g. Turn up concealed edge of counterflashings built into masonry or concrete walls not less than 1/4 inch and extend not less than 2 inches into wall.
      - h. Fold exposed edges of counterflashings 1/2 inch.
      - i. Install counterflashing to provide a spring action against base flashing.
    2. Thru-Wall Flashing, see also Section 07 62 70 for piping and conduit penetrations:
      - a. Start flashing 1/2 inch behind exposed face of wall and extend through wall.
      - b. Lap-seam joints and seal with sealant.
      - c. Provide sealant around penetrations through flashing.
  - F. Seal metal joints watertight.
  - G. Secure gutters and downspouts in place with concealed fasteners.
    1. Install downspouts not less than 1 inch clear from walls.
    2. Fasten downspouts to walls at top, bottom, and at an intermediate point not exceeding 60 inches on center, with leader straps or concealed rack-and-pin type fasteners.
  - H. Connect downspouts to downspout boots, and grout connection watertight.
  - I. Set splash pans under downspouts. Set in place with adhesive.
  - J. Scuppers and Overflows Installation:
    1. Mechanically fasten and solder joints.



2. Fold outside edges under 1/2 inch on all sides.
  3. Join the bottom edge to closure flange, where necessary, and form ridge to act as a gravel stop around scupper inlet.
  4. Coat interior of scuppers and overflows with bituminous plastic cement.
- K. Metal Flashing at Wall and Roof Penetrations and Equipment Supports:
1. Exception:
    - a. Roofing: Where single ply system assembly has provided flashing for penetrations.
    - b. Walls: Where prefabricated flashing panels has provided flashing for penetrations.
  2. Penetrations through Single Ply (ex; PVC or TPO) membrane:
    - a. Roofing contractor is to install Single Ply (ex; PVC or TPO) cones and or flashing per roofing manufacturers standard details.
    - b. Roofing contractor is to provide sealant and stainless draw band to seal Single Ply (ex; PVC or TPO) cones and or flashings in accordance with the roofing manufacturer's standard details.
  3. Provide metal flashing for all pipes, ducts, and conduits projecting through the roof surface and for equipment supports, guy wire anchors, and similar items supported by or attached to the roof deck or walls.
    - a. Goose-necks, rainhoods, power roof ventilators, and other plumbing, HVAC and electrical products are specified as appropriate in:
      - 1) Division 21 - Fire Suppression.
      - 2) Division 22 - Plumbing.
      - 3) Division 23 - Heating, Ventilating, and Air-Conditioning (HVAC).
      - 4) Division 26 - Electrical.
    - b. Coordinate also with sheet metal curbs specified in Section 07 72 00.
  4. Single Pipe Vents: Provide lead flashing as indicated on Drawings.
    - a. Set flange of sleeve in bituminous plastic cement and nail 3 inches on centers.
    - b. Bend the top of sleeve over and extend down into the vent pipe a minimum of 2 inches.
    - c. For long runs or long rises above the deck, where it is impractical to cover the vent pipe with lead, use a two-piece formed galvanized sheet metal housing.
    - d. Set metal housing with a metal sleeve having a 4 inch roof flange in bituminous plastic cement and nailed 3 inches on center.
    - e. Extend sleeve a minimum of 8 inches above the roof deck and lapped a minimum of 3 inches by a metal hood secured to the vent pipe by a draw band.
    - f. Seal the area of hood in contact with vent pipe with specified sealant. Sealants are specified in Section 07 92 00 - Joint Sealants.
  5. Roof Penetration Flashing:
    - a. Base Flashing:
      - 1) Extend flange onto roof 6 inches minimum away from penetration.
      - 2) Extend flange upward around penetration to at least 8 inches above roofing felts.
      - 3) Fold back upper and side roof flange edges 1/2 inch minimum.

- 4) Lap and solder joints.
- b. Counterflashing: Overlap base flashing 1 inch minimum with storm collar sloped away from penetration. Secure to penetration with draw band and sealant.
6. Equipment Support and Pad Flashing:
  - a. Fully cap support and pad.
  - b. Overlap base flashing 4 inches.
  - c. Lap and solder joints.
  - d. Provide sealant around penetrations through-flashing.

### **3.04 CLEANING AND PREPARATION FOR FIELD PAINTING**

- A. Metal Preparation: As sheet metal installation progresses, neutralize excess flux with 5 to 10 percent washing soda solution, and thoroughly rinse.
- B. Repairs: Repair or replace damaged and deformed sheet metal.
- C. Cleaning: Wash down exposed surfaces and remove stains, scrap and debris such that sheet metal is ready to receive field painting and related Work.
  1. Wash down exposed surfaces and remove soiling, dust, contamination from steel wool and drilling residue, and other scrap and debris.
  2. Scrub surfaces with detergent solution as necessary to remove grease and oil films, handling marks, and stains.

### **3.05 FIELD PAINTING**

- A. Field Painting: Field-paint exposed sheet metal for corrosion resistance and decorative purposes. Field finish painting is specified in Section 09 91 13 - Exterior Painting.

### **3.06 FIELD QUALITY CONTROL**

- A. See Section 01 45 00 - Quality Control, for field inspection requirements.
- B. Inspection will involve surveillance of work during installation to ascertain compliance with specified requirements.

### **3.07 SCHEDULE**

- A. Gutters, Downspouts, and Scuppers: Field painted
- B. Coping, Cap, Parapet, Sill and Ledge Flashings: Thermoplastic membrane cladding.
- C. Counterflashings at Roofing Terminations (over roofing base flashings):
- D. Counterflashings at Curb-Mounted Roof Items:
- E. Roofing Penetration Flashings, for Pipes, Structural Steel, and Equipment Supports: Field Painted

**END OF SECTION**



**SECTION 07 72 00**  
**ROOF ACCESSORIES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Curbs.
- B. Equipment rails.
- C. Roof penetrations mounting curbs.
- D. Non-penetrating pedestals.

**1.02 RELATED REQUIREMENTS**

- A. Division 7 - Thermal and Moisture Protection: Roofing System
- B. Section 07 62 00 - Sheet Metal Flashing and Trim: Roof accessory items fabricated from sheet metal.

**1.03 REFERENCE STANDARDS**

- A. 29 CFR 1910.23 - Ladders; current edition.
- B. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products; 2017.
- C. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2016a.
- D. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2018.
- E. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes; 2014.
- F. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric); 2013.
- G. MSS SP-58 - Pipe Hangers and Supports - Materials, Design, Manufacture, Selection, Application, and Installation; 2018.
- H. OSHA 29 CFR 1910.23 - Fall Protection in General Industry; current edition.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Manufacturer's data sheets on each product to be used.
  - 1. Preparation instructions and recommendations.
  - 2. Storage and handling requirements and recommendations.
  - 3. Installation methods.
  - 4. Maintenance requirements.
- C. Shop Drawings: Submit detailed layout developed for this project and provide dimensioned location and number for each type of roof accessory.

1. Non-penetrating Rooftop Supports: Submit design calculations for loadings and spacings.
  2. Submit shop drawings sealed and signed by a Professional Engineer experienced in design of this type of work and licensed in California.
- D. Warranty Documentation:
1. Submit manufacturer warranty.
  2. Ensure that forms have been completed in District's name and registered with manufacturer.
  3. Submit documentation that roof accessories are acceptable to roofing manufacturer, and do not limit the roofing warranty.

### **1.05 QUALITY ASSURANCE**

- A. Pre-Installation Conference: Participate in conference with insulation and built-up roofing manufacturer and applicator as required in roofing section.

### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store products under cover and elevated above grade.

### **1.07 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. Correct defective Work within a five year period after Date of Substantial Completion.
- C. Provide five year manufacturer warranty for smoke hatches.

### **1.08 WARRANTY**

- A. Extended Warranty, Roof Hatches and Smoke Hatches: Manufacturer's standard five year warranty.

## **PART 2 PRODUCTS**

### **2.01 ROOF CURBS**

- A. Manufacturers:
  1. AES Industries Inc.: [www.aescurb.com](http://www.aescurb.com).
  2. Custom Curb, Inc.; Model No. CRC-3.
  3. Portals Plus: [www.portalsplus.com](http://www.portalsplus.com).
  4. Thybar Corp.; Model No. TC-3; [www.thybar.com](http://www.thybar.com)
  5. The Pate Company; Model No. pc-2: [www.patecurbs.com](http://www.patecurbs.com).
  6. Roof Products & Systems (RPS): [www.rpscurbs.com](http://www.rpscurbs.com).
  7. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Roof Curbs Mounting Assemblies: Factory fabricated hollow sheet metal construction, internally reinforced, and capable of supporting superimposed live and dead loads and

designated equipment load with fully mitered and sealed corner joints welded or mechanically fastened, and integral counterflashing with top and edges formed to shed water.

1. Applications: Roof curbs used for roof penetrations/openings as indicated on drawings, HVAC units, exhaust fans, pipe penetrations, and equipment supports.
  2. Roof Curb Mounting Substrate: Curb substrate consists of wood roof deck.
  3. Sheet Metal Material:
    - a. Galvanized Steel: Hot-dip zinc coated steel sheet complying with ASTM A653/A653M, SS Grade 33; G60 coating designation; 18 gage, 0.048 inch thick.
  4. Roofing Cants: Provide integral sheet metal roofing cants dimensioned to begin slope at top of roofing system at 1:1 slope; minimum cant height 4 inches.
  5. Provide layouts and configurations indicated on drawings.
- C. Curbs Adjacent to Roof Openings: Provide curb on each side of opening, with top of curb horizontal for equipment mounting.
1. Provide preservative treated wood nailers along top of curb.
  2. Insulate inside curbs with 1-1/2 inch thick fiberglass insulation.
  3. Height Above Finished Roof Surface: 8 inches, minimum.
- D. Equipment Rail Curbs: Straight curbs on each side of equipment, with top of curbs horizontal and level with each other for equipment mounting.
1. Height Above Finished Roof Surface: 8 inches, minimum.
  2. Provide gage of shell and size of nailers as necessary to support the full weight of the equipment.
- E. Pipe, Duct, or Conduit Mounting Curbs: Vertical posts, minimum 8 inches square unless otherwise indicated.
1. Provide sliding channel welded along top edge with adjustable height steel bracket, fabricated to fit item supported.
  2. Height Above Finished Roof Surface: 8 inches, minimum.

## 2.02 ROOF HATCHES AND VENTS

- A. Roof Hatch Manufacturers:
1. BILCO Company; Type E - Ladder Access: [www.bilco.com/#sle](http://www.bilco.com/#sle).
  2. Acudor Products Inc; Galvanized Steel Roof Hatch: [www.acudor.com/#sle](http://www.acudor.com/#sle).
  3. Babcock-Davis; ThermalMAX: [www.babcockdavis.com/#sle](http://www.babcockdavis.com/#sle).
  4. Dur-Red Products: [www.dur-red.com](http://www.dur-red.com).
  5. JL Industries: [www.activarcpg.com/JL Industries](http://www.activarcpg.com/JL%20Industries).
  6. Milcor, Inc: [www.milcorinc.com](http://www.milcorinc.com).
  7. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Roof Hatches: Factory-assembled galvanized steel frame and cover, complete with operating and release hardware.
1. Style: Provide flat metal covers unless otherwise indicated.

2. Mounting: Provide frames and curbs suitable for mounting conditions as indicated on drawings.
  3. Size: As indicated on drawings; single-leaf style unless indicated as double-leaf.
    - a. For Ladder Access: Single leaf; 36 by 36 inches.
- C. Frames and Curbs: One-piece curb and frame with integral cap flashing to receive roof flashings; extended bottom flange to suit mounting.
1. Material: Galvanized steel, 14 gage, 0.0747 inch thick.
  2. Finish: Factory prime paint.
  3. Insulation: Manufacturer's standard; 1 inch rigid glass fiber, located on outside face of curb.
  4. Curb Height: 12 inches from surface of roof deck, minimum.
  5. Flange: 3-1/2 inches with pre-drilled holes for attachment to roof deck..
- D. Metal Covers: Flush, insulated, hollow metal construction.
1. Capable of supporting 40 psf live load, internal loading of 20 psf (0.96 kPa).
  2. Material: Galvanized steel; outer cover 14 gage, 0.0747 inch thick, liner 22 gage, 0.03 inch thick.
  3. Finish: Factory prime paint.
  4. Insulation: Manufacturer's standard 1 inch rigid glass fiber.
  5. Gasket: Neoprene, continuous around cover perimeter.
- E. Safety Railing System: Manufacturer's standard accessory safety rail system mounted directly to curb.
1. Comply with 29 CFR 1910.23, with a safety factor of two.
  2. Posts and Rails: Aluminum tube.
  3. Gate: Same material as railing; automatic closing with latch.
  4. Finish: Manufacturer's standard, factory applied finish.
  5. Gate Hinges and Post Guides: ASTM B221 (ASTM B221M), 6063 alloy, T5 temper aluminum.
  6. Mounting Brackets: Hot dipped galvanized steel, 1/4 inch thick, minimum.
  7. Fasteners: Stainless steel, Type 316.
  8. Manufacturers:
    - a. BILCO Company; Bil-Guard 2.0: [www.bilco.com/#sle](http://www.bilco.com/#sle).
    - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- F. Hardware: Steel, zinc coated and chromate sealed, unless otherwise indicated or required by manufacturer.
1. Lifting Mechanisms: Compression or torsion spring operator with shock absorbers that automatically opens upon release of latch; capable of lifting covers despite 10 psf load.
  2. Hinges: Heavy duty pintle type.
  3. Automatic hold open arm with vinyl-coated handle for manual release.

- a. Automatic hold-open arm complete with red or contrasting colored vinyl grip handle to permit easy release and one-hand control of cover to closed and latched position.
4. Latch: Upon closing, engage latch automatically and reset manual release.
5. Manual Release: Pull handle on interior and exterior.
6. Locking: Padlock hasp on interior and exterior.

### **2.03 NON-PENETRATING ROOFTOP SUPPORTS/ASSEMBLIES**

- A. Non-Penetrating Rooftop Support/Assemblies: Manufacturer-engineered and factory-fabricated, with pedestal bases that rest on top of roofing membrane, and not requiring any attachment to roof structure and not penetrating roofing assembly.
  1. Design Loadings and Configurations: As required by applicable codes.
  2. Height: Provide minimum clearance of 6 inches under supported items to top of roofing.
  3. Support Spacing and Base Sizes: As required to distribute load sufficiently to prevent indentation of roofing assembly.
  4. Steel Components: Stainless steel, or carbon steel hot-dip galvanized after fabrication in accordance with ASTM A123/A123M.
  5. Hardware, Bolts, Nuts, and Washers: Stainless steel, or carbon steel hot-dip galvanized after fabrication in accordance with ASTM A153/A153M.
  6. Manufacturers:
    - a. Metal Roof Innovations, Ltd. S-5! Attachment Solutions; S-5! Utility System: [www.s-5.com/#sle](http://www.s-5.com/#sle).
    - b. PHP Systems/Design: [www.phpsd.com](http://www.phpsd.com).
    - c. Portals Plus: [www.portalsplus.com/#sle](http://www.portalsplus.com/#sle).
    - d. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Pipe Supports: Provide attachment fixtures complying with MSS SP-58 and as indicated.
  1. Attachment/Support Fixtures: As recommended by manufacturer, same type as indicated for equivalent indoor hangers and supports; corrosion resistant material.
  2. See relevant piping system specification section for additional requirements.
- C. Non-Penetrating Pedestals: Steel pedestals with square, round, or rectangular bases.
  1. Bases: High density polypropylene.
  2. Base Sizes: As required to distribute load sufficiently to prevent indentation of roofing assembly.
  3. Steel Components: Stainless steel, or carbon steel hot-dip galvanized after fabrication in accordance with ASTM A123/A123M.
  4. Manufacturers:
    - a. Metal Roof Innovations, Ltd. S-5! Attachment Solutions; S-5! Utility System: [www.s-5.com/#sle](http://www.s-5.com/#sle).
    - b. Portals Plus; Pedestal Plus: [www.portalsplus.com/#sle](http://www.portalsplus.com/#sle).
    - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.



## **2.04 ACCESSORIES**

### **A. Ladder Safety Post:**

1. Furnish and install where indicated on plans ladder safety post Model LU-1 manufactured by Bilco Company; [www.bilco.com](http://www.bilco.com), or equal. The ladder safety post shall be pre-assembled from the manufacturer.
  - a. Substitutions: See Section 01 60 00 - Product Requirements.
2. Performance characteristics:
  - a. Tubular post shall lock automatically when fully extended.
  - b. Safety post shall have controlled upward and downward movement.
    - 1) Release lever shall disengage the post to allow it to be returned to its lowered position.
  - c. Adjustable Mounting Bracket Spacing: Up to 14 inches on center.
    - 1) Clamp Bracket Size: 1-1/4 inch in diameter.
3. Post: High strength square tubing. A pull up loop shall be provided at the upper end of the post to facilitate raising the post.
4. Activation: Pull up loop shall be provided at the upper end of the post to facilitate raising the post.
5. Material of construction: Steel (Model LU-1, LU-2).
6. Balancing spring: A stainless steel spring balancing mechanism shall be provided to provide smooth, easy, controlled operation when raising and lowering the safety post.
7. Hardware: All mounting hardware shall be Type 316 stainless steel.
8. Factory Finish: Yellow powder coat steel (Model LU-1).

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Do not begin installation until substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

### **3.02 PREPARATION**

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using methods recommended by manufacturer for achieving acceptable results for applicable substrate under project conditions.

### **3.03 INSTALLATION**

- A. Install in accordance with manufacturer's instructions, in manner that maintains roofing system weather-tight integrity.
- B. Operational Units: Test and operate units with operable components. Clean and lubricate joints and hardware. Adjust for proper operation.

**3.04 CLEANING**

- A. Clean installed work to like-new condition.

**3.05 PROTECTION**

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Date of Substantial Completion.

**END OF SECTION**



**SECTION 07 84 00**  
**FIRESTOPPING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Firestopping systems.
- B. Firestopping of all joints and penetrations in fire resistance rated and smoke resistant assemblies, whether indicated on drawings or not, and other openings indicated.

**1.02 RELATED REQUIREMENTS**

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 01 70 00 - Execution and Closeout Requirements: Cutting and patching.
- C. Section 07 05 53 - Fire and Smoke Assembly Identification.
- D. Section 09 21 16 - Gypsum Board Assemblies: Gypsum wallboard fireproofing.

**1.03 REFERENCE STANDARDS**

- A. California Building Code: Section 714 - Penetrations and 715 - Fire Resistant Joint Systems.
- B. Comply with applicable requirements of the following standards. Where these standards conflict with other specified requirements, the most restrictive requirement shall govern.
- C. ASTM E119 - Standard Test Methods for Fire Tests of Building Construction and Materials; 2016a.
  - 1. Use 2012a as indicated in 2016 CBC Referenced Standards.
- D. ASTM E814 - Standard Test Method for Fire Tests of Penetration Firestop Systems; 2013a.
  - 1. Use 2013 as indicated in 2016 CBC Referenced Standards.
- E. ASTM E1966 - Standard Test Method for Fire Resistive Joint Systems; 2007 (Reapproved 2011).
  - 1. Use 2007a as indicated in 2016 CBC Referenced Standards.
- F. ASTM E2174 - Standard Practice for On-Site Inspection of Installed Firestops; 2014b.
  - 1. Use 2010ae1 as indicated in 2016 CBC Referenced Standards.
- G. ASTM E2393 - Standard Practice for On-Site Inspection of Installed Fire Resistive Joint Systems and Perimeter Fire Barriers; 2010a (Reapproved 2015).
  - 1. Use 2010ae1 as indicated in 2016 CBC Referenced Standards.
- H. ASTM E2307 - Standard Test Method for Determining Fire Resistance of Perimeter Fire Barriers Using Intermediate-Scale, Multi-story Test Apparatus; 2015b.
  - 1. Use 2010 as indicated in 2016 CBC Referenced Standards.
- I. ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi; 2015.
- J. ITS (DIR) - Directory of Listed Products; current edition.
- K. FM 4991 - Approval Standard for Firestop Contractors; 2013.

- L. FM (AG) - FM Approval Guide; current edition.
- M. Firestop Contractors International Association (FCIA): M.O.P. Manual of Practice.
- N. International Firestop Council (IFC); [www.firestop.org](http://www.firestop.org):
  - 1. Reference 1: Recommended IFC Guidelines for Evaluating Firestop Engineering Judgments.
  - 2. Reference 2: Inspectors Pocket Guide; Fifth Edition.
- O. NFPA 101 - Life Safety Code; 2015.
  - 1. Use 2015 as indicated in 2016 CBC Referenced Standards.
- P. SCAQMD 1168 - South Coast Air Quality Management District Rule No.1168; current edition.
- Q. UL 1479 - Standard for Fire Tests of Penetration Firestops; Current Edition, Including All Revisions.
  - 1. Use 2003 as indicated in 2016 CBC Referenced Standards.
- R. UL 2079 - Standard for Tests for Fire Resistance of Building Joint Systems; Current Edition, Including All Revisions.
  - 1. Use 2004 as indicated in 2016 CBC Referenced Standards.
- S. UL (DIR) - Online Certifications Directory; current listings at [database.ul.com](http://database.ul.com).
- T. UL (FRD) - Fire Resistance Directory; current edition.
  - 1. UL runs ASTM E814 under their designation of UL 1479 and publishes the results in their "FIRE RESISTANCE DIRECTORY" that is updated annually with a midyear supplement.
  - 2. Through-Penetration Firestop Devices (XHCR)
  - 3. Fire Resistance Ratings (BXUV)
  - 4. Through-Penetration Firestop Systems (XHEZ)
  - 5. Fill, Voids, or Cavity Material (XHHW)
  - 6. Forming Materials (XHKU)
- U. UL Qualified Firestop Contractor Program

#### **1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Schedule of Firestopping: List each type of penetration, fire rating of the penetrated assembly, and firestopping test or design number.
- C. Product Data: Provide data on product characteristics, performance ratings, and limitations.
- D. Sustainable Design Submittal: Submit VOC content documentation for all non-preformed materials.
- E. Manufacturer's Installation Instructions: Indicate preparation and installation instructions.
- F. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- G. Certificate from authority having jurisdiction indicating approval of materials used.
- H. Installer Qualification: Submit qualification statements for installing mechanics.

### 1.05 QUALITY ASSURANCE

- A. Provide products for all trades from the same manufacturer to the greatest extent possible and from the same supplier/distributor.
- B. Fire Testing: Provide firestopping assemblies of designs that provide the scheduled fire ratings when tested in accordance with methods indicated.
  - 1. Listing in UL (FRD), FM (AG), or ITS (DIR) will be considered as constituting an acceptable test report.
  - 2. Valid evaluation report published by ICC Evaluation Service, Inc. (ICC-ES) at [www.icc-es.org](http://www.icc-es.org) will be considered as constituting an acceptable test report.
  - 3. Submission of actual test reports is required for assemblies for which none of the above substantiation exists.
- C. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
  - 1. One firestop manufacturer shall be used for the entirety of applications on this project unless otherwise approved by the Architect. The manufacturer will be required to furnish UL tested systems for all applications pertaining to the project, in addition to material safety data sheets and all other relevant information.
    - a. Materials of different manufacture than allowed by the tested and listed system shall not be intermixed in the same firestop system or opening.
    - b. Tested and listed firestop systems are to be used before an Engineering Judgment (EJ) or Equivalent Fire Resistance Rated Assembly (EFRRRA) is installed.
  - 2. A manufacturer's knowledgeable direct representative (manufacturer authorized; distributor, independent representative, manufacturer's representative, or agent) to be on-site during initial installation of firestop systems to train appropriate contractor personnel in proper selection and installation procedures. This will be done per manufacturer's written recommendations published in their literature and drawing details.
- D. Installer Qualifications: Company specializing in performing the work of this section and:
  - 1. Trained by manufacturer.
  - 2. Approved by Factory Mutual Research Corporation under FM 4991, or meeting any two of the following requirements:
    - a. UL Qualified Firestop Contractor
    - b. Verification of minimum three years documented experience installing work of this type.
    - c. Shown to have successfully completed not less than 5 comparable scale projects.
    - d. Verification of at least five satisfactorily completed projects of comparable size and type.
    - e. Firestop Contractors International Association Contractor Member in good standing.
    - f. Licensed by local authorities having jurisdiction (AHJ).

### 1.06 MOCK-UP

- A. Install one firestopping assembly representative of each fire rating design required on project.

1. Where one design may be used for different penetrating items or in different wall constructions, install one assembly for each different combination.
- B. Obtain approval of authorities having jurisdiction (AHJ) before proceeding.
- C. If accepted, mock-up will represent minimum standard for the Work.
- D. If accepted, mock-up may remain as part of the Work. Remove and replace mock-ups not accepted.

### **1.07 FIELD CONDITIONS**

- A. Comply with firestopping manufacturer's recommendations for temperature and conditions during and after installation; maintain minimum temperature before, during, and for three days after installation of materials.
- B. Provide ventilation in areas where solvent-cured materials are being installed.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Firestopping Manufacturers:
  1. Basis of Design: Specified Technologies, Inc: [www.stifirestop.com/#sle](http://www.stifirestop.com/#sle).
  2. 3M Fire Protection Products: [www.3m.com/firestop](http://www.3m.com/firestop).
  3. A/D Fire Protection Systems Inc: [www.adfire.com](http://www.adfire.com).
  4. Hilti, Inc: [www.us.hilti.com/#sle](http://www.us.hilti.com/#sle).
  5. Nelson FireStop Products: [www.nelsonfirestop.com](http://www.nelsonfirestop.com).
  6. Rectorseal; Bio FireShield and Metacaulk Systems: [www.rectorseal.com](http://www.rectorseal.com).
  7. Tremco Commercial Sealants & Waterproofing; TREMstop Acrylic: [www.tremcosealants.com/#sle](http://www.tremcosealants.com/#sle).
  8. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

### **2.02 REGULATORY REQUIREMENTS**

- A. Firestop System installation must meet requirements of ASTM E814, ASTM E2307, ASTM E1966 and UL 1479 or UL 2079 tested assemblies that provide a fire rating equal to that of construction being penetrated.
  1. Positive pressure in accordance with California Building Code (CBC) for ratings. Reference: CBC Section 714.3.1.2.
  2. Comply with UL Standard 2079 for top of wall assemblies.
  3. Conform to CBC Section 714.3.1.1 and 714.3.2.
- B. For those firestop applications that exist for which no UL tested system is available through any manufacturer, a manufacturer's engineering judgment derived from similar UL system designs or other tests will be submitted to local authorities having jurisdiction for their review and approval prior to installation. Engineer judgment drawings must follow requirements set forth by the International Firestop Council (September 7, 1994).

### **2.03 MATERIALS**

- A. Firestopping Materials: Any materials meeting requirements.
- B. Volatile Organic Compound (VOC) Content: Provide products having VOC content lower than that required by SCAQMD 1168.
- C. Mold and Mildew Resistance: Provide firestopping materials with mold and mildew resistance rating of zero(0) in accordance with ASTM G21.
- D. Primers, Sleeves, Forms, Insulation, Packing, Stuffing, and Accessories: Provide type of materials as required for tested firestopping assembly.
- E. Fire Ratings: Refer to drawings for required systems and ratings.

### **2.04 FIRESTOPPING ASSEMBLY REQUIREMENTS**

- A. Through Penetration Firestopping: Use system that has been tested according to ASTM E814 to have fire resistance F Rating equal to required fire rating of penetrated assembly.
  - 1. Temperature Rise: Provide systems that have been tested to show T Rating as indicated.
  - 2. Air Leakage: Provide systems that have been tested to show L Rating as indicated.
  - 3. Watertightness: Provide systems that have been tested to show W Rating as indicated.
  - 4. Listing by FM (AG), ITS (DIR), UL (DIR), or UL (FRD) in their certification directories will be considered evidence of successful testing.

### **2.05 FIRESTOPPING PENETRATIONS THROUGH GYPSUM BOARD WALLS**

- A. Penetrations By:
  - 1. Penetrations by Structural Struts, Cables or Threaded Rod:
    - a. 1 and 2 Hour Wall Construction: UL System W-L-7136; F Rating: 1 and 2 Hour; T Rating: 0 Hour; SpecSeal Series SSS Sealant, SpecSeal LCI Sealant, SpecSeal LC150 Sealant, or SpecSeal LE600 Sealant.
  - 2. Multiple Penetrations in Large Openings:
    - a. 1, 2, 3, and 4 Hour Wall Construction with EZ Path: UL System W-L-3377; F Rating: 1, 2, 3, and 4 Hour; T Rating: 0, 1/2, 3/4, 1, 1-1/2, and 2 Hour; Firestop Device: EZ PATH Series 22, 33 or 44+ Fire Rated Pathway, optional steel sleeve.
    - b. 1 and 2 Hour Wall Construction: UL System W-L-8026; F Rating: 1 and 2 Hour; T Rating: 0, 1/2, 1, 1-3/4 and 2 Hour; mineral wool packing with SpecSeal Series SSS Sealant or SpecSeal LCI Sealant.
    - c. 1 and 2 Hour Wall Construction: UL System W-L-1168; F Rating: 1 and 2 Hour; T Rating: 1/4, 3/4 and 1 Hour; SpecSeal LC150 Sealant, SpecSeal Series SSS Sealant or SpecSeal LCI Sealant.
    - d. 1 and 2 Hour Wall Construction: UL System W-L-3214; F Rating: 1 and 2 Hour; T Rating: 1/4, 3/4 and 1 Hour; SpecSeal LC150 Sealant, SpecSeal Series SSS Sealant or SpecSeal LCI Sealant.
    - e. 1 and 2 Hour Wall Construction: UL System W-L-8027; F Rating: 1 and 2 Hour; T Rating: 1/4 Hour; SpecSeal LCI Sealant.
  - 3. Uninsulated Metallic Pipe, Conduit, and Tubing:



- a. 1 and 2 Hour Wall Construction: UL System W-L-1049; F Rating: 1 and 2 Hour; T Rating: 0 Hour; SpecSeal Series SSS Sealant or SpecSeal LCI Sealant.
  - b. 1 and 2 Hour Wall Construction: UL System W-L-1222; F Rating: 1 and 2 Hour; T Rating: 1/4, 3/4 and 1 Hour; SpecSeal LCI Sealant.
  - c. 1 and 2 Hour Wall Construction: UL System W-L-1049; F Rating: 1 and 2 Hour; T Rating: 0 Hour; SpecSeal 100, 101, 102, 105, 120 or 129 Sealant, SpecSeal LCI Sealant.
4. Uninsulated Non-Metallic Pipe, Conduit, and Tubing:
- a. 1 and 2 Hour Wall Construction with pipe clamp ring: UL System W-L-2029; F Rating: 1 and 2 Hour; T Rating: 1, 1-1/2 and 2 Hour; SpecSeal Firestop Collar, SpecSeal LCC Collar.
  - b. 1 and 2 Hour Wall Construction: UL System W-L-2100; F Rating: 1 and 2 Hour; T Rating: 0, 1/4, 1 and 1-1/2 Hour; SpecSeal Series SSS Sealant or SpecSeal LCI Sealant.
  - c. 1 and 2 Hour Wall Construction: UL System W-L-2241; F Rating: 1 and 2 Hour; T Rating: 0, 1/4, 1, and 1-3/4 Hour; SpecSeal LCI Sealant.
  - d. 1 and 2 Hour Wall Construction: UL System W-L-2548; F Rating: 1 and 2 Hour; T Rating: 0 Hour; SpecSeal LCI Sealant or SpecSeal Series SSS Sealant.
5. Electrical Cables Not In Conduit:
- a. 1 and 2 Hour Wall Construction: UL System W-L-3169; F Rating: 1 and 2 Hour; T Rating: 1/4 and 3/4 Hour; SpecSeal LCI Sealant.
  - b. 1 and 2 Hour Wall Construction: UL System W-L-3210; F Rating: 1 and 2 Hour; T Rating: 3/4 Hour; mineral wool packing with SpecSeal Series SSS Sealant, SpecSeal LCI Sealant or SpecSeal Putty.
6. Cable Trays with Electrical Cables:
- a. 2 Hour Construction: UL System W-L-4011; Hilti CFS-BL Firestop Block.
  - b. 1 and 2 Hour Wall Construction: UL System W-L-4074; F Rating: 1 and 2 Hour; T Rating: 1/4, 1/2, 1 and 1-1/4 Hour; mineral wool packing with SpecSeal LCI Sealant.
  - c. 1 Hour Construction: UL System W-L-4011; Hilti CFS-BL Firestop Block.
7. Insulated Pipes:
- a. 1 and 2 Hour Wall Construction: UL System W-L-5014; F Rating: 1 and 2 Hour; T Rating: 1 Hour; SpecSeal Series SSS Sealant or SpecSeal LCI Sealant.
  - b. 1 and 2 Hour Wall Construction: UL System W-L-5054; F Rating: 1 and 2 Hour; T Rating: 3/4 and 1 Hour; SpecSeal Series SSS Sealant or SpecSeal LCI Sealant.
  - c. 1 Hour Construction: UL System W-L-5028; Hilti FS-ONE MAX Intumescent Firestop Sealant.
  - d. 1 Hour Construction: UL System W-L-5029; Hilti FS-ONE Intumescent Firestop Sealant.
  - e. 1 Hour Construction: UL System W-L-5096; Hilti FS-ONE Intumescent Firestop Sealant.
  - f. 1 Hour Construction: UL System W-L-5096; Hilti FS-ONE Intumescent Firestop Sealant, CP 606 Flexible Firestop Sealant, or CP 601S Elastomeric Firestop Sealant.
8. HVAC Ducts, Uninsulated:

- a. 1 and 2 Hour Wall Construction with up to 100 x 100 inch duct: UL System W-L-7025; F Rating: 1 and 2 Hour; T Rating: 1/2 Hour; Polyethylene backer rod or mineral wool packing with SpecSeal Series SSS Sealant, SpecSeal LCI Sealant, SpecSeal LC150 Sealant or SpecSeal LE 600 Sealant.
  - b. 1 and 2 Hour Wall Construction with up to 24 inch round duct: UL System W-L-7026; F Rating: 1 and 2 Hour; T Rating: 0 Hour; Polyethylene backer rod or mineral wool packing with SpecSeal Series SSS Sealant, SpecSeal LCI Sealant, SpecSeal LC150 Sealant or SpecSeal LE 600 Sealant.
  - c. 1 and 2 Hour Wall Construction with up to 24 x 24 inch duct: UL System W-L-7029; F Rating: 1 and 2 Hour; T Rating: 1/4 Hour; Polyethylene backer rod or mineral wool packing with SpecSeal Series SSS Sealant, SpecSeal LCI Sealant, SpecSeal LC150 Sealant or SpecSeal LE 600 Sealant.
9. HVAC Ducts, Insulated:
- a. 1 and 2 Hour Wall Construction with up to 20 inch round duct: UL System W-L-7179; F Rating: 1 and 2 Hour; T Rating: 3/4 Hour; SpecSeal Series SSS Sealant, or SpecSeal LCI Sealant.
  - b. 1 Hour Construction: UL System W-L-7156; Hilti FS-ONE MAX Intumescent Firestop Sealant.

## **2.06 FIRESTOPPING SYSTEMS**

- A. Firestopping: Any material meeting requirements.
  - 1. Fire Ratings: Use system that is listed by FM (AG), ITS (DIR), or UL (FRD) and tested in accordance with ASTM E814, ASTM E119, or UL 1479 with F Rating equal to fire rating of penetrated assembly and minimum T Rating Equal to F Rating and in compliance with other specified requirements.

## **PART 3 EXECUTION**

### **3.01 SEQUENCING AND SCHEDULING**

- A. Project coordination is essential to inform and educate all the parties involved with the firestopping process of their role and how they can affect firestopping on the project. A pre-construction meeting shall be scheduled and required for all parties involved prior to the start of construction.
- B. Do not cover up firestopping installations until District's inspection agency or the Authorities Having Jurisdiction have examined each installation.

### **3.02 EXAMINATION**

- A. Verify openings are ready to receive the work of this section.
- B. Pre-Installation Inspection: Inspect all fire and smoke barriers for penetrations of any type; mark or otherwise identify all penetrations indicating action required: 1) repair; 2) firestopping; or 3) smokestopping.
  - 1. Conduct inspection prior to covering up or enclosing walls or ceilings.
  - 2. Conduct inspection jointly with authorized representative of authority having jurisdiction.

- C. If the configuration of a particular penetration does not conform to the configuration necessary for the required firestopping assembly:
  - 1. Notify the installer of the penetration for modification of the configuration to suit the assembly.
  - 2. Do not use the firestopping assembly in other configurations except as specifically stated in the test report or as approved by the authority having jurisdiction.

### **3.03 PREPARATION**

- A. Clean substrate surfaces of dirt, dust, grease, oil, loose material, or other materials that could adversely affect bond of firestopping material.
- B. Remove incompatible materials that could adversely affect bond.
- C. Install backing materials to prevent liquid material from leakage.
- D. Priming:
  - 1. Prime substrates where recommended by firestopping manufacturer using that manufacturer's recommended products and methods.
  - 2. Confine primers to areas of bond.
  - 3. Do not allow spillage and migration onto exposed surfaces.
- E. Masking Tape:
  - 1. Use masking tape to prevent firestopping from contacting adjoining surfaces that will remain exposed upon completion of Work.
  - 2. Remove tape as soon as it is possible to do so without disturbing the firestopping seal with substrates.
- F. Verify that system components are clean, dry, and ready for installation.
- G. Verify that field dimensions are as shown on the Drawings and as recommended by the manufacturer.
- H. Prepare penetrations in accordance with the material manufacturer's instructions.
- I. Ventilation: Ventilate per firestopping manufacturers' instructions or Material Safety Data Sheet (MSDS).

### **3.04 INSTALLATION**

- A. Install materials in manner described in fire test report and in accordance with manufacturer's instructions, completely closing openings.
  - 1. Provide all accessory materials.
- B. Do not cover installed firestopping until inspected by District's Independent Testing Agency.
- C. Penetration Firestops:
  - 1. Coordinate with other trades to assure that all pipes, conduit, cable, and other items, which penetrate fire rated construction, have been permanently installed prior to installation of firestop assemblies.
  - 2. Schedule the work to assure that partitions and all other construction that conceals penetrations are not erected prior to the installation of firestop and smoke seals.

3. Install forming/damming materials and other accessories in accordance with manufacturers written instructions.
4. Install fill materials for through-penetration firestop systems by proven techniques to produce the following results:
  - a. Completely fill voids and cavities formed by openings, forming materials, accessories, and penetrating items.
  - b. Install materials so they contact and adhere to substrates formed by openings and penetrating items.
5. For fill materials that will remain exposed after completing Work, finish to produce smooth, uniform surfaces
- D. Remove combustible forming materials, unless they are a required component of the tested assembly.
- E. Do not cover installed firestopping until inspected by authorities having jurisdiction.
- F. Install labeling required by code; 07 05 53 - Fire and Smoke Assembly Identification.
  1. Near fire and smoke barriers, mark each exposed penetration with label identifying it as a fire-stopped or smoke-stopped assembly.

### **3.05 FIELD QUALITY CONTROL**

- A. Independent Testing Agency: Inspection agency employed and paid by District, will examine penetration firestopping in accordance with ASTM E2174, and ASTM E2393.
- B. The inspector shall advise the Contractor of any deficiencies noted within one (1) working day.
- C. Repair or replace penetration firestopping and joints at locations where inspection results indicate firestopping or joints do not meet specified requirements.
- D. Do not proceed to enclose firestopping with other construction until inspection agency has verified that the firestop installation complies with the requirements.
- E. Submit report of inspection to the Construction Manager and Architect.

### **3.06 CLEANING**

- A. Hazardous disposal of firestop materials shall be strictly observed as noted on the individual MSDS.
- B. Clean adjacent surfaces of firestopping materials.
  1. Clean up excess material adjacent to penetrations promptly; use methods and materials approved by the manufacturers of the penetration seals and of surfaces to be cleaned.

### **3.07 PROTECTION**

- A. Protect adjacent surfaces from damage by material installation.
- B. Protect firestopping during and after curing period from contact with contaminating substances.
- C. Protect installed Work from damage from construction operations using substantial barriers as necessary.

D. Repair damaged materials in accordance with manufacturer's instructions.

**END OF SECTION**

**SECTION 07 92 00**  
**JOINT SEALANTS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Nonsag gunnable joint sealants.
- B. Self-leveling pourable joint sealants.
- C. Joint backings and accessories.
- D. District-provided field quality control.

**1.02 RELATED REQUIREMENTS**

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions: Additional requirements for sealants and primers.
- B. Section 07 13 00 - Sheet Waterproofing: Sealing cracks and joints in waterproofing substrate surfaces using materials specified in this section.
- C. Section 07 25 00 - Weather Barriers: Sealants required in conjunction with air barriers and vapor retarders.
- D. Section 07 84 00 - Firestopping: Firestopping sealants.
- E. Section 07 95 13 - Expansion Joint Cover Assemblies: Sealants forming part of expansion joint cover assemblies.
- F. Section 08 71 00 - Door Hardware: Setting exterior door thresholds in sealant.
- G. Section 09 21 16 - Gypsum Board Assemblies: Sealing acoustical and sound-rated walls and ceilings.
- H. Section 09 30 00 - Tiling: Sealant between tile and plumbing fixtures and at junctions with other materials and changes in plane.
- I. Division 23 - Heating, Ventilation and Air-Conditioning (HVAC): Duct sealants.

**1.03 REFERENCE STANDARDS**

- A. ASTM C661 - Standard Test Method for Indentation Hardness of Elastomeric-Type Sealants by Means of a Durometer; 2015.
- B. ASTM C794 - Standard Test Method for Adhesion-In-Peel of Elastomeric Joint Sealants; 2015a.
- C. ASTM C834 - Standard Specification for Latex Sealants; 2014.
- D. ASTM C919 - Standard Practice for Use of Sealants in Acoustical Applications; 2012.
- E. ASTM C920 - Standard Specification for Elastomeric Joint Sealants; 2014a.
- F. ASTM C1087 - Standard Test Method for Determining Compatibility of Liquid-Applied Sealants with Accessories Used in Structural Glazing Systems; 2016.
- G. ASTM C1193 - Standard Guide for Use of Joint Sealants; 2016.
- H. ASTM C1311 - Standard Specification for Solvent Release Sealants; 2014.
- I. ASTM C1521 - Standard Practice for Evaluating Adhesion of Installed Weatherproofing Sealant Joints; 2013.

- J. ASTM D2240 - Standard Test Method for Rubber Property--Durometer Hardness; 2015.
- K. SWRI (VAL) - SWR Institute Validated Products Directory; Current Listings at [www.swrionline.org](http://www.swrionline.org).

#### **1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data for Sealants: Submit manufacturer's technical data sheets for each product to be used, that includes the following.
  - 1. Physical characteristics, including movement capability, VOC content, hardness, cure time, and color availability.
  - 2. List of backing materials approved for use with the specific product.
  - 3. Substrates that product is known to satisfactorily adhere to and with which it is compatible.
  - 4. Substrates the product should not be used on.
  - 5. Substrates for which use of primer is required.
  - 6. Installation instructions, including precautions, limitations, and recommended backing materials and tools.
  - 7. Sample product warranty.
  - 8. Certification by manufacturer indicating that product complies with specification requirements.
  - 9. SWRI Validation: Provide currently available sealant product validations as listed by SWRI (VAL) for specified sealants.
- C. Product Data for Accessory Products: Submit manufacturer's technical data sheet for each product to be used, including physical characteristics, installation instructions, and recommended tools.
- D. Color Cards for Selection: Where sealant color is not specified, submit manufacturer's color cards showing standard colors available for selection.
- E. Samples for Verification: Where custom sealant color is specified, obtain directions from Architect and submit at least two physical samples for verification of color of each required sealant.
- F. Preconstruction Laboratory Test Reports: Submit at least four weeks prior to start of installation.
- G. Installation Plan: Submit at least four weeks prior to start of installation.
- H. Preinstallation Field Adhesion Test Plan: Submit at least two weeks prior to start of installation.
- I. Field Quality Control Plan: Submit at least two weeks prior to start of installation.
- J. Preinstallation Field Adhesion Test Reports: Submit filled out Preinstallation Field Adhesion Test Reports log within 10 days after completion of tests; include bagged test samples and photographic records.
- K. Installation Log: Submit filled out log for each length or instance of sealant installed.

- L. Field Quality Control Log: Submit filled out log for each length or instance of sealant installed, within 10 days after completion of inspections/tests; include bagged test samples and photographic records, if any.

### **1.05 QUALITY ASSURANCE**

- A. Maintain one copy of each referenced document covering installation requirements on site.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- C. Installer Qualifications: Company specializing in performing the work of this section and with at least three years of documented experience.
- D. Preconstruction Laboratory Testing: Arrange for sealant manufacturer(s) to test each combination of sealant, substrate, backing, and accessories.
  - 1. Adhesion Testing: In accordance with ASTM C794.
  - 2. Compatibility Testing: In accordance with ASTM C1087.
  - 3. Allow sufficient time for testing to avoid delaying the work.
  - 4. Deliver to manufacturer sufficient samples for testing.
  - 5. Report manufacturer's recommended corrective measures, if any, including primers or techniques not indicated in product data submittals.
  - 6. Testing is not required if sealant manufacturer provides data showing previous testing, not older than 24 months, that shows satisfactory adhesion, lack of staining, and compatibility.
- E. Installation Plan: Include schedule of sealed joints, including the following.
  - 1. Joint width indicated in contract documents.
  - 2. Joint depth indicated in contract documents; to face of backing material at centerline of joint.
  - 3. Method to be used to protect adjacent surfaces from sealant droppings and smears, with acknowledgement that some surfaces cannot be cleaned to like-new condition and therefore prevention is imperative.
  - 4. Approximate date of installation, for evaluation of thermal movement influence.
  - 5. Installation Log Form: Include the following data fields, with known information filled out.
    - a. Unique identification of each length or instance of sealant installed.
    - b. Location on project.
    - c. Substrates.
    - d. Sealant used.
    - e. Stated movement capability of sealant.
    - f. Primer to be used, or indicate as "No primer" used.
    - g. Size and actual backing material used.
    - h. Date of installation.
    - i. Name of installer.
    - j. Actual joint width; provide space to indicate maximum and minimum width.



- k. Actual joint depth to face of backing material at centerline of joint.
  - l. Air temperature.
- F. Preinstallation Field Adhesion Test Plan: Include destructive field adhesion testing of one sample of each combination of sealant type and substrate, except interior acrylic latex sealants, and include the following for each tested sample.
  - 1. Identification of testing agency.
  - 2. Name(s) of sealant manufacturers' field representatives who will be observing
  - 3. Preinstallation Field Adhesion Test Log Form: Include the following data fields, with known information filled out.
    - a. Substrate; if more than one type of substrate is involved in a single joint, provide two entries on form, for testing each sealant substrate side separately.
    - b. Test date.
    - c. Location on project.
    - d. Sealant used.
    - e. Stated movement capability of sealant.
    - f. Test method used.
    - g. Date of installation of field sample to be tested.
    - h. Date of test.
    - i. Copy of test method documents.
    - j. Age of sealant upon date of testing.
    - k. Test results, modeled after the sample form in the test method document.
    - l. Indicate use of photographic record of test.
- G. District will employ an independent testing agency to perform the field quality control inspection and testing as referenced in PART 3 of this section and as follows, to prepare and submit the field quality control plan and log, and to provide recommendations of remedies in the case of failure.
  - 1. Contractor shall cooperate with testing agency and repair failures discovered and destructive test location damage.
- H. Field Quality Control Plan:
  - 1. Visual inspection of entire length of sealant joints.
  - 2. Non-destructive field adhesion testing of sealant joints, except interior acrylic latex sealants.
    - a. For each different sealant and substrate combination, allow for one test every 12 inches in the first 10 linear feet of joint and one test every 24 inches thereafter.
    - b. If any failures occur in the first 10 linear feet, continue testing at 12 inch intervals at no extra cost to District.
  - 3. Destructive field adhesion testing of sealant joints, except interior acrylic latex sealant.
    - a. For each different sealant and substrate combination, allow for one test every 100 feet in the first 1000 linear feet, and one test per 1000 linear feet thereafter, or once per floor on each elevation.
    - b. If any failures occur in the first 1000 linear feet, continue testing at frequency of one test per 500 linear feet at no extra cost to District.

4. Field Quality Control Log Form: Show same data fields as on Preinstallation Field Adhesion Test Log, with known information filled out and lines for multiple tests per sealant/substrate combinations; include visual inspection and specified field testing; allow for possibility that more tests than minimum specified may be necessary.
- I. Field Adhesion Test Procedures:
    1. Allow sealants to fully cure as recommended by manufacturer before testing.
    2. Have a copy of the test method document available during tests.
    3. Take photographs or make video records of each test, with joint identification provided in the photos/videos; for example, provide small erasable whiteboard positioned next to joint.
    4. Record the type of failure that occurred, other information required by test method, and the information required on the Field Quality Control Log.
    5. When performing destructive tests, also inspect the opened joint for proper installation characteristics recommended by manufacturer, and report any deficiencies.
    6. Deliver the samples removed during destructive tests in separate sealed plastic bags, identified with project, location, test date, and test results, to District.
    7. If any combination of sealant type and substrate does not show evidence of minimum adhesion or shows cohesion failure before minimum adhesion, report results to Architect.
  - J. Non-Destructive Field Adhesion Test: Test for adhesion in accordance with ASTM C1521, using Nondestructive Spot Method.
    1. Record results on Field Quality Control Log.
    2. Repair failed portions of joints.
  - K. Destructive Field Adhesion Test: Test for adhesion in accordance with ASTM C1521, using Destructive Tail Procedure.
    1. Sample: At least 18 inch long.
    2. Minimum Elongation Without Adhesive Failure: Consider the tail at rest, not under any elongation stress; multiply the stated movement capability of the sealant in percent by two; then multiply 1 inch by that percentage; if adhesion failure occurs before the "1 inch mark" is that distance from the substrate, the test has failed.
    3. If either adhesive or cohesive failure occurs prior to minimum elongation, take necessary measures to correct conditions and re-test; record each modification to products or installation procedures.
    4. Record results on Field Quality Control Log.
    5. Repair failed portions of joints.
  - L. Field Adhesion Tests of Joints: Test for adhesion using most appropriate method in accordance with ASTM C1521, or other applicable method as recommended by manufacturer.

## **1.06 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. Correct defective work within a five year period after Date of Substantial Completion.

- C. Warranty: Include coverage for installed sealants and accessories that fail to achieve watertight seal , exhibit loss of adhesion or cohesion, or do not cure.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Non-Sag Sealants: Permits application in joints on vertical surfaces without sagging or slumping.
1. Adhesives Technology Corporation: [www.atcepoxy.com](http://www.atcepoxy.com).
  2. BASF Construction Chemicals-Building Systems: [www.buildingsystems.basf.com](http://www.buildingsystems.basf.com).
  3. Bostik Inc: [www.bostik-us.com](http://www.bostik-us.com).
  4. Dow Corning Corporation: [www.dowcorning.com/construction/sle](http://www.dowcorning.com/construction/sle).
  5. Fortifiber Building Systems Group: [www.fortifiber.com/sle](http://www.fortifiber.com/sle).
  6. Hilti, Inc: [www.us.hilti.com/#sle](http://www.us.hilti.com/#sle).
  7. Momentive Performance Materials, Inc (formerly GE Silicones): [www.momentive.com/sle](http://www.momentive.com/sle).
  8. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
  9. The QUIKRETE Companies: [www.quikrete.com](http://www.quikrete.com).
  10. Sherwin-Williams Company: [www.sherwin-williams.com](http://www.sherwin-williams.com).
  11. Sika Corporation: [www.usa-sika.com](http://www.usa-sika.com).
  12. Specified Technologies Inc: [www.stifirestop.com/#sle](http://www.stifirestop.com/#sle).
  13. Tremco Commercial Sealants & Waterproofing: [www.tremcosealants.com/#sle](http://www.tremcosealants.com/#sle).
  14. W.R. Meadows, Inc: [www.wrmeadows.com/sle](http://www.wrmeadows.com/sle).
  15. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Self-Leveling Sealants: Pourable or self-leveling sealant that has sufficient flow to form a smooth, level surface when applied in a horizontal joint.
1. Adhesives Technology Corporation: [www.atcepoxy.com](http://www.atcepoxy.com).
  2. BASF Construction Chemicals-Building Systems: [www.buildingsystems.basf.com](http://www.buildingsystems.basf.com).
  3. Bostik Inc: [www.bostik-us.com](http://www.bostik-us.com).
  4. Dayton Superior Corporation: [www.daytonsuperior.com](http://www.daytonsuperior.com).
  5. Dow Corning Corporation: [www.dowcorning.com/construction/sle](http://www.dowcorning.com/construction/sle).
  6. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
  7. The QUIKRETE Companies: [www.quikrete.com](http://www.quikrete.com).
  8. Sherwin-Williams Company: [www.sherwin-williams.com](http://www.sherwin-williams.com).
  9. Sika Corporation: [www.usa-sika.com](http://www.usa-sika.com).
  10. Tremco Commercial Sealants & Waterproofing: [www.tremcosealants.com/#sle](http://www.tremcosealants.com/#sle).
  11. W.R. Meadows, Inc: [www.wrmeadows.com/sle](http://www.wrmeadows.com/sle).
  12. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## 2.02 JOINT SEALANT APPLICATIONS

### A. Scope:

1. Exterior Joints: Seal open joints, whether or not the joint is indicated on drawings, unless specifically indicated not to be sealed. Exterior joints to be sealed include, but are not limited to, the following items.
  - a. Wall expansion and control joints.
  - b. Joints between door, window, and other frames and adjacent construction.
  - c. Joints between different exposed materials.
  - d. Openings below ledge angles in masonry.
  - e. Other joints indicated below.
2. Interior Joints: Do not seal interior joints unless specifically indicated to be sealed. Interior joints to be sealed include, but are not limited to, the following items.
  - a. Joints between door, window, and other frames and adjacent construction.
  - b. In sound-rated wall and ceiling assemblies, gaps at electrical outlets, wiring devices, piping, and other openings; between wall/ceiling and other construction; and other flanking sound paths.
    - 1) Exception: Such gaps and openings in gypsum board finished stud walls and suspended ceilings.
    - 2) Exception: Through-penetrations in sound-rated assemblies that are also fire-rated assemblies.
  - c. Other joints indicated below.
3. Do not seal the following types of joints.
  - a. Intentional weepholes in masonry.
  - b. Joints indicated to be treated with manufactured expansion joint cover or some other type of sealing device.
  - c. Joints where sealant is specified to be provided by manufacturer of product to be sealed.
  - d. Joints where installation of sealant is specified in another section.
  - e. Joints between suspended panel ceilings/grid and walls.

### B. Type EP-1 - Exterior Joints: Use non-sag non-staining silicone sealant, unless otherwise indicated.

1. Type SM-1 - Lap Joints in Sheet Metal Fabrications: Butyl rubber, non-curing.
2. Type SM-1 - Lap Joints between Manufactured Metal Panels: Butyl rubber, non-curing.
3. Type CP-1 - Control and Expansion Joints in Concrete Paving: Self-leveling polyurethane "traffic-grade" sealant.

### C. Type IP-1 - Interior Joints: Use non-sag polyurethane sealant, unless otherwise indicated.

1. Type IA-1 - Wall and Ceiling Joints in Non-Wet Areas: Acrylic emulsion latex sealant.
2. Type WP-1 - Wall and Ceiling Joints in Wet Areas: Non-sag polyurethane sealant for continuous liquid immersion.
3. Type WP-1 - Floor Joints in Wet Areas: Non-sag polyurethane "non-traffic-grade" sealant suitable for continuous liquid immersion.

4. Wall, Ceiling, and Floor Joints Where Tamper-Resistance is Required: Non-sag tamper-resistant silyl-terminated polyurethane sealant.
  5. Type FS-1 - Joints between Fixtures in Wet Areas and Floors, Walls, and Ceilings: Mildew-resistant silicone sealant; white.
  6. Type IA-1 - In Sound-Rated Assemblies: Acrylic emulsion latex sealant.
  7. Type EPX-1 - Narrow Control Joints in Interior Concrete Slabs: Self-leveling epoxy sealant.
  8. Type WFP-1 - Other Floor Joints: Self-leveling polyurethane "traffic-grade" sealant.
- D. Interior Wet Areas: restrooms and kitchens; fixtures in wet areas include plumbing fixtures, countertops, cabinets, and other similar items.
  - E. Sound-Rated Assemblies: Walls and ceilings identified as "STC-rated", "sound-rated", or "acoustical".
  - F. Areas Where Tamper-Resistance is Required: As indicated on drawings.

### **2.03 JOINT SEALANTS - GENERAL**

- A. Sealants and Primers: Provide products with levels of volatile organic compound (VOC) content as indicated in Section 01 61 16.
- B. Colors: As indicated on the drawings. Match adjacent surface.

### **2.04 NONSAG JOINT SEALANTS**

- A. Type NS-1 - Non-Staining Silicone Sealant: ASTM C920, Grade NS, Uses M and A; not expected to withstand continuous water immersion or traffic.
  1. Movement Capability: Plus and minus 50 percent, minimum.
  2. Hardness Range: 15 to 35, Shore A, when tested in accordance with ASTM C661.
  3. Color: To be selected by Architect from manufacturer's full range.
  4. Cure Type: Single-component, neutral moisture curing.
  5. Service Temperature Range: Minus 65 to 180 degrees F.
  6. Manufacturers:
    - a. Dow Chemical Company; 790 Silicone Building Sealant: [consumer.dow.com/en-us/industry/ind-building-construction.html/#sle](http://consumer.dow.com/en-us/industry/ind-building-construction.html/#sle).
    - b. Dow Chemical Company; 791 Silicone Weatherproofing Sealant: [consumer.dow.com/en-us/industry/ind-building-construction.html/#sle](http://consumer.dow.com/en-us/industry/ind-building-construction.html/#sle).
    - c. Dow Chemical Company; 795 Silicone Building Sealant: [consumer.dow.com/en-us/industry/ind-building-construction.html/#sle](http://consumer.dow.com/en-us/industry/ind-building-construction.html/#sle).
    - d. Momentive Performance Materials, Inc (formerly GE Silicones): [www.momentive.com/sle](http://www.momentive.com/sle).
    - e. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
    - f. Sika Corporation; Sikasil WS-290: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).
    - g. Sika Corporation; Sikasil WS-295: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).
    - h. Tremco Commercial Sealants & Waterproofing; Spectrem 2: [www.tremcosealants.com/#sle](http://www.tremcosealants.com/#sle).

- i. Tremco Commercial Sealants & Waterproofing; Spectrem 3: [www.tremcosealants.com/#sle](http://www.tremcosealants.com/#sle).
  - j. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Silicone Sealant: ASTM C920, Grade NS, Uses M and A; not expected to withstand continuous water immersion or traffic.
  - 1. Movement Capability: Plus and minus 25 percent, minimum.
  - 2. Color: To be selected by Architect from manufacturer's full range.
  - 3. Cure Type: Single-component, neutral moisture curing
  - 4. Service Temperature Range: Minus 65 to 180 degrees F.
  - 5. Manufacturers:
    - a. Fortifiber Building Systems Group; Moistop Sealant: [www.fortifiber.com/#sle](http://www.fortifiber.com/#sle).
    - b. Dow Chemical Company; 758 Silicone Weather Barrier Sealant: [consumer.dow.com/en-us/industry/ind-building-construction.html/#sle](http://consumer.dow.com/en-us/industry/ind-building-construction.html/#sle).
    - c. Momentive Performance Materials, Inc (formerly GE Silicones): [www.momentive.com/sle](http://www.momentive.com/sle).
    - d. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
    - e. Sherwin-Williams Company; Silicone Rubber All Purpose Sealant: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
    - f. Sika Corporation; Sikasil GP: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).
    - g. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- C. Type FS-1 - Mildew-Resistant Silicone Sealant: ASTM C920, Grade NS, Uses M and A; single component, mildew resistant; not expected to withstand continuous water immersion or traffic.
  - 1. Color: White.
  - 2. Manufacturers:
    - a. BASF Construction Chemicals-Building Systems; OmniPlus, by Sonneborn Building Products Div.: [www.buildingsystems.basf.com](http://www.buildingsystems.basf.com).
    - b. Dow Corning Corporation; 786 Silicone Sealant: [www.dowcorning.com](http://www.dowcorning.com).
    - c. Momentive Performance Materials, Inc (GE Silicones products); Silpruf SCS 1700 Sanitary: [www.momentive.com](http://www.momentive.com).
    - d. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
    - e. Sika Corporation; Sikasil GP: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).
    - f. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- D. Type ST-1 - Silyl-Terminated Polyether (STPE) and Polyurethane (STPU) Sealant: ASTM C920, Grade NS, Uses M and A; single component; not expected to withstand continuous water immersion or traffic.
  - 1. Movement Capability: Plus and minus 35 percent, minimum.
  - 2. Hardness Range: 20 to 40, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
  - 5. Manufacturers:

- a. Sherwin-Williams Company; Stampede 100 Low-Modulus Hybrid Urethane Sealant: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
  - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- E. Tamper-Resistant, Silyl-Terminated Polyurethane (STPU) Sealant: ASTM C920, Grade NS, Uses M and A; single component; not expected to withstand continuous water immersion or traffic.
  - 1. Movement Capability: Plus and minus 12-1/2 percent, minimum
  - 2. Hardness Range: 25 to 30, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
  - 5. Manufacturers:
    - a. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
    - b. Sika Corporation; SikaHyflex-150 LM: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).
    - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- F. Type PS-1 - Polyurethane Sealant: ASTM C920, Grade NS, Uses M and A; single or multi-component; not expected to withstand continuous water immersion or traffic.
  - 1. Movement Capability: Plus and minus 25 percent, minimum.
  - 2. Hardness Range: 20 to 35, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
  - 5. Manufacturers:
    - a. The QUIKRETE Companies; QUIKRETE® Polyurethane Non-Sag Sealant: [www.quikrete.com/#sle](http://www.quikrete.com/#sle).
    - b. Sherwin-Williams Company; Stampede-1/-TX Polyurethane Sealant: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
    - c. Sika Corporation; Sikaflex-1a: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).
    - d. Sika Corporation; Sikaflex-15 LM: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).
    - e. Tremco Commercial Sealants & Waterproofing; Dymeric 240 FC: [www.tremcosealants.com/#sle](http://www.tremcosealants.com/#sle).
    - f. W. R. Meadows, Inc; POURTHANE NS: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - g. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- G. Type WP-1 - Polyurethane Sealant for Continuous Water Immersion: ASTM C920, Grade NS, Uses M and A; single or multi-component; explicitly approved by manufacturer for continuous water immersion; suitable for traffic exposure when recessed below traffic surface .
  - 1. Movement Capability: Plus and minus 35 percent, minimum.
  - 2. Hardness Range: 20 to 35, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
  - 5. Manufacturers:
    - a. Sika Corporation; Sikaflex-1a: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).

- b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- H. Non-Sag "Traffic-Grade" Polyurethane Sealant: ASTM C920, Grade NS, Uses M and A; single or multi-component; explicitly approved by manufacturer for continuous water immersion and traffic without the necessity to recess sealant below traffic surface.
  - 1. Movement Capability: Plus and minus 25 percent, minimum.
  - 2. Hardness Range: 40 to 50, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
- I. Tamper-Resistant Polyurethane Sealant: ASTM C920, Grade NS, Uses M, G, and A; single or multi-component; not expected to withstand continuous water immersion or traffic.
  - 1. Movement Capability: Plus and minus 12-1/2 percent, minimum.
  - 2. Hardness Range: 50 to 60, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
- J. Epoxy Sealant: ASTM C920, Grade NS, Uses M and A; single or multi-component; not expected to withstand continuous water immersion or traffic.
  - 1. Hardness Range: 65 to 75, Shore A, when tested in accordance with ASTM C661.
  - 2. Color: To be selected by Architect from manufacturer's full range.
  - 3. Service Temperature Range: Minus 40 to 180 degrees F.
  - 4. Manufacturers:
    - a. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
    - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- K. Polysulfide Sealant: ASTM C920, Grade NS, Uses M and A; single or multi-component; not expected to withstand continuous water immersion or traffic.
  - 1. Movement Capability: Plus and minus 25 percent, minimum.
  - 2. Hardness Range: 20 to 35, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Manufacturers:
    - a. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
    - b. W.R. Meadows, Inc; Deck-O-Seal Gun Grade: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- L. Polysulfide Sealant for Continuous Water Immersion: Polysulfide; ASTM C920, Grade NS, Uses M and A; single or multi-component; explicitly approved by manufacturer for continuous water immersion; not expected to withstand traffic.
  - 1. Movement Capability: Plus and minus 25 percent, minimum.
  - 2. Hardness Range: 20 to 35, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
  - 5. Manufacturers:



- a. Pecora Corporation; Synthacalk GC2+: [www.pecora.com/#sle](http://www.pecora.com/#sle).
  - b. W.R. Meadows, Inc; Deck-O-Seal Gun Grade: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
  - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- M. Acrylic-Urethane Sealant: Water-based; ASTM C920, Grade NS, Uses M and A; single component; paintable; not expected to withstand continuous water immersion or traffic.
- 1. Movement Capability: Plus and minus 12-1/2 percent, minimum.
  - 2. Hardness Range: 20 to 40, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: White.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
  - 5. Manufacturers:
    - a. Sherwin-Williams Company; Shermax Urethanized Elastomeric Sealant: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
    - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- N. Type 1A-1 - Acrylic Emulsion Latex: Water-based; ASTM C834, single component, non-staining, non-bleeding, non-sagging; not intended for exterior use.
- 1. Color: To be selected by Architect from manufacturer's full range.
  - 2. Grade: ASTM C834; Grade - Minus 18 Degrees C.
  - 3. Manufacturers:
    - a. Hilti, Inc; CP 506 Smoke and Acoustical Sealant: [www.us.hilti.com/#sle](http://www.us.hilti.com/#sle).
    - b. Hilti, Inc; CP 572 Smoke and Acoustical Spray Sealant: [www.us.hilti.com/#sle](http://www.us.hilti.com/#sle).
    - c. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
    - d. Sherwin-Williams Company; 950A Siliconized Acrylic Latex Caulk: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
    - e. Specified Technologies Inc; Smoke N' Sound Acoustical Sealant: [www.stifirestop.com/#sle](http://www.stifirestop.com/#sle).
    - f. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- O. Non-Curing Butyl Sealant: Solvent-based; ASTM C1311; single component, non-sag, non-skinning, non-hardening, non-bleeding; vapor-impermeable; intended for fully concealed applications.

## 2.05 SELF-LEVELING SEALANTS

- A. Self-Leveling Silicone Sealant: ASTM C920, Grade P, Uses M and A; single or multicomponent, explicitly approved by manufacturer for traffic exposure when recessed below traffic surface; not expected to withstand continuous water immersion.
- 1. Movement Capability: Plus 100 percent, minus 50 percent, minimum.
  - 2. Hardness Range: 0 to 15, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
  - 5. Manufacturers:
    - a. Sika Corporation; Sikasil 728SL: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).

- b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Type P-1 - Self-Leveling Polyurethane Sealant: ASTM C920, Grade P, Uses M and A; single or multi-component; explicitly approved by manufacturer for traffic exposure; not expected to withstand continuous water immersion .
  - 1. Movement Capability: Plus and minus 25 percent, minimum.
  - 2. Hardness Range: 35 to 55, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
  - 5. Manufacturers:
    - a. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
    - b. The QUIKRETE Companies; QUIKRETE® Polyurethane Self-Leveling Sealant: [www.quikrete.com/#sle](http://www.quikrete.com/#sle).
    - c. Sherwin-Williams Company; Stampede 1SL Polyurethane Sealant: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
    - d. Sika Corporation; Sikaflex-1c SL: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).
    - e. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- C. Type WFP-1 - Self-Leveling Polyurethane Sealant for Continuous Water Immersion: Polyurethane; ASTM C920, Grade P, Uses M and A; single or multi-component; explicitly approved by manufacturer for traffic exposure and continuous water immersion.
  - 1. Movement Capability: Plus and minus 25 percent, minimum.
  - 2. Hardness Range: 35 to 55, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's full range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
  - 5. Manufacturers:
    - a. Sika Corporation; Sikaflex-1c SL: [www.usa-sika.com/#sle](http://www.usa-sika.com/#sle).
    - b. W. R. MEADOWS, Inc; POURTHANE SL: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- D. Self-Leveling Silyl-Terminated Polyether/Polyurethane (STPE/STPU) Sealant: ASTM C920, Grade P, Uses M and A; single component; explicitly approved by manufacturer for traffic exposure; not expected to withstand continuous water immersion.
  - 1. Movement Capability: Plus and minus 35 percent.
  - 2. Hardness Range: 30 to 55, Shore A, when tested in accordance with ASTM C661.
  - 3. Color: To be selected by Architect from manufacturer's standard range.
  - 4. Service Temperature Range: Minus 40 to 180 degrees F.
  - 5. Manufacturers:
    - a. Pecora Corporation: [www.pecora.com](http://www.pecora.com).
    - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- E. Self-Leveling Polysulfide Sealant: ASTM C920, Grade P, Uses M and A; multicomponent; explicitly approved by manufacturer for traffic exposure and continuous water immersion.
  - 1. Movement Capability: Plus and minus 25 percent.

2. Hardness Range: 30 to 55, Shore A, when tested in accordance with ASTM C661.
  3. Color: To be selected by Architect from manufacturer's full range.
  4. Service Temperature Range: Minus 40 to 180 degrees F.
  5. Manufacturers:
    - a. W.R. Meadows, Inc; Deck-O-Seal (pourable): [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- F. Rigid Self-Leveling Polyurethane Joint Filler: Two part, low viscosity, fast setting; intended for cracks and control joints not subject to significant movement.
1. Hardness Range: Greater than 100, Shore A, and 50 to 80, Shore D, when tested in accordance with ASTM C661.
  2. Manufacturers:
    - a. ARDEX Engineered Cements; ARDEX ARDIFIX: [www.ardexamericas.com/#sle](http://www.ardexamericas.com/#sle).
    - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- G. Type EPX-1 - Semi-Rigid Self-Leveling Epoxy Joint Filler: Epoxy or epoxy/polyurethane copolymer; intended for filling cracks and control joints not subject to significant movement; rigid enough to support concrete edges under traffic.
1. Composition: Multi-component, 100 percent solids by weight.
  2. Durometer Hardness: Minimum of 85 for Type A or 35 for Type D, after seven days when tested in accordance with ASTM D2240.
  3. Color: To be selected by Architect from manufacturer's standard colors.
  4. Joint Width, Minimum: 1/8 inch.
  5. Joint Depth: Provide product suitable for joints from 1/8 inch to 2 inches in depth including space for backer rod.
  6. Manufacturers:
    - a. Dayton Superior Corporation; Pro-Poxy P606: [www.daytonsuperior.com/#sle](http://www.daytonsuperior.com/#sle).
    - b. Nox-Crete; DynaFlex 502: [www.nox-crete.com/#sle](http://www.nox-crete.com/#sle).
    - c. W.R. Meadows, Inc; Rezi-Weld Flex: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
    - d. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- H. Semi-Rigid Self-Leveling Polyurea Joint Filler: Two-component, 100 percent solids; intended for filling cracks and control joints not subject to significant movement; rigid enough to support concrete edges under traffic.
1. Durometer Hardness, Type A: 75, minimum, after seven days when tested in accordance with ASTM D2240.
  2. Color: To be selected by Architect from manufacturer's standard colors.
  3. Joint Width, Minimum: 1/8 inch.
  4. Joint Depth: Provide product suitable for joints from 1/8 inch to 1 inch in depth excluding space for backer rod.
  5. Manufacturers:
    - a. Adhesives Technology Corporation; Crackbond JF-311: [www.atcepoxy.com/#sle](http://www.atcepoxy.com/#sle).

- b. ARDEX Engineered Cements; ARDEX ARDISEAL RAPID PLUS: [www.ardexamericas.com/#sle](http://www.ardexamericas.com/#sle).
- c. Nox-Crete; DynaFlex JF-85: [www.nox-crete.com/#sle](http://www.nox-crete.com/#sle).
- d. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that joints are ready to receive work.
- B. Verify that backing materials are compatible with sealants.
- C. Preinstallation Adhesion Testing: Install a sample for each test location indicated in the test plan.
  - 1. Test each sample as specified in PART 1 under QUALITY ASSURANCE article.
  - 2. Notify Architect of date and time that tests will be performed, at least 7 days in advance.
  - 3. Arrange for sealant manufacturer's technical representative to be present during tests.
  - 4. Record each test on Preinstallation Adhesion Test Log as indicated.
  - 5. If any sample fails, review products and installation procedures, consult manufacturer, or take whatever other measures are necessary to ensure adhesion; re-test in a different location; if unable to obtain satisfactory adhesion, report to Architect.
  - 6. After completion of tests, remove remaining sample material and prepare joint for new sealant installation.

### **3.02 PREPARATION**

- A. Remove loose materials and foreign matter that could impair adhesion of sealant.
- B. Clean joints, and prime as necessary, in accordance with manufacturer's instructions.
- C. Perform preparation in accordance with manufacturer's instructions and ASTM C1193.
- D. Mask elements and surfaces adjacent to joints from damage and disfigurement due to sealant work; be aware that sealant drips and smears may not be completely removable.
- E. Concrete Floor Joints That Will Be Exposed in Completed Work: Test joint filler in inconspicuous area to verify that it does not stain or discolor slab.

### **3.03 INSTALLATION**

- A. Perform work in accordance with sealant manufacturer's requirements for preparation of surfaces and material installation instructions.
- B. Perform installation in accordance with ASTM C1193.
- C. Perform acoustical sealant application work in accordance with ASTM C919.
- D. Measure joint dimensions and size joint backers to achieve the following, unless otherwise indicated:
  - 1. Width/depth ratio of 2:1.
  - 2. Neck dimension no greater than 1/3 of the joint width.
  - 3. Surface bond area on each side not less than 75 percent of joint width.

- E. Install bond breaker backing tape where backer rod cannot be used.
- F. Install sealant free of air pockets, foreign embedded matter, ridges, and sags, and without getting sealant on adjacent surfaces.
- G. Do not install sealant when ambient temperature is outside manufacturer's recommended temperature range, or will be outside that range during the entire curing period, unless manufacturer's approval is obtained and instructions are followed.
- H. Nonsag Sealants: Tool surface concave, unless otherwise indicated; remove masking tape immediately after tooling sealant surface.
- I. Concrete Floor Joint Filler: After full cure, shave joint filler flush with top of concrete slab.

#### **3.04 FIELD QUALITY CONTROL**

- A. District will employ an independent testing agency to perform field quality control inspection and testing as specified in PART 1 under QUALITY ASSURANCE article.
- B. Non-Destructive Adhesion Testing: If there are any failures in first 100 linear feet, notify Architect immediately.
- C. Destructive Adhesion Testing: If there are any failures in first 1000 linear feet, notify Architect immediately.
- D. Remove and replace failed portions of sealants using same materials and procedures as indicated for original installation.
- E. Repair destructive test location damage immediately after evaluation and recording of results.

#### **3.05 POST-OCCUPANCY**

- A. Post-Occupancy Inspection: Perform visual inspection of entire length of project sealant joints at a time that joints have opened to their greatest width; i.e. at low temperature in thermal cycle. Report failures immediately and repair.

**END OF SECTION**

**SECTION 08 06 71**  
**DOOR HARDWARE SCHEDULE**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Preliminary schedule of door hardware sets for swinging, and other door types as indicated on drawings.

**1.02 RELATED REQUIREMENTS**

- A. Section 08 71 00 - Door Hardware: Requirements to comply with in coordination with this section.

**1.03 REFERENCE STANDARDS**

- A. BHMA (CPD) - Certified Products Directory; 2016.
- B. BHMA A156.3 - American National Standard for Exit Devices; 2014.
- C. BHMA A156.5 - American National Standard for Cylinders and Input Devices for Locks; 2014.
- D. BHMA A156.13 - American National Standard for Mortise Locks & Latches Series 1000; 2012.
- E. BHMA A156.18 - American National Standard for Materials and Finishes; 2012.
- F. DHI (H&S) - Sequence and Format for the Hardware Schedule; 1996.

**1.04 SUBMITTALS**

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Comply with submittal requirements as indicated in Section 08 71 00.

**PART 2 PRODUCTS**

**2.01 MANUFACTURERS**

- A. Only manufacturers listed in Door Hardware Schedule or Section 08 71 00 are considered acceptable, unless noted otherwise.
- B. Obtain each type of door hardware as indicated from a single manufacturer and single supplier.
- C. Products are listed and certified compliant with specified standards by BHMA (CPD).
- D. Manufacturer's Abbreviations: Coordinate with manufacturers listed in Section 08 71 00.
  - 1. AA - ASSA High Security Locks
  - 2. AD/AR - Adams Rite, Assa Abloy Door Security Solutions.
  - 3. BM - Besam, Assa Abloy Door Security Solutions.
  - 4. CR - Corbin Russwin, Assa Abloy Door Security Solutions.
  - 5. CUR - Curries, Assa Abloy Door Security Solutions.
  - 6. HES - HES, Assa Abloy Door Security Solutions.
  - 7. HD - HID Global, Assa Abloy Door Security Solutions.

8. McK/MK - McKinney, Assa Abloy Door Security Solutions.
9. MR/MKR - Markar.
10. NO/NOR - Norton.
11. PEM/PE - Pemko, Assa Abloy Door Security Solutions.
12. RIX/RF - Rixson Specialty Door Controls, Assa Abloy Door Security Solutions.
13. ROC/RO - Rockwood.
14. SA - Sargent, Assa Abloy Door Security Solutions.
15. SEC/SU - Securitron, Assa Abloy Door Security Solutions.
16. ST/SDC - Stanley Door Closers, Dormakaba.
17. ST/SH - Stanley Hinges, Dormakaba.
18. ST/STH - Stanley Commercial Hardware, Stanly Works.
19. YA - Yale, Assa Abloy Door Security Solutions.
20. TBD - To be determined.
21. BYO/OT - By Others.

## **2.02 DESCRIPTION**

- A. Door hardware sets provided represent the design intent, they are only a guideline and should not be considered a detailed or complete hardware schedule.
  1. Provide door hardware item(s) as required for similar purposes, even when item is not listed for a door in Door Hardware Schedule.
  2. Necessary items that are not included in a Hardware Set should be added and have the appropriate additional hardware as required for proper application and functionality.
  3. Door hardware supplier is responsible for providing proper size and hand of door for products required in accordance with Door Hardware Schedule and as indicated on drawings.
  4. Quantities listed are for each Pair (PR) of doors, or for each Single (SGL) door, as indicated in hardware sets.

## **2.03 LOCK FUNCTION CODES**

- A. Function Codes for Cylindrical Locks: Complying with BHMA A156.5.
- B. Function Codes for Mortise Locks: Complying with BHMA A156.13.
- C. Function Codes for Exit Devices: Complying with BHMA A156.3.

## **2.04 FINISHES**

- A. Finishes: Complying with BHMA A156.18.

## **PART 3 EXECUTION**

### **3.01 DOOR HARDWARE SCHEDULE**

- A. Organize listing of door hardware components within each hardware set in compliance with 10-Part scheduling sequence indicated in DHI (H&S), unless otherwise indicated.

- B. See door schedule in drawings for hardware set assignments.
- C. No hardware shall be ordered until Finished Hardware has been reviewed and approved by Architect's hardware consultant.
- D. Provide Factory order numbers for all products supplied on this project as part of close out documents for District's warranty records.
- E. Any door count quantity shown in the HW set listings is for reference only. Contractor shall verify all door quantities with the Architectural Drawings.

**Hardware Sets**

**Set: 1.0**

Doors: 001, 006, 007  
Description: Sliding Doors

1 Sliding doors All materials by Door Manufacturer

**Set: 2.0**

Doors: 004, 005  
Description: Exterior Sgl - Panic - CR

|                            |   |       |    |   |
|----------------------------|---|-------|----|---|
| 1 Continuous Hinge         | FM300 WEP                                       | 630   | MR |   |
| 1 Exit Device (nightlatch) | 5CH LC 16 43 8804 x 525 edge guard on touch pad | US32D | SA |   |
| 2 Cylinder as req'd        | to match existing facility std                  |       | AA |   |
| 1 Electric Strike          | 9500  | 630   | HS | ⚡ |
| 1 Vandal Resistant Trim    | VRT24 C   | US32D | RO |   |
| 1 Door Closer              | 351 P10   | EN    | SA |   |
| 1 Door Stop                | 466   | Black | RO |   |
| 1 Threshold                | Per Sill Detail                                 |       | PE |   |
| 1 Rain Guard               | 346C (omit @ overhang)                          |       | PE |   |
| 1 Sweep                    | 18062CNB  |       | PE |   |
| 1 Position Switch          | DPS   |       | SU | ⚡ |
| 1 Power Supply             | BPS-24  |       | SU | ⚡ |

Notes: Weatherstripping by Aluminum Door Supplier  
Card Reader, wiring and electrical interface by Security Contractor  
Operational Narrative: Door normally closed and locked. Upon presentation of valid credential, door will momentarily unlock. Free egress at all times. In the event of activation of the Fire alarm or loss of power, doors will remain closed and locked.



**Set: 3.0**

Doors: 003, 008

Description: Exterior Pair - Panic

|   |                          |   |       |      |
|---|--------------------------|---|-------|------|
| 2 | Continuous Hinge         | FM300 WEP                                       | 630   | MR   |
| 1 | Remov Mullion            | L980A   | 628   | SA   |
| 1 | Exit Device (nightlatch) | 5CH LC 16 43 8804 x 525 edge guard on touch pad | US32D | SA   |
| 1 | Exit Device (Exit only)  | 5CH LC 16 43 8810 x 525 edge guard on touch pad | US32D | Sa   |
| 4 | Cylinder as req'd        | to match existing facility std                  |       | AA   |
| 1 | Vandal Resistant Trim    | VRT26 C   | US32D | RO   |
| 1 | Vandal Resistant Trim    | VRT26   | US32D | RO   |
| 1 | Door Closer              | 351 P10   | EN    | SA   |
| 1 | Door Stop                | 466   | Black | RO   |
| 1 | Threshold                | Per Sill Detail                                 |       | PE   |
| 1 | Rain Guard               | 346C (omit @ overhang)                          |       | PE   |
| 1 | Sweep                    | 18062CNB  |       | PE   |
| 1 | Mullion Seal             | 5110  |       | PE   |
| 1 | Position Switch          | DPS   |       | SU ⚡ |

Notes: Weatherstripping by Aluminum Door Supplier

**Set: 4.0**

Doors: 002

Description: Exterior Sgl - CR

|   |                         |                                |       |      |
|---|-------------------------|--------------------------------|-------|------|
| 1 | Continuous Hinge        | FM300 WEP                      | 630   | MR   |
| 1 | Classroom Intruder Lock | LC 8238 LNP                    | US26D | SA ⚡ |
| 2 | Cylinder as req'd       | to match existing facility std |       | AA   |
| 1 | Door Closer             | 351 O                          | EN    | SA   |
| 1 | OH Stop                 | 1-X36                          | 630   | RF   |
| 1 | Threshold               | Per Sill Detail                |       | PE   |
| 1 | Rain Guard              | 346C (omit @ overhang)         |       | PE   |
| 1 | Sweep                   | 18062CNB                       |       | PE   |
| 1 | Position Switch         | DPS                            |       | SU ⚡ |

Notes: Weatherstripping by Aluminum Door Supplier

**Set: 5.0**

Doors: 140

Description: Interior Pair - Panic

|                        |                                |       |    |
|------------------------|--------------------------------|-------|----|
| 6 Hinge (heavy weight) | T4A3786 (NRP)                  | US26D | MK |
| 2 Classroom Lock       | NB-AD701315 ETP                | US26D | SA |
| 2 Cylinder as req'd    | to match existing facility std |       | AA |
| 2 Door Closer          | 351 O                          | EN    | SA |
| 2 Wall Stop            | 403                            | 626   | RO |

**Set: 6.0**

Doors: 110, 121

Description: Interior Sgl - CR

|                             |                                |       |    |   |
|-----------------------------|--------------------------------|-------|----|---|
| 3 Hinge (heavy weight)      | T4A3786 (NRP) QCW              | US26D | MK | ⚡ |
| 1 Fail Secure Electric Lock | LC RX 8271-24V LNP             | US26D | SA | ⚡ |
| 1 Cylinder as req'd         | to match existing facility std |       | AA |   |
| 1 Door Closer               | 351 O/P9                       | EN    | SA |   |
| 1 Kick Plate                | K1050 10" 4BE CSK              | US32D | RO |   |
| 1 Wall Stop                 | 403                            | US26D | RO |   |
| 3 Silencers                 | 608                            | GRY   | RO |   |
| 1 ElectroLynx Harness       | QC-C1500P                      |       | MK | ⚡ |
| 1 ElectroLynx Harness       | QC-C400P                       |       | MK | ⚡ |
| 1 Position Switch           | DPS                            |       | SU | ⚡ |
| 1 Power Supply              | BPS-24                         |       | SU | ⚡ |

Notes: Card Reader, wiring and electrical interface by Security Contractor

Operational Narrative: Door normally closed and locked. Upon presentation of valid credential, door will momentarily unlock. Free egress at all times. In the event of activation of the Fire alarm or loss of power, doors will remain closed and locked.

**Set: 7.0**

Doors: 102, 118

Description: Interior Sgl multi-occup toilet/womens lounge

|                           |                                |       |    |
|---------------------------|--------------------------------|-------|----|
| 3 Hinge (heavy weight)    | T4A3786 (NRP)                  | US26D | MK |
| 1 Classroom intruder Lock | 8238 LNP                       | US26D | SA |
| 2 Cylinder as req'd       | to match existing facility std |       | AA |
| 1 Door Closer             | 351 O                          | EN    | SA |
| 1 Kick Plate              | K1050 10" 4BE CSK              | US32D | RO |
| 1 Wall Stop               | 403                            | US26D | RO |
| 3 Silencer                | 608                            |       | RO |

**Set: 8.0**

Doors: 114, 134A

Description: Interior Sgl Stor/Mailroom

|                        |                                |          |
|------------------------|--------------------------------|----------|
| 3 Hinge (heavy weight) | T4A3786 (NRP)                  | US26D MK |
| 1 Storeroom Lock       | LC 8204 LNP                    | US26D SA |
| 2 Cylinder as req'd    | to match existing facility std | AA       |
| 1 Door Closer          | 351 H                          | EN SA    |
| 1 Kick Plate           | K1050 10" 4BE CSK              | US32D RO |
| 1 Wall Stop            | 403                            | US26D RO |
| 3 Silencer             | 608                            | RO       |

**Set: 9.0**

Doors: 112, 113, 115, 116, 123B, 124, 125, 126, 127

Description: Interior Sgl Office / Lounge

|                        |                                |          |
|------------------------|--------------------------------|----------|
| 3 Hinge (heavy weight) | T4A3786 (NRP)                  | US26D MK |
| 1 Office Lock          | LC 8205 LNP                    | US26D SA |
| 1 Cylinder as req'd    | to match existing facility std | AA       |
| 1 Wall Stop            | 403                            | US26D RO |
| 3 Silencer             | 608                            | RO       |

**Set: 10.0**

Doors: 117

Description: Conference

|                        |               |          |
|------------------------|---------------|----------|
| 3 Hinge (heavy weight) | T4A3786 (NRP) | US26D MK |
| 1 Passage Set          | 8215 LNP      | US26D SA |
| 1 Wall Stop            | 403           | US26D RO |
| 3 Silencer             | 608           | RO       |

**END OF SECTION**





**SECTION 08 11 13**  
**HOLLOW METAL DOORS AND FRAMES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Non-fire-rated hollow metal doors and frames.
- B. Hollow metal frames for wood doors.
- C. Fire-rated hollow metal doors and frames.
- D. Accessories, including glazing, louvers, and matching panels.

**1.02 RELATED REQUIREMENTS**

- A. Section 08 14 16 - Flush Wood Doors: Wood doors to be installed in steel frames specified in this section.
- B. Section 08 71 00 - Door Hardware.
- C. Section 08 80 00 - Glazing: Glass for doors and borrowed lites.
- D. Section 09 91 23 - Interior Painting: Field painting.

**1.03 ABBREVIATIONS AND ACRONYMS**

- A. ANSI: American National Standards Institute.
- B. HMMA: Hollow Metal Manufacturers Association.
- C. NAAMM: National Association of Architectural Metal Manufacturers.
- D. NFPA: National Fire Protection Association.
- E. SDI: Steel Door Institute.
- F. UL: Underwriters Laboratories.

**1.04 REFERENCE STANDARDS**

- A. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- B. ANSI/SDI A250.11 - Recommended Erection Instructions for Steel Frames; 2012.
- C. ANSI/SDI A250.4 - Test Procedure and Acceptance Criteria for Physical Endurance for Steel Doors, Frames and Frame Anchors; 2011.
- D. ANSI/SDI A250.6 - Recommended Practice for Hardware Reinforcing on Standard Steel Doors and Frames; 2003 (R2009).
- E. ANSI/SDI A250.8 - Specifications for Standard Steel Doors and Frames (SDI-100); 2014.
- F. ANSI/SDI A250.10 - Test Procedure and Acceptance Criteria for Prime Painted Steel Surfaces for Steel Doors and Frames; 2011.
- G. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2009.
- H. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2015.

- I. ASTM A1008/A1008M - Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Solution Hardened, and Bake Hardenable; 2016.
- J. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength; 2015.
- K. BHMA A156.115 - American National Standard for Hardware Preparation in Steel Doors and Steel Frames; 2014.
- L. ITS (DIR) - Directory of Listed Products; current edition.
- M. NAAMM HMMA 830 - Hardware Selection for Hollow Metal Doors and Frames; 2002.
- N. NAAMM HMMA 831 - Hardware Locations for Hollow Metal Doors and Frames; 2011.
- O. NAAMM HMMA 840 - Guide Specifications for Installation and Storage of Hollow Metal Doors and Frames; 2007.
- P. NAAMM HMMA 861 - Guide Specifications for Commercial Hollow Metal Doors and Frames; 2006.
- Q. NFPA 80 - Standard for Fire Doors and Other Opening Protectives; 2016.
- R. NFPA 105 - Standard for Smoke Door Assemblies and Other Opening Protectives; 2016.
- S. NFPA 252 - Standard Methods of Fire Tests of Door Assemblies; 2012.
  - 1. Use 2012 as indicated in 2016 CBC Referenced Standards.
- T. SDI 117 - Manufacturing Tolerances for Standard Steel Doors and Frames; 2013.
- U. UL (DIR) - Online Certifications Directory; current listings at database.ul.com.
- V. UL 10B - Standard for Fire Tests of Door Assemblies; Current Edition, Including All Revisions.
  - 1. Use 2008 as indicated in 2016 CBC Referenced Standards.
- W. UL 10C - Standard for Positive Pressure Fire Tests of Door Assemblies; Current Edition, Including All Revisions.
  - 1. Use 2009 as indicated in 2016 CBC Referenced Standards.
- X. UL 1784 - Standard for Air Leakage Tests of Door Assemblies; Current Edition, Including All Revisions.

#### **1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Materials and details of design and construction, hardware locations, reinforcement type and locations, anchorage and fastening methods, and finishes; and one copy of referenced standards/guidelines.
- C. Shop Drawings: Details of each opening, showing elevations, glazing, frame profiles, and any indicated finish requirements.
  - 1. Show fabrication and installation of steel doors and frames. Include details of each frame type, elevations of door design types, conditions at openings, details of construction, location and installation requirements of door and frame hardware and reinforcements, and details of joints and connections. Show anchorage and accessory items.

2. Provide schedule of doors and frames using same reference numbers for details and openings as those indicated on Drawings.
  3. Indicate coordination of glazing frames and stops with glass and glazing requirements.
- D. Samples: Submit two samples of metal, 2 inch by 2 inch in size showing factory finishes, colors, and surface texture.
- E. Installation Instructions: Manufacturer's published instructions, including any special installation instructions relating to this project.
- F. Manufacturer's Certificate: Certification that products meet or exceed specified requirements.
- G. Manufacturer's Qualification Statement.
- H. Installer's Qualification Statement.

### **1.06 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than three years documented experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years of documented experience.
- C. Maintain at project site copies of reference standards relating to installation of products specified.

### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Delivery: Provide packaging such as cardboard, or other containers to protect surfaces of hollow metal doors. Strap welded frames together in pairs with head of one unit inverted or provide temporary spreaders fastened to the bottom of each frame.
- B. Comply with NAAMM HMMA 840 or ANSI/SDI A250.8 (SDI-100) in accordance with specified requirements.
1. Store doors and frames on platforms under cover.
  2. Store doors and frames in dry storage spaces, with adequate ventilation, free from dust, and which permits easy access for inspection and handling.
  3. Avoid using nonvented plastic or canvas shelters that create a humidity chamber.
  4. If the wrapper on the door becomes wet, remove the wrapper.
- C. Protect with resilient packaging; avoid humidity build-up under coverings; prevent corrosion and adverse effects on factory applied painted finish.

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. Fire-Rated Door Assemblies: Meet the requirements of the California Building Code (CBC), Title 24, Part 2, Chapter 7 - Fire Resistance Rated Construction for the fire resistive ratings indicated, and which are labeled by Underwriter's Laboratories, Factory Mutual, or other testing agency acceptable to the State Fire Marshal.



1. Fire-rated door and frame construction: Conform to NFPA 252, applicable CBC Standard and requirements of Factory Mutual System (FM). Labels on fire-rated doors and frames shall identify FM listing approval. Comply with UL 10B.
2. Fire-rated door and frame installation: NFPA 80 - Fire Door Installation and applicable CBC Standards for fire rated class indicated.
3. Fire-rated doors, intumescent seals: UL 10C compliant. If intumescent seals are required for the fire labeled assembly, furnish flush with door edge type seals or kerfed in frame type seals. Surface applied adhesive seals will not be accepted. Coordinate frame fabrication to allow use of kerfed in frame type seal options.
4. Temperature rise rating: At exit stairwell enclosures, exit passageways, and horizontal exits, provide doors which are labeled for a maximum transmitted temperature end point not to exceed 450 degrees above ambient at the end of 30 minutes of fire exposure.
5. Oversize fire-rated door assemblies: For units exceeding sizes of tested assemblies, provide certification by a testing agency acceptable to the State Fire Marshal that doors comply with standard construction requirements for tested and labeled fire-rated door assemblies except for size.
6. Where fire resistive doors are indicated to be equipped with louvers, provide fusible link type louvers acceptable to the testing agency labeling the fire door and frame assembly.
  - a. Exception: Louvers are not to be used in "S" rated door assemblies. CBC Section 716.5.3.1.
7. All exit/access doorways and other doors opening into a fire rated corridor shall be protected by tight-fitting smoke and draft control assemblies having a fire rating of not less than 20 minutes when tested in accordance with CBC Standards and shall be labeled accordingly per CBC section 716.5.7.

## 2.02 MANUFACTURERS

- A. Hollow Metal Doors and Frames:
  1. Ceco Door, an Assa Abloy Group company: [www.assaabloydss.com](http://www.assaabloydss.com).
  2. Curries, an Assa Abloy Group company: [www.assaabloydss.com](http://www.assaabloydss.com).
  3. Security Metal Products; [www.secmet.com](http://www.secmet.com).
  4. Substitutions: Not permitted.

## 2.03 PERFORMANCE REQUIREMENTS

- A. Requirements for Hollow Metal Doors and Frames:
  1. Steel Sheet: Comply with one or more of the following requirements; galvanized steel complying with ASTM A653/A653M, cold-rolled steel complying with ASTM A1008/A1008M, or hot-rolled pickled and oiled (HRPO) steel complying with ASTM A1011/A1011M, commercial steel (CS) Type B, for each.
  2. Accessibility: Comply with ADAAG 2010 and CBC Chapter 11B.
  3. Exterior Door Top Closures: Flush end closure channel, with top and door faces aligned.
  4. Door Edge Profile: Beveled, both sides.

5. Typical Door Face Sheets: Flush.
  6. Glazed Lights: Non-removable stops on non-secure side; sizes and configurations as indicated on drawings. Style: Manufacturers standard.
  7. Hardware Preparations, Selections and Locations: Comply with NAAMM HMMA 830 and NAAMM HMMA 831 or BHMA A156.115 and ANSI/SDI A250.8 (SDI-100) in accordance with specified requirements.
  8. Zinc Coating for Typical Interior and/or Exterior Locations: Provide metal components zinc-coated (galvanized) and/or zinc-iron alloy-coated (galvannealed) by the hot-dip process in accordance with ASTM A653/A653M, with manufacturer's standard coating thickness, unless noted otherwise for specific hollow metal doors and frames.
    - a. Based on NAAMM HMMA Custom Guidelines: Provide at least A25/ZF75 (galvannealed) for interior applications, and at least A60/ZF180 (galvannealed) or G60/Z180 (galvanized) for corrosive locations.
- B. Hollow Metal Panels: Same construction, performance, and finish as doors.
- C. Combined Requirements: If a particular door and frame unit is indicated to comply with more than one type of requirement, comply with the specified requirements for each type; for instance, an exterior door that is also indicated as being sound-rated must comply with the requirements specified for exterior doors and for sound-rated doors; where two requirements conflict, comply with the most stringent.

#### **2.04 HOLLOW METAL DOORS**

- A. Door Finish: Factory primed and field finished.
- B. Interior Doors, Non-Fire Rated:
1. Basis of Design Product: 707 Series as manufactured by Curries, or approved equal.
  2. Based on SDI Standards: ANSI/SDI A250.8 (SDI-100).
    - a. Level 2 - Heavy-duty.
    - b. Physical Performance Level B, 500,000 cycles; in accordance with ANSI/SDI A250.4.
    - c. Model 2 - Seamless.
    - d. Door Face Metal Thickness: 18 gage, 0.042 inch, minimum.
    - e. Zinc Coating: A60/ZF180 galvannealed coating; ASTM A653/A653M.
  3. Door Core Material: Manufacturers standard core material/construction and in compliance with requirements.
  4. Door Thickness: 1-3/4 inch, nominal.
- C. Fire-Rated Doors:
1. Based on SDI Standards: ANSI/SDI A250.8 (SDI-100).
    - a. Level 2 - Heavy-duty.
    - b. Physical Performance Level B, 500,000 cycles; in accordance with ANSI/SDI A250.4.
    - c. Model 2 - Seamless.
    - d. Door Face Metal Thickness: 18 gage, 0.042 inch, minimum.
  2. Fire Rating: As indicated on Door Schedule, tested in accordance with UL 10C and NFPA 252 ("positive pressure fire tests").

- a. Temperature-Rise Rating (TRR) Across Door Thickness: In accordance with local building code and authorities having jurisdiction.
- b. Provide units listed and labeled by UL (DIR) or ITS (DIR).
- c. Attach fire rating label to each fire rated unit.
- d. Smoke and Draft Control Doors (Indicated with letter "S" on Drawings and/or Door Schedule): Self-closing or automatic closing doors in accordance with NFPA 80 and NFPA 105, with fire-resistance-rated wall construction rated the same or greater than the fire-rated doors, and the following;
  - 1) Maximum Air Leakage: 3.0 cfm/sq ft of door opening at 0.10 inch w.g. pressure, when tested in accordance with UL 1784 at both ambient and elevated temperatures.
  - 2) Gasketing: Provide gasketing or edge sealing as necessary to achieve leakage limit.
  - 3) Label: Include the "S" label on fire-rating label of door.
3. Door Core Material: Manufacturers standard core material/construction in compliance with requirements.
  - a. Fabricate to the requirements of NFPA 252 for the hourly rates indicated.
  - b. Fabricate labeled fire resistive doors at stairwells, exit passageways, and horizontal exits with mineral fiberboard composite core that will provide the specified maximum transmitted temperature end point.
4. Door Thickness: 1-3/4 inch, nominal.

## **2.05 HOLLOW METAL FRAMES**

- A. Comply with standards and/or custom guidelines as indicated for corresponding door in accordance with applicable door frame requirements.
- B. Basis of Design Product: CM Series as manufactured by Curries, or approved equal.
- C. Frame Finish: Same as hollow metal door.
- D. Interior Door Frames, Non-Fire Rated: Full profile/continuously welded type.
  1. Frame Metal Thickness: 16 gage, 0.053 inch, minimum.
    - a. Openings over 48 inches: 14 gage, 0.067 inch, minimum.
- E. Door Frames, Fire-Rated: Full profile/continuously welded type.
  1. Fire Rating: Same as door, labeled.
  2. Fire rated frames require metal applied label indicating rating designation.
  3. Frame Metal Thickness: 16 gage, 0.053 inch, minimum.
- F. Frames for Wood Doors: Comply with frame requirements in accordance with corresponding door.

## **2.06 FINISHES**

- A. Primer: Rust-inhibiting, complying with ANSI/SDI A250.10, door manufacturer's standard.
- B. Touch-Up Primer for Galvanized Surfaces: SSPC-Paint 20, Type I - Inorganic, complying with VOC limitations of authorities having jurisdiction.
- C. Field Applied Finish Painting: As specified in:

1. Section 09 91 23 - Interior Painting.
  2. Exterior Doors (Abuse Resistant): Section 09 96 00 - High-Performance Coatings.
- D. Bituminous Coating: Asphalt emulsion or other high-build, water-resistant, resilient coating.

## 2.07 ACCESSORIES

- A. Glazing: As specified in Section 08 80 00.
- B. Removable Stops: Formed sheet steel, shape as indicated on drawings, mitered or butted corners; prepared for countersink style tamper proof screws.
1. Glazing Stops: Channel glazing stops, completely fit ready for removal and glazing at site.
- C. Mechanical Fasteners for Concealed Metal-to-Metal Connections: Self-drilling, self-tapping, steel with electroplated zinc finish.
- D. Supports and Anchors: Fabricate of not less than 16 gage sheet steel; galvanized where used with galvanized frames or at exterior, damp or wet locations.
1. Anchors: Provide in accordance with ANSI/SDI A250.11.
    - a. Anchors at fire rated frames shall also conform to UL 10B.
    - b. Provide one floor anchor and the number of wall anchors listed below welded into each jamb member.
      - 1) Number of anchors at:
        - (a) Steel Stud Partitions: Typically 4, and 5 for doors over 7'-0" high.
    - c. Wall anchors shall be of type indicated for the specific wall condition and of same material specified for frames.
    - d. Provide head anchors welded into head member as recommended by the frame manufacturer.
    - e. All anchors shall be 16 gage minimum for galvanized frames and 16 gage minimum for cold or hot rolled steel frames.
    - f. Provide "Z" spacer type anchors for all wood studs.
  2. Punch and dimple jambs within 6 inches of bottom for attachment to concrete stem walls where occur.
- E. Grout for Frames: Portland cement grout with maximum 4 inch slump for hand troweling; thinner pumpable grout is prohibited.
- F. Silencers: Resilient rubber, fitted into drilled hole; provide three on strike side of single door, three on center mullion of pairs, and two on head of pairs without center mullions.
- G. Temporary Frame Spreaders: Provide for factory- or shop-assembled frames.
1. Provide all frames with frame spreader at bottom to insure frame integrity during shipping.
- H. Inserts, Bolts, and Fasteners: Manufacturer's standard units. Where items are to be built into exterior walls, hot-dip galvanize in compliance with ASTM A153/A153M, Class C or D as applicable.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify that opening sizes and tolerances are acceptable.
- C. Verify that finished walls are in plane to ensure proper door alignment.

### **3.02 PREPARATION**

- A. Coat inside of frames to be installed in masonry or to be grouted, with bituminous coating, prior to installation.
- B. Reinforce all frames for surface mounted hardware and cut-out, drilled and tapped to receive mortised hardware.
- C. Coat inside of exterior frames with bituminous coating to a thickness of 1/16 inch.

### **3.03 INSTALLATION**

- A. Install doors and frames in accordance with manufacturer's instructions and related requirements of specified door and frame standards or custom guidelines indicated.
- B. In addition, install fire rated units in accordance with NFPA 80 and their listing.
  - 1. Provide clearances as specified in NFPA 80, NFPA 105, and as required by California Building Code (CBC).
- C. Coordinate frame anchor placement with wall construction.
- D. Install door hardware as specified in Section 08 71 00.
  - 1. Comply with recommended practice for hardware placement of doors and frames in accordance with ANSI/SDI A250.6 or NAAMM HMMA 861.
- E. Comply with glazing installation requirements of Section 08 80 00.
- F. Coordinate installation of electrical connections to electrical hardware items.
- G. Doors Installation, General: Hang doors and adjust for proper clearances and operation. Refer to Section 08 71 00 - Door Hardware for hardware requirements.
- H. Window Installation, General: Place glazing and adjust for proper clearances. Refer to Section 08 80 00 - Glazing for Installation requirements.
- I. Touch up damaged factory finishes.

### **3.04 REPAIRS:**

- A. Make repairs only if permitted by Architect. Otherwise, replace damaged components.
- B. Fill surface depressions with metallic paste filler, allow to thoroughly cure, sand flush, and smooth for an invisible appearance with adjacent metal surfaces.
- C. Sand smooth all rusted areas.
- D. Repair galvanized surfaces with specified repair compound.
- E. Apply touch-up paint using air drying primer compatible with shop-applied finish.

### **3.05 TOLERANCES**

- A. Flush Steel Door Installation Tolerances: Fit hollow metal doors accurately in frames, within clearances specified in ANSI/SDI A250.8.
- B. Clearances Between Door and Frame: Comply with related requirements of specified frame standards or custom guidelines indicated in accordance with SDI 117 or NAAMM HMMA 861.
- C. Maximum Diagonal Distortion: 1/16 inch measured with straight edge, corner to corner.

### **3.06 ADJUSTING**

- A. Adjust for smooth and balanced door movement.
- B. Test sound control doors for force to close, latch, and unlatch; adjust as necessary in compliance with requirements.

### **3.07 CLEANING AND PROTECTION**

- A. Prime Coat Touch-up: Immediately after installation, sand smooth all corroded (rusted), damaged and deteriorated areas of prime coat and apply touch-up coat of compatible air-drying primer.
- B. Protection: Protect installed frames and doors from damage.
  - 1. Provide protective coverings and other devices as necessary, in conformance to requirements specified in Section 01 50 00 - Temporary Facilities and Controls.
  - 2. Remove protective devices from prefinished components for Substantial Completion review.
- C. Final Adjustments: Check and readjust operating hardware items, leaving steel doors and frames undamaged and in complete and proper operating condition.
- D. Cleaning: Clean doors and frames of surface contaminants detrimental to proper application of field-applied finishes.

### **3.08 SCHEDULE - SEE DRAWINGS**

- A. Refer to Door and Frame Schedule on the drawings.

**END OF SECTION**



**SECTION 08 14 16**  
**FLUSH WOOD DOORS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Flush wood doors; flush configuration; fire rated and non-rated.
- B. Transom panels.

**1.02 RELATED REQUIREMENTS**

- A. Section 08 11 13 - Hollow Metal Doors and Frames.
- B. Section 08 43 13 - Aluminum-Framed Storefronts.
- C. Section 08 71 00 - Door Hardware.
- D. Section 08 80 00 - Glazing.
- E. Section 09 91 23 - Interior Painting: Field finishing of doors.

**1.03 REFERENCE STANDARDS**

- A. Project Type:
  - 1. Public
- B. Code agency:
  - 1. California Building Code
  - 2. DSA
- C. 28 CFR 35 - Structural Sealant Glazing Systems; 1985 (R2006).
- D. ANSI A135.4 - American National Standard for Basic Hardboard; 2012.
- E. ASTM C1048 - Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass; 2012.
- F. ASTM E413 - Classification for Rating Sound Insulation; 2016.
- G. NFPA 80 - Standard for Fire Doors and Other Opening Protectives; 2016.
  - 1. Use 2016 as indicated in 2016 CBC Referenced Standards.
- H. NFPA 105 - Standard for Smoke Door Assemblies and Other Opening Protectives; 2016.
- I. UL 10C - Standard for Positive Pressure Fire Tests of Door Assemblies; Current Edition, Including All Revisions.
  - 1. Use 2009 as indicated in 2016 CBC Referenced Standards.
- J. UL 1784 - Standard for Air Leakage Tests of Door Assemblies; Current Edition, Including All Revisions.
  - 1. Use 2001 with revisions as indicated in 2016 CBC Referenced Standards.
- K. WDMA I.S. 1A - Interior Architectural Wood Flush Doors; 2013.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.



- B. Product Data: Indicate door core materials and construction; veneer species, type and characteristics.
- C. Shop Drawings: Show doors and frames, elevations, sizes, types, swings, undercuts, beveling, blocking for hardware, factory machining, factory finishing, cutouts for glazing and other details.
- D. Samples: Submit two samples of door construction, 10 by 10 inch in size cut from top corner of door.
- E. Samples: Submit two samples of door veneer, 12 by 12 inch in size illustrating wood grain, stain color, and sheen.
- F. Certificate: Submit labels and certificates required by quality assurance and quality control programs.
- G. Test Reports: Show compliance with specified requirements for the following:
  - 1. Sound-retardant doors and frames; sealed panel tests are not acceptable.
- H. Manufacturer's Installation Instructions: Indicate special installation instructions.
- I. Specimen warranty.
- J. Warranty, executed in District's name.

#### **1.05 QUALITY ASSURANCE**

- A. Maintain one copy of the specified door quality standard on site for review during installation and finishing.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section, with not less than three years of documented experience.
  - 1. Company with at least one project within the past 5 years with value of woodwork within 20 percent of cost of woodwork for this project.
- C. Installer Qualifications: Company specializing in performing work of the type specified in this section, with not less than three years of documented experience.

#### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Package, deliver and store doors in accordance with specified quality standard.
- B. Accept doors on site in manufacturer's packaging. Inspect for damage.
- C. Protect doors with resilient packaging sealed with heat shrunk plastic. Do not store in damp or wet areas; or in areas where sunlight might bleach veneer. Seal top and bottom edges with tinted sealer if stored more than one week. Break seal on site to permit ventilation.

#### **1.07 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. Interior Doors: Provide manufacturer's warranty for the life of the installation.
- C. Include coverage for delamination of veneer, warping beyond specified installation tolerances, defective materials, and telegraphing core construction.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Basis of Design Product: GPD PC and GPD FD as manufactured by Graham.
- B. Wood Veneer Faced Doors:
  - 1. Graham Wood Doors: [www.grahamdoors.com/#sle](http://www.grahamdoors.com/#sle).
  - 2. Substitutions: Not permitted.

### **2.02 DOORS AND PANELS**

- A. Doors: Refer to drawings for locations and additional requirements.
  - 1. Quality Level: Custom Grade, Heavy Duty performance, in accordance with WDMA I.S. 1A.
  - 2. Wood Veneer Faced Doors: 5-ply unless otherwise indicated.
- B. Exterior Doors: Flush solid core construction and water repellent treated.
  - 1. Thickness: 1-3/4 inches, unless otherwise indicated.
  - 2. Facing: Maple veneer with factory transparent finish as indicated on drawings.
- C. Interior Doors: 1-3/4 inches thick unless otherwise indicated; flush construction.
  - 1. Provide solid core doors at each location.
  - 2. Fire Rated Doors: Tested to 60 minutes and ratings as indicated on drawings in accordance with UL 10C - Positive Pressure; Underwriters Laboratories Inc. (UL) or Intertek/Warnock Hersey (WHI) labeled without any visible seals when door is open.
    - a. Comply with CBC Section 716.5.1.
  - 3. Smoke and Draft Control Doors (Indicated as "S" on Drawings): In addition to required fire rating, provide door assemblies tested in accordance with UL 1784 with maximum air leakage of 3.0 cfm per sq ft of door opening at 0.10 inch wg pressure at both ambient and elevated temperatures for "S" label; if necessary, provide additional gasketing or edge sealing.
    - a. Comply with CBC Section 716.5.3.1.
  - 4. Sound-Rated Doors: Minimum STC as indicated on drawings, calculated in accordance with ASTM E413, tested in accordance with ASTM E90.
  - 5. White Maple, Premium Grade, Quarter Sliced, Balanced Matched veneer facing with factory transparent finish.
  - 6. Hardboard facing for field opaque finish as indicated on drawings.
- D. Transom Panels: Same construction and finish as door; same performance rating as door.

### **2.03 DOOR AND PANEL CORES**

- A. Non-Rated Solid Core and 20 Minute Rated Doors: Type particleboard core (PC), plies and faces as indicated.

- B. Fire-Rated Doors: Mineral core type, with fire resistant composite core (FD), plies and faces as indicated above; with core blocking as required to provide adequate anchorage of hardware without through-bolting.
- C. Sound-Rated Doors: Equivalent to type, with particleboard core (PC) construction as required to achieve STC rating specified; plies and faces as indicated above.

#### **2.04 DOOR FACINGS**

- A. Veneer Facing for Transparent Finish: White Maple, HPVA Grade AA, quarter cut, with balance match between leaves of veneer, running match of spliced veneer leaves assembled on door or panel face.
  - 1. Vertical Edges: Any option allowed by quality standard for grade.
  - 2. "Running Match" each pair of doors and doors in close proximity to each other.
  - 3. "Pair Match" each pair of doors; "Set Match" pairs of doors within 10 feet of each other when doors are closed.
  - 4. Transoms: Continuous match to doors.
- B. Hardboard Facing for Opaque Finish: ANSI A135.4, Class 1 - Tempered, S2S (smooth two sides) hardboard, 1/8 inch thick.
- C. Facing Adhesive: Type II - water resistant.

#### **2.05 DOOR CONSTRUCTION**

- A. Fabricate doors in accordance with door quality standard specified.
- B. Cores Constructed with stiles and rails:
  - 1. Provide solid blocks at lock edge and top of door for closer for hardware reinforcement.
  - 2. Internally reinforce mineral core doors for hardware attachment without the use of through bolt fasteners.
- C. At exterior doors, provide aluminum flashing at the top and bottom rail.
- D. Glazed Openings: Non-removable stops on non-secure side; sizes and configurations as indicated on drawings.
- E. Factory machine doors for hardware other than surface-mounted hardware, in accordance with hardware requirements and dimensions.
- F. Factory fit doors for frame opening dimensions identified on shop drawings, with edge clearances in accordance with specified quality standard.
  - 1. Exception: Doors to be field finished.
- G. Cut and configure exterior door edge to receive recessed weatherstripping devices.
- H. Provide edge clearances in accordance with the quality standard specified.

#### **2.06 FACTORY FINISHING - WOOD VENEER DOORS**

- A. Finish work in accordance with WDMA I.S. 1A for grade specified and as follows:
  - 1. Transparent:
    - a. System - TR-6, Catalyzed Polyurethane.
    - b. Stain: As selected by Architect.

- c. Sheen: Flat.
- 2. Opaque:
  - a. Manufacturers standard, in compliance with performance duty level indicated.
  - b. Color: As selected by Architect.
  - c. Sheen: Gloss.
- B. Factory finish doors in accordance with approved sample.
- C. Seal door top edge with color sealer to match door facing.

## **2.07 ACCESSORIES**

- A. Hollow Metal Door Frames: As specified in Section 08 11 13.
- B. Metal Louvers: As specified in Section 08 1113.
- C. Glazed Openings: Comply with CBC Section 716.6.3 and Chapter 24.
  - 1. Vision Panel: Factory installed.
    - a. Size (WxH): 6 by 37 inches.
  - 2. G-4 Heat-Strengthened and Fully Tempered Glass: ASTM C1048.
  - 3. G-6 Fire-Protection-Rated Glass: Safety Certification, 28 CFR 35, Category II.
    - a. Comply with CBC Section 716.6.
  - 4. Tint: Clear.
- D. Glazing: As specified in Section 08 80 00.
- E. Glazing Stops: Wood, of same species as door facing, butted corners; prepared for countersink style tamper proof screws.
- F. Door Hardware: As specified in Section 08 71 00.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify that opening sizes and tolerances are acceptable.
- C. Do not install doors in frame openings that are not plumb or are out-of-tolerance for size or alignment.

### **3.02 INSTALLATION**

- A. Install doors in accordance with manufacturer's instructions and specified quality standard.
  - 1. Install fire-rated doors in accordance with NFPA 80 requirements.
  - 2. Install smoke and draft control doors in accordance with NFPA 105 requirements.
- B. Factory-Finished Doors: Do not field cut or trim; if fit or clearance is not correct, replace door.
- C. Field-Finished Doors: Trimming to fit is acceptable.
  - 1. Adjust width of non-rated doors by cutting equally on both jamb edges.
  - 2. Trim maximum of 3/4 inch off bottom edges.

- 3. Trim fire-rated doors in strict compliance with fire rating limitations.
- D. Use machine tools to cut or drill for hardware.
- E. Coordinate installation of doors with installation of frames and hardware.
- F. Coordinate installation of glazing.
- G. Install door louvers plumb and level.

**3.03 TOLERANCES**

- A. Conform to specified quality standard for fit and clearance tolerances.
- B. Conform to specified quality standard for telegraphing, warp, and squareness.

**3.04 ADJUSTING**

- A. Adjust doors for smooth and balanced door movement.
- B. Adjust closers for full closure.

**3.05 SCHEDULE - SEE DRAWINGS**

**END OF SECTION**

**SECTION 08 31 00**  
**ACCESS DOORS AND PANELS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Wall and ceiling access door and frame units.

**1.02 RELATED REQUIREMENTS**

- A. Section 09 21 16 - Gypsum Board Assemblies: Openings in partitions.
- B. Section 09 21 16 - Gypsum Board Assemblies: Openings in ceilings.
- C. Section 09 30 00 - Tiling: Tile finishes on and around openings.
- D. Section 09 91 23 - Interior Painting: Field paint finish.
- E. Divisions 22, 23, 26, 27, and 28: Mechanical and Electrical components requiring access.
  - 1. Access doors in ductwork.

**1.03 REFERENCE STANDARDS**

- A. ITS (DIR) - Directory of Listed Products; current edition.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide sizes, types, finishes, hardware, scheduled locations, and details of adjoining work.
  - 1. If other than specified products by specified manufacturer, submit product data for each type of access door to be used. Include schedule of access door types, sizes and locations.
- C. Shop Drawings: Indicate exact position of each access door and/or panel unit.
  - 1. For access doors other than shown on Drawings, submit marked floor plan giving locations of all access doors. Submit shop drawing for Architect's review before laying out utility services which require access doors.
- D. Manufacturer's Installation Instructions: Indicate installation requirements.
- E. Project Record Documents: Record actual locations of each access unit.

**1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years documented experience.

**1.06 QUALITY ASSURANCE**

- A. Single-Source Responsibility: Obtain access doors for entire project from one source from a single manufacturer.

- B. Regulation Requirements: Fire rated access doors shall conform to California Building Code (CBC) Title 24, Part 2, Chapter 7. Panels shall bear the label of Underwriters Laboratories or other testing agency acceptable to the State Fire Marshal.
- C. Size Variations: Obtain Architect's acceptance of manufacturer's standard size units, which may vary slightly from sizes indicated.
- D. Coordination: Furnish inserts and anchoring devices for building into adjoining Work for installation of access doors.

### **1.07 PROJECT CONDITIONS**

- A. Verification: Obtain specific locations and sizes for required access doors for Work specified in Plumbing, Mechanical, Electrical or other Sections, for access to concealed equipment, and indicate on submitted schedule.
- B. Special-Size Access Doors: Sizes up to 20-inches by 30-inches used where necessary or as indicated. Indicate special size access doors on submitted schedule.

## **PART 2 PRODUCTS**

### **2.01 ACCESS DOORS AND PANELS**

- A. Access Door Materials and Fabrication, General: Provide each access door assembly manufactured as an integral unit, complete with all parts, and ready for installation.
  - 1. If size is not indicated, provide size as directed to adequately access concealed operable mechanisms.

### **2.02 ACCESS DOORS AND PANELS ASSEMBLIES**

- A. Wall-Mounted Units:
  - 1. Location: As indicated on drawings.
  - 2. Material: Steel.
  - 3. Size: 12 inch by 12 inch.
  - 4. Door/Panel: Hinged, standard duty, with tool-operated spring or cam lock and no handle.
  - 5. Wall Mounting Criteria: Provide surface-mounted face frame and door surface flush with frame surface.
  - 6. Gypsum Board Mounting Criteria: Provide drywall bead frame with door surface flush with wall surface.
- B. Wall-Mounted Units in Wet Areas:
  - 1. Material: Steel, hot-dipped zinc, or zinc-aluminum-alloy coated.
  - 2. Size: 12 inch by 12 inch.
  - 3. Door/Panel: Hinged, standard duty, with tool-operated spring or cam lock and no handle.
  - 4. Wall Mounting Criteria: Provide surface-mounted face frame and door surface flush with frame surface.

5. Gypsum Board Mounting Criteria: Provide drywall bead frame with door surface flush with wall surface.
- C. Ceiling-Mounted Units:
1. Material: Steel.
  2. Size - Other Ceilings: 12 inch by 12 inch.
  3. Door/Panel: Hinged, standard duty, with tool-operated spring or cam lock and no handle.

### **2.03 WALL AND CEILING MOUNTED UNITS**

- A. Manufacturers:
1. ACUDOR Products Inc: [www.acudor.com/#sle](http://www.acudor.com/#sle).
  2. Babcock-Davis: [www.babcockdavis.com](http://www.babcockdavis.com).
  3. Cendrex, Inc: [www.cendrex.com/#sle](http://www.cendrex.com/#sle).
  4. JL Industries Division of Activar, Inc.: [www.activarcpg.com/jl-industries](http://www.activarcpg.com/jl-industries).
  5. Larsen's Manufacturing Co.: [www.larsensmfg.com](http://www.larsensmfg.com).
  6. Karp Associates, Inc: [www.karpinc.com](http://www.karpinc.com).
  7. Milcor, Inc: [www.milcorinc.com](http://www.milcorinc.com).
  8. Nystrom, Inc: [www.nystrom.com](http://www.nystrom.com).
  9. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Wall and Ceiling Mounted Units: Factory fabricated door and frame, fully assembled units with corner joints welded, filled and ground flush; square and without rack or warp; coordinate requirements with type of installation assembly being used for each unit.
1. Style: As indicated on drawings.
  2. Door Style: Single thickness with rolled or turned in edges.
  3. Frames: 16 gage, 0.0598 inch, minimum thickness.
    - a. Exposed flange: Nominal 1-inch wide around perimeter of frame. Provide flange at flush-mounted (surface) access doors.
    - b. For installation at gypsum drywall or gypsum veneer plaster finishes: Provide perforated frames with drywall bead.
  4. Heavy Duty Frames: 14 gage, 0.0747 inch, minimum thickness.
  5. Heavy Duty Single Steel Sheet Door Panels: 14 gage, 0.0747 inch, minimum thickness.
  6. Insulation: Non-combustible mineral wool or glass fiber.
- C. Provide recess-mounted doors for concealed installation in:
1. Acoustical tile-finished gypsum board ceilings, where indicated.
  2. Gypsum board walls, where indicated.
  3. Ceramic tile walls, where indicated.



## **2.04 WALL AND CEILING GYPSUM BOARD ACCESS PANELS**

- A. Gypsum Board Access Panels: Provide rectangular, square, and circular access panel with recessed and gasketed aluminum perimeter frame that acts as finishing edge and having concealed mechanical touch-latch with safety cable and free-pivoting hinge.
  - 1. Rectangular Panel Frame Size: 24 by 36 inch set within 1/2 inch thick gypsum board.
  - 2. Square Panel Frame Size: 24 by 24 inch set within 1/2 inch thick gypsum board.
  - 3. Circular Ceiling Panel Frame Diameter: 24 inch set within 1/2 inch thick gypsum board.
  - 4. Panel Style: Standard style.
  - 5. Panel Frame: 1 inch margin with concealed countersunk screw mounting.

## **2.05 ACCESSORIES**

- A. Furnish attachment devices and fasteners of type required to secure access doors to types of support shown.
- B. Locks:
  - 1. Non-Rated Access Doors: By Manufacturer, type where indicated
    - a. Cam-action latch with special square-shanked key.
  - 2. Key all locks alike, unless otherwise scheduled.
  - 3. Where shown or scheduled, provide one cylinder lock per access door.
  - 4. For recess-mounted access doors, provide access sleeves for each locking device.
  - 5. Provide plastic grommets for installation in holes cut through finish.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that rough openings are correctly sized and located.
- B. Begin installation only after substrates have been properly prepared, and if the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

### **3.02 PREPARATION**

- A. Clean surfaces thoroughly prior to proceeding with this work.
- B. Prepare surfaces using methods recommended by manufacturer for applicable substrates in accordance with project conditions.

### **3.03 INSTALLATION**

- A. Install units in accordance with manufacturer's instructions, in compliance with requirements of listing authority..
- B. Install frames plumb and level in openings, and secure units rigidly in place.
- C. Provide for correct termination of adjoining finish materials.
- D. Position units to provide convenient access to concealed equipment when necessary.

### **3.04 ADJUST AND CLEAN**

- A. Adjust access doors and hardware after installation for proper and smooth operation.
- B. Remove and replace panels or frames that are warped, bowed, or otherwise damaged.
- C. Remove protective coverings and clean stainless steel access doors during cleaning for Substantial Completion Review.

### **3.05 SCHEDULES**

- A. Access Door Locations:
  - 1. Provide access doors where indicated on Architectural, Mechanical, Plumbing and Electrical Drawings.
  - 2. Access doors indicated and required for Mechanical, Plumbing and Electrical Work shall be of a type matching those specified in this Section.
  - 3. Provide access doors as required to service building systems and as required by governing authorities, although not shown on Drawings.
    - a. Provide at smoke or fire detector in attic spaces. Size to allow for access and testing.
  - 4. Locate access doors, where practical, in building service areas and not in public or guest view.
  - 5. Submit proposed locations for access doors, not indicated on Drawings, to Architect for review prior to rough-in.
- B. Non-Fire Rated Door and Frame Units in Walls:
  - 1. In Gypsum Board on Studs:
    - a. For service and utility locations, primer paint finish, Model DSC-214M manufactured by Karp.
    - b. For food service, toilet and damp locations, stainless steel, Model DSC-214M manufactured by Karp.
    - c. For Administration, Multi-Purpose and similar areas accessible by general public, recessed face for field-applied and finished plaster on door face, Model RDW manufactured by Karp.
    - d. For toilets and locations accessible by general public with ceramic tile wall finish, flush-mounted with face of tile, stainless steel, Model DSB-214M manufactured by Karp.
- C. Non-Fire Rated Door and Frame Units in Ceilings:
  - 1. In Gypsum Board on Metal Furring:
    - a. For service and utility locations, primer paint finish, Model DSC-214M manufactured by Karp.
    - b. For food service, toilet and damp locations, stainless steel, Model DSC-214M manufactured by Karp.
    - c. For Administration, Multi-Purpose and similar areas accessible by general public, recessed face for field-applied and finished plaster on door face, Model RDW manufactured by Karp.

### **END OF SECTION**



**SECTION 08 42 29**  
**AUTOMATIC ENTRANCES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Packaged power-operated door assemblies of following types:
  - 1. Sliding type.
- B. Controllers, actuators and safety devices.
- C. Maintenance.

**1.02 RELATED REQUIREMENTS**

- A. Section 26 05 83 - Wiring Connections.
- B. Section 28 10 00 - Access Control: Connection to access control system; access control devices used as actuators.
- C. Section 28 46 20 - Fire Alarm: Connection to fire alarm system.

**1.03 DEFINITIONS**

- A. AAADM: American Association of Automatic Door Manufacturers.

**1.04 REFERENCE STANDARDS**

- A. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- B. ASTM E283 - Standard Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen; 2004 (Reapproved 2012).
- C. BHMA A156.10 - American National Standard for Power Operated Pedestrian Doors; 2017.
- D. BHMA A156.19 - American National Standard for Power Assist and Low Energy Power Operated Doors; 2013.
- E. ITS (DIR) - Directory of Listed Products; current edition.
- F. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- G. NFPA 101 - Life Safety Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- H. UL (DIR) - Online Certifications Directory; Current Edition.
- I. UL 325 - Standard for Door, Drapery, Gate, Louver, and Window Operators and Systems; Current Edition, Including All Revisions.

**1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Shop Drawings:

1. Indicate layout and dimensions; head, jamb, and sill conditions; elevations; components, anchorage, recesses, materials, and finishes, electrical characteristics and connection requirements.
  2. Wiring Diagrams: For power, signal, and activation / safety device wiring.
  3. Identify installation tolerances required, assembly conditions, routing of service lines and conduit, and locations of operating components and boxes.
- C. Product Data: Provide data on system components, sizes, features, and finishes.
  - D. Samples: Submit two samples of exposed to view hardware, and attachment hardware.
  - E. Manufacturer's Installation Instructions: Indicate special procedures, perimeter conditions requiring special attention, and manufacturer's hardware and component templates.
  - F. Manufacturer's Qualification Statement.
  - G. Installer's Qualification Statement.
  - H. Maintenance Contract.
  - I. Project Record Documents: Record actual locations of concealed equipment, services, and conduit.
  - J. Maintenance Data: Include manufacturer's parts list and maintenance instructions for each type of hardware and operating component.
  - K. Warranty: Submit manufacturer warranty and ensure that forms have been completed in District's name and registered with manufacturer.
  - L. Maintenance Materials: Furnish the following for District's use in maintenance of project.
    1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.
    2. Wrenches and other tools required for maintenance of equipment.

#### **1.06 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than three years of documented experience, and a member of AAADM.
- B. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years documented experience.
  1. Certified by AAADM.

#### **1.07 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. Correct defective Work within a five year period after Date of Substantial Completion.
- C. Provide two year manufacturer warranty.

### **PART 2 PRODUCTS**

#### **2.01 REGULATORY REQUIREMENTS**

- A. Automatic and power-assisted doors shall comply with CBC Section 11B-404.3.

## 2.02 MANUFACTURERS

- A. Sliding Automatic Entrance Door Assemblies:
  - 1. Stanley Access Technologies; Dura-Glide 3000 Sliding: [www.stanleyaccess.com/#sle](http://www.stanleyaccess.com/#sle).
  - 2. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## 2.03 POWER OPERATED DOORS

- A. Power Operated Doors: Provide products that comply with NFPA 101 and requirements of authorities having jurisdiction; provide equipment selected for actual door weight and for light pedestrian traffic, unless otherwise indicated.
  - 1. Sliding and Folding Door Operators: In the event of power failure, provide for manual open, close, and break-away operation of door leaves.
  - 2. Packaged Door Assemblies: Provide components by single manufacturer, factory-assembled, including doors, frames, operators, actuators, and safeties.
    - a. Finish exposed equipment components to match door and frame finish.
  - 3. Air Leakage: Maximum of 1.0 cu ft/min/sq ft of wall area, when tested in accordance with ASTM E283 at 1.57 lbs/sq ft pressure differential across assembly.
- B. Sliding and Folding Doors with Full Power Operators: Comply with BHMA A156.10; safeties required; provide break-away operation unless otherwise indicated; in the event of break-away operation, interrupt power operation.
  - 1. Comply with UL 325; acceptable evidence of compliance includes UL (DIR) or ITS (DIR) listing or test report by testing agency acceptable to authorities having jurisdiction.
  - 2. Force Required to Swing Break-Away Panel: 50 pound-force, maximum, measured at 1 inch from the latch edge of the door at any point in the closing cycle.
- C. Operators:
  - 1. Electric Operators: 1/4 hp minimum, self-contained, gear driven.

## 2.04 AUTOMATIC ENTRANCE DOOR ASSEMBLIES

- A. Comply with ADA Standards for egress requirements.
- B. Framing and Transom Members: Provide manufacturer's standard extruded aluminum framing, reinforced as required to support imposed loads.
  - 1. Nominal Sizes:
    - a. Single Slide and Bi-Parting Sliding Doors: 1-3/4 inch wide by 4-1/2 inch deep.
  - 2. Concealed Fastening: Provide concealed fastening pocket in framing, with continuous flush insert cover extending full length of each framing member.
  - 3. Transoms: Provide flush glazed transom with framing that is integral with automatic entrance framing system.
- C. Door and Sidelight Construction: Heavy duty interlocked extruded aluminum tubular stile and rail sections, through-rod bolted construction with steel corner support at hinge stile of carrier-suspended swinging panels or mechanically fastened corners with welded reinforcing brackets to reduce sag in sliding or breakout mode.
  - 1. Door Thickness: 1-3/4 inch, nominal.

2. Stile Design:
    - a. Narrow stile, 2 inch, nominal width.
  3. Top Rail Height: 4 inch, nominal.
  4. Center Rail (Muntin Bar) Height: 2 inch, nominal.
  5. Bottom Rail Height: 4 inch, nominal.
  6. Glazing Stops: Manufacturer's standard snap-on extruded aluminum square stops with preformed resilient glazing gaskets.
  7. Glazing Stop Width: Manufacturers standard.
  8. Glazing Thickness: 5/8 inch, insulated.
- D. Sliding Automatic Door: Single leaf track-mounted, electric operation, extruded aluminum glazed door, with frame, and operator concealed overhead.
1. Operation: Power open, power boost operation.
  2. Exterior-Side Actuator/Safety: Motion sensor.
  3. Interior-Side Actuator/Safety: Motion sensor.
  4. Hold Open: Toggle switch at inside head of doors; this is not a fire-rated door.
  5. Door and Frame Finish: Same as adjacent framing system.

## **2.05 CONTROLLERS, ACTUATORS, AND SAFETIES**

- A. Controller: Provide microprocessor operated controller for each door.
- B. Comply with BHMA A156.10 for actuator and safety types and zones.
- C. Proximity Detector Actuator/Safety: Passive infrared; distance of control sensitivity adjustable.
- D. Performance Data: Microprocessor to collect and store performance data as follows:
  1. Counter: A non-resettable counter to track operating cycles.
  2. Event Reporting: Unit shall include event and error recording including number of occurrences of events and errors, and cycle count of most recent events and errors.
  3. LED Display: Display presenting the current operating state of the controller.

## **2.06 ELECTRICAL CHARACTERISTICS AND COMPONENTS**

- A. Electrical Characteristics:
  1. 1/4 hp.
  2. 4 rated load amperes.
  3. 120 volts, single phase, 60 Hz.
- B. Wiring Terminations: Provide terminal lugs to match branch circuit conductor quantities, sizes, and materials indicated. Enclose terminal lugs in terminal box sized to NFPA 70.
- C. Disconnect Switch: Factory mount disconnect switch in control panel.

## **2.07 ACCESSORIES**

- A. Steel Clips, Supports, and Steel Anchors: Galvanized to 1.25 oz/sq ft.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that surfaces are ready to receive work and dimensions are as indicated on shop drawings.
- B. Verify that electric power is available and is of the correct characteristics.

### **3.02 INSTALLATION**

- A. Install equipment in accordance with manufacturer's instructions.
- B. Provide for thermal expansion and contraction of door and frame units and live and dead loads that may be transmitted to operating equipment.
- C. Provide for dimensional distortion of components during operation.
- D. Coordinate installation of components with related and adjacent work; level and plumb.

### **3.03 FIELD QUALITY CONTROL**

- A. Manufacturers Field Services:
  - 1. Manufacturer's representative shall provide technical assistance and guidance for installation of doors.
  - 2. Before placing doors into operation, AAADM certified technician shall inspect and approve doors for compliance with BHMA A156.19. Certified technician shall be approved by manufacturer.

### **3.04 ADJUSTING**

- A. Adjust door equipment for correct function and smooth operation.
- B. Adjust doors in compliance with BHMA A156.19.

### **3.05 CLEANING**

- A. Remove temporary protection, clean exposed surfaces.

### **3.06 CLOSEOUT ACTIVITIES**

- A. Engage a factory-authorized representative to train District's maintenance personnel to adjust, operate, and maintain safe operation of the door.
- B. Demonstrate operation, operating components, adjustment features, and lubrication requirements.

### **3.07 MAINTENANCE**

- A. See Section 01 70 00 - Execution and Closeout Requirements, for additional requirements relating to maintenance service.
- B. Provide a separate maintenance contract for specified maintenance service.
- C. Provide service and maintenance of operating equipment for one year from Date of Substantial Completion, at no extra charge to District.



1. During the warranty period a factory-trained technician shall perform service and affect repairs. A safety inspection shall be performed after each adjustment or repair and a completed inspection form shall be submitted to the District.
2. During the warranty period all warranty work, including but not limited to emergency service, shall be performed during normal business hours.
3. Manufacturer shall have in place a dispatch procedure that shall be available 24 hours a Day, 7 Days a week for emergency call back service.

**END OF SECTION**

**SECTION 08 43 13**  
**ALUMINUM-FRAMED STOREFRONTS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Aluminum-framed storefront, with vision glass.
- B. Infill panels of glass.
- C. Aluminum doors and frames.
- D. Weatherstripping.
- E. Perimeter sealant.

**1.02 RELATED REQUIREMENTS**

- A. Section 05 50 00 - Metal Fabrications: Steel attachment devices.
- B. Section 06 10 00 - Rough Carpentry: Attachment to wood.
- C. Section 07 92 00 - Joint Sealants: Sealing joints between frames and adjacent construction.
- D. Section 08 42 29 - Automatic Entrances.
- E. Section 08 71 00 - Door Hardware: Hardware items other than specified in this section.
- F. Section 08 80 00 - Glazing: Glass and glazing accessories.
- G. Section 12 24 00 - Window Shades: Attachments to framing members.

**1.03 REFERENCE STANDARDS**

- A. AAMA 501.2 - Field Check of Metal Storefronts, Curtain Walls, and Sloped Glazing Systems for Water Leakage; 2009 (part of AAMA 501).
- B. AAMA 609 & 610 - Cleaning and Maintenance Guide for Architecturally Finished Aluminum (Combined Document); 2015.
- C. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- D. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures; Most Recent Edition Cited by Referring Code or Reference Standard.
  - 1. Use 2010 as indicated in 2016 CBC Referenced Standards.
- E. ASTM B209 - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate; 2014.
  - 1. Use 2010 as indicated in 2016 CBC Referenced Standards.
- F. ASTM B209M - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate (Metric); 2014.
- G. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes; 2014.
- H. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric); 2013.

- I. ASTM E283 - Standard Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen; 2004 (Reapproved 2012).
- J. ASTM E330/E330M - Standard Test Method for Structural Performance of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference; 2014.
  - 1. Use 2002 as indicated in 2016CBC Referenced Standards.
- K. ASTM E331 - Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference; 2000 (Reapproved 2016).
- L. SSPC-Paint 20 - Zinc-Rich Primers (Type I, "Inorganic," and Type II, "Organic"); 2002 (Ed. 2004).

#### **1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Coordinate with installation of other components that comprise the exterior enclosure.
- B. Preinstallation Meeting: Conduct a preinstallation meeting one week before starting work of this section; require attendance by all affected installers.

#### **1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Structural and Energy design of the system has already been used as a basis of approval by Division of the State Architect and other agencies. If a substitution is proposed, then the Contractor is responsible for the re-approval of the documents in a timely manner within the original project schedule, along with all professional and agency fees related to this substitution. See Section 01 63 00 - Product Substitution Procedures.
- C. Product Data: Provide component dimensions, describe components within assembly, anchorage and fasteners, glass and infill, internal drainage details.
  - 1. Include construction details and fabrication methods, profiles and dimensions of individual components, data on hardware, accessories, and finishes.
- D. Shop Drawings: Indicate system dimensions, framed opening requirements and tolerances, affected related work, expansion and contraction joint location and details, and field welding required.
  - 1. Complete, indicating elevation views of all units, attachments to surrounding construction of Project, type of glazing, and all door hardware and weatherstripping. All Shop Drawings shall be prepared by manufacturer and shall include manufacturer's logo.
- E. Samples: Submit two samples 2 x 3 inches in size illustrating finished aluminum surface, glass, glazing materials.
- F. Manufacturer's Certificate: Certify that the products supplied meet or exceed the specified requirements.
- G. Hardware Schedule: Complete itemization of each item of hardware to be provided for each door, cross-referenced to door identification numbers in Contract Documents.
- H. Field Quality Control Submittals: Report of field testing for water penetration and air leakage.
- I. Manufacturer's Qualification Statement.
- J. Installer's Qualification Statement.

- K. Warranty: Submit manufacturer warranty and ensure forms have been completed in District's name and registered with manufacturer.

#### **1.06 QUALITY ASSURANCE**

- A. Regulatory Requirements: Comply with Code requirements for safety glazing, accessibility and exit devices.
  - 1. Conform to applicable requirements of the ADA Standards regarding accessibility requirements for door and entrance hardware.
  - 2. Exit Doors: Openable at all times from the inside without the use of a key or any special knowledge or effort.
  - 3. Exit devices shall comply with CBC Section 1010.1.9.1 and 11B-404.2.7. Lever handle trim shall match locksets.
  - 4. Conform to applicable requirements of Title 24, Part 2, CCR, including Sections 11B-404.2.7, 11B-404.2.9, and 1010.1.9, regarding exiting and accessibility requirements for door and entrance hardware.
  - 5. Exterior doors to have 5 pounds maximum pressure to open and interior doors to have 5 pounds maximum pressure to open. The maximum effort to operate fire doors may be increased to the maximum allowable by the appropriate administrative authority, but in no case shall the pressure exceed 15 pounds. CBC 11B-404.2.9.
- B. Manufacturer Qualifications: Company specializing in performing work of type specified and with at least three years of documented experience.
- C. Installer Qualifications: Company specializing in performing work of type specified and with at least three years of documented experience and approved by manufacturer.
- D. Single-Source Responsibility: All entrances and storefront framing and doors, including finish, shall be the product of one manufacturer.

#### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Handle products of this section in accordance with AAMA CW-10.
- B. Protect finished aluminum surfaces with wrapping. Do not use adhesive papers or sprayed coatings that bond to aluminum when exposed to sunlight or weather.
  - 1. Store storefront sections out of contact with the ground and under a weather tight covering. Do not cover storefront sections with polyethylene film or similar coverings that will create a humidity chamber.
  - 2. Protect surfaces during shipping and handling to prevent scratching, gouging or other damage to the finish.

#### **1.08 FIELD CONDITIONS**

- A. Do not install sealants when ambient temperature is less than 40 degrees F. Maintain this minimum temperature during and 48 hours after installation.

#### **1.09 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.

- B. All doors shall carry manufacturer's lifetime warranty on door corner construction, provided in writing.
- C. Correct defective Work within a five year period after Date of Substantial Completion.
- D. Provide five year manufacturer warranty against failure of glass seal on insulating glass units, including interpane dusting or misting. Include provision for replacement of failed units.
- E. Provide five year manufacturer warranty against excessive degradation of exterior finish. Include provision for replacement of units with excessive fading, chalking, or flaking.

## **PART 2 PRODUCTS**

### **2.01 BASIS OF DESIGN -- FRAMING FOR INSULATING GLAZING**

- A. Front-Set Style, Thermally-Broken: As indicated on Drawings.
  - 1. Basis of Design: Arcadia Corp; Offset Glazed System TC470 Series - Thermal - Shear Block Inside Set: [www.arcadiainc.com](http://www.arcadiainc.com).
  - 2. Basis of Design: Arcadia Corp; Offset Glazed System TC670 Series - Thermal - Shear Block Inside Set: [www.arcadiainc.com](http://www.arcadiainc.com).
  - 3. Vertical Mullion Dimensions: 2 inches wide by 4-1/2 inches deep.
  - 4. Vertical Mullion Dimensions: 2 inches wide by 6 inches deep.

### **2.02 BASIS OF DESIGN -- FRAMING FOR MONOLITHIC GLAZING**

- A. Center-Set Style: (Interior)
  - 1. Basis of Design: Arcadia Corp; Center Glazed System A400 Series - Non-Them - Shear Block Inside Set: [www.arcadiainc.com](http://www.arcadiainc.com).
  - 2. Vertical Mullion Dimensions: 1-3/4 inches wide by 4 inches deep.

### **2.03 BASIS OF DESIGN -- SWINGING DOORS**

- A. Wide Stile, Insulating Glazing, Thermally-Broken:
  - 1. Basis of Design: Arcadia Corp; WS512HD Series Heavy Duty Wide Stile: [www.arcadiainc.com](http://www.arcadiainc.com).

### **2.04 ACCEPTABLE MANUFACTURERS**

- A. Other Manufacturers: Provide either the product identified as "Basis of Design" or an equivalent product of another manufacturer
- B. Aluminum-Framed Storefront and Doors:
  - 1. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
    - a. For any product not identified as "Basis of Design", submit information as specified for substitutions.
    - b. Substitution may or may not be accepted after Architect and District review with complete evaluation for content and schedule impact.
    - c. Substitutions shall include all costs for redesign with consequential changes by other trades along with the Architect and related approvals by governing agencies.

- 1) Revision to shop drawings illustrating changes is not considered adequate for DSA review and approval.
- d. Substitutions may be acceptable, based on Architect's review and approval, for submittal to DSA.
  - 1) If substituted manufacturer cannot reproduce design and DSA approval in a timely manner, then they shall be subject to a time and material back charge for any delays in the project.
  - 2) Architect approval is required prior to DSA submittal and DSA approval is required prior to installation.

## **2.05 ALUMINUM-FRAMED STOREFRONT**

- A. Aluminum-Framed Storefront: Factory fabricated, factory finished aluminum framing members with infill, and related flashings, anchorage and attachment devices.
  1. Glazing Rabbet: For 1 inch insulating glazing.
  2. Finish: Superior performing organic coatings.
    - a. Factory finish all surfaces that will be exposed in completed assemblies.
    - b. Touch-up surfaces cut during fabrication so that no natural aluminum is visible in completed assemblies, including joint edges.
    - c. Coat concealed metal surfaces that will be in contact with cementitious materials or dissimilar metals with bituminous paint.
  3. Finish Color: As selected by Architect from manufacturer's standard line.
  4. Fabrication: Joints and corners flush, hairline, and weatherproof, accurately fitted and secured; prepared to receive anchors and hardware; fasteners and attachments concealed from view; reinforced as required for imposed loads.
  5. Construction: Eliminate noises caused by wind and thermal movement, prevent vibration harmonics, and prevent "stack effect" in internal spaces.
  6. System Internal Drainage: Drain to the exterior by means of a weep drainage network any water entering joints, condensation occurring in glazing channel, and migrating moisture occurring within system.
  7. Expansion/Contraction: Provide for expansion and contraction within system components caused by cycling temperature range of 170 degrees F over a 12 hour period without causing detrimental effect to system components, anchorages, and other building elements.
  8. Movement: Allow for movement between storefront and adjacent construction, without damage to components or deterioration of seals.
  9. Perimeter Clearance: Minimize space between framing members and adjacent construction while allowing expected movement.
  10. Air and Vapor Seal: Maintain continuous air barrier and vapor retarder throughout assembly, primarily in line with inside pane of glazing and inner sheet of infill panel and heel bead of glazing compound.
  11. Preparation for Window Treatments: Provide reinforced interior horizontal head rail.
- B. Performance Requirements:

1. Wind Loads: Design and size components to withstand the specified load requirements without damage or permanent set, when tested in accordance with ASTM E330/E330M, using loads 1.5 times the design wind loads and 10 second duration of maximum load.
  - a. Design Wind Loads: Comply with requirements of ASCE 7.
  - b. Member Deflection: Limit member deflection to flexure limit of glass or 1/175 of span, maximum 3/4 inch (over 11'-0" span), in any direction, with full recovery of glazing materials.
2. Water Penetration Resistance on Manufactured Assembly: No uncontrolled water on interior face, when tested in accordance with ASTM E331 at pressure differential of 12 psf.
3. Air Leakage Laboratory Test: Maximum of 0.06 cu ft/min sq ft of wall area, when tested in accordance with ASTM E283 at 6.27 psf pressure differential across assembly.
4. Resistance to Forcible Entry: Jambs adjacent to door locks shall resist a force of 1600 pounds.

## **2.06 COMPONENTS**

- A. Aluminum Framing Members: Tubular aluminum sections, drainage holes and internal weep drainage system.
  1. Framing members for interior applications need not be thermally broken.
  2. Glazing Stops: Flush.
  3. Cross-Section: As indicated on drawings.
  4. Structurally Reinforced Members: Extruded aluminum with internal reinforcement of structural steel member.
- B. Glazing: As specified in Section 08 80 00.
  1. For Exterior Framing: Type as indicated on Drawings.
  2. For Interior Framing: Type as indicated on Drawings.
- C. Swing Doors: Glazed aluminum.
  1. Thickness: 1-3/4 inches.
  2. Top Rail: 5-1/8 inches wide, nominal.
  3. Vertical Stiles: 5 inches wide, nominal. Coordinate with hardware for a complete installation.
  4. Bottom Rail: 10 inches high, minimum.
  5. Glazing Stops: Beveled.
  6. Finish: Same as storefront.

## **2.07 MATERIALS**

- A. Extruded Aluminum: ASTM B221 (ASTM B221M).
- B. Sheet Aluminum: ASTM B209 (ASTM B209M).
- C. Fasteners: Stainless steel.

- D. Exposed Flashings: Aluminum sheet, 20 gage, 0.032 inch minimum thickness; finish to match framing members.
- E. Concealed Flashings: Sheet aluminum, 26 gage, 0.017 inch minimum thickness.
- F. Perimeter Sealant: Type as specified in Section 07 92 00 - Joint Sealants.
- G. Glazing Gaskets: Type to suit application to achieve weather, moisture, and air infiltration requirements.
- H. Glazing Accessories: As specified in Section 08 80 00.
- I. Shop and Touch-Up Primer for Steel Components: Zinc oxide, alkyd, linseed oil primer appropriate for use over hand cleaned steel.
- J. Touch-Up Primer for Galvanized Steel Surfaces: SSPC-Paint 20, zinc rich.

## 2.08 FINISHES

- A. Superior Performing Organic Coatings System: Polyvinylidene fluoride (PVDF) multi-coat superior performing organic coatings system complying with AAMA 2605, including at least 70 percent PVDF resin, and at least 80 percent of aluminum extrusion and panels surfaces having minimum total dry film thickness (DFT) of 1.2 mils, 0.0012 inch.
  - 1. Manufacturers:
    - a. PPG Metal Coatings; Duranar: [www.ppgmetalcoatings.com/#sle](http://www.ppgmetalcoatings.com/#sle).
    - b. Sherwin-Williams Company; SHER-NAR 5000: [oem.sherwin-williams.com/#sle](http://oem.sherwin-williams.com/#sle).
    - c. Valspar; Fluropon: [www.valsparcoilextrusion.com/#sle](http://www.valsparcoilextrusion.com/#sle).
- B. Color: As selected by Architect from manufacturer's full range.
- C. Touch-Up Materials: As recommended by coating manufacturer for field application.

## 2.09 HARDWARE

- A. For each door, include weatherstripping, sill sweep strip, and threshold.
- B. Door Hardware for Aluminum Entrances and Storefronts:
  - 1. Install standard door hardware as specified in this Section and custom hardware and door thresholds as specified in Section 08 71 00 - Door Hardware.
  - 2. Hardware shall be operable with one hand and not require tight gripping, pinching or twisting of the wrist.
  - 3. Mounting heights as indicated on Section 08 71 00 Door Hardware.
- C. Hardware Finish: Plated or metallic finish, BHMA 626 satin chrome, BHMA 627 satin aluminum and BHMA 630 satin stainless steel, as applicable.
- D. Other Door Hardware: As specified in Section 08 71 00.
- E. Weatherstripping: manufacturer's standard replaceable compressible weatherstripping gaskets of molded neoprene complying with ASTM D2000 or molded PVC complying with ASTM D2287, continuous and replaceable; provide on all exterior doors.
  - 1. Provide manufacturer's optional bottom rail weathering strip.
  - 2. Retainer finish to match door.
- F. Sill Sweep Strips: Resilient seal type, retracting, of neoprene; provide on all doors.



- G. Threshold: Extruded aluminum, one piece per door opening, ribbed surface; provide on all doors.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify dimensions, tolerances, and method of attachment with other work.
  - 1. Dimensions: Verify dimensions shown on Drawings and obtain field measurements of actual construction prior to preparing shop drawings and ordering products.
  - 2. Substrate Conditions: Verify that conditions of substrate and adjoining Work are suitable for proper installation of entrance and storefront Work.
- B. Verify that wall openings and adjoining air and vapor seal materials are ready to receive work of this section.

### **3.02 INSTALLATION**

- A. Install wall system in accordance with manufacturer's instructions.
- B. Anchoring: Firmly anchor framing using fasteners as recommended by manufacturer, sized to suit loads and type suitable for substrate, to positively attach members for long life under hard use.
- C. Attach to structure to permit sufficient adjustment to accommodate construction tolerances and other irregularities.
- D. Provide alignment attachments and shims to permanently fasten system to building structure.
- E. Align assembly plumb and level, free of warp or twist. Maintain assembly dimensional tolerances, aligning with adjacent work.
- F. Provide thermal isolation where components penetrate or disrupt building insulation.
- G. Install sill flashings. Turn up ends and edges; seal to adjacent work to form water tight dam.
  - 1. Comply with requirements specified in Section 07 62 00 - Sheet Metal Flashing and Trim. Set sill flashing in bedding sealant as specified in Section 07 92 00 - Joint Sealants.
- H. Where fasteners penetrate sill flashings, make watertight by seating and sealing fastener heads to sill flashing.
- I. Coordinate attachment and seal of perimeter air and vapor barrier materials.
- J. Internal wiring:
  - 1. Failed wiring connections shall be replaced at no additional cost to District.
- K. Pack fibrous insulation in shim spaces at perimeter of assembly to maintain continuity of thermal barrier.
- L. Door Installation: Assemble doors in shop with glazing installed.
  - 1. Door Joints: Make joints rigid and suitable for heavy use.
  - 2. Set thresholds in bed of sealant and secure.
  - 3. Adjustment: Adjust operating hardware and door operation for smooth movements, without binding and without exceeding allowable forces of accessibility regulations.

- M. Install glass in accordance with Section 08 80 00, using glazing method required to achieve performance criteria.
- N. Install perimeter sealant in accordance with Section 07 92 00 - Joint Sealants.
- O. Touch-up minor damage to factory applied finish; replace components that cannot be satisfactorily repaired.

### **3.03 TOLERANCES**

- A. Maximum Variation from Plumb: 0.06 inch per 3 feet non-cumulative or 0.06 inch per 10 feet, whichever is less.

### **3.04 FIELD QUALITY CONTROL**

- A. Provide services of storefront manufacturer's field representative to observe for proper installation of system and submit report.
- B. See Section 01 45 00 - Quality Control, for general testing and inspection requirements by Contractor.
- C. Water-Spray Test: Provide water spray quality test of installed storefront components in accordance with 1 during construction process and before installation of interior finishes.
  - 1. Perform a minimum of two tests in each designated area as indicated on drawings.
  - 2. Conduct tests in each area prior to 10 percent and 50 percent completion of this work.
  - 3. Testing: Water test all storefront and glazing after completion by spraying with hose heavily for 5 minutes. Repair all leaks discovered by testing procedures and repeat test until leak-free performance is achieved.
  - 4. Provide written report to Architect and IOR.
- D. Repair or replace storefront components that have failed designated field testing, and retest to verify performance complies with specified requirements.

### **3.05 ADJUSTING**

- A. Adjust operating hardware and sash for smooth operation.

### **3.06 CLEANING**

- A. Remove protective material from pre-finished aluminum surfaces.
- B. Wash down surfaces with a solution of mild detergent in warm water, applied with soft, clean wiping cloths, and take care to remove dirt from corners and to wipe surfaces clean.
  - 1. Flush thoroughly and wipe surfaces clean.
  - 2. Remove excess sealant by moderate use of mineral spirits or other solvent acceptable to sealant manufacturer.
- C. Upon completion of installation, thoroughly clean aluminum surfaces in accordance with AAMA 609 & 610.
- D. Remove excess sealant by method acceptable to sealant manufacturer.
- E. Glass Cleaning: See Section 08 80 00 - Glazing.

**END OF SECTION**



**SECTION 08 71 00**  
**DOOR HARDWARE**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Hardware for wood, aluminum, and hollow metal doors.
- B. Electrically operated and controlled hardware.
- C. Lock cylinders for doors that hardware is specified in other sections.
- D. Thresholds.
- E. Weatherstripping and gasketing.

**1.02 RELATED REQUIREMENTS**

- A. Section 06 41 00 - Architectural Wood Casework: Cabinet hardware.
- B. Section 07 92 00 - Joint Sealants: Sealants for setting exterior door thresholds.
- C. Section 08 06 71 - Door Hardware Schedule: Schedule of door hardware sets.
- D. Section 08 11 13 - Hollow Metal Doors and Frames.
- E. Section 08 14 16 - Flush Wood Doors.
- F. Section 08 43 13 - Aluminum-Framed Storefronts: Door hardware, except as noted in section.
- G. Section 10 14 00 - Signage: Additional signage requirements.
- H. Section 28 10 00 - Access Control: Electronic access control devices.

**1.03 REFERENCE STANDARDS**

- A. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- B. BHMA (CPD) - Certified Products Directory; 2017.
- C. BHMA A156.1 - American National Standard for Butts and Hinges; 2016.
- D. BHMA A156.3 - American National Standard for Exit Devices; 2014.
- E. BHMA A156.4 - American National Standard for Door Controls - Closers; 2013.
- F. BHMA A156.5 - American National Standard for Cylinders and Input Devices for Locks; 2014.
- G. BHMA A156.7 - American National Standard for Template Hinge Dimensions; 2016.
- H. BHMA A156.8 - American National Standard for Door Controls - Overhead Stops and Holders; 2015.
- I. BHMA A156.15 - American National Standard for Release Devices - Closer Holder, Electromagnetic and Electromechanical; 2015.
- J. BHMA A156.16 - American National Standard for Auxiliary Hardware; 2013.
- K. BHMA A156.17 - American National Standard for Self Closing Hinges & Pivots; 2014.
- L. BHMA A156.20 - American National Standard for Strap and Tee Hinges, and Hasps; 2006 (Reaffirmed 2012).
- M. BHMA A156.21 - American National Standard for Thresholds; 2014.

- N. BHMA A156.22 - American National Standard for Door Gasketing and Edge Seal Systems, Builders Hardware Manufacturers Association; 2017.
- O. BHMA A156.25 - American National Standard for Electrified Locking Devices; 2013.
- P. BHMA A156.26 - American National Standard for Continuous Hinges; 2012.
- Q. BHMA A156.28 - American National Standard for Recommended Practices for Mechanical Keying Systems; 2013.
- R. BHMA A156.31 - American National Standard for Electric Strikes and Frame Mounted Actuators; 2013.
- S. BHMA A156.115 - American National Standard for Hardware Preparation in Steel Doors and Steel Frames; 2016.
- T. BHMA A156.115W - Hardware Preparation in Wood Doors with Wood or Steel Frames; 2006.
- U. DHI (H&S) - Sequence and Format for the Hardware Schedule; 1996.
- V. DHI (KSN) - Keying Systems and Nomenclature; 1989.
- W. DHI (LOCS) - Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames; 2004.
- X. DHI WDHS.3 - Recommended Locations for Architectural Hardware for Flush Wood Doors; 1993; also in WDHS-1/WDHS-5 Series, 1996.
- Y. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- Z. UL (DIR) - Online Certifications Directory; Current Edition.

#### **1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Coordinate the manufacture, fabrication, and installation of products that door hardware is installed on.
- B. Sequence installation to ensure utility connections are achieved in an orderly and expeditious manner.
- C. Preinstallation Meeting: Convene a preinstallation meeting one week prior to commencing work of this section; attendance is required by affected installers and the following:
  - 1. Architect.
  - 2. Installer's Architectural Hardware Consultant (AHC).
  - 3. Hardware Installer.
  - 4. Owner's Security Consultant.
- D. Furnish templates for door and frame preparation to manufacturers and fabricators of products requiring internal reinforcement for door hardware.
- E. Keying Requirements Meeting:
  - 1. Schedule meeting at project site prior to Contractor occupancy.
  - 2. Attendance Required:
    - a. Contractor.
    - b. District and relevant staff.
    - c. Architect.

- d. Installer's Architectural Hardware Consultant (AHC).
  - e. Hardware Installer.
3. Agenda:
    - a. Establish keying requirements.
    - b. Verify locksets and locking hardware are functionally correct for project requirements.
    - c. Verify that keying and programming complies with project requirements.
    - d. Establish keying submittal schedule and update requirements.
  4. Incorporate "Keying Requirements Meeting" decisions into keying submittal upon review of door hardware keying system including, but not limited to, the following:
    - a. Access control requirements.
    - b. Key control system requirements.
    - c. Schematic diagram of preliminary key system.
  5. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, District, participants, and those affected by decisions made.
    - a. Furnish District's written approval of the system; do not order keys or cylinders without written confirmation of actual requirements from the District.
  6. Deliver established keying requirements to manufacturers.

#### **1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Manufacturer's catalog literature for each type of hardware, marked to clearly show products to be furnished for this project, and includes construction details, material descriptions, finishes, and dimensions and profiles of individual components.
- C. Shop Drawings - Door Hardware Schedule: Submit detailed listing that includes each item of hardware to be installed on each door. Use door numbering scheme as included in Contract Documents.
  1. Prepared by or under supervision of Architectural Hardware Consultant (AHC).
  2. Comply with DHI (H&S) using door numbers and hardware set numbers as indicated in construction documents.
    - a. Submit in vertical format, refer to Section 08 06 71.
  3. List groups and suffixes in proper sequence.
  4. Provide complete description for each door listed.
  5. Provide manufacturer's and product names, and catalog numbers; include functions, types, styles, sizes and finishes of each item.
  6. Include account of abbreviations and symbols used in schedule.
- D. Shop Drawings - Electrified Door Hardware: Submit diagrams for power, signal, and control wiring for electrified door hardware that include details of interface with building safety and security systems. Provide elevations and diagrams for each electrified door opening as follows:

1. Prepared by or under supervision of Architectural Hardware Consultant (AHC) and Electrified Hardware Consultant (EHC).
  2. Elevations: Submit front and back elevations of each door opening showing electrified devices with connections installed and an operations narrative describing how opening operates from either side at any given time.
  3. Diagrams: Submit point-to-point wiring diagram that shows each device in door opening system with related colored wire connections to each device.
- E. Samples for Verification:
1. Submit minimum size of 2 by 4 inch for sheet samples, and minimum length of 4 inch for other products.
  2. Submit one (1) sample of hinge, latchset, lockset, and closer illustrating style, color, and finish.
  3. Return full-size samples to be incorporated into this Work.
  4. Submit product description with samples.
- F. Manufacturer's Installation Instructions: Indicate special procedures and perimeter conditions requiring special attention.
- G. Maintenance Data: Include data on operating hardware, lubrication requirements, and inspection procedures related to preventative maintenance.
1. Submit manufacturer's parts lists and templates.
  2. Bitting List: List of combinations as furnished.
- H. Keying Schedule:
1. Submit three (3) copies of Keying Schedule in compliance with requirements established during Keying Requirements Meeting unless otherwise indicated.
- I. Installer's Qualification Statement.
- J. Supplier's Qualification Statement.
- K. District Responsibilities for submittal review:
1. Complete keying schedule.
  2. Complete keying legend.
  3. Provide original letter of authorization allowing hardware supplier to purchase keying hardware and to have the bitting list sent to District.
  4. Provide District the locksmith's name, address, phone number and email.
  5. Identify how doors are to be keyed.
  6. For existing systems, provide the registry number.
- L. Warranty: Submit manufacturer's warranty and ensure that forms have been completed in District's name and registered with manufacturer.
- M. Project Record Documents: Record actual locations of concealed equipment, services, and conduit.
- N. Maintenance Materials and Tools: Furnish the following for District's use in maintenance of project.

1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.
2. Lock Cylinders: Ten for each master keyed group.
3. Temporary Cores: Return to and receipt by Contractor.
4. Tools: Two sets of each special wrench or tool applicable for each different or special hardware component, whether supplied by hardware component manufacturer or not.

#### **1.06 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum three years of documented experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified for commercial door hardware with at least three years of documented experience.
- C. Supplier Qualifications: Company with certified Architectural Hardware Consultant (AHC) and Electrified Hardware Consultant (EHC) to assist in work of this section.

#### **1.07 REGULATORY REQUIREMENTS**

- A. Comply with State Fire Marshal Standard 12-10-3 Exits, Section 12-10-302.
  1. The cross-bar shall extend across not less than one-half the width of the door/gate.
  2. The ends of the cross-bar shall be curved, guarded or otherwise designed to prevent catching on the clothing of persons during egress.
- B. Conform to applicable requirements of the Americans with Disabilities Act Accessibility Guidelines regarding accessibility requirements for door and entrance hardware including gates.
  1. Doors/doorways as part of an accessible route shall comply with CBC Sections 11B-404.
  2. Doors shall meet California Building Code Sections 11B-206.5, 11b-404.1 and 1010.1.
  3. The clear opening width for a door shall be 32 inches minimum. CBC Section 11B-404.2.3
    - a. For a swinging door it shall be measured between the face of the door and the stop, with the door open 90 degrees.
    - b. There shall be no projections into it below 34 inches and 4 inches maximum projections into it between 34 inches and 80 inches above the finish floor or ground.
    - c. Door closers and stops shall be permitted to be 78 inches minimum above the finish floor or ground.
    - d. Exception: Doors not requiring full passage through the opening, that is, to spaces less than 24 inches in depth, may have the clear opening width reduced to 20 inches. Example: shallow closets.
  4. Handles, pulls, latches, locks, and other operable parts on accessible doors shall comply with CBC Section 11B-309.4 and shall be operable with one hand and shall not require tight grasping, pinching, or twisting of the wrist.
    - a. Operable parts of such hardware shall be 34 inches minimum and 44 inches maximum above finish floor or ground.
    - b. Where sliding doors are in the fully open position, operating hardware shall be exposed and usable from both side. CBC Section 11B-404.2.7



5. The force for pushing or pulling open a door shall be as follows : CBC Section 11B-404.2.9.
  - a. Interior Hinged Doors, sliding or folding doors, and exterior hinged doors: 5 lbs maximum.
  - b. Required Fire Doors: the maximum opening force allowable by the DSA authority, not to exceed 15 lbs..
  - c. These forces do not apply to the force required to retract latch bolts or disengage other devices that hold the door in a closed position.
  - d. The force required to activate any operable parts, such as retracting latch bolts or disengaging other devices, shall be 5 lbs. maximum to comply with CBC Section 11B-309.4.
6. Door closing speed shall be as follows: CBC Section 11B-404.2.8
  - a. Closer shall be adjusted so that the required time to move a door from an open position of 90 degrees to a position of 12 degrees from the latch is 5 seconds minimum.
  - b. Spring hinges shall be adjusted so that the required time to move a door from an open position of 70 degrees to the closed position is 1.5 seconds minimum.
7. Thresholds shall comply with CBC Section 11B-404.2.5.
8. Floor stops shall not be located in the path of travel and 4 inches maximum from walls.
9. Pair of doors: Limit swing of one leaf to 90 degrees so that a clear floor space is provided beyond the arc of the swing for the wall-mounted tactile sign. CBC Section 11B-703.4.2.1
- C. Door and door hardware encroachment: when door is swung fully-open into means-of-egress path, the door, including the hardware, may not encroach or project more than 7 inches into the required exit width. California Building Code 1005.7.1.

#### **1.08 DELIVERY, STORAGE, AND HANDLING**

- A. Package hardware items individually; label and identify each package with door opening code to match door hardware schedule.

#### **1.09 PROJECT CONDITIONS AND COORDINATION:**

- A. Where exact types of hardware specified are not adaptable to finished shape or size of members requiring hardware, provide suitable types having as nearly as practical the same operation and quality as type specified, subject to Architect's approval.
- B. Coordination:
  1. Coordinate hardware with other work.
  2. Provide hardware items of proper design for use on doors and frames of the thickness, profile, swing, security and similar requirements indicated, as necessary for proper installation and function, regardless of omissions or conflicts in the information on the Contract Documents.
  3. Furnish related trades with the following information:
    - a. Location of embedded and attached items to concrete.
    - b. Location of wall-mounted hardware, including wall stops.
    - c. Location of finish floor materials and floor-mounted hardware.

- d. Locations for conduit and raceways as needed for electrical, electronic and electro-pneumatic hardware items.
    - 1) Fire/life-safety system interfacing.
    - 2) Point-to-point wiring diagrams plus riser diagrams to related trades.
  - e. Coordinate: flush top rails of doors at outswinging exteriors, and throughout where adhesive-mounted seals occur.
  - f. Manufacturers' templates to door and frame fabricators.
- C. Check Shop Drawings for doors and entrances to confirm that adequate provisions will be made for proper hardware installation.

### **1.10 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. Warranty against defects in material and workmanship for period indicated, from Date of Substantial Completion.
  - 1. Closers: Five years, minimum.
    - a. Mechanical thirty year year for door closers.
    - b. Electrical two year year for door closers.
  - 2. Exit Devices: Three years, minimum.
  - 3. Locksets and Cylinders: Three years, minimum.
    - a. Seven years for extra heavy-duty cylindrical lock.
  - 4. Other Hardware: Two years, minimum.

## **PART 2 PRODUCTS**

### **2.01 DESIGN AND PERFORMANCE CRITERIA**

- A. Provide specified door hardware as required to make doors fully functional, compliant with applicable codes, and secure to extent indicated.
- B. Provide individual items of single type, of same model, and by same manufacturer.
- C. Provide door hardware products that comply with the following requirements:
  - 1. Applicable provisions of federal, state, and local codes.
  - 2. Accessibility: ADA Standards, CBC Chapter 11B.
  - 3. Listed and certified compliant with specified standards by BHMA (CPD).
  - 4. Auxiliary Hardware: BHMA A156.16.
  - 5. Straps and Tee Hinges: BHMA A156.20.
  - 6. Hardware Preparation for Steel Doors and Steel Frames: BHMA A156.115.
  - 7. Hardware Preparation for Wood Doors with Wood or Steel Frames: BHMA A156.115W.
  - 8. Products Requiring Electrical Connection: Listed and classified by UL (DIR) as suitable for the purpose specified.
- D. Electrically Operated and/or Controlled Hardware: Provide necessary power supplies, power transfer hinges, relays, and interfaces as required for proper operation; provide wiring

between hardware and control components and to building power connection in compliance with NFPA 70.

1. Refer to Section 28 10 00 for additional access control system requirements.
- E. Lock Function: Provide lock and latch function numbers and descriptions of manufacturer's series. Refer to Section 08 06 71 for listing of hardware sets.
  1. Exit Doors: Openable at all times from the inside without the use of a key or any special knowledge or effort.
- F. Fasteners:
  1. Provide fasteners of proper type, size, quantity, and finish that comply with commercially recognized standards for proposed applications.
    - a. Aluminum fasteners are not permitted.
    - b. Provide phillips flat-head screws with heads finished to match door surface hardware unless otherwise indicated.
  2. Provide machine screws for attachment to reinforced hollow metal and aluminum frames.
    - a. Self-drilling (Tek) type screws are not permitted.
  3. Provide stainless steel machine screws and lead expansion shields for concrete and masonry substrates.
  4. Coordinate With Doors: Ensure provision of proper blocking to support wood screws at wood doors and machine screws at metal doors/frames to mounting panic hardware and door closers.
  5. No through-bolts are allowed on any door type.
  6. Concealed Fasteners: Do not use through or sex bolt type fasteners on door panel sides indicated as concealed fastener locations, unless otherwise indicated.

## 2.02 HINGES

- A. Hinges: Comply with BHMA A156.1, Grade 1.
  1. Self Closing Hinges: Comply with BHMA A156.17.
  2. Butt Hinges: Comply with BHMA A156.1 and BHMA A156.7 for templated hinges.
    - a. Provide hinge width required to clear surrounding trim.
    - b. Drawings typically depict doors at 90 degrees, doors will actually swing to maximum allowable.
      - 1) Use wide-throw conventional or continuous hinges as needed up to 8 inches in width to allow door to stand parallel to wall for true 180-degree opening.
      - 2) Advise Architect if 8 inch width is insufficient.
    - c. Conform to manufacturer's published hinge selection standard for door dimensions, weight and frequency, and to hinge selection as scheduled.
      - 1) Where manufacturer's standard exceeds the scheduled product, furnish the heavier of the two choices, notify Architect of deviation from scheduled hardware.
    - d. Conventional Hinges: Steel or stainless steel pins and concealed bearings. Hinge open widths minimum, but of sufficient throw to permit maximum door swing.

3. Continuous Hinges: Comply with BHMA A156.26.
  - a. Pinned steel/stainless steel type: continuous stainless steel, 0.25-inch diameter stainless-steel hinge pin.
    - 1) Use engineered application-specific wide-throw units as needed to provide maximum swing degree of swing, advise Architect if required width exceeds 8 inches.
4. Provide hinges on every swinging door.
5. Provide five-knuckle full mortise butt hinges unless otherwise indicated.
6. Provide ball-bearing hinges at each door with closer.
7. Provide non-removable pins on exterior outswinging doors.
  - a. Out-swinging exterior doors: Non-ferrous with non-removable (NRP) pins and security studs.
  - b. Non-ferrous material exteriors and at doors subject to corrosive atmospheric conditions.
8. Provide non-removable pins on interior outswinging doors at locations as indicated in Door Hardware Schedule.
9. Provide power transfer hinges where electrified hardware is mounted in door leaf.
10. Provide following quantity of butt hinges for each door:
  - a. Doors up to 60 inches High: Two hinges.
  - b. Doors From 60 inches High up to 90 inches High: Three hinges.
  - c. Doors 90 inches High up to 120 inches High: Four hinges.

### **2.03 POWER TRANSFER DEVICES**

- A. Quick Connect Transfer Hinge Manufacturers:
  1. McKinney; an Assa Abloy Group company: QC (# Wires): [www.assaabloydss.com](http://www.assaabloydss.com).
  2. Hager Companies: ETW-QC (# Wires): [www.hagerco.com](http://www.hagerco.com).
  3. Stanley, dormakaba Group: C: [www.stanleyhardwarefordoors.com/#sle](http://www.stanleyhardwarefordoors.com/#sle).
  4. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Door Wire Harnesses Manufacturers:
  1. McKinney; an Assa Abloy Group company: QC-C Series: [www.assaabloydss.com](http://www.assaabloydss.com).
  2. Hager Companies: Quick Connect: [www.hagerco.com](http://www.hagerco.com).
  3. Stanley, dormakaba Group: WH Series: [www.stanleyhardwarefordoors.com/#sle](http://www.stanleyhardwarefordoors.com/#sle).
  4. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- C. Concealed Quick Connect Electric Power Transfers: Provide concealed wiring pathway housing mortised into the door and frame for low voltage electrified door hardware.
- D. Connectors and Wires:
  1. ElectroLynx™ standardized plug connectors and sufficient number of concealed wires (up to 12) to accommodate the electrified functions specified in the Door Hardware Sets. Connectors plug directly to through-door wiring harnesses for connection to electric locking devices and power supplies.

- E. Wire nut connections are not acceptable.
- F. Electric Door Wire Harnesses:
  - 1. Provide electric/data transfer wiring harnesses with standardized plug connectors to accommodate up to twelve (12) wires.
  - 2. Connectors plug directly to through-door wiring harnesses for connection to electric locking devices and power supplies.
  - 3. Provide a connector for through-door electronic locking devices and from hinge to junction box above the opening.
  - 4. Provide sufficient number and type of concealed wires to accommodate electric function of specified hardware.
  - 5. Determine the length required for each electrified hardware component for the door type, size and construction, minimum of two per electrified opening.
  - 6. Provide one each of the following tools as part of the base bid contract:
    - a. McKinney; an Assa Abloy Group company: Electrical Connecting Kit: QC-R001: [www.assaabloydss.com](http://www.assaabloydss.com).
    - b. McKinney; an Assa Abloy Group company: Connector Hand Tool: QC-R003: [www.assaabloydss.com](http://www.assaabloydss.com).

#### **2.04 EXIT DEVICES**

- A. Exit Devices: Comply with BHMA A156.3, Grade 1.
  - 1. Lever design to match lockset trim.
  - 2. Provide cylinder with cylinder dogging or locking trim.
  - 3. Provide exit devices properly sized for door width and height.
  - 4. Provide strike as recommended by manufacturer for application indicated.
  - 5. Provide UL (DIR) listed exit device assemblies for fire-rated doors and panic device assemblies for non-fire-rated doors.
- B. General features:
  - 1. Push-through push-pad design.
    - a. No exposed push-pad fasteners, no exposed cavities when operated.
    - b. Return stroke fluid dampeners and rubber bottoming dampeners, plus anti-rattle devices.
    - c. Furnish stainless steel or brass touch pad cover on all exit devices.
  - 2. Releasable in normal operation with 5-lb. maximum operating force per California State CBC Chapter 11B-309.4
  - 3. Readily openable from egress side with one hand and without tight grasping, tight pinching, or twisting of the wrist to operate.
  - 4. End caps: Impact-resistant, flush-mounted.
    - a. No raised edges or lips to catch carts or other equipment.
    - b. Cast or forged material and is not to overlap the mechanism case.

5. Where devices span over door lite frame and the face of the selected lite manufacturer's frame is raised from the face of the door, furnish panic hardware manufacturer's fitted shims or glass-bead kits at no additional cost to the project.
  - a. No exposed rivets or screws on back of device that would be visible through a glass lite.
6. Comply with CBC Section 1010.1.9 and State Fire Marshal Standard 12-10-3 Exits, Section 12-10-302.
7. All mounting fasteners to be concealed. Devices to be non-handed or field reversible.
8. Furnish stainless steel latchbolt with 3/4 inch throw and security dead-latching for all rim and surface vertical rod exit devices.
9. Doors wider than 36 inch provide long bar exit devices
10. Doors taller than 7 ft. supply extension rods for required series.
11. Protect lever trim by a shear pin, which will withstand a rotational force of 35 ft.-lbs before shearing.
  - a. Where a heavy duty, vandal resistant trim is specified, conform to ANSI 156.3 Grade 1 Security Trim standard.
    - 1) Vandal resistance lever to operate in both directions.
    - 2) Protect lever trim by a shear pin, which will withstand a rotational force of 70 ft.-lbs before shearing.
    - 3) The lever is not to separate from the escutcheon.
12. Trim to meet ANSI/BHMA 156.3 Trim Security Test.

## **2.05 ELECTRIC STRIKES**

- A. Electric Strikes: Comply with BHMA A156.31, Grade 1.
  1. Provide UL (DIR) listed burglary-resistant electric strike; style to suit locks.
  2. Provide non-handed 24 VDC electric strike suitable for door frame material and scheduled lock configuration.
  3. Provide field selectable Fail Safe/Fail Secure modes.
  4. Provide transformer and rectifier as necessary for complete installation.
  5. Connect electric strikes into fire alarm where non-rated doors are scheduled to release with fire or sprinkler alarm condition.

## **2.06 LOCK CYLINDERS**

- A. Lock Cylinders: Provide key access on outside of each lock, unless otherwise indicated.
  1. Provide standard, electronic, conventional, full size interchangeable core (FSIC), and small format interchangeable core (SFIC) type cylinders, Grade 1, with six-pin core in compliance with BHMA A156.5 at locations indicated.
  2. Provide cylinders from same manufacturer as locking device.
  3. Provide cams and/or tailpieces as required for locking devices.
  4. Furnish keyed at factory of lock manufacturer where permanent records are maintained.
  5. Locks and cylinders by the same manufacturer.

6. Within specific Door Sections, when provisions for lock cylinder are being referenced to this Section, provide specified lock cylinder and keyed to building keying system, unless otherwise indicated.

## **2.07 ELECTROMECHANICAL LOCKS**

- A. Electromechanical Locks: Comply with BHMA A156.25, Grade 1.
  1. Provide motor-driven or solenoid-driven locks, with strike that is applicable to frame.
  2. Type: Mortise deadbolt.

## **2.08 CLOSERS**

- A. Closers: Comply with BHMA A156.4, Grade 1.
  1. Type: Surface mounted to door.
  2. Provide door closer on each exterior door.
  3. At outswinging exterior doors, mount closer on interior side of door.

## **2.09 OVERHEAD STOPS AND HOLDERS**

- A. Overhead Stops and Holders (Door Checks): Comply with BHMA A156.8, Grade 1.
  1. Provide stop for every swinging door, unless otherwise indicated.
  2. Stop is not required if positive stop feature is specified for door closer; positive stop feature of door closer is not an acceptable substitute for a stop, unless otherwise indicated.

## **2.10 KICK PLATES**

- A. Kick Plates: Provide along bottom edge of push side of every door with closer, except aluminum storefront and glass entry doors, unless otherwise indicated.
  1. Size: 10 inch high by 2 inch less door width (LDW) on push side of door.

## **2.11 DOOR HOLDERS**

- A. Door Holders: Comply with BHMA A156.16, Grade 1.
  1. Provide surface mounted door holders when wall or floor stop is not applicable and hold-open device is mounted on door.
  2. Type: Lever, or kick down stop, with rubber bumper at bottom end.
  3. Material: Aluminum.

## **2.12 ELECTROMAGNETIC DOOR HOLDERS**

- A. Electromagnetic Door Holders: Comply with BHMA A156.15.
  1. Type: Wall mounted, single unit, standard duty, with strike plate attached to door.
  2. Holding Force, Standard Duty: 40 lbs-force, minimum.
  3. Voltage: 12 VDC, and provide power supplies by same manufacturer as holders.
  4. Fail safe; door released to close automatically when electrical current is interrupted.

### **2.13 WALL STOPS**

- A. Wall Stops: Comply with BHMA A156.16, Grade 1 and Resilient Material Retention Test as described in this standard.
  - 1. Provide wall stops to prevent damage to wall surface upon opening door.
  - 2. Type: Bumper, concave, wall stop.
  - 3. Material: Brass housing with rubber insert.

### **2.14 THRESHOLDS**

- A. Thresholds: Comply with BHMA A156.21.
  - 1. Provide threshold at interior doors for transition between two different floor types, and over building expansion joints, unless otherwise indicated.
  - 2. Provide threshold at each exterior door, unless otherwise indicated.
  - 3. Type: Flat surface.
  - 4. Material: Aluminum.
  - 5. Threshold Surface: Fluted horizontal grooves across full width.
  - 6. Field cut threshold to profile of frame and width of door sill for tight fit.
  - 7. Provide non-corroding fasteners at exterior locations.

### **2.15 WEATHERSTRIPPING AND GASKETING**

- A. Weatherstripping and Gasketing: Comply with BHMA A156.22.
  - 1. Head and Jamb Type: Adjustable.
  - 2. Door Sweep Type: Encased in retainer.
  - 3. Material: Aluminum, with brush weatherstripping.
  - 4. Provide weatherstripping on each exterior door at head, jambs, and meeting stiles of door pairs, unless otherwise indicated; .
  - 5. Provide door bottom sweep on each exterior door, unless otherwise indicated.

### **2.16 SILENCERS**

- A. Silencers: Provide at equal locations on door frame to mute sound of door's impact upon closing.
  - 1. Single Door: Provide three on strike jamb of frame.
  - 2. Pair of Doors: Provide two on head of frame, one for each door at latch side.
  - 3. Material: Rubber, gray color.

### **2.17 KEY CONTROL SYSTEMS**

- A. Key Control Systems: Comply with guidelines of BHMA A156.28.
  - 1. Provide keying information in compliance with DHI (KSN) standards.
  - 2. Keying: Grand master keyed.
  - 3. Include construction keying and control keying with removable core cylinders.



- a. Provide temporary keyed-alike cores.
  - b. Remove at substantial completion and install permanent cylinders/cores in District's presence.
    - 1) Demonstrate that construction key no longer operates.
4. Key to existing keying system.
    - a. Factory registered master key system.
    - b. Schlage Restricted keyway, interchangeable core.
    - c. Contact District Locksmith with for keying requirements.
    - d. Key blanks available only from factory-direct sources, not available from after-market key blank manufacturers.
    - e. For estimate use factory GMK charge.
    - f. Furnish District's written approval of the system.
  5. Supply keys in following quantities:
    - a. 4 each Master keys.
    - b. 1 each Grand Master keys.
    - c. 6 each Construction Master keys.
    - d. 15 each Construction keys.
    - e. 2 each Construction Control keys.
    - f. 2 each Control keys if new system.
    - g. 2 each Extra Cylinder cores.
    - h. 2 each Change keys for each keyed core.
  6. Key Management System: For each keyed lock on project, provide one set of consecutively numbered duplicate key tags with hanging hole and snap catch.
  7. Security Key Tags: For each keyed lock on project, provide one set of matching key tags for permanent attachment to one key of each set.
  8. Provide key collection envelopes, receipt cards, and index cards in quantity suitable to manage number of keys.
  9. Deliver keys with identifying tags to District by security shipment direct from hardware supplier.
  10. Bitting List: Use secured shipment direct from point of origination to District upon completion.
  11. Permanent Keys and Cores: Stamped with applicable key marking for identification. Do not include actual key cuts within visual key control marks or codes. Stamp permanent keys "Do Not Duplicate."

## **2.18 KEY CABINET**

- A. Key Cabinet: Sheet steel construction, piano hinged door with key lock; BHMA A156.28.
  1. Mounting: Wall-mounted.
  2. Capacity: Actual quantity of keys, plus 25 percent additional capacity.
  3. Size: 14-1/2 inches wide by 18 inches high by 5 inches deep.
  4. Size key hooks to hold 6 keys each.

5. Finish: Baked enamel, manufacturer's standard color.
6. Key cabinet lock to building keying system.

## **2.19 FIRE DEPARTMENT LOCK BOX**

- A. Manufacturers:
  1. Knox Company; Knox-Box Rapid Entry System; Model 3227: [www.knoxbox.com](http://www.knoxbox.com).
  2. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Fire Department Lock Box: at Buildings or Site Walls
  1. Heavy-duty, recessed, solid stainless-steel box with hinged door and interior gasket seal; single drill resistant lock with dust covers and tamper alarm.
  2. Capacity: Holds 10 keys.
  3. Finish: Manufacturer's standard dark bronze.
- C. Fire Department Lock Box: at Buildings or Site Walls
  1. Heavy-duty, surface mounted, solid stainless-steel box with hinged door and interior gasket seal; single drill resistant lock with dust covers and tamper alarm.
  2. Capacity: Holds 10 keys.
  3. Finish: Manufacturer's standard dark bronze.
  4. Mounted to posts at manual gates (for driveways/roads) and as indicated on Drawings:
    - a. Key lock boxes shall be located at driver's side of gate entrance in a visible location as directed by Fire Department.
      - 1) Box shall be welded secure to metal posts. Box shall be 4 to 4-1/2 feet from top of box to finished grade.
    - b. Obtain approval from Fire Department of mounting location/position and operating standards before installation.
    - c. Products:
      - 1) Knox Company; Model 3208 or 3166, as applicable.
      - 2) Knox Decal 1001 shall be placed on gate.
      - 3) Substitutions: See Section 01 60 00 - Product Requirements. Only if allowed or required by local Fire Department.
- D. Provide Knox Fire Department alert decals on all exterior doors of the facility and on all interior doors that keys have been furnished for within the lock box.
  1. If the building/facility is protected with a fire alarm system or burglar alarm system, the lock boxes shall be "tamper" monitoring.
  2. The tamper monitoring must include the following:
    - a. All central stations shall be UL listed.
    - b. For combination Fire/Burglar Alarm Panels, the Knox Box monitoring shall be through the fire side of the panel.
    - c. Central stations upon receiving a Knox Box tamper alarm signal shall:
      - 1) Notify and respond to local Police Department (Knox Box tamper).
      - 2) Notify and respond to the local Fire Department (Knox Box tamper).

## **2.20 POWER SUPPLY**

- A. Power Supply: Hard wired, with multiple zones providing eight (8) breakers for each output panel with individual control switches and LED's; UL (DIR) Class 2 listed.
  - 1. Power: 24 VAC, 10 Amp; with 120 VAC power supply.
  - 2. Operating Temperature: 32 to 110 degrees F.
  - 3. Provide with emergency release terminals that release devices upon activation of fire alarm system.

## **2.21 FINISHES**

- A. Finishes: Identified in Section 08 06 71 - Door Hardware Schedule.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that doors and frames are ready to receive this work; labeled, fire-rated doors and frames are properly installed, and dimensions are as indicated on shop drawings.
- B. Verify that electric power is available to power operated devices and of correct characteristics.

### **3.02 INSTALLATION**

- A. Install hardware in accordance with manufacturer's instructions and applicable codes.
  - 1. Locate hardware per SDI-100 and applicable building, fire, life-safety, accessibility, and security codes.
  - 2. Set units level, plumb and true to line and location. Adjust and reinforce attachment substrate for proper installation and operation. Remove and reinstall or replace work deemed defective by Architect.
    - a. Gaskets:
      - 1) Install jamb-applied gaskets before closers, overhead stops, rim strikes, etc; fasten hardware over and through these seals.
      - 2) Install sweeps across bottoms of doors before astragals, cope sweeps around bottom pivots, trim astragals to tops of sweeps.
    - b. When hardware is to be attached to existing metal surface and insufficient reinforcement exists, use RivNuts, NutSerts or similar anchoring device for screws.
    - c. Use manufacturers' fasteners furnished with hardware items, or submit Request for Substitution with Architect.
    - d. Replace fasteners damaged by power-driven tools.
  - 3. Core concrete for exterior door stop anchors. Set anchors in approved non-shrink grout.
  - 4. Lubricate and adjust existing hardware scheduled to remain. Carefully remove and give to District items not scheduled for reuse.
- B. Use templates provided by hardware item manufacturer.
- C. Do not install surface mounted items until application of finishes to substrate are fully completed.

- D. Door Hardware Mounting Heights: Distance from finished floor to center line of hardware item. As indicated in following list; unless noted otherwise in Door Hardware Schedule or on drawings.
  - 1. Comply with California Building Code, Section 1010.1.9.2, 11B-309.4 and 11B-404.2.7.
    - a. Refer also to CBC requirements noted in Part 1 of this section.
  - 2. For Steel Doors and Frames: Install in compliance with DHI (LOCS) recommendations.
  - 3. For Steel Doors and Frames: Refer to Section 08 11 13.
  - 4. For Aluminum-Framed Storefront Doors and Frames: Refer to Section 08 43 13.
  - 5. For Wood Doors: Install in compliance with DHI WDHS.3 recommendations.
  - 6. Flush Wood Doors: Refer to Section 08 14 16.
  - 7. Mounting heights in compliance with ADA Standards:
    - a. Locksets: 34 to 44 inches.
    - b. Push/Pulls: 34 to 44 inches.
    - c. Dead Locks: 44 inches.
    - d. Exit Devices: 36 (clear) to 44 inches.
    - e. Where new hardware is to be installed near existing doors/hardware scheduled to remain, match locations of existing hardware when compliant with codes.
- E. Set exterior door thresholds with full-width bead of elastomeric sealant at each point of contact with floor providing a continuous weather seal; anchor thresholds with stainless steel countersunk screws.
  - 1. Refer to Section 07 92 00 for additional requirements.
- F. Locate overhead stops for minimum 90 degrees at rest and for maximum allowable degree of swing.

### **3.03 FIELD QUALITY CONTROL**

- A. Perform field inspection and testing under provisions of Section 01 45 00 - Quality Control.
- B. Provide an Architectural Hardware Consultant (AHC) to inspect installation and certify that hardware and installation has been furnished and installed in accordance with manufacturer's instructions and as specified.

### **3.04 ADJUSTING**

- A. Adjust work under provisions of Section 01 70 00 - Execution and Closeout Requirements.
- B. Adjust hardware for smooth operation.
  - 1. Adjust and check for proper operation and function. Replace units, which cannot be adjusted to operate freely and smoothly.
    - a. Hardware damaged by improper installation or adjustment methods: repair or replace to District's satisfaction.
    - b. Adjust doors to fully latch with no more than 1 pound of pressure.
    - c. Adjust door closers per "Commissioning" article below.
- C. Adjust gasketing for complete, continuous seal; replace if unable to make complete seal.

- D. Final inspection: Installer to provide letter to District that upon completion installer has visited the Project and has accomplished the following:
  - 1. Has re-adjusted hardware.
  - 2. Has evaluated maintenance procedures and recommend changes or additions, and instructed District's personnel.
  - 3. Has identified items that have deteriorated or failed.
  - 4. Has submitted written report identifying problems.

### **3.05 COMMISSIONING:**

- A. Conduct these tests prior to request for certificate of substantial completion:
  - 1. With installer, access control contractor and electrical contractor present, test electrical, electronic and electro-pneumatic hardware systems for satisfactory operation.
  - 2. With installer and electrical contractor present, test hardware interfaced with fire/life-safety system for proper operation and release.
  - 3. Inspection of means-of-egress panic-hardware doors:
    - a. Contractor shall provide an independent third-party inspection service to prepare a report listing the proper operation and functionality of these doors.
    - b. Include a statement that there are zero deficiencies with the openings with panic hardware.
  - 4. With installer present, test door hardware operation for compliance with push and pull force requirements per ADA and CBC.

### **3.06 CLEANING**

- A. Clean finished hardware in accordance with manufacturer's written instructions after final adjustments have been made.
- B. Clean adjacent surfaces soiled by hardware installation.
- C. Replace items that cannot be cleaned to manufacturer's level of finish quality at no additional cost.
- D. See Section 01 74 19 - Construction Waste Management and Disposal, for additional requirements.

### **3.07 PROTECTION**

- A. Protect finished Work under provisions of Section 01 70 00 - Execution and Closeout Requirements.
- B. Do not permit adjacent work to damage hardware or finish.

### **3.08 CLOSEOUT**

- A. Return of temporary cores for return/receipt by Contractor.
- B. Final inspection: Installer to provide letter to District that upon completion installer has visited the Project and has accomplished the following:
  - 1. Has re-adjusted hardware.

2. Has evaluated maintenance procedures and recommend changes or additions, and instructed District's personnel.
3. Has identified items that have deteriorated or failed.
4. Has submitted written report identifying problems.

### **3.09 SCHEDULE OF FINISH HARDWARE**

- A. See door schedule in drawings for hardware set assignments.
- B. No hardware shall be ordered until Finish Hardware has been reviewed and approved by Architect's hardware consultant.
- C. Provide Factory order numbers for all products supplied on this project as part of close out documents for Owner's warranty records.
- D. See schedule in Section 08 06 71 - Door Hardware Schedule.

**END OF SECTION**



**SECTION 08 80 00**  
**GLAZING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Glazing units.
- B. Glazing compounds and accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 07 92 00 - Joint Sealants: Sealants for other than glazing purposes.
- B. Section 08 11 13 - Hollow Metal Doors and Frames: Glazed lites in doors and borrowed lites.
- C. Section 08 14 16 - Flush Wood Doors: Glazed lites in doors.
- D. Section 10 28 00 - Toilet Accessories: Mirrors.

**1.03 REFERENCE STANDARDS**

- A. 28 CFR 35 - Structural Sealant Glazing Systems; 1985 (R2006).
- B. ANSI Z97.1 - American National Standard for Safety Glazing Materials Used in Buildings, Safety Performance Specifications and Methods of Test; 2010.
  - 1. Use 2014 as indicated in 2016 CBC Referenced Standards.
- C. ASTM C864 - Standard Specification for Dense Elastomeric Compression Seal Gaskets, Setting Blocks, and Spacers; 2005 (Reapproved 2015).
- D. ASTM C1036 - Standard Specification for Flat Glass; 2011.
- E. ASTM C1048 - Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass; 2012.
- F. GANA (GM) - GANA Glazing Manual; 2009.
- G. GANA (SM) - GANA Sealant Manual; 2008.

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Preinstallation Meeting: Convene a preinstallation meeting one week before starting work of this section; require attendance by each of the affected installers.

**1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data on Glazing Unit Glazing Types: Provide structural, physical and environmental characteristics, size limitations, special handling and installation requirements.
- C. Product Data on Glazing Compounds and Accessories: Provide chemical, functional, and environmental characteristics, limitations, special application requirements, and identify available colors.
- D. Samples: Submit two samples 8 by 8 inch in size of glass units.
- E. Samples: Submit 4 inch long bead of glazing sealant, color as selected.



- F. Samples: Submit two samples, 12 inch long strip of representative material of adjoining material., color as selected.
- G. Certificate: Certify that products of this section meet or exceed specified requirements.
- H. Manufacturer's Qualification Statement.
- I. Installer's Qualification Statement.
- J. Warranty Documentation: Submit manufacturer warranty and ensure that forms have been completed in District's name and registered with manufacturer.
- K. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.

### **1.06 QUALITY ASSURANCE**

- A. Perform Work in accordance with GANA (GM) and GANA (SM) for glazing installation methods. Maintain one copy on site.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years of documented experience.
- C. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years documented experience and personnel certified under the National Glass Association's Certified Glass Installer program.
- D. Testing Agency Qualifications: Independent firm specializing in performing testing and inspections of the type specified in this section.

### **1.07 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. Remedial Provisions: Upon notification of defects, within the warranty period, party providing warranty or guarantee shall replace the glass and glazing at no cost to District.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Glass Fabricators:
  - 1. Glasswerks Inc.: [www.glasswerks.com](http://www.glasswerks.com).
  - 2. GlasPro, Inc.: [www.glas-pro.com](http://www.glas-pro.com)
  - 3. Viracon, Inc: [www.viracon.com](http://www.viracon.com).
  - 4. Substitutions: Refer to Section 01 63 00 - Product Substitution Procedures.
- B. Float Glass Manufacturers:
  - 1. AGC Glass Company North America, Inc: [www.us.agc.com](http://www.us.agc.com).
  - 2. Cardinal Glass Industries: [www.cardinalcorp.com](http://www.cardinalcorp.com).
  - 3. GlasPro, Inc.: [www.glas-pro.com](http://www.glas-pro.com)
  - 4. Guardian Industries Corp: [www.sunguardglass.com](http://www.sunguardglass.com).
  - 5. Pilkington North America Inc: [www.pilkington.com/na](http://www.pilkington.com/na).

6. Vitro Architectural Glass, formerly PPG Industries, Inc: [www.vitroglazings.com](http://www.vitroglazings.com).
7. Substitutions: Refer to Section 01 63 00 - Product Substitution Procedures.

## **2.02 REGULATORY REQUIREMENTS**

- A. Comply with the all applicable codes and ordinances, including California Building Code (CBC), Title 24, Part 2, Chapter 24 as amended and adopted by authorities having jurisdiction, and US Consumer Product Safety Commission Standard 28 CFR 35 CI and CII.
- B. Where safety glass is indicated or required, provide glazing materials that conform to ANSI Z97.1 and CPSC 28 CFR 35 and are so identified in accordance with CBC Section 2406.3.
- C. Glass Identification:
  1. Per CBC Section 2403.1, each light shall bear the manufacturer's label designating the type and thickness of glass.
    - a. When approved by the enforcement agency, labels may be omitted from other than safety glazing materials, provided an affidavit is furnished by the glazing contractor certifying that each light is glazed in accordance with approved plans and specifications.
    - b. Identification of safety glazing material installed in hazardous locations as defined in Section 2406 of this chapter shall be identified by label which will specify the labeler, whether the manufacturer or installer, and state that safety glazing material has been utilized in such installations.
    - c. The label shall be legible and visible from the inside of the building after installation and shall specify that label shall not be removed.
    - d. Tempered glass shall have an etched manufacturer's label.

## **2.03 GLASS MATERIALS**

- A. Float Glass: Provide float glass based glazing unless otherwise indicated.
  1. Annealed Type: ASTM C1036, Type I - Transparent Flat, Class 1 - Clear, Quality - Q3.
  2. Kind HS - Heat-Strengthened Type: Complies with ASTM C1048.
  3. Kind FT - Fully Tempered Type: Complies with ASTM C1048.
  4. Fully Tempered Safety Glass: Complies with ANSI Z97.1 or 28 CFR 35 criteria for safety glazing used in hazardous locations.
    - a. Where fully tempered is indicated, provide glass that has been tempered by the tong-less horizontal method.
  5. Impact Resistant Safety Glass: Complies with ANSI Z97.1 and 28 CFR 35 criteria; Class A/Category II.

## **2.04 GLAZING UNITS**

- A. Monolithic Interior Vision Glazing:
  1. Applications: Interior glazing unless otherwise indicated.
  2. Glass Type: Annealed float glass.
  3. Tint: Clear.
  4. Thickness: 1/4 inch, nominal.

5. Glazing Method: Dry glazing method, gasket glazing.
- B. Monolithic Safety Glazing: Non-fire-rated.
1. Applications:
    - a. Glazed lites in doors, except fire doors.
    - b. Glazed sidelights to doors, except in fire-rated walls and partitions.
    - c. Other locations required by applicable federal, state, and local codes and regulations.
    - d. Other locations indicated on drawings.
  2. Glass Type: Fully tempered safety glass as specified.
  3. Tint: Clear.
  4. Thickness: 1/4 inch, nominal.
  5. Glazing Method: Dry glazing method, gasket glazing.

## **2.05 ACCESSORIES**

- A. Setting Blocks: Silicone, with 80 to 90 Shore A durometer hardness; ASTM C864 Option II. Length of 0.1 inch for each square foot of glazing or minimum 4 inch by width of glazing rabbet space minus 1/16 inch by height to suit glazing method and pane weight and area.
- B. Spacer Shims: Neoprene, 50 to 60 Shore A durometer hardness; ASTM C864 Option II. Minimum 3 inch long by one half the height of the glazing stop by thickness to suit application, self adhesive on one face.
- C. Glazing Tape, Back Bedding Mastic Type: Preformed, butyl-based, 100 percent solids compound with integral resilient spacer rod applicable to application indicated; 5 to 30 cured Shore A durometer hardness; coiled on release paper; black color.
  1. Width: As required for application.
  2. Thickness: As required for application.
- D. Glazing Gaskets: Resilient silicone extruded shape to suit glazing channel retaining slot; ASTM C864 Option II; color black.
- E. Glazing Clips: Manufacturer's standard type.

## **PART 3 EXECUTION**

### **3.01 VERIFICATION OF CONDITIONS**

- A. Verify that openings for glazing are correctly sized and within tolerances, including those for size, squareness, and offsets at corners.
- B. Verify that the minimum required face and edge clearances are being provided.
- C. Verify that surfaces of glazing channels or recesses are clean, free of obstructions that may impede moisture movement, weeps are clear, and support framing is ready to receive glazing system.
- D. Verify that sealing between joints of glass framing members has been completed effectively.
- E. Proceed with glazing system installation only after unsatisfactory conditions have been corrected.

### **3.02 PREPARATION**

- A. Clean contact surfaces with appropriate solvent and wipe dry within maximum of 24 hours before glazing. Remove coatings that are not tightly bonded to substrates.
- B. Seal porous glazing channels or recesses with substrate compatible primer or sealer.
- C. Prime surfaces scheduled to receive sealant where required for proper sealant adhesion.

### **3.03 INSTALLATION, GENERAL**

- A. Install glazing in compliance with written instructions of glass, gaskets, and other glazing material manufacturers, unless more stringent requirements are indicated, including those in glazing referenced standards.
- B. Do not exceed edge pressures around perimeter of glass lites as stipulated by glass manufacturer.
- C. Set glass lites of system with uniform pattern, draw, bow, and similar characteristics.
- D. Set glass lites in proper orientation so that coatings face exterior or interior as indicated.
- E. Prevent glass from contact with any contaminating substances that may be the result of construction operations such as, and not limited to the following; weld splatter, fire-safing, plastering, mortar droppings, etc.

### **3.04 INSTALLATION - DRY GLAZING METHOD (GASKET GLAZING)**

- A. Application - Exterior and/or Interior Glazed: Set glazing infills from either the exterior or the interior of the building.
- B. Place setting blocks at 1/4 points with edge block no more than 6 inch from corners.
- C. Rest glazing on setting blocks and push against fixed stop with sufficient pressure on gasket to attain full contact.
- D. Install removable stops without displacing glazing gasket; exert pressure for full continuous contact.

### **3.05 CLEANING**

- A. See Section 01 74 19 - Construction Waste Management and Disposal, for additional requirements.
- B. Remove excess glazing materials from finish surfaces immediately after application using solvents or cleaners recommended by manufacturers.
- C. Remove non-permanent labels immediately after glazing installation is complete.
- D. Clean glass and adjacent surfaces after sealants are fully cured.
- E. Clean glass on both exposed surfaces not more than 4 days prior to Date of Substantial Completion in accordance with glass manufacturer's written recommendations.

### **3.06 PROTECTION**

- A. After installation, mark pane with an 'X' by using removable plastic tape or paste.

- B. Remove and replace glass that is damaged during construction period prior to Date of Substantial Completion.

**END OF SECTION**

**SECTION 09 05 61**  
**COMMON WORK RESULTS FOR FLOORING PREPARATION**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. This section applies to floors identified in Contract Documents that are receiving the following types of floor coverings:
  - 1. Resilient tile and sheet.
  - 2. Broadloom carpet.
  - 3. Thin-set ceramic tile and stone tile.
- B. Removal of existing floor coverings.
- C. Preparation of existing concrete floor slabs for installation of floor coverings.
- D. Testing of concrete floor slabs for moisture and alkalinity (pH) by Contractor.
  - 1. Building is known to have moisture related issues with existing flooring.
- E. Remediation of concrete floor slabs due to unsatisfactory moisture or alkalinity (pH) conditions.
  - 1. Contractor shall perform all specified remediation of concrete floor slabs. If such remediation is indicated by testing agency's report and is due to a condition not under Contractor's control or could not have been predicted by examination prior to entering into the contract, a contract modification will be issued.
- F. Patching compound.
- G. Remedial floor coatings.

**1.02 RELATED REQUIREMENTS**

- A. Section 01 45 00 - Quality Control: Additional requirements relating to testing agencies and testing.
- B. Section 03 30 00 - Cast-in-Place Concrete: Concrete admixture for slabs to receive adhered flooring, to prevent moisture content-related flooring failures.
- C. Section 03 30 00 - Cast-in-Place Concrete: Limitations on curing requirements for new concrete floor slabs.

**1.03 REFERENCE STANDARDS**

- A. ASTM C109/C109M - Standard Test Method for Compressive Strength of Hydraulic Cement Mortars (Using 2-in. or (50-mm) Cube Specimens); 2016a.
- B. ASTM C472 - Standard Test Methods for Physical Testing of Gypsum, Gypsum Plasters and Gypsum Concrete; 1999 (Reapproved 2014).
- C. ASTM F710 - Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring; 2019.
- D. ASTM F1869 - Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride; 2016a.

- E. ASTM F2170 - Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using in situ Probes; 2017.
- F. RFCI (RWP) - Recommended Work Practices for Removal of Resilient Floor Coverings; 2011.

#### **1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Coordinate scheduling of cleaning and testing, so that preliminary cleaning has been completed for at least 24 hours prior to testing.

#### **1.05 SUBMITTALS**

- A. Visual Observation Report: For existing floor coverings to be removed.
- B. Floor Covering and Adhesive Manufacturers' Product Literature: For each specific combination of substrate, floor covering, and adhesive to be used; showing:
  - 1. Moisture and alkalinity (pH) limits and test methods.
  - 2. Manufacturer's required bond/compatibility test procedure.
- C. Testing Agency's Report:
  - 1. Description of areas tested; include floor plans and photographs if helpful.
  - 2. Summary of conditions encountered.
  - 3. Moisture and alkalinity (pH) test reports.
  - 4. Copies of specified test methods.
  - 5. Recommendations for remediation of unsatisfactory surfaces.
  - 6. Product data for recommended remedial coating.
  - 7. Include certification of accuracy by authorized official of testing agency.
  - 8. Submit report to Architect.
  - 9. Submit report not more than two business days after conclusion of testing.
- D. Adhesive Bond and Compatibility Test Report.
- E. Floor Moisture Testing Technician Certificate: International Concrete Repair Institute (ICRI) Concrete Slab Moisture Testing Technician- Grade I certificate.
- F. Copy of RFCI (RWP).

#### **1.06 QUALITY ASSURANCE**

- A. Moisture and alkalinity (pH) testing shall be performed by an independent testing agency employed and paid by Contractor.
- B. Contractor may perform adhesive and bond test with Contractor's own personnel or hire a testing agency.
- C. Testing Agency Qualifications: Independent testing agency experienced in the types of testing specified.
  - 1. Submit evidence of experience consisting of at least 3 test reports of the type required, with project District's project contact information.
- D. Contractor's Responsibility Relating to Independent Agency Testing:
  - 1. Provide access for and cooperate with testing agency.

2. Confirm date of start of testing at least 10 days prior to actual start.
  3. Allow at least 4 business days on site for testing agency activities.
  4. Achieve and maintain specified ambient conditions.
  5. Notify District when specified ambient conditions have been achieved and when testing will start.
- E. Floor Moisture Testing Technician Qualifications: International Concrete Repair Institute (ICRI) Concrete Slab Moisture Testing Technician Certification- Grade I.
- F. Remedial Coating Installer Qualifications: Company specializing in performing work of the type specified in this section, trained by or employed by coating manufacturer, and able to provide at least 3 project references showing at least 3 years' experience installing moisture emission coatings.

### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver, store, handle, and protect products in accordance with manufacturer's instructions and recommendations.
- B. Deliver materials in manufacturer's packaging; include installation instructions.
- C. Keep materials from freezing.

### **1.08 FIELD CONDITIONS**

- A. Maintain ambient temperature in spaces where concrete testing is being performed, and for at least 48 hours prior to testing, at not less than 65 degrees F or more than 85 degrees F.
- B. Maintain relative humidity in spaces where concrete testing is being performed, and for at least 48 hours prior to testing, at not less than 40 percent and not more than 60 percent.

## **PART 2 PRODUCTS**

### **2.01 MATERIALS**

- A. Patching Compound: Floor covering manufacturer's recommended product, suitable for conditions, and compatible with adhesive and floor covering. In the absence of any recommendation from flooring manufacturer, provide a product with the following characteristics:
  1. Cementitious moisture-, mildew-, and alkali-resistant compound, compatible with floor, floor covering, and floor covering adhesive, and capable of being feathered to nothing at edges.
  2. Latex or polyvinyl acetate additions are permitted; gypsum content is prohibited.
  3. Compressive Strength: 3000 psi, minimum, after 28 days, when tested in accordance with ASTM C109/C109M or ASTM C472, whichever is appropriate.
  4. Products:
    - a. ARDEX Engineered Cements, Inc; ARDEX K-15: [www.ardexamericas.com](http://www.ardexamericas.com).
    - b. Mapei International; Mapei Ultraplan 1 Plus: [www.mapei.com](http://www.mapei.com).
    - c. Sika Corporation; Sika Level-315: [www.sikafloorusa.com](http://www.sikafloorusa.com).
    - d. Substitutions: See Section 01 63 00 - Product Substitution Procedures.



- B. Alternate Flooring Adhesive: Floor covering manufacturer's recommended product, suitable for the moisture and pH conditions present; low-VOC. In the absence of any recommendation from flooring manufacturer, provide a product recommended by adhesive manufacturer as suitable for substrate and floor covering and for conditions present.
- C. Remedial Floor Coating: Single- or multi-layer coating or coating/overlay combination intended by its manufacturer to resist water vapor transmission to degree sufficient to meet flooring manufacturer's emission limits, resistant to the level of alkalinity (pH) found, and suitable for adhesion of flooring without further treatment.
  - 1. Thickness: As required for application and in accordance with manufacturer's installation instructions.
  - 2. Products:
    - a. ARDEX Engineered Cements; ARDEX MC RAPID: [www.ardexamericas.com/#sle](http://www.ardexamericas.com/#sle).
    - b. Custom Building Products; TechMVC Moisture Vapor and Alkalinity Barrier: [www.custombuildingproducts.com/#sle](http://www.custombuildingproducts.com/#sle).
    - c. Floor Seal Technology, Inc; MES 100 with Floor Seal FloorCem SLU: [www.floorseal.com/#sle](http://www.floorseal.com/#sle).
    - d. Koster American Corporation; Koster VAP I 2000 with Koster SL Premium overlay: [www.kosterusa.com/#sle](http://www.kosterusa.com/#sle).
    - e. LATICRETE International, Inc; LATICRETE NXT Vapor Reduction Coating with LATICRETE NXT Level Plus: [www.laticrete.com/#sle](http://www.laticrete.com/#sle).
    - f. LATICRETE International, Inc; LATICRETE SUPERCAP Moisture Vapor Control with LATICRETE SUPERCAP Underlayment: [www.laticrete.com/#sle](http://www.laticrete.com/#sle).
    - g. Maxxon Corporation; Aquafin SG2: [www.maxxon.com/#sle](http://www.maxxon.com/#sle).
    - h. Sika Corporation; Sikafloor Moisture Tolerance Epoxy Primer and Sikafloor Self-Leveling Moisture Tolerant Resurfacer: [www.sikafloorusa.com/#sle](http://www.sikafloorusa.com/#sle).
    - i. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## **PART 3 EXECUTION**

### **3.01 CONCRETE SLAB PREPARATION**

- A. Follow recommendations of testing agency.
- B. Perform following operations in the order indicated:
  - 1. Existing concrete slabs (on-grade and elevated) with existing floor coverings:
    - a. Visual observation of existing floor covering, for adhesion, water damage, alkaline deposits, and other defects.
    - b. Removal of existing floor covering.
  - 2. Preliminary cleaning.
  - 3. Moisture vapor emission tests; 3 tests in the first 1000 square feet and one test in each additional 1000 square feet, unless otherwise indicated or required by flooring manufacturer.
  - 4. Internal relative humidity tests; in same locations as moisture vapor emission tests, unless otherwise indicated.

5. Alkalinity (pH) tests; in same locations as moisture vapor emission tests, unless otherwise indicated.
  6. Specified remediation, if required.
  7. Patching, smoothing, and leveling, as required.
  8. Other preparation specified.
  9. Adhesive bond and compatibility test.
  10. Protection.
- C. Remediations:
1. Active Water Leaks or Continuing Moisture Migration to Surface of Slab: Correct this condition before doing any other remediation; re-test after correction.
  2. Excessive Moisture Emission or Relative Humidity: If an adhesive that is resistant to the level of moisture present is available and acceptable to flooring manufacturer, use that adhesive for installation of the flooring; if not, apply remedial floor coating or remedial sheet membrane over entire suspect floor area.
  3. Excessive Alkalinity (pH): If remedial floor coating is necessary to address excessive moisture, no additional remediation is required; if not, if an adhesive that is resistant to the level present is available and acceptable to the flooring manufacturer, use that adhesive for installation of the flooring; otherwise, apply a skim coat of specified patching compound over entire suspect floor area.

### **3.02 REMOVAL OF EXISTING FLOOR COVERINGS**

- A. Comply with local, State, and federal regulations and recommendations of RFCI Recommended Work Practices for Removal of Resilient Floor Coverings, as applicable to floor covering being removed.
- B. Dispose of removed materials in accordance with local, State, and federal regulations and as specified.

### **3.03 PRELIMINARY CLEANING**

- A. Clean floors of dust, solvents, paint, wax, oil, grease, asphalt, residual adhesive, adhesive removers, film-forming curing compounds, sealing compounds, alkaline salts, excessive laitance, mold, mildew, and other materials that might prevent adhesive bond.
- B. Do not use solvents or other chemicals for cleaning.

### **3.04 MOISTURE VAPOR EMISSION TESTING**

- A. Where the floor covering manufacturer's requirements conflict with either the referenced test method or this specification, comply with the manufacturer's requirements.
- B. Where this specification conflicts with the referenced test method, comply with the requirements of this section.
- C. Test in accordance with ASTM F1869 and as follows.
- D. Plastic sheet test and mat bond test may not be substituted for the specified ASTM test method, as those methods do not quantify the moisture content sufficiently.

- E. In the event that test values exceed floor covering manufacturer's limits, perform remediation as indicated. In the absence of manufacturer limits, perform remediation if test values exceed 3 pounds per 1000 square feet per 24 hours.
- F. Report: Report the information required by the test method.

### **3.05 INTERNAL RELATIVE HUMIDITY TESTING**

- A. Where the floor covering manufacturer's requirements conflict with either the referenced test method or this specification, comply with the manufacturer's requirements.
- B. Where this specification conflicts with the referenced test method, comply with the requirements of this section.
- C. Test in accordance with ASTM F2170 Procedure A and as follows.
- D. Testing with electrical impedance or resistance apparatus may not be substituted for the specified ASTM test method, as the values determined are not comparable to the ASTM test values and do not quantify the moisture content sufficiently.
- E. In the event that test values exceed floor covering manufacturer's limits, perform remediation as indicated. In the absence of manufacturer limits, perform remediation if any test value exceeds 75 percent relative humidity.
- F. Report: Report the information required by the test method.

### **3.06 ALKALINITY TESTING**

- A. Where the floor covering manufacturer's requirements conflict with either the referenced test method or this specification, comply with the manufacturer's requirements.
- B. The following procedure is the equivalent of that described in ASTM F710, repeated here for the Contractor's convenience.
  - 1. Use a wide range alkalinity (pH) test paper, its associated chart, and distilled or deionized water.
  - 2. Place several drops of water on a clean surface of concrete, forming a puddle approximately 1 inch in diameter. Allow the puddle to set for approximately 60 seconds, then dip the alkalinity (pH) test paper into the water, remove it, and compare immediately to chart to determine alkalinity (pH) reading.
  - 3. Use of a digital pH meter with probe is acceptable; follow meter manufacturer's instructions.
- C. In the event that test values exceed floor covering manufacturer's limits, perform remediation as indicated. In the absence of manufacturer limits, perform remediation if alkalinity (pH) test value is over 10.

### **3.07 PREPARATION**

- A. See individual floor covering section(s) for additional requirements.
- B. Comply with recommendations of testing agency.
- C. Comply with requirements and recommendations of floor covering manufacturer.
- D. Fill and smooth surface cracks, grooves, depressions, control joints and other non-moving joints, and other irregularities with patching compound.

- E. Do not fill expansion joints, isolation joints, or other moving joints.

### **3.08 ADHESIVE BOND AND COMPATIBILITY TESTING**

- A. Comply with requirements and recommendations of floor covering manufacturer.

### **3.09 APPLICATION OF REMEDIAL FLOOR COATING**

- A. Comply with requirements and recommendations of coating manufacturer.
- B. Install remedial coating over all concrete floor areas where moisture emission and/or alkalinity exceeds the floor covering manufacturer's published limits.
- C. Prepare floor areas to be coated in accordance with coating manufacturer's requirements.
  - 1. Mask and protect adjacent wall and floor surfaces from damage due to this work.
- D. Apply coating using manufacturer's recommended procedures.
- E. Apply 1/8 inch thick cementitious surfacing over coating in areas to receive adhesively applied floor coverings.
- F. Verify that prepared floor slab has moisture emission rate and alkalinity meeting requirements.

### **3.10 PROTECTION**

- A. Cover prepared floors with building paper or other durable covering.

**END OF SECTION**



**SECTION 09 21 16**  
**GYPSUM BOARD ASSEMBLIES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Acoustic insulation.
- B. Gypsum sheathing.
- C. Cementitious backing board.
- D. Gypsum wallboard.
- E. Joint treatment and accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 06 10 00 - Rough Carpentry: Building framing.
- B. Section 06 10 00 - Rough Carpentry: Wood blocking product and execution requirements.
- C. Section 07 92 00 - Joint Sealants: Sealing acoustical gaps in construction other than gypsum board or plaster work.
- D. Section 09 30 00 - Tiling: Tile backing board.

**1.03 REFERENCE STANDARDS**

- A. ANSI A108.11 - American National Standard Specifications for Interior Installation of Cementitious Backer Units; 2010 (Reaffirmed 2016).
- B. ANSI A118.9 - American National Standard Specifications for Test Methods and Specifications for Cementitious Backer Units; 1999 (Reaffirmed 2016).
- C. ASTM C475/C475M - Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board; 2015.
  - 1. Use 2012 as indicated in 2016 CBC Referenced Standards.
- D. ASTM C514 - Standard Specification for Nails for the Application of Gypsum Board; 2004 (Reapproved 2014).
  - 1. Use 2004 (Reapproved 2009)e1 as indicated in 2016 CBC Referenced Standards.
- E. ASTM C557 - Standard Specification for Adhesives for Fastening Gypsum Wallboard to Wood Framing; 2003 (Reapproved 2017).
  - 1. Use 2003 (Reapproved 2009)e1 as indicated in 2016 CBC Referenced Standards.
- F. ASTM C665 - Standard Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing; 2017.
- G. ASTM C840 - Standard Specification for Application and Finishing of Gypsum Board; 2018b.
  - 1. Use 2011 as indicated in 2016 CBC Referenced Standards.
- H. ASTM C1047 - Standard Specification for Accessories For Gypsum Wallboard and Gypsum Veneer Base; 2014a.
- I. ASTM C1177/C1177M - Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing; 2013.

1. Use 2008 as indicated in 2016 CBC Referenced Standards.
- J. ASTM C1325 - Standard Specification for Non-Asbestos Fiber-Mat Reinforced Cementitious Backer Units; 2017a.
  1. Use 2008b as indicated in 2016 CBC Referenced Standards.
- K. ASTM C1396/C1396M - Standard Specification for Gypsum Board; 2017.
  1. Use 2013 as indicated in 2016 CBC Referenced Standards.
- L. ASTM D3273 - Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber; 2016.
- M. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2018b.
  1. Use 2013a as indicated in 2016 CBC Referenced Standards.
- N. GA-216 - Application and Finishing of Gypsum Panel Products; 2016.
  1. Use 2013 as indicated in 2016 CBC Referenced Standards.
- O. United States Gypsum Co. (USG) Specification and Technical Bulletins No. SA 923, No. SA 924, and No. SA 925, as applicable for materials location, installation and condition of construction.

#### **1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide data on gypsum board, accessories, and joint finishing system.
  1. Joint Treatment Materials: Submit manufacturer's product data, indicating VOC content.
- C. Application Procedures: Submit a general written description of procedures to be followed where fire-rated work is being done and where alternative assemblies are proposed.

#### **1.05 QUALITY ASSURANCE**

- A. Installer Qualifications: Company specializing in performing gypsum board installation and finishing, with minimum five years of experience.
- B. Regulatory Requirements: Conform to California Building Code (CBC), Title 24, Part 2, Chapter 7 and Chapter 25, as amended and adopted by authorities having jurisdiction.
- C. Copies of Documents at Site: Maintain at the project site a copy of each referenced document that prescribes execution requirements.

#### **1.06 DELIVERY, STORAGE AND HANDLING**

- A. Deliver gypsum board and accessories in manufacturer's original unopened containers, bundles or rolls bearing manufacturer's identification.
- B. Store materials inside the building or in other dry weather tight enclosure. Stack gypsum board flat and off the floor. Do not stack long lengths over shorter lengths.
- C. Store flammable adhesives away from fire, sparks and smoking areas.
- D. Handle gypsum board to prevent damage to edges, ends, and surfaces.

## **PART 2 PRODUCTS**

### **2.01 GYPSUM BOARD ASSEMBLIES**

- A. Provide completed assemblies complying with ASTM C840 and GA-216.
  - 1. See PART 3 for finishing requirements.

### **2.02 BOARD MATERIALS**

- A. General: Gypsum board, joint treatment and finishing materials shall be manufactured from asbestos-free materials.
- B. Manufacturers - Gypsum-Based Board:
  - 1. CertainTeed Corporation: [www.certainteed.com/#sle](http://www.certainteed.com/#sle).
  - 2. Continental Building Products: [www.continental-bp.com/#sle](http://www.continental-bp.com/#sle).
  - 3. Georgia-Pacific Gypsum: [www.gpgypsum.com/#sle](http://www.gpgypsum.com/#sle).
  - 4. National Gypsum Company: [www.nationalgypsum.com/#sle](http://www.nationalgypsum.com/#sle).
  - 5. PABCO Gypsum: [www.pabco gypsum.com/#sle](http://www.pabco gypsum.com/#sle).
  - 6. USG Corporation: [www.usg.com/#sle](http://www.usg.com/#sle).
  - 7. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- C. Gypsum Wallboard: Paper-faced gypsum panels as defined in ASTM C1396/C1396M; sizes to minimize joints in place; ends square cut.
  - 1. Application: Use for vertical surfaces and ceilings, unless otherwise indicated.
  - 2. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
    - a. Mold-resistant board is required whenever board is being installed before the building is enclosed and conditioned.
    - b. Mold resistant board is required at all locations.
  - 3. At Assemblies Indicated with Fire-Rating: Use type required by indicated tested assembly; if no tested assembly is indicated, use Type X board, UL or WH listed.
  - 4. Thickness:
    - a. Vertical Surfaces: 5/8 inch.
    - b. Ceilings: 5/8 inch.
    - c. Multi-Layer Assemblies: Thicknesses as indicated on drawings.
  - 5. Mold Resistant Paper Faced Products:
    - a. CertainTeed Corporation; ProRoc Brand Moisture & Mold Resistant Gypsum Board.
    - b. Georgia-Pacific Gypsum; ToughRock Mold-Guard.
    - c. Georgia-Pacific Gypsum; ToughRock Fireguard X Mold-Guard.
    - d. National Gypsum Company; Gold Bond XP Gypsum Board.
    - e. USG Corporation; Sheetrock Brand Mold Tough Gypsum Panels.
    - f. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- D. Backing Board For Wet Areas:
  - 1. Application: Surfaces behind tile in wet areas including locations where noted.



2. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
  3. ANSI Cement-Based Board: Non-gypsum-based; aggregated Portland cement panels with glass fiber mesh embedded in front and back surfaces complying with ANSI A118.9 or ASTM C1325.
    - a. Thickness: 1/2 inch.
    - b. Products:
      - 1) Custom Building Products; Wonderboard: [www.custombuildingproducts.com/#sle](http://www.custombuildingproducts.com/#sle).
      - 2) National Gypsum Company; PermaBase Cement Board: [www.nationalgypsum.com/#sle](http://www.nationalgypsum.com/#sle).
      - 3) USG Corporation; Durock Cement Board Next Gen: [www.usg.com](http://www.usg.com).
      - 4) Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- E. Exterior Sheathing Board: Sizes to minimize joints in place; ends square cut.
1. Application: Exterior sheathing, unless otherwise indicated.
  2. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
  3. Glass Mat Faced Sheathing: Glass mat faced gypsum substrate as defined in ASTM C1177/C1177M.
  4. At Assemblies Indicated with Fire-Rating: Use type required by indicated tested assembly; if no tested assembly is indicated, use Type X board, UL or WH listed.
  5. Core Type: Regular and Type X, as indicated.
  6. Type X Thickness: 5/8 inch.
  7. Regular Board Thickness: 1/2 inch.
  8. Edges: Square, for vertical application or horizontal.
  9. Glass Mat Faced Products:
    - a. CertainTeed Corporation; GlasRoc Brand.
    - b. Georgia-Pacific Gypsum; DensGlass Sheathing.
    - c. Georgia-Pacific Gypsum; DensGlass Fireguard Sheathing.
    - d. National Gypsum Company; Gold Bond eXP Sheathing.
    - e. USG Corporation: Securock Brand Glass Mat Sheathing.
    - f. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

### **2.03 GYPSUM WALLBOARD ACCESSORIES**

- A. Acoustic Insulation: ASTM C665; preformed glass fiber, friction fit type, unfaced. Thickness: 3-1/2 inch.
  1. Application:
    - a. Partitions with STC Rating:
      - 1) Insulation fill at gypsum board partition stud framing.
      - 2) Surround penetrations in gypsum board partitions.
    - b. Gypsum board ceilings adjacent to sound-rated partitions.
  2. Surface Burning Characteristics as per ASTM E84: Flame Spread of 10; Smoke Developed of 10.

3. Products:
  - a. Owens-Corning; Sound Attenuation Batts: [www.owenscorning.com](http://www.owenscorning.com).
  - b. CertainTeed; "NoiseReducer" Sound Attenuation Batts: [www.certainteed.com](http://www.certainteed.com).
  - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Sealants: For penetrations at fire-rated construction, provide firestopping as specified in Section 07 84 00 - Firestopping.
- C. Acoustic Sealant: Acrylic emulsion latex or water-based elastomeric sealant; do not use solvent-based non-curing butyl sealant.
  1. Non-staining, gunnable, synthetic-rubber sealant recommended for sealing interior concealed joints to reduce airborne sound transmission.
  2. Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the following acoustical sealants for concealed joints:
    - a. Products:
      - 1) Franklin International, Inc; Titebond GREENchoice Professional Acoustical Smoke and Sound Sealant: [www.titebond.com/#sle](http://www.titebond.com/#sle).
      - 2) Liquid Nails, a brand of PPG Architectural Coatings; AS-825 Acoustical Sound Sealant: [www.liquidnails.com/#sle](http://www.liquidnails.com/#sle).
      - 3) Specified Technologies Inc; Smoke N Sound Acoustical Sealant: [www.stifirestop.com/#sle](http://www.stifirestop.com/#sle).
      - 4) Ohio Sealants, Inc.; Pro-Series SC-170 Rubber Base Sound Sealant.
      - 5) Pecora Corp.; BA-98.
      - 6) Tremco, Inc.; Tremco Acoustical Sealant.
      - 7) USG Corporation; USG Sheetrock Acoustical Sealant
- D. Beads, Joint Accessories, and Other Trim: ASTM C1047, aluminum or galvanized steel, unless noted otherwise.
  1. Manufacturers - Finishing Accessories:
    - a. Flannery, Inc.: [flannerytrim.com](http://flannerytrim.com).
    - b. Fry Reglet: [fryreglet.com](http://fryreglet.com).
    - c. Phillips Manufacturing Co: [www.phillipsmfg.com](http://www.phillipsmfg.com).
    - d. Pittcon Industries: [www.pittconindustries.com](http://www.pittconindustries.com)
    - e. Trim-tex, Inc.: [www.trim-tex.com](http://www.trim-tex.com).
    - f. CEMCO Products, Inc; [www.cemco.com](http://www.cemco.com).
    - g. USG Corporation: [www.usg.com](http://www.usg.com)
    - h. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
  2. Corner Beads: Low profile, for 90 degree outside corners.
    - a. Cornerbead: USG Sheetrock B1 XW EL, or equal.
    - b. L Trim: USG Paper-faced "L" trim, B4 or equal.
- E. Joint Materials: ASTM C475/C475M and as recommended by gypsum board manufacturer for project conditions.
  1. Fiberglass Tape: 2 inch wide, coated glass fiber tape for joints and corners, except as otherwise indicated.

2. Joint Compound: Drying type, vinyl-based, ready-mixed.
    - a. USG Easy Sand, Durabond 45 or 90 joint compound, or equal as approved by Architect.
    - b. Products:
      - 1) CertainTeed Corporation; Extreme All-Purpose Joint Compound: [www.certainteed.com/#sle](http://www.certainteed.com/#sle).
      - 2) Continental Building Products: [www.continental-bp.com/#sle](http://www.continental-bp.com/#sle).
      - 3) Substitutions: See Section 01 63 00 - Product Substitution Procedures.
  3. Joint Compound: Setting type, field-mixed.
- F. High Build Drywall Surfer: Vinyl acrylic latex-based coating for spray application, designed to take the place of skim coating and separate paint primer in achieving Level 5 finish.
1. Products:
    - a. CertainTeed Corporation; Level V Wall and Ceiling Primer/Surfer with M2Tech: [www.certainteed.com/#sle](http://www.certainteed.com/#sle).
    - b. USG Corp.; Sheetrock® Brand Tuff -Hide™ Primer-Surfer: [www.usg.com](http://www.usg.com)
    - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- G. Nails for Attachment to Wood Members: ASTM C514, as required for fire-resistive construction.
- H. Anchorage to Substrate: Tie wire, nails, screws, and other metal supports, of type and size to suit application; to rigidly secure materials in place.
- I. Adhesive for Attachment to Metal:
1. Do not use adhesive containing benzene, carbon tetrachloride, or trichloroethylene.
    - a. Adhesive shall contain a maximum VOC content of 50 grams per liter.
    - b. Adhesive must meet the requirements of low emitting materials credit.
  2. Products:
    - a. Franklin International, Inc; Titebond PROvantage Professional Drywall Adhesive: [www.titebond.com/#sle](http://www.titebond.com/#sle).
    - b. Liquid Nails, a brand of PPG Architectural Coatings; DWP-24 Drywall Construction Adhesive: [www.liquidnails.com/#sle](http://www.liquidnails.com/#sle).
    - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that project conditions are appropriate for work of this section to commence.
- B. Coordinate gypsum board Work with Work specified in other Sections to properly locate framing members and to provide additional framing and backing as necessary for recessed and built-in components.
  1. Verify that framing and furring are securely attached and of sizes and spacing to provide a suitable substrate to receive gypsum board.
  2. Maintain a minimum temperature of 50 degrees F for a period extending from 48 hours before installation until the joint compounds have completely dried.

- C. Examine substrates which gypsum board wall construction attaches to or abuts, including the following.
  - 1. Preset hollow metal frames
  - 2. Cast-in-anchors.
  - 3. Piping.
  - 4. Conduit.
  - 5. Ductwork.
- D. Beginning of installation means acceptance of substrate.
- E. Provide adequate and continuous ventilation to ensure proper drying, setting or curing of taping and finishing compounds. Provide temporary air circulators in enclosed areas lacking natural ventilation. GA-216, article 18.2.
- F. Provide fixtures, anchors, sleeves, inserts and miscellaneous items, and provide openings and chases as necessary. Prior to closing in and finishing of drywall Work, ascertain that piping, conduit, ductwork and fixtures which are to be concealed and which penetrate gypsum boards are in place, tested and approved.
- G. Scaffolding: Construct, erect and maintain in conformance with applicable laws and ordinances.
- H. Fire Protection: Where required, the Work shall comply with the requirements for the protection rating indicated in the governing building code.

### **3.02 ACOUSTIC ACCESSORIES INSTALLATION**

- A. Acoustic Insulation: Place tightly within spaces, around cut openings, behind and around electrical and mechanical items within partitions, and tight to items passing through partitions.
- B. Acoustic Sealant: Install in accordance with manufacturer's instructions.
  - 1. Place one bead continuously on substrate before installation of perimeter framing members.
  - 2. Place continuous bead at perimeter of each layer of gypsum board.
  - 3. Seal around all penetrations by conduit, pipe, ducts, and rough-in boxes, except where firestopping is provided.

### **3.03 BOARD INSTALLATION**

- A. Comply with ASTM C840, GA-216, and manufacturer's instructions. Install to minimize butt end joints, especially in highly visible locations.
  - 1. Comply with USG Specification and Technical Bulletins No. SA 923, No. SA 924, and No. SA 925, as applicable for materials location, installation and condition of construction.
- B. Regulatory Requirements: Install gypsum board products in accordance with applicable Code requirements and requirements of listed assemblies shown on Drawings.
- C. Single-Layer Non-Rated: Install gypsum board in most economical direction, with staggered ends and edges occurring over firm bearing.
  - 1. Exception: Tapered edges to receive joint treatment at right angles to framing.

2. In wood frame construction, erect panels horizontally only.
- D. Double-Layer Non-Rated: Use gypsum board for first layer, placed parallel to framing or furring members, with ends and edges occurring over firm bearing. Place second layer perpendicular to framing or furring members. Offset joints of second layer from joints of first layer.
  - E. Fire-Rated Construction: Install gypsum board in strict compliance with requirements of assembly listing.
    1. Single Layer: Install and fasten gypsum board in accordance with CBC Title 24, Part 2, Table 7-B for steel or wood construction. Install gypsum board vertically, with edges and ends occurring over firm bearing.
    2. Double Layer: Install and fasten gypsum board in accordance with CBC Title 24, Part 2, Table 7B. Install base layer horizontally with ends occurring over firm bearing. Install face layer vertically with ends and edges occurring over firm bearing. Stagger joints 24 inches each side and opposite sides. Attach with required screws.
  - F. Exposed Gypsum Board in Interior Wet Areas: Seal joints, cut edges, and holes with water-resistant sealant.
  - G. Exterior Sheathing: Comply with ASTM C1280. Install sheathing vertically, with edges butted tight and ends occurring over firm bearing.
    1. Seal joints, cut edges, and holes with water-resistant sealant.
  - H. Cementitious Backing Board: Install over steel framing members and plywood substrate where indicated, in accordance with ANSI A108.11 and manufacturer's instructions.
  - I. Installation on Wood Framing: For rated assemblies, comply with requirements of listing authority. For non-rated assemblies, install as follows:
    1. Single-Layer Applications: Adhesive application.
    2. Double-Layer Application: Install base layer using screws or nails. Install face layer using adhesive.

### **3.04 INSTALLATION OF TRIM AND ACCESSORIES**

- A. Use longest practical lengths. Place corner beads at external corners. Place edge trim when gypsum board abuts dissimilar materials. Surfaces indicated to receive non-textured finish and semi-gloss enamels.
- B. Control Joints: Place control joints consistent with lines of building spaces and as indicated.
  1. Not more than 30 feet apart on walls and ceilings over 50 feet long.
- C. Corner Beads: Install at external corners, using longest practical lengths.
- D. Edge Trim: Install at locations where gypsum board abuts dissimilar materials.

### **3.05 JOINT TREATMENT**

- A. Glass Mat Faced Gypsum Board and Exterior Glass Mat Faced Sheathing: Use fiberglass joint tape, embed and finish with setting type joint compound.
- B. Paper Faced Gypsum Board: Use paper joint tape, embed with drying type joint compound and finish with drying type joint compound.
- C. Finish gypsum board in accordance with levels defined in ASTM C840, as follows:

1. Level 5: Walls and ceilings to receive, eggshell, semi-gloss or gloss paint finish and other areas specifically indicated. (Including High-Gloss thin wallcovering.)
  2. Level 4: Walls and ceilings to receive paint finish or wall coverings, unless otherwise indicated.
  3. Level 3: Walls to receive textured wall finish or heavy textured paint.
  4. Level 2: In utility areas, behind cabinetry, and on backing board to receive tile finish.
  5. Level 1: Fire rated wall areas above finished ceilings, whether or not accessible in the completed construction.
  6. Level 0: Temporary partitions.
- D. Tape, fill, and sand all exposed joints, edges, and corners, including inside corners to produce smooth surface ready to receive finishes.
1. Feather coats of joint compound so that camber is maximum 1/32 inch.
  2. Tape shall be set over joint and seated into joint compound, leaving sufficient adhesive under tape to provide proper bond.
  3. Internal angles, both horizontal and vertical, shall be reinforced and with tape folded to form straight and true angle.
  4. Metal external corners shall be cemented in place.
  5. Joints shall be allowed to dry according to Gypsum Association Standards based on temperature and humidity. Allow for at least 24 hours between each application of joint compound.
  6. The final application of compound and sanding shall leave all surfaces uniformly smooth and in condition to receive specified finish.
  7. Taping, filling, and sanding is not required at surfaces behind adhesive applied ceramic tile and fixed cabinetry.
  8. Taping, filling and sanding is not required at base layer of double layer applications.
- E. Spray apply high build drywall surfacer over entire surface after joints have been properly treated; achieve a flat and tool mark-free finish.
- F. Fill and finish joints and corners of cementitious backing board as recommended by manufacturer.

### **3.06 TOLERANCES**

- A. Maximum Variation of Finished Gypsum Board Surface from True Flatness: 1/8 inch in 10 feet in any direction.

### **3.07 REPAIR, CLEAN-UP AND PROTECTION**

- A. Repair fastener pops by driving a new fastener approximately 1-1/2 inches from the fastener pop and reset the popped fastener. When face paper is punctured, install a new fastener approximately 1-1/2 inches from the defective fastener. Fill damaged surfaces with compound.

- B. Upon completion of the work, remove from adjacent surfaces, overspray, splatter and daubs of taping and finish compound and textured finishes. Remove tools, equipment, unused material and cuttings and leave the work in a clean orderly manner.

**END OF SECTION**

## SECTION 09 22 36

### LATH

#### PART 1 GENERAL

##### 1.01 SECTION INCLUDES

- A. Metal lath for cement plaster.
- B. Furring for metal lath.
- C. Metal ceiling framing.

##### 1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 - Rough Carpentry: Sheathing on exterior walls.
- B. Section 07 25 00 - Weather Barriers: Weather barrier under exterior plaster and stucco.
- C. Section 08 31 00 - Access Doors and Panels: Product requirements for metal access panels integral with metal lath.
- D. Section 09 21 16 - Gypsum Board Assemblies: Sheathing on exterior walls.
- E. Section 09 24 00 - Cement Plastering.

##### 1.03 REFERENCE STANDARDS

- A. ASTM C841 - Standard Specification for Installation of Interior Lathing and Furring; 2003 (Reapproved 2018).
  - 1. Use 2003(2013) as indicated in 2016 CBC Ch. 35 Referenced Standards.
- B. ASTM C847 - Standard Specification for Metal Lath; 2018.
  - 1. Use 2012 as indicated in 2016 CBC Ch. 35 Referenced Standards.
- C. ASTM C954 - Standard Specification for Steel Drill Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Steel Studs From 0.033 in. (0.84 mm) to 0.112 in. (2.84 mm) in Thickness; 2015.
- D. ASTM C1002 - Standard Specification for Steel Self-Piercing Tapping Screws for Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs; 2018.
  - 1. Use 2007 as indicated in 2016 CBC Ch. 35 Referenced Standards.
- E. ASTM C1032 - Standard Specification for Woven Wire Plaster Base; 2018.
- F. ASTM C1063 - Standard Specification for Installation of Lathing and Furring to Receive Interior and Exterior Portland Cement-Based Plaster; 2019.
  - 1. Use 2012d as indicated in 2016 CBC Ch. 35 Referenced Standards.
- G. Plaster Assemblies Manual - Technical Information Services Bureau (TSIB) of Western Walls & Ceilings Contractors Association (WWCCA); Current Edition.

##### 1.04 SUBMITTALS

- A. See Section 01 33 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on furring and lathing components, structural characteristics, material limitations, and finish.



## **1.05 QUALITY ASSURANCE**

- A. Maintain one copy of each installation standard referenced on site throughout the duration of lathing and plastering work.
- B. Installer Qualifications: Company specializing in performing the work of this section with at least three years of documented experience.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Metal Lath: All products listed are "or equal".
  - 1. Brand X Metals: [www.brandxmetals.com](http://www.brandxmetals.com).
  - 2. Cemco: [www.cemcosteel.com/#sle](http://www.cemcosteel.com/#sle).
  - 3. Clarkwestern Dietrich Building Systems LLC: [www.clarkdietrich.com/#sle](http://www.clarkdietrich.com/#sle).
  - 4. Fry Reglet: [www.fryreglet.com](http://www.fryreglet.com).
  - 5. Pittcon Industries: [www.pittconindustries.com](http://www.pittconindustries.com).
  - 6. Structa Wire Corporation: [www.structawire.com/#sle](http://www.structawire.com/#sle).
  - 7. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

### **2.02 FRAMING AND LATH ASSEMBLIES**

- A. Provide completed assemblies with the following characteristics:
  - 1. Maximum Deflection of Vertical Assemblies: 1:360 under lateral point load of 100 lbs.
  - 2. Maximum Deflection of Horizontal Assemblies: 1:240 deflection under dead loads and wind uplift.
- B. Fire Rated Assemblies: Provide components complying with requirements for fire rated assemblies specified in the section where the plaster finish is specified.

### **2.03 FRAMING MATERIALS**

- A. Furring Channels: Formed steel, minimum 0.020 inch thick, 3/8 inch deep by 7/8 inch high, splicing permitted; galvanized.
- B. Main Ceiling Channels: Formed steel, asphalt coated, minimum 0.05 inch thick, 3/4 inch deep by 1-1/2 inch high, single piece, no splicing; galvanized.
- C. Hangers: Steel wire, of size and type to suit application, to support ceiling components in place to deflection limits as indicated.
- D. Ceiling Hangers: Rolled steel sections, of size and type to suit application, to rigidly support ceiling components in place to deflection limits as indicated; galvanized.
- E. Lateral Bracing: Formed steel, minimum 0.060 inch thick, size and length as required; galvanized.

### **2.04 LATH**

- A. Diamond Mesh Metal Lath: ASTM C847, galvanized; self-furring.

1. Weight: To suit application, comply with deflection criteria, and as specified in ASTM C841 or ASTM C1063 for framing spacing.
  2. Minimum Weight: 3.4 lb/sq yd.
- B. Ribbed Metal Lath: ASTM C847, galvanized; 3/8 inch thick. For soffit use only.
1. Weight: To suit application, comply with deflection criteria, and as specified in ASTM C841 or ASTM C1063 for framing spacing.
  2. Minimum Weight: 3.4 lb/sq yd.
- C. Corner Mesh: Formed sheet steel, minimum 0.018 inch thick, perforated flanges shaped to permit complete embedding in plaster, minimum 2 inch size; same finish as lath.
- D. Strip Mesh: Expanded metal lath, same weight as lath, 2 inch wide by 24 inch long; same finish as lath.
- E. Beads, Screeds, Joint Accessories, and Other Trim: Depth governed by plaster thickness, maximum possible lengths.
1. Galvanized Steel Accessories:
    - a. Types specified below conforming to Technical Services Information Bureau of the Western Walls and Ceilings Contractors Association (WWCCA) "Plaster Assemblies Manual".
    - b. Where galvanized accessories are specified, use hot-dip galvanized steel, ASTM A653, designation G60.
    - c. Provide metal shapes, of longest possible length, used as grounds of such size and dimension as to provide for required plaster thickness.
  2. Material: Formed galvanized sheet steel, expanded metal flanges.
  3. Casing Beads with Weep Holes: Square edges.
    - a. Product: #66 Expanded Flange Casing Bead manufactured by Cemco.
    - b. Fabricated of 26 gage hot-dip galvanized steel. Provide beads with expanded metal flange and inverted vee at plaster edge of face flange.
  4. Corner Beads: Square-Edge corners.
    - a. Corner Reinforcement: Fabricated from expanded metal with large openings, from welded or woven copper bearing steel wire of minimum 28 gage, hot-dip galvanized, minimum 3 inches wide.
      - 1) Product: No. 2-A Corner Bead manufactured by Cemco.
      - 2) Product: No. 2-A Reinforced Flange Corner Bead manufactured by Cemco.
    - b. Cornerite: Expanded Metal, weighing 0.105 pounds per lineal foot, bent in center to form 105 degree angle, 6 inches wide (total).
      - 1) Product: Cornerite manufactured by Cemco.
  5. Base Screeds: Bevelled edges.
    - a. Foundation Weep Screeds: Perforated type.
      - 1) Product: No. 7 Foundation Sill Screed manufactured by Cemco.
      - 2) Product: No. 7 Extended Foundation Screed manufactured by Cemco. For locations where plaster is just above a paving surface.
  6. Drip Screeds: Fabricated from 0.018 inch thick; G-90 hot-dip galvanized steel.
    - a. Product: #12 Soffit Drip Edge manufactured by Cemco.

- b. Product: #6 Head Drip Screed manufactured by Cemco. For locations above other flashing such as door and window heads.
- 7. Window/Door Drips: Self weeping 26 gage hot-dip galvanized steel.
  - a. Product: No. 3 Flashing Screed manufactured by Cemco. For locations where plaster is offset 1-1/2 inches back from projection.
- 8. Strip Lath: Strip Reinforcement (Expanded Metal), weighing 2.5 lbs/sq.yd., 6 inches wide. Use hot-dip galvanized at all locations where galvanized metal lath occurs.
- 9. Control Joints: Accordion profile with factory-installed protective tape, 2 inch flanges.
  - a. Product: Double "V" Control Joint (#15) manufactured by Cemco.
  - b. Stress Relief Joints (Expansion and Control Joints): Stress Relief Control Joints, fabricated of 26 gage (0.0217 inch) hot-dip galvanized steel with G60 hot-dip galvanized coating.
    - 1) Recesses on control joints shall be covered with removable tape or filled with rope to prevent plaster from filling the recess.
- 10. Aluminum Accessories (Where Detailed):
  - a. Specified Manufacturer: Fry Reglet Corporation; [www.fryreglet.com](http://www.fryreglet.com).
  - b. Acceptable Manufacturers:
    - 1) Interior Specialties Division, Gordon, Inc.; [www.gordon-inc.com](http://www.gordon-inc.com).
    - 2) Substitutions: See Section 01 60 00 - Product Requirements.
  - c. Casing Beads: Fry Reglet, F-shaped aluminum, FPM-75-75, 3/4 inch reveal or Fry J-Molding JPM-75 as detailed.
  - d. Control Joints: Fry Reglet, Channel Screed, PCS-75-50, 1/2 inch wide reveal or as detailed on Drawings.
  - e. All intersections factory fabricated with joints heliarc welded and backs sealed with permanent waterproof tape. Provide connector clips and sealant at butt joints of straight sections.
  - f. Aluminum Finish:
    - 1) Clear anodized.
  - g. Fasteners: 1-1/4 inch long S-12 pancake head, USG, Buildex Division of Illinois Tool Works or equal.

## 2.05 ACCESSORIES

- A. Access Panels: As specified in Section 08 31 00.
- B. Anchorage: Tie wire, nails, and other metal supports, of type and size to suit application; to rigidly secure materials in place, galvanized per ASTM C1063.
  - 1. At Vertical Surfaces:
    - a. Tie Wire: 18 gage.
  - 2. At Horizontal Surfaces:
    - a. Tie Wire: 18 gage, double strand.
- C. Fasteners: Self-piercing tapping screws; ASTM C1002 or ASTM C954.
  - 1. At Vertical Surfaces:
    - a. Screws: Self-drilling TEKS for metal stud attachment.

2. At Horizontal Surfaces:
  - a. Screws: Self-drilling TEKS for metal stud attachment.
- D. Tie Wire: Annealed galvanized steel.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify that substrates are ready to receive work and conditions are suitable for application.
- C. Do not begin until unacceptable conditions have been corrected.
- D. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

### **3.02 INSTALLATION - GENERAL**

- A. Install interior lath and furring for gypsum plaster in accordance with ASTM C841.
- B. Install metal lath and furring for Portland cement plaster in accordance with ASTM C1063.
- C. Install lath and furring for fire-rated assemblies in accordance with requirements of assembly as indicated.

### **3.03 CEILING AND SOFFIT FRAMING INSTALLATION**

- A. Install furring after work above ceiling or soffit is complete. Coordinate the location of hangers with other work.
- B. Install furring independent of walls, columns, and above-ceiling work.
- C. Securely anchor hangers to structural members or embed in structural slab. Space hangers as required to limit deflection to criteria indicated. Use rigid hangers at exterior soffits.
- D. Space main carrying channels at maximum 72 inch on center, and not more than 6 inches from wall surfaces. Lap splice securely.
- E. Securely fix carrying channels to hangers to prevent turning or twisting and to transmit full load to hangers.
- F. Install furring channels perpendicular to carrying channels, not more than 2 inches from perimeter walls, and rigidly secure. Lap splices securely.
- G. Reinforce openings in suspension system that interrupt main carrying channels or furring channels with lateral channel bracing. Extend bracing minimum 24 inches past each opening.
- H. Laterally brace suspension system.

### **3.04 CONTROL AND EXPANSION JOINT INSTALLATION**

- A. At unsheathed open framing, provide double stud construction behind control joint.
- B. Locate joints as indicated on drawings and comply with ASTM C1063.
  1. Area of plaster panel not to exceed 144 sq ft for vertical surfaces.
    - a. Expansion Joint Spacing: 36 feet on center and as indicated on drawings.
  2. Area of plaster panel not to exceed 100 sq ft for horizontal, curved or angled surfaces.

3. Spacing between control joints not to exceed 18 ft in each direction.
  - a. Narrow panels should not exceed 12 feet in length.
4. Area bounded by control joints not to exceed a length-to-width ratio of 2-1/2 to 1.
5. Vertical control joints should pass through horizontal control joints. Vertical control joints must terminate at horizontal expansion joints.
6. Joint Placement: Approved by Architect before plastering.
- C. Install expansion joints where an expansion joint occurs in base exterior wall.
- D. Install prefabricated joint accessories in accordance with ASTM C1063.
  1. Install factory-made joints at reveal-to-reveal and reveal-to-control joint intersections.
- E. Discontinue metal lath at joint and apply 12 inch wide strip of flexible flashing behind each joint
- F. Hold casing beads back 3/8 to 1/4 inch from abutting frames and other elements to provide joint for sealant.
- G. Apply sealant at splices, intersections and terminals in accordance with Section 07 92 00 - Joint Sealants.

### **3.05 ACCESS PANELS INSTALLATION**

- A. Install access panels and rigidly secure in place.
- B. Install frames plumb and level in opening. Secure rigidly in place.
- C. Position to provide convenient access to concealed work requiring access.

### **3.06 LATH INSTALLATION**

- A. Apply lath taut, with long dimension perpendicular to supports.
- B. Lath shall not be continuous through control or expansion joints.
- C. Apply ribbed lath with self-furring ribs perpendicular to supports at soffits and horizontal surfaces.
  1. Lap sides of ribbed lath minimum 1-1/2 inches.
  2. Nest outside ribs of rib lath together.
  3. Attach lath to supports using specified screws at maximum 6 inches on center vertical and 16 inches on center horizontal.
  4. At horizontal metal lath application, secure lath to each support with specified screws.
- D. Expanded metal lath at vertical supports, apply self-furring "grooved" metal lath with self-furring rib perpendicular to supports.
  1. Install per Table 2507.2 California Building Code.
  2. Installation shall maintain lath 1/4 inch away from vertical supports.
- E. Attach metal lath to supports using screws at maximum 12 inches on center.
- F. Attach horizontal metal lath to metal supports using tie wire at maximum 6 inches on center vertical.
- G. Continuously reinforce internal angles with corner mesh, except where the metal lath returns 3 inches from corner to form the angle reinforcement; fasten at perimeter edges only.

- H. Place corner bead with mesh at external wall corners; fasten at outer edges of lath only.
- I. Place strip lath diagonally at corners of lathed openings. Secure rigidly in place.
- J. Place strip lath centered over junctions of dissimilar backing materials on same plane. Secure rigidly in place.
- K. Place base screeds at termination of plaster areas; secure rigidly in place.
  - 1. Install weep screeds at foundation. Install minimum 4 inches above earth or 2 inches above paved areas.
  - 2. To allow moisture to escape from a portland cement plaster (stucco) assembly, no sealant shall be placed at the bottom of the plaster termination.
- L. Place 4 inch wide strips of lath centered over junctions of dissimilar backing materials, and secure rigidly in place.
- M. Place lath vertically above each top corner and each side of door frames to 6 inches above ceiling line.
- N. Place casing beads at terminations of plaster finish. Butt and align ends, cope or miter at corners. Secure rigidly in place, maximum 12 inches on centers..
- O. Place additional strip mesh diagonally at corners of lathed openings. Secure rigidly in place.

### **3.07 FIELD QUALITY CONTROL**

- A. Inspection: Notify Architect minimum 2 days prior to scratch coat for inspection of all in-place lath and accessories.

### **3.08 TOLERANCES**

- A. Install accessories to lines and levels.
- B. Maximum Variation from True Lines and Levels: 1/8 inch in 10 feet.
- C. Maximum Variation from True Position: 1/8 inch.

**END OF SECTION**



**SECTION 09 24 00**  
**CEMENT PLASTERING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Cement plastering.

**1.02 RELATED REQUIREMENTS**

- A. Section 07 25 00 - Weather Barriers: Weather barrier under exterior plaster.
- B. Section 08 31 00 - Access Doors and Panels: Access panels.
- C. Section 09 21 16 - Gypsum Board Assemblies: Gypsum Sheathing: Solid backing at all exterior plaster.
- D. Section 09 22 36 - Lath: Lath, furring, beads, screeds, and joint accessories for plaster base.
- E. Section 09 91 13 - Exterior Painting: Finish paint over intergral color plaster.

**1.03 REFERENCE STANDARDS**

- A. ASTM C150/C150M - Standard Specification for Portland Cement; 2018.
- B. ASTM C206 - Standard Specification for Finishing Hydrated Lime; 2014.
- C. ASTM C207 - Standard Specification for Hydrated Lime for Masonry Purposes; 2018.
- D. ASTM C926 - Standard Specification for Application of Portland Cement-Based Plaster; 2018a.
- E. ASTM C932 - Standard Specification for Surface-Applied Bonding Compounds for Exterior Plastering; 2006 (Reapproved 2013).
- F. TSIB (PAM) - Plaster Assemblies Manual, Technical Services Information Bureau; Current Edition.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittals procedures.
- B. Product Data: Provide data on plaster materials and trim accessories.
- C. Evaluation Service Reports: Show compliance with specified requirements.
- D. Samples:
  - 1. Submit two samples, 8 by 8 inch in size illustrating finish color and texture.
  - 2. Submit two samples of each type trim accessory.

**1.05 QUALITY ASSURANCE**

- A. Installer Qualifications: Company specializing in performing the work of this section with minimum three years documented experience.
- B. Copies of Documents at Project Site: Maintain at the project site a copy of each referenced document that prescribes execution requirements.



## **1.06 MOCK-UP**

- A. Mock-Up Panel: Construct a 4 foot wide by 8 foot high sample panel of plaster work at the jobsite demonstrating installation procedures, finish texture, and color. Show each phase of installation including framing and reinforcement.
- B. After color and texture samples have been approved and returned, construct a mock-up not less than as noted above in size, of each texture type, in location approved by Architect.
  - 1. Use workmen, equipment and techniques proposed for use on the project.
  - 2. The panel may be constructed as a portion of the finished work, provided the approved panel is clearly identified for future reference.
  - 3. The approved panel shall become the standard of comparison for cement plaster work for the project.
  - 4. If mock-up is not a part of building construction, it must be removed when directed by Architect after completion of project.

## **1.07 FIELD CONDITIONS**

- A. Exterior Plaster Work: Do not apply plaster when substrate or ambient air temperature is 40 degrees F or lower, or when temperature is expected to drop below 40 degrees F within 48 hours of application.

## **PART 2 PRODUCTS**

### **2.01 CEMENT PLASTER APPLICATIONS**

- A. Lath Plaster Base: Metal lath.
  - 1. Plaster Type: Factory prepared plaster mix.
  - 2. Number of Coats: Three.
  - 3. First Coat: Apply to a nominal thickness of 3/8 inch.
  - 4. Second Coat: Apply to a nominal thickness of 3/8 inch.
  - 5. Leveling Coat: Apply to a nominal thickness of 1/32 to 1/16 inch.
  - 6. Finish: Acrylic.

### **2.02 FACTORY PREPARED CEMENT PLASTER**

- A. Exterior Portland cement plaster system made of scratch and brown base coat, leveling coat with reinforcing mesh, and acrylic finish coat; install in accordance with ASTM C926.
  - 1. Provide weather resistive barrier as part of the system, by the same manufacturer.
  - 2. Manufacturer - Basis of Design:
    - a. Omega Products International, Inc.; Super Cement with Crack Isolation System: [www.omega-products.com](http://www.omega-products.com).
  - 3. Other Acceptable Manufacturers:
    - a. Omega Products International, Inc.: [www.omega-products.com](http://www.omega-products.com).
    - b. Parex USA, Inc; Armourwall 300: [www.parexusa.com/#sle](http://www.parexusa.com/#sle).
    - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

- B. Premixed One-Coat Base: Mixture of Type I Portland cement complying with ASTM C150/C150M, hydrated lime complying with ASTM C206 and/or ASTM C207, fibers and other approved ingredients; install in accordance with ASTM C926.
- C. Premixed Base Coats: Mixture of cement, aggregate, fibers, and proprietary admixtures for scratch and brown coats; install in accordance with ASTM C926.
- D. Primer: Acrylic, as recommended by coating manufacturer and compatible with plaster base coat.
- E. Premixed Finish Coating: Integrally colored, cementitious coating.
  - 1. Color: to match existing.

### **2.03 ACCESSORIES**

- A. Lath: As specified in Section 09 22 36.
- B. Beads, Screeds, and Joint Accessories: As specified in Section 09 22 36.
- C. Bonding Compound: Provide type recommended for bonding plaster to solid surfaces, complying with ASTM C932.
- D. Reinforcing Mesh: 4.5 oz/sq yd alkali-resistant mesh.
- E. Water Resistive Barrier: As specified in Section 07 25 00.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions are acceptable prior to starting this work.
- B. Verify lath is flat, secured to substrate, and joint and surface perimeter accessories are properly in place.
- C. Verify mechanical and electrical equipment and services located within areas to receive this work have been properly tested and approved.

### **3.02 PREPARATION**

- A. Roughen smooth concrete surfaces and apply bonding compound in accordance with manufacturer's written installation instructions.

### **3.03 MIXING**

- A. Mix only as much plaster as can be used prior to initial set.
- B. Mix materials dry, to uniform color and consistency, before adding water.
- C. Protect mixtures from frost or freezing temperatures, contamination, and excessive evaporation.

### **3.04 APPLICATION**

- A. Apply plaster in accordance with manufacturer's written instructions and comply with ASTM C926.
- B. Base Coats:
  - 1. Apply base coat(s) to fully embed lath and to specified thickness.

2. Follow guidelines in ASTM C926 and manufacturer's written installation instructions for moist curing base coats and application of subsequent coats.
- C. Leveling Coat:
1. Apply leveling coat to specified thickness.
  2. Fully embed reinforcing mesh in leveling coat.
- D. Finish Coats:
1. Primer and Acrylic or Cementitious Coatings: Match existing.
    - a. Remove surface contaminants such as dust and dirt without damaging substrate.
    - b. Apply primer in accordance with manufacturer's instructions.
    - c. Apply finish coating in number of coats and to thickness recommended by manufacturer.
    - d. Finish coat to match existing texture.
  2. Acrylic Finish Texture: Apply to a consistent finish.
    - a. TSIB (PAM) Fine Sand.
    - b. OmegaFlex Fine
- E. Finish Painting Overcoat: See Section 09 91 13 - Exterior Painting.

### **3.05 TOLERANCES**

- A. Maximum Variation from True Flatness: 1/4 inch in 10 feet.

### **3.06 REPAIR**

- A. Patching: Remove loose, damaged or defective plaster and replace with plaster of same composition; finish to match surrounding area.
- B. Damaged Plaster:
1. Plaster Detached from Framing:
    - a. Remove loose and broken plaster.
    - b. Repair or replace damaged water-resistant backing and lath in compliance with specified standards.
    - c. Remove finish coat from surrounding area in the same plane by sandblasting.
    - d. Provide a scratch coat and a brown coat mixed with liquid bonding agent instead of water to the areas devoid of plaster.
    - e. Provide a coat of liquid bonding agent to entire wall plane.
    - f. Provide 1/8 inch thick finish coat to entire wall plane. Match existing texture and color.
  2. Cracked Plaster 1/8 inch to 1/2 inch:
    - a. Remove loose material from crack with a wire brush.
    - b. Fill crack with slurry of stucco and liquid bonding agent.
    - c. Provide a coat of liquid bonding agent to entire wall plane.
    - d. Provide 1/8 inch thick finish coat to entire wall plane and match existing texture and color.
  3. Cracks Larger than 1/2 inch - Painted:

- a. Remove loose material from crack with a wire brush.
- b. Fill crack with slurry of one part Portland cement to three parts masonry or stucco sand and liquid bonding agent to match existing texture of adjacent surface.
- c. Paint entire wall plane, color to match existing.
- d. Where patching of plaster over existing lath is feasible, fasten loose lath and install new lath with nails at 6 inch centers.
  - 1) Where metal is furnished, lap new lath 6 inches over existing and tie at 6 inch centers.
  - 2) Provide waterproof, air barrier, and vapor barrier as required, shingled into existing.
- e. Patching of Holes, Cracks, and Gouges:
  - 1) Patch holes, cracks, gouges, missing sections, and other defects in existing improvements.
  - 2) For holes over 1 inch in size, cut small sections of lath and place in opening attached to existing material.
    - (a) Install 3 coats of plaster.
  - 3) For holes one inch and smaller, install bonding agent to existing surfaces and neatly fill hole with plaster, installing necessary coats to match adjacent surfaces, eliminate cracks and match existing surface texture.
  - 4) Cracks, gouges, and other defects shall be filled with plaster or spackle as required and neatly finished to match adjacent existing improvements.

**END OF SECTION**



**SECTION 09 30 00**  
**TILING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Tile for floor applications.
- B. Tile for wall applications.
- C. Stone thresholds.

**1.02 RELATED REQUIREMENTS**

- A. Section 07 92 00 - Joint Sealants: Sealing joints between tile work and adjacent construction and fixtures.
- B. Section 08 31 00 - Access Doors and Panels: Access panels set in tile surface.
- C. Division 22 - Plumbing: Plumbing Fixtures, Floor drains and miscellaneous devices.

**1.03 REFERENCE STANDARDS**

- A. ANSI A108/A118/A136 - American National Standard Specifications for the Installation of Ceramic Tile (Compendium); 2017.
  - 1. Use 1999 (Reapproved 2002) as indicated in CBC 2016 Referenced Standards.
- B. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- C. ANSI A108.5 - American National Standard Specifications for Installation of Ceramic Tile with Dry-Set Portland Cement Mortar or Latex-Portland Cement Mortar; 1999 (Reaffirmed 2010).
- D. ANSI A108.10 - American National Standard Specifications for Installation of Grout in Tilework; 1999 (Reaffirmed 2010).
- E. ANSI A108.11> ANSI A108/A118/A136.1 - American National Standard for Interior of Cementitious Backer Units; 2010 (Revised).
- F. ANSI A118.1 - American National Standard Specifications for Dry-Set Cement Mortar; 2012 (Revised).
- G. ANSI A118.3 - American National Standard Specifications for Chemical Resistant, Water Cleanable Tile-Setting and -Grouting Epoxy and Water Cleanable Tile-Setting Epoxy Adhesive; 2013 (Revised).
- H. ANSI A118.4 - American National Standard Specifications for Modified Dry-Set Cement Mortar; 2012 (Revised).
- I. ANSI A118.5 - American National Standard Specifications for Chemical Resistant Furan Mortars and Grouts for Tile Installation; 1999 (Reaffirmed 2016).
- J. ANSI A118.7 - American National Standard Specifications for High Performance Cement Grouts for Tile Installation; 2010 (Reaffirmed 2016).
- K. ANSI A118.10 - American National Standard Specifications for Load Bearing, Bonded, Waterproof Membranes For Thin-Set Ceramic Tile And Dimension Stone Installation; 2014.
- L. ANSI A118.12 - American National Standard Specifications for Crack Isolation Membranes for Thin-Set Ceramic Tile and Dimension Stone Installation; 2014.

- M. ANSI A137.1 - American National Standard Specifications for Ceramic Tile; 2012.
  - 1. Use 2012 as indicated in CBC 2016 Referenced Standards.
- N. ANSI/NFSI B101.3 - Test Method for Measuring Wet DCOF of Common Hard Surface Floor Materials; 2012.
- O. ASTM C373 - Standard Test Methods for Determination of Water Absorption and Associated Properties by Vacuum Method for Pressed Ceramic Tiles and Glass Tiles and Boil Method for Extruded Ceramic Tiles and Non-tile Fired Ceramic Whiteware Products; 2017.
- P. ASTM C847 - Standard Specification for Metal Lath; 2018.
- Q. ASTM D638 - Standard Test Method for Tensile Properties of Plastics; 2014.
- R. ASTM F710 - Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring; 2019.
- S. ASTM F1869 - Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride; 2016a.
- T. BAAQMD 8-51 - Bay Area Air Quality Management District Regulation 8, Rule 51, Adhesive and Sealant Products; 2002.
- U. SCAQMD 1168 - Adhesive and Sealant Applications; 1989 (Amended 2017).
- V. TCNA (HB) - Handbook for Ceramic, Glass, and Stone Tile Installation; 2017.

#### **1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Preinstallation Meeting: Convene a preinstallation meeting one week before starting work of this section; require attendance by all affected installers.

#### **1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide manufacturers' data sheets on tile, mortar, grout, and accessories. Include instructions for using grouts and adhesives.
- C. Shop Drawings: Indicate tile layout, patterns, color arrangement, perimeter conditions, junctions with dissimilar materials, control and expansion joints, thresholds, and setting details.
- D. Samples: Mount tile and apply grout on two plywood panels, minimum 18 by 18 inches in size illustrating pattern, color variations, and grout joint size variations. Provide full size tile samples with grout color selections.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
  - 1. Submit manufacturer's certification that grout materials being provided are suitable for intended use, meet or exceed referenced ANSI standards, and are listed on Ceramic Tile Institute "Tested Materials" list.
  - 2. Prior to shipment of tile to jobsite, deliver Master Grade Certificates to Architect, complying with TCNA/ANSI A137.1.
- F. Master Grade Certificate: Submit for each type of tile, signed by the tile manufacturer and tile installer.
- G. Installer's Qualification Statement:

1. Submit documentation of National Tile Contractors Association (NTCA) or Tile Contractors' Association of America (TCAA) accreditation.
  2. Submit documentation of completion of apprenticeship and certification programs.
- H. Maintenance Data: Include recommended cleaning methods, cleaning materials, and stain removal methods.
- I. Maintenance Materials: Furnish the following for District's use in maintenance of project.
1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.
  2. Extra Tile: One box, minimum of 24 pieces of each size, color, and surface finish combination.

### 1.06 QUALITY ASSURANCE

- A. Maintain one copy of and ANSI A108/A118/A136 and TCNA (HB) on site.
- B. Requirements for Persons with Disabilities: Provide ceramic tile flooring meeting slip-resistant requirements of California Code of Regulations (CCR), Title 24, Part 2, Chapter 11B and ADA Standards, latest amendment.
1. Tile flooring surface shall be stable, firm, and slip resistant. CBC Section 11B-302.1 General.
  2. Tile flooring Surface shall demonstrate a dynamic coefficient of friction of at least 0.42 wet per DCOF AcuTest ANSI A137.1 Section 9.6 and ANSI/NFSI B101.3(using a BOT-3000 testing unit) will be accepted as meeting the intent of slip resistance; CBC 11B-302 Floor or Ground Surfaces and ADA Standards.
    - a. Ramp surface: Provide wet DCOF value of 0.46.
- C. Regulatory Requirements:
1. California Plumbing Code:
    - a. Floor Drains:
      - 1) Inspection of Work - All surfaces prepared by others shall be inspected by the tile installer before starting tile work and all unsatisfactory conditions reported to the Administrative Authority. Starting tile work by the tile installer shall be considered as acceptance of surfaces prepared by others.
      - 2) Surfaces - All surfaces to receive tile work shall be clean, structurally sound, and slopes shall to conform to CBC.  
Note: No tile work shall proceed until the pan and drain construction has been inspected and approved by the Administrative Authority, where required.
    - b. Definition:
      - 1) Receptor: An approved plumbing fixture or device of such material, shape, and capacity as to adequately receive the discharge from indirect waste pipes, so constructed and located as to be readily cleaned. CPC 220.0
- D. Manufacturer Qualifications: Company specializing in manufacturing the types of products specified in this section, with minimum five years of documented experience.
- E. Installer Qualifications:
1. Company specializing in performing tile installation, with minimum of five years of documented experience.



- a. Accredited Five-Star member of the National Tile Contractors Association (NTCA) or Trowel of Excellence member of the Tile Contractors' Association of America (TCAA).
- 2. Installer Certification:
  - a. Ceramic Tile Education Foundation (CTEF): Certified Tile Installer (CTI).
  - b. Apprenticeship Program: Installer has achieved Journeyworker status through an apprenticeship from the International Union of Bricklayers and Allied Craftworkers (IUBAC) or a U.S. Department of Labor (DOL)-recognized program.
  - c. Advanced Certifications for Tile Installers (ACT): Certification in the installation of membranes, mortar bed (mud) floors, mortar (mud) walls, large format tile, gauged porcelain tile/panels/slabs, and grouts.

### **1.07 MOCK-UP**

- A. See Section 01 45 00 - Quality Control, for general requirements for mock-up.
- B. Construct tile mock-up where indicated on drawings, incorporating all components specified for the location.
  - 1. Minimum size of mock-up is indicated on drawings.
  - 2. Approved mock-up may remain as part of the Work.

### **1.08 DELIVERY, STORAGE, AND HANDLING**

- A. Delivery:
  - 1. Deliver tile, cement, lime, mortar and grout to the project site in unopened containers, labeled with the manufacturer's name and brand designation.
  - 2. Grade seal tile cartons by the manufacturer in accordance with ANSI A137.1.
  - 3. Include hallmarks on labels for dry set and latex mortars certifying compliance with ANSI A118.1 and ANSI A118.4 respectively.
- B. Storage: Store tile and cementitious materials in dry, weather tight enclosures. Store stand in a well drained area on a solid surface to prevent mixing with foreign matter.
- C. Protect adhesives from freezing or overheating in accordance with manufacturer's instructions.

### **1.09 FIELD CONDITIONS**

- A. Do not install solvent-based products in an unventilated environment.
- B. Maintain ambient and substrate temperature of 50 degrees F and rising during installation of mortar and grout materials. Temperature of the substrate shall not exceed 100 degrees F.
- C. Shade work from direct sunlight during tile installation as needed to prevent rapid evaporation caused by excessive heat.

### **1.10 WARRANTY**

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Correct defective Work within a one year period after Date of Substantial Completion.
- C. Provide ten year manufacturer warranty for waterproofing liners.

## **PART 2 PRODUCTS**

### **2.01 TILE**

- A. Acceptable Manufacturers: All products by the same manufacturer.
  - 1. American Olean Corporation: [www.americanolean.com/#sle](http://www.americanolean.com/#sle).
  - 2. Dal-Tile Corporation: [www.daltile.com/#sle](http://www.daltile.com/#sle).
  - 3. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Porcelain Tile: ANSI A137.1, standard grade.
  - 1. Moisture Absorption: 0 to 0.5 percent as tested in accordance with ASTM C373.
  - 2. Size: As indicated on Drawings, nominal.
  - 3. Thickness: 3/8 inch.
  - 4. Edges: Cushioned.
  - 5. Surface Finish: Unglazed.
  - 6. Color(s): To be selected by Architect from manufacturer's standard range.
  - 7. Trim Units: Matching bullnose, double bullnose, cove base, and cove shapes in sizes coordinated with field tile.

### **2.02 TRIM AND ACCESSORIES**

- A. Thresholds: Type and color as indicated on Drawings or as selected by Architect, honed finish; 2 inches wide by full width of wall or frame opening; 1/2 inch thick; beveled one long edge with radiused corners on top side; without holes, cracks, or open seams.
  - 1. Applications:
    - a. At doorways where tile terminates.
  - 2. Acceptable Manufacturers/Distributors: See Ceramic Tile Article above.
  - 3. Solid Polymer Fabricated: ASTM D638.
    - a. Color and Pattern: As indicated on drawings.
    - b. Manufacturers:
      - 1) Formica Corporation Product: Signatures: [www.formica.com](http://www.formica.com).
      - 2) Avonite Surfaces Product Avonite: [www.avonitesurfaces.com](http://www.avonitesurfaces.com).
      - 3) Dupont Product: Corian: [www.corian.com](http://www.corian.com).
      - 4) Panolam Industries International, Inc.(Nevamar); Product Fountainhead: [www.nevamar.com](http://www.nevamar.com).
      - 5) Wilsonart International, Inc Product: Gibraltar: [www.wilsonart.com](http://www.wilsonart.com).

### **2.03 SETTING MATERIALS**

- A. Interior adhesives, sealants, primers and sealants used as filler must meet the requirements of low emitting materials. Conform to SCAQMD 1168 and BAAQMD 8-51.
- B. Manufacturers:
  - 1. Bostik Inc: [www.bostik-us.com](http://www.bostik-us.com).
  - 2. Custom Building Products: [www.custombuildingproducts.com](http://www.custombuildingproducts.com).

3. LATICRETE International, Inc: [www.laticrete.com](http://www.laticrete.com).
  4. Mapei Corporation: [www.mapei.com](http://www.mapei.com).
  5. Merkrete, by Parex USA, Inc: [www.merkrete.com](http://www.merkrete.com).
  6. TEC, an H.B. Fuller Construction Products Brand: [www.tecspecialty.com/#sle](http://www.tecspecialty.com/#sle).
  7. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- C. Epoxy Adhesive and Mortar Bond Coat: ANSI A118.3 and TCNA (HB).
1. Applications: Where indicated on drawings.
  2. Products:
    - a. Custom Building Products; EBM-Lite Epoxy Bonding Mortar: [www.custombuildingproducts.com/#sle](http://www.custombuildingproducts.com/#sle).
    - b. LATICRETE International, Inc; LATICRETE LATAPOXY 300 Adhesive: [www.laticrete.com/#sle](http://www.laticrete.com/#sle).
    - c. Merkrete, by Parex USA, Inc; Merkrete Pro Epoxy: [www.merkrete.com/#sle](http://www.merkrete.com/#sle).
- D. Dry-Set Portland Cement Mortar Bond Coat: ANSI A118.1 and TCNA (HB), Zero-volatile organic compound (VOC) content..
1. Products:
    - a. Custom Building Products: [www.custombuildingproducts.com](http://www.custombuildingproducts.com).
    - b. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- E. Mortar Bed Materials: Pre-packaged mix of Portland cement, sand, latex additive, and water.
1. Products:
    - a. Custom Building Products; ProLite Tile & Stone Mortar: [www.custombuildingproducts.com](http://www.custombuildingproducts.com).
    - b. LATICRETE International, Inc: [www.laticrete.com/#sle](http://www.laticrete.com/#sle).
    - c. Merkrete, by Parex USA, Inc: [www.merkrete.com/#sle](http://www.merkrete.com/#sle).
    - d. Proflex Products, Inc: [www.proflex.us/#sle](http://www.proflex.us/#sle).
    - e. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## 2.04 GROUTS

- A. Manufacturers:
1. Basis of Design: Custom Building Products: [www.custombuildingproducts.com](http://www.custombuildingproducts.com).
  2. Custom Building Products: [www.custombuildingproducts.com](http://www.custombuildingproducts.com).
  3. LATICRETE International, Inc: [www.laticrete.com/#sle](http://www.laticrete.com/#sle).
  4. MAPEI Corporation: [www.mapei.com](http://www.mapei.com).
  5. Merkrete, by Parex USA, Inc: [www.merkrete.com](http://www.merkrete.com).
  6. TEC, an H.B. Fuller Construction Products Brand: [www.tecspecialty.com/#sle](http://www.tecspecialty.com/#sle).
  7. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. High Performance Polymer Modified Grout: ANSI A118.7 polymer modified cement grout.
1. Applications: Use this type of grout where indicated on exterior over plaster.

2. Use sanded grout for joints 1/8 inch wide and larger; use unsanded grout for joints less than 1/8 inch wide.
  3. Color(s): As selected by Architect from manufacturer's full line.
  4. Products:
    - a. Bostik Inc: [www.bostik-us.com](http://www.bostik-us.com).
    - b. Custom Building Products; Fusion Pro Single Component Grout: [www.custombuildingproducts.com](http://www.custombuildingproducts.com).
    - c. LATICRETE International, Inc: [www.laticrete.com/#sle](http://www.laticrete.com/#sle).
    - d. Mapei, Inc.; Keracolor S Grout unsanded: [www.mapei.com](http://www.mapei.com)
    - e. Merkrete, by Parex USA, Inc: [www.merkrete.com/#sle](http://www.merkrete.com/#sle).
    - f. TEC, an H.B. Fuller Construction Products Brand: [www.tecspecialty.com/#sle](http://www.tecspecialty.com/#sle).
    - g. TEC Specialty Construction Brands; Accucolor® Premium Sanded Grout: [www.tecspecialty.com](http://www.tecspecialty.com).
    - h. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- C. Epoxy Grout: ANSI A118.3 chemical resistant and water-cleanable epoxy grout.
1. Applications: Toilet Room Floors.
  2. Color(s): As indicated on drawings.
  3. Products:
    - a. Custom Building Products; CEG-Lite 100% Solids Commercial Epoxy Grout: [www.custombuildingproducts.com](http://www.custombuildingproducts.com).
    - b. LATICRETE International, Inc: [www.laticrete.com/#sle](http://www.laticrete.com/#sle).
    - c. MAPEI Corporation; Kerapoxy Epoxy Grout: [www.mapei.com](http://www.mapei.com).
    - d. Merkrete, by Parex USA, Inc: [www.merkrete.com/#sle](http://www.merkrete.com/#sle).
    - e. TEC, an H.B. Fuller Construction Products Brand: [www.tecspecialty.com/#sle](http://www.tecspecialty.com/#sle).
    - f. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- D. Stain Resistant Grout Additive: Liquid admixture for sanded and unsanded cement-based grouts; mix with dry grout material in place of water.
1. Applications: Toilet Rooms.

## 2.05 MAINTENANCE MATERIALS

- A. Tile Sealant: Gunnable, silicone, siliconized acrylic, or urethane sealant; moisture and mildew resistant type.
1. Applications: Between tile and plumbing fixtures.
  2. Color(s): As selected by Architect from manufacturer's full line.
  3. Products:
    - a. ARDEX Engineered Cements: [www.ardexamericas.com/#sle](http://www.ardexamericas.com/#sle).
    - b. Custom Building Products; Commercial 100% Silicone Caulk: [www.custombuildingproducts.com/#sle](http://www.custombuildingproducts.com/#sle).
    - c. LATICRETE International, Inc: [www.laticrete.com/#sle](http://www.laticrete.com/#sle).
    - d. MAPEI Corporation; Mapesil Silicone Sealant: [www.mapei.com](http://www.mapei.com).
    - e. Merkrete, by Parex USA, Inc: [www.merkrete.com/#sle](http://www.merkrete.com/#sle).

- f. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Grout Sealer: Liquid-applied, moisture and stain protection for existing or new Portland cement grout.
  - 1. Composition: Water-based colorless silicone.
    - a. Wall Grout Sealer: Silicone sealer, clear penetrating.
    - b. Floor Grout and Tile Sealer: Acrylic emulsion, 18 percent solids, clear, non-yellowing, slip resistant.
  - 2. Products:
    - a. Specified Manufacturer: Aqua-Mix: [www.custombuildingproducts.com](http://www.custombuildingproducts.com); local representative Dale Roberts (951) 255-0243.
    - b. Merkrete, by Parex USA, Inc; Merkrete Grout Sealer: [www.merkrete.com/#sle](http://www.merkrete.com/#sle).
    - c. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## 2.06 ACCESSORY MATERIALS

- A. Concrete Floor Slab Crack Isolation Membrane: Material complying with ANSI A118.12; not intended as waterproofing.
  - 1. Crack Resistance: No failure at 1/8 inch gap, minimum.
  - 2. Fluid or Trowel Applied Type:
    - a. Material: Synthetic rubber or Acrylic.
    - b. Thickness: 20 mils, maximum.
    - c. Products:
      - 1) Custom Building Products; Custom 9240 Waterproofing and Anti-Fracture Membrane: [www.custombuildingproducts.com](http://www.custombuildingproducts.com).
      - 2) LATICRETE International, Inc; LATICRETE Blue 92 Anti-Fracture Membrane: [www.laticrete.com/#sle](http://www.laticrete.com/#sle).
      - 3) MAPEI Corporation; Mapelastic HPG w/Fiberglass Mesh: [www.mapei.com](http://www.mapei.com).
      - 4) Merkrete, by Parex USA, Inc; Merkrete Fracture Guard: [www.merkrete.com/#sle](http://www.merkrete.com/#sle).
      - 5) Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Waterproofing Membrane at Floors: Specifically designed for bonding to cementitious substrate under thick mortar bed or thin-set tile; complying with ANSI A118.10.
  - 1. Crack Resistance: No failure at 1/16 inch gap, minimum; comply with ANSI A118.12.
  - 2. Fluid or Trowel Applied Type with Embedded Reinforcing Fabric:
    - a. Material: Synthetic rubber or Acrylic.
    - b. Thickness: 25 mils, minimum, dry film thickness.
    - c. Products:
      - 1) Custom Building Products; RedGard Crack Prevention and Waterproofing Membrane: [www.custombuildingproducts.com/#sle](http://www.custombuildingproducts.com/#sle).
      - 2) LATICRETE International, Inc: [www.laticrete.com/#sle](http://www.laticrete.com/#sle).
      - 3) Merkrete, by Parex USA, Inc: [www.merkrete.com/#sle](http://www.merkrete.com/#sle).
      - 4) Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- C. Cleavage Membrane Under Thick Mortar Bed:

1. Material: No. 15 asphalt saturated felt.
- D. Reinforcing Mesh: 2 by 2 inch size weave of 16/16 wire size; welded fabric, galvanized.
- E. Membrane at Walls:
  1. Material: No. 15 asphalt saturated felt.
- F. Metal Lath: ASTM C847, Flat diamond mesh, of weight to suit application, galvanized finish.
- G. Mesh Tape: 2 inch wide self-adhesive fiberglass mesh tape.

## **PART 3 EXECUTION**

### **3.01 REGULATORY REQUIREMENTS FOR INSTALLATION**

- A. California Plumbing Code:
  1. Floor Drains:
    - a. Floors shall be sloped maximum 2% to drains. CPC 411.4.

### **3.02 EXAMINATION**

- A. Verify that sub-floor surfaces are smooth and flat within the tolerances specified for that type of work and are ready to receive tile.
  1. Walls and floors to be level, plumb and true to within the listed for each applicable TCNA (HB) assembly method used.
- B. Confirm that rough-ins for plumbing, mechanical and electrical work behind tile have been installed and tested.
- C. Verify that wall surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive tile.
- D. Verify that sub-floor surfaces are dust-free and free of substances that could impair bonding of setting materials to sub-floor surfaces.
- E. Verify that concrete sub-floor surfaces are ready for tile installation by testing for moisture emission rate and alkalinity; obtain instructions if test results are not within the following limits:
  1. Moisture Emission Rate: Not greater than 3 lb per 1000 sq ft per 24 hours, test in accordance with ASTM F1869.
  2. Alkalinity (pH): Verify pH range of 5 to 9, test in accordance with ASTM F710.
- F. Verify that required floor-mounted utilities are in correct location.

### **3.03 PREPARATION**

- A. Protect surrounding work from damage.
- B. Vacuum clean surfaces and damp clean.
- C. Seal substrate surface cracks with filler. Level existing substrate surfaces to acceptable flatness tolerances.
- D. Prepare substrate surfaces for adhesive installation in accordance with adhesive manufacturer's instructions.

### 3.04 INSTALLATION - GENERAL

- A. Waterproof/Anti-Fracture Membrane Application: Comply with manufacturer's written instructions and recommendations for substrate, tile setting method and Project conditions.
- B. Install tile and thresholds and grout in accordance with applicable requirements of ANSI A108.1a through ANSI A108.1a , manufacturer's instructions, and TCNA (HB) recommendations.
- C. Expansion Joints: Provide expansion joints at locations and spacings as recommended by TCNA (HB) Detail EJ171 and as indicated on Drawings. Keep joints free of setting bed mix and grout.
- D. Lay tile to pattern indicated. Do not interrupt tile pattern through openings.
  - 1. Joint Pattern: Lay tile in grid pattern unless otherwise indicated on Drawings or directed by Architect. Lay out tile pattern and center tile fields both directions in each space or on each wall area. Provide uniform joint widths.
  - 2. Coordinate with work of Division 22 - Plumbing for access door locations to coincide (at least 2 sides) with tile joints.
- E. Set tile firmly on new; setting bed or backerboard surfaces with a minimum of 100 percent coverage at floors.
  - 1. Back-butter ribbed tiles and other tiles in accordance with TCNA/ANSI A108.5.
  - 2. Spacers on tile determine joint width between tiles.
  - 3. Strings or pegs may be used to space tile that have no spacers.
  - 4. Bring all surfaces to a true plane at proper position or elevation.
  - 5. Thoroughly beat-in all tile with a beating block while mortar coat is still plastic.
  - 6. Beating shall fill minimum of 95 percent of entire space between units and setting bed.
  - 7. Eighty percent coverage of individual tiles is permitted for walls in non-wet areas.
- F. Cut and fit tile to penetrations through tile, leaving sealant joint space. Form corners and bases neatly. Align floor joints.
  - 1. Prepare surfaces, cut, fit and set tile. Extend tile into recesses and under equipment and fixtures to form a complete covering without interruptions. Terminate tile neatly at obstructions, edges, and corners, without disruption of pattern or joint alignment.
- G. Place tile joints uniform in width, subject to variance in tolerance allowed in tile size. Make joints watertight, without voids, cracks, excess mortar, or excess grout. All inside corners shall be coved. No butted 90 degree intersections permitted. All outside corners shall be bull nosed.
- H. Form internal angles square and external angles bullnosed.
- I. Install thresholds where indicated.
- J. Sound tile after setting. Replace hollow sounding units.
- K. Keep control and expansion joints free of mortar, grout, and adhesive.
- L. Prior to grouting, allow installation to completely cure; minimum of 48 hours.
- M. Grout tile joints unless otherwise indicated. Use standard grout unless otherwise indicated.

- N. At changes in plane and tile-to-tile control joints, use tile sealant instead of grout, with either bond breaker tape or backer rod as appropriate to prevent three-sided bonding.

**3.05 INSTALLATION - FLOORS - MORTAR BED METHODS**

- A. Over interior concrete substrates, install in accordance with TCNA (HB) Method with waterproof membrane, unless otherwise indicated.
  - 1. Where waterproofing membrane is indicated, with standard grout or no mention of grout type, install in accordance with TCNA (HB) Method F121.
- B. Cleavage Membrane: Lap edges and ends.
- C. Waterproofing Membrane: Install as recommended by manufacturer .
- D. Mortar Bed Thickness: 1-1/4 inch, unless otherwise indicated.

**3.06 GROUTING**

- A. Joint Width: As follows unless indicated otherwise on Drawings.
  - 1. Glazed Wall Tile, Unmounted: As determined by spacing lugs.
  - 2. Glazed Floor Tile, Unmounted: 1/8 inch.
  - 3. Porcelain Floor Tile: 1/4 inch.
  - 4. Mounted Tile: As determined by factory-produced spacing.
  - 5. Trim and Accessories: Match adjoining tile units.
- B. Wall Tile Grouting: TCNA/ANSI A108.10, latex-portland cement.
- C. Floor Tile Grouting: TCNA/ANSI A108.10, latex-portland cement.
- D. Do not begin grouting tiles until they are firmly set and a minimum of 48 hours of curing has occurred.
- E. Remove spacers, ropes, glue, and similar foreign matter prior to grouting.
- F. When using proprietary grout, comply with manufacturer's instructions and recommendations unless otherwise more stringent requirements are specified.
- G. Force maximum amount of approved grout into joints in accordance with pertinent recommendations contained in TCNA/ANSI A108.10.
- H. Fill joints of cushion-edge tile to depth of cushion; fill joints of square-edge tile flush with tile surface.
- I. Fill all gaps and skips.
- J. Do not permit mortar or mounting mesh to show through grouted joints.
- K. Provide hard finished grout which is uniform in color, smooth, and without voids, pin holes, or low spots.
- L. Leave tile clean.

**3.07 TOLERANCES**

- A. Subsurface Guidelines: Refer to TCNA (HB) for a complete guidelines.

|            |                   |
|------------|-------------------|
| Mortar Bed | 1/4 inch: 10 feet |
|------------|-------------------|



|  |  |
|--|--|
| Thin Bed w/ cementitious bonding material w/ Tiles <15"              | 1/4 inch: 10 feet from plane<br>Maximum 1/16 inch variation in 12 inches from high points. |
| Thin Bed w/ cementitious bonding material w/ Tiles any side >15"     | 1/8 inch: 10 feet from plane<br>Maximum 1/16 inch variation in 24 inches from high points. |
| Thin Bed w/ organic adhesive bonding material w/ Tiles any side >15" | 1/16 inch in 3 feet<br>No abrupt irregularities >1/32 inch                                 |

- B. Lippage Guidelines: Refer to TCNA (HB) for a complete guidelines.

| Tile Type                            | Tile Size (in.) | Joint Width (in.)     | Allowable Lippage (in.) |
|--------------------------------------|-----------------|-----------------------|-------------------------|
| Glazed Wall/<br>Mosaics              | 1 x 1 to 6 x 6  | 1/16 to 1/8           | 1/32                    |
| Quarry                               | 6 x 6 to 8 x 8  | 1/4 or greater        | 1/16                    |
| Pressed Floor and<br>Porcelain Tiles | All             | 1/16 to less than 1/4 | 1/32                    |
| Pressed Floor and<br>Porcelain Tiles | All             | 1/4 or greater        | 1/16                    |

### 3.08 GROUT SEALER

- A. Clean grout and apply sealer in accordance with manufacturer's instructions and recommendations.

### 3.09 JOINT SEALANT

- A. Apply sealant after tile is grouted, grout is cured and tile field is thoroughly clean and dry.
- B. Seal between tile and all penetrating elements.
- C. Seal perimeter of tile field where tile base is not provided.
- D. Sealant Locations shall include:
1. Around plumbing penetrations.
  2. Around door frames and other items set in wall.
- E. Refer to Section 07 92 00 - Joint Sealants for additional requirements.

### 3.10 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Provide manufacturer's field representative to inspect waterproofing.
- C. Repair or remove and reinstall as required.
- D. Repeat until a satisfactory result is achieved.

### 3.11 CLEANING

- A. Clean tile and grout surfaces.
1. After completion of setting and grouting, thoroughly clean and polish tile.

2. Do not use acid or acid cleaners to clean tile.
3. When tile is thoroughly clean and dry, polish glazed tile with clean dry cloths.

### **3.12 PROTECTION**

- A. Do not permit traffic over finished floor surface for 4 days after installation.
- B. Cover floors with kraft paper and protect from dirt and residue from other trades.
- C. Where floor is to be exposed for prolonged periods cover with plywood or other similar type walkways

**END OF SECTION**



**SECTION 09 51 00**  
**SUSPENDED ACOUSTICAL CEILINGS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Suspended metal grid ceiling system.
- B. Acoustical units.
- C. Specialized architectural ceiling lay-in panels

**1.02 RELATED REQUIREMENTS**

- A. Section 05 31 00 - Steel Decking: Placement of special anchors or inserts for suspension system.
- B. Section 07 21 00 - Thermal Insulation: Acoustical insulation.
- C. Section 08 31 00 - Access Doors and Panels: Access panels.
- D. Section 21 13 00 - Fire-Suppression Sprinkler Systems: Sprinkler heads in ceiling system.
- E. Division 23 - Heating, Ventilating, and Air-Conditioning (HVAC) - Air Outlets and Inlets: Air diffusion devices in ceiling.
- F. Division 26 - Electrical - Interior Lighting: Light fixtures in ceiling system.
- G. Division 27 - Communications - Public Address Systems: Speakers in ceiling system.
- H. Section 28 46 20 - Fire Alarm: Fire alarm components in ceiling system.

**1.03 REFERENCE STANDARDS**

- A. ASCE 7 - Minimum Design Loads for Buildings and Other Structures; 2010, with 2013 Supplements and Errata.
- B. ASTM A568/A568M - Standard Specification for Steel, Sheet, Carbon, Structural, and High-Strength, Low-Alloy, Hot-Rolled and Cold-Rolled, General Requirements For; 2014.
- C. ASTM A641/A641M - Standard Specification for Zinc-Coated (Galvanized) Carbon Steel Wire; 2009a (Reapproved 2014).
- D. ASTM C635/C635M - Standard Specification for the Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings; 2013a.
  - 1. Use 2013a as indicated in 2016 CBC Referenced Standards.
- E. ASTM C636/C636M - Standard Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-In Panels; 2013.
- F. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2016.
- G. ASTM E580/E580M - Standard Practice for Installation of Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels in Areas Subject to Earthquake Ground Motions; 2014.
- H. ASTM E1264 - Standard Classification for Acoustical Ceiling Products; 2014.
- I. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2016.

1. Use 2013a as indicated in 2016 CBC Referenced Standards.
- J. CHPS (HPPD) - High Performance Products Database; Current Edition at [www.chps.net/](http://www.chps.net/).
- K. DSA Interpretation of Regulations, issued by the Division of the State Architect (DSA).
- L. ITS (DIR) - Directory of Listed Products; Intertek Testing Services NA, Inc.; current edition.
- M. UL (FRD) - Fire Resistance Directory; current edition.
- N. UL (GGG) - GREENGUARD Gold Certified Products; current listings at <http://productguide.ulenvironment.com/QuickSearch.aspx>.

#### **1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Sequence work to ensure acoustical ceilings are not installed until building is enclosed, sufficient heat is provided, dust generating activities have terminated, and overhead work is completed, tested, and approved.
- B. Do not install acoustical units until after interior wet work is dry.

#### **1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Shop Drawings: Indicate grid layout and related dimensioning.
  1. Shop drawings shall show:
    - a. Reflected ceiling plans;
    - b. Location of acoustical ceilings and suspension systems;
    - c. Location of light fixtures, diffusers, speakers and other exposed to view items;
    - d. List of materials;
    - e. Dimensions, jointing, method of hanger attachment, fastenings and other pertinent information.
    - f. Shop drawings may be in the form of revised copies of the Architect's reflected ceiling plan showing any proposed changes from the layout indicated.
- C. Product Data: Provide data on suspension system components.
  1. Submit manufacturer's catalog cuts, specifications, and other data for each component of the acoustical ceiling systems as necessary to demonstrate compliance with these specifications.
  2. Submit copies of the suspension system manufacturer's current ICC Evaluation Service Report.
- D. Samples: Submit two samples 12 by 12 inch in size illustrating material and finish of acoustical units.
- E. Samples: Submit six samples each, 12 inches long, of suspension system main runner.
- F. Manufacturer's Installation Instructions: Indicate special procedures.
- G. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.
  2. Extra Acoustical Units: Five boxes of each type and size. Each box to have a minimum of 10 panels.

## **1.06 QUALITY ASSURANCE**

- A. Suspension System Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- B. Acoustical Unit Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.

## **1.07 DELIVERY, STORAGE AND HANDLING**

- A. Deliver materials to the project in original unopened packages bearing the manufacturer's name, brand designation, and label verifying compliance with these specifications. Store materials in properly protected and dry storage area.
- B. Immediately before installation, store acoustical units for not less than 24 hours at the same temperature and relative humidity as the space where they are to be installed.

## **1.08 FIELD CONDITIONS**

- A. Maintain uniform temperature of minimum 60 degrees F, or as recommended by the manufacturer for products provided; and maximum humidity of 40 percent prior to, during, and after acoustical unit installation.

## **1.09 WARRANTY**

- A. Warranty Period:
  - 1. Attachment devices (for wall installation): One (1) year from date of substantial completion.
  - 2. Ceiling Panels and Grid: Ten (10) years from date of substantial completion.

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. Flame Spread Rating: Provide acoustical ceiling units bearing the label of Underwriters' Laboratories, or other testing agency acceptable to the State Fire Marshal, indicating that the units provide the specified flame spread rating.
  - 1. Class A Flame spread rating 0-15, smoke developed 0-15 per ASTM E84 for each acoustical tile type.
- B. Seismic Requirements: Furnish and install suspension systems in accordance with the suspension system manufacturer's current ICC Evaluation Service Report; the California Building Code (CBC), Title 24 Part 2, Table No. 1607A.1; CBC Title 24 Part 2, Chapter 25.
  - 1. Include the following Interpretation of Regulations, issued by the Division of the State Architect (DSA).
    - a. IR A-5: Acceptance of Products, Materials, and Evaluation Reports; Revised 1/27/17.
    - b. IR 16-9: Pendant Mounted Light Fixtures; Revised 11/3/10.
    - c. IR 25-2.13: Metal Suspension Systems for Lay-In Panel Ceilings; Revised 11/9/17.
    - d. IR 25-1: Maximum Allowable Load for 10 Gage and 12 Gage Wires; Revised 9/23/10.

## 2.02 MANUFACTURERS

- A. Acoustic Tiles/Panels:
  - 1. Armstrong World Industries, Inc: [www.armstrong.com/#sle](http://www.armstrong.com/#sle).
    - a. Local contacts Dai-Nee Tan 949-275-8169 or Tim Traber 760-473-1108
  - 2. CertainTeed Corporation: [www.certainteed.com/#sle](http://www.certainteed.com/#sle).
  - 3. USG: [www.usg.com/#sle](http://www.usg.com/#sle).
  - 4. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Suspension Systems:
  - 1. Same as for acoustical units.
  - 2. Rockfon, LLC: [www.rockfon.com](http://www.rockfon.com).
  - 3. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## 2.03 ACOUSTICAL UNITS

- A. Acoustical Units - General: ASTM E1264, Class A.
  - 1. VOC Content: Certified as Low Emission by one of the following:
    - a. Product listing in UL (GGG).
    - b. Product listing in CHPS (HPPD).
- B. Acoustical Panels Type ACP-1: Painted and scored mineral fiber, ASTM E1264 Type III, with the following characteristics:
  - 1. Size: 24 by 48 inches with 24 x 24 inch scored panels.
  - 2. Thickness: 3/4 inches.
  - 3. Composition: Wet felted.
  - 4. Density: 1.09 lb/sq.ft..
  - 5. Light Reflectance: 85 percent, determined in accordance with ASTM E1264.
  - 6. NRC Range: 0.65, determined in accordance with ASTM E1264.
  - 7. Ceiling Attenuation Class (CAC): 35, determined in accordance with ASTM E1264.
  - 8. Fire Rating: Class A
    - a. Flame Spread and Smoke Developed Ratings: 0-25 flame spread and 0-50 smoke developed in accordance with ASTM E84.
  - 9. Edge: Beveled Tegular 9/16 inch.
  - 10. Surface Color: White.
  - 11. Surface Pattern: Non-directional fissured.
  - 12. Suspension System: Exposed grid Type TBAR-1.
  - 13. Basis of Design Product: Cirrus, Second Look II No. 510 as manufactured by Armstrong World Industries, or approved equal.
- C. Acoustical Panels Type ACP-2: Painted and scored mineral fiber, ASTM E1264 Type III, with the following characteristics:
  - 1. Size: 24 by 48 inches with 6 x 48 inch scored panels.

2. Thickness: 3/4 inches.
3. Composition: Wet felted.
4. Density: 1.09 lb/sq.ft..
5. Light Reflectance: 85 percent, determined in accordance with ASTM E1264.
6. NRC Range: 0.65, determined in accordance with ASTM E1264.
7. Ceiling Attenuation Class (CAC): 35, determined in accordance with ASTM E1264.
8. Fire Rating: Class A
  - a. Flame Spread and Smoke Developed Ratings: 0-25 flame spread and 0-50 smoke developed in accordance with ASTM E84.
9. Edge: Beveled Tegular 9/16 inch.
10. Surface Color: White.
11. Surface Pattern: Non-directional fissured.
12. Suspension System: Exposed grid Type TBAR-2.
13. Basis of Design Product: Cirrus, Second Look II No. 511 as manufactured by Armstrong World Industries, or approved equal.

#### **2.04 SUSPENSION SYSTEM(S)**

- A. Metal Suspension Systems - General: Complying with ASTM C635/C635M; die cut and interlocking components, with stabilizer bars, clips, splices, perimeter moldings, and hold down clips as required.
  1. Main runners, cross runners, splices, expansion devices, intersection connectors shall be designed to carry a mean ultimate test load of not less than 180 lbs. in compression and tension per ASTM E580/E580M Section 5.1.2.
- B. Exposed Steel Suspension System Type TBAR-1: Formed steel, commercial quality cold rolled; heavy-duty.
  1. Profile: Tee; 9/16 inch wide face.
  2. Molding: Angle or shadow type, compliant with seismic requirements and as indicated on Drawings.
  3. Construction: Double web.
  4. Recycled Content; 30%, Post-Consumer.
  5. Finish: White painted, unless noted otherwise.
  6. Acceptable products:
    - a. Armstrong; Suprafine XL 7501HRC main runners; FastSize; XL7541 , XL7549, XL7541, and XL7520 cross runners - ICC ESR-1308.
    - b. Chicago Metallic 4000 Tempra Series - ICC-ESR-2631.
    - c. Donn Corp.(USG); DXL26 main runners; DXL-216 cross runners - ICC ESR-1222.

#### **2.05 ACCESSORIES**

- A. Accesories are to be compliant with seismic requirements indicated in the ESR approval documents.



- B. Support Channels and Hangers: Galvanized steel; size and type to suit application, seismic requirements, and ceiling system flatness requirement specified.
  - 1. Suspension wires shall be #12 gage (0.106 inch diameter), soft annealed, and galvanized steel wires with Class 1 coating.
- C. Clips:
  - 1. SJCG (Armstrong) – Seismic Joint Clip, 5 inches x 1-1/2 inch, hot-dipped galvanized cold-rolled steel per ASTM A568/A568M. The two piece unit is designed to accommodate a seismic separation joint. The clip is compatible with 15/16 inch and 9/16 inch grid systems including Prelude, Suprafine, and Silhouette. The SJCG is not suitable for use with Vector panel installations.
- D. Touch-up Paint: Type and color to match acoustical and grid units.

### **PART 3 EXECUTION**

#### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify that layout of hangers does not interfere with other work.
- C. Wet operations such as plastering and concrete work shall be completed and dry before installation of acoustical ceilings.
  - 1. Mechanical, electrical and other work above the ceiling line shall be completed and approved before start of acoustical ceiling installation.
- D. Examine surfaces and conditions affecting proper installation of the materials, and report defects in materials or surfaces to which acoustical tile is applied.
  - 1. Do not start work until deficiencies have been corrected.
  - 2. Start of work of this section constitutes acceptance of the surfaces.

#### **3.02 INSTALLATION - GENERAL**

- A. Place units as indicated on the shop drawings.
  - 1. Install with joints true and straight and junctures with ceilings, walls and openings neat and tight.
  - 2. Completed work shall present a smooth plane and level surface, free from unevenness, edge or corner offsets, cupping, scratches and other imperfections.
- B. ESR-1308, Section 4.4.3.1, Alternate Seismic Design Category D, E and F Installation: Under this installation, the runners must be rated heavy-duty and have a minimum simple span uniform load of 16.35 pounds per lineal foot (238 N/m); maximum ceiling weight permitted is 4 pounds per square foot (19.5 kg/m<sup>2</sup>).
- C. The SJCG Seismic Separation Joint Clip is to be installed per the manufacturer's instructions, CS-3815.
- D. Label/mark ceiling panels where valves, dampers, equipment, VAV boxes and similar, are located above.
  - 1. Coordinate with above ceiling trades to provide a label, colored dot, or other demarcation located on the T-bar grid.

### 3.03 INSTALLATION - SUSPENSION SYSTEM

- A. Install suspension system in accordance with ASTM C 636/C 636M, ASTM E 580/E 580M, and manufacturer's instructions and as supplemented in this section.
- B. Rigidly secure system, including integral mechanical and electrical components, for maximum deflection of 1:360.
- C. Lay out system to a balanced grid design with edge units no less than 50 percent of acoustical unit size.
- D. Install after major above-ceiling work is complete. Coordinate the location of hangers with other work.
- E. Provide hanger clips during steel deck erection. Provide additional hangers and inserts as required.
- F. Hang suspension system independent of walls, columns, ducts, pipes and conduit. Where carrying members are spliced, avoid visible displacement of face plane of adjacent members.
- G. Where ducts or other equipment prevent the regular spacing of hangers, reinforce the nearest affected hangers and related carrying channels to span the extra distance.
- H. Do not support components on main runners or cross runners if weight causes total dead load to exceed deflection capability.
- I. Support fixture loads using supplementary hangers located within 6 inches of each corner, or support components independently.
- J. At exterior application of MetalWorks Vector Exterior, provide vertical compression posts of 20 ga. x 2-1/2 inch metal stud at each intersection of suspension grid main runner and cross-bar; 24 inches o.c. each way.
- K. Do not eccentrically load system or induce rotation of runners.
- L. Form expansion joints as detailed. Form to accommodate plus or minus 1 inch movement. Maintain visual closure.

### 3.04 DSA IR-25-2.13 METAL SUSPENSION SYSTEMS FOR LAY-IN PANEL CEILINGS

- A. General Requirements: CBC Section 1616A1.20 (1616.10.16\*) requires the design and installation to be in compliance with ASTM C635/C635M, ASTM C636/C636M, and ASTM E580/E580M, Section 5, with modifications.
  - Note: Amendments in CBC Section 1616A.1.20 (1616.10.16\*) replace and append ASCE 7, Section 13.5.6.
  - 1. The requirements in DSA IR 25-2.13 apply to flat and level ceiling systems whose total weight, including ceiling mounted air terminals, services and light fixtures, does not exceed four (4) psf. Heavier systems, systems that are not flat and level, those supporting lateral loads from partitions, and free floating ceilings supported by chains or cables, are beyond the scope of DSA IR 25-2.13 and will be as indicated on Drawings.
- B. Ceiling Design & Installation Requirements:
  - 1. Ceiling System Components:
    - a. Shall comply with ASTM C635/C635M and Section 5.1 of ASTM E580/E580M.
    - b. The ceiling grid system must be rated heavy duty as defined by ASTM C635/C635M.

- c. Main runners, cross runners, splices, expansion devices, and intersection connectors shall be designed to carry a mean ultimate test load of not less than 180 lbs. in compression and tension per ASTM E580/E580M Section 5.1.2.
  - d. Ceiling wire shall be Class 1 zinc coated (galvanized) carbon steel conforming to ASTM A641/A641M. Wire shall be #12 gage (0.106 inch diameter) with soft temper and minimum tensile strength = 70 ksi. The maximum allowable (ASD) tension load for wire meeting this specification is 350 pounds.
    - 1) Four (4) turns of the wire within 1.5 inches will develop the wire allowable load.
    - 2) Three (3) turns of the wire within 3 inches is assumed to develop no more than 50 percent of wire allowable load.
2. Suspension System Installation:
- a. Shall comply with ASTM C636/C636M and Section 5.2 of ASTM E580/E580M.
  - b. #12 gage hanger wires may be used for up to and including a 4 by 4 foot grid spacing and shall be attached to main runners. Splices in hanger wires shall develop 50 percent of the wire allowable load.
  - c. Provide #12 gage hanger wires at the ends of all main and cross runners within eight (8) inches of the support or within one-fourth (1/4) of the length of the end tee, whichever is least, for the perimeter of the ceiling area. Perimeter wires are not required when the length of the end tee is eight (8) inches or less.
  - d. Ceiling grid members shall be attached to two (2) adjacent walls per ASTM E580/E580M, Section 5.2.3. Ceiling grid members shall be at least 3/4 inch clear of other walls. If walls run diagonally to ceiling grid system runners, one end of main and cross runners should be free, and a minimum of 3/4 inch clear of wall.
  - e. The width of the perimeter supporting closure angle shall be not less than two (2) inches. Use of angles with smaller widths in conjunction with proprietary perimeter clips may be acceptable in accordance with Section 5 of DSA IR 25-2.13.
  - f. At the perimeter of the ceiling area, where main or cross runners are not connected to the adjacent wall, provide interconnection between the runners at the free end to prevent lateral spreading. A metal stabilizer or a #16 gage wire with a positive mechanical connection to the runner may be used and placed within eight (8) inches of the wall. Where the perpendicular distance from the wall to the first parallel runner is eight (8) inches or less, the stabilizer or #16 gage wire is not required.
3. Lateral Force Bracing Assembly Installation:
- a. Lateral force bracing assemblies consisting of a compression strut and four (4) #12 gage splayed bracing wires oriented 90 degrees from each other are required for all ceiling areas.
    - 1) Exception: Lateral force bracing may be omitted for suspended acoustical ceiling systems with a ceiling area not to exceed 144 square feet, for all values of SDS, when perimeter support is provided in accordance with subparagraph 3.04 B.2 of this section and perimeter walls are designed to carry the ceiling lateral forces.
  - b. Lateral force bracing assemblies shall be spaced per Table 1 for all values of the component importance factor (Ip) of the ceiling.

- c. There shall be a brace assembly a distance of not more than one half of the above spacing from each surrounding wall, expansion joint and at the edges of any ceiling vertical offset. For example, where the brace spacing is 8 x 12 feet, the edge distance shall be 4 feet in the direction of the 8 foot spacing and 6 feet in the direction of the 12 foot spacing.
- d. The slope of bracing wires shall not exceed 45 degrees from the horizontal plane and wires shall be taut. Splices in bracing wires shall develop the wire allowable load.
- e. Compression struts shall meet the following requirements:
  - 1) The strut shall be sized to adequately resist the vertical component force induced by the ceiling bracing wires and have a maximum  $kl/r$  not to exceed 300. The struts listed in Appendix A of DSA IR 25-2.13 meet this requirement for ceilings complying with the general requirements of this referenced IR.
  - 2) The strut shall not be more than one (horizontal) in six (vertical) out of plumb.

**TABLE 1: Lateral Force Brace Assembly Spacing**

| Design Spectral Acceleration<br>Parameter S(DS)        | Brace Assembly Spacing (ft.) |                     |
|--|------------------------------|---------------------|
|  | $z/h \leq 0.5$ *             | $z/h \geq 0.5$ * ** |
| S(DS) Less than or equal to 1.15                       | 12 x 12 feet                 | 12 x 12 feet        |
| S(DS) Greater than 1.15 and less than or equal to 1.73 | 12 x 12 feet                 | 8 x 12 feet         |
| S(DS) Greater than 1.73                                | 8 x 12 feet                  | 8 x 8 feet          |

\*Where, as defined in ASCE 7, Section 13.3.1:

z = height in structure of point of attachment of ceiling with respect to the base.

h = average roof height of the structure with respect to the base.

\*\*It shall be permitted to use the brace assembly spacing for “ $z/h > 0.5$ ” for the full building height.

- 4. Attachment of Hanger and Bracing Wires:
  - a. Fasten hanger wires with not less than three (3) tight turns in three (3) inches. Hanger wire loops shall be tightly wrapped and sharply bent to prevent any vertical movement or rotation of the member within the loops (see ASTM E580/E580M, Section 5.2.7.2).
  - b. Fasten bracing wires with not less than four (4) tight turns in 1-1/2 inches.
  - c. Hanger and bracing wire anchorage to the structure shall be installed in such a manner that the direction of the anchorage aligns closely with the direction of the wire. (e.g. bracing wire ceiling clips must be bent as shown in the details and rotated as required to align closely with the direction of the wire, screw eyes in wood must be installed so they align closely with the direction of the wire, etc.).
  - d. Separate all ceiling hanger and bracing wires at least 6 inches from all unbraced ducts, pipes, conduit, etc.
  - e. Hanger and bracing wires shall not attach to or bend around obstructions including but not limited to: piping, ductwork, conduit and equipment. Provide trapeze or other supplementary support members at obstructions to allow typical hanger

- spacing. Brace assemblies must be configured and/or located in order to avoid obstructions in addition to maintaining the required brace assembly spacing.
- f. Provide additional hangers, struts and brace assemblies as required at all ceiling breaks, soffits, or discontinuous areas.
  - g. Hanger wires that are more than one (horizontal) in six (vertical) out of plumb shall have counter-sloping wires.
    - 1) Note: See ASTM C636/C636M, Figure 1, for counter-sloping methods.
  - h. Attachment of the bracing wires to the structure above and to the main runners shall be adequate for the load imposed. The weight (Wp) shall be taken as not less than 4 psf for calculating seismic forces (Fp).
  - i. Post-installed anchors (e.g. expansion anchors, screw anchors and power actuated fasteners) shall have a current Evaluation Report acceptable to DSA in accordance with IR A-5.
  - j. Power-actuated fasteners in concrete are not permitted for bracing wires.
5. Expansion Joints, Seismic Separation Joints:
    - a. Expansion joints shall be provided in the ceiling at intersections of corridors and at junctions of corridors and lobbies or other similar areas.
    - b. For ceiling areas exceeding 2,500 sq. ft., a seismic separation joint shall be provided to divide the ceiling into areas not exceeding 2,500 sq. ft. in accordance with ASTM E580/E580M, Section 5.2.9.
  6. Ceiling Fixtures, Terminals, and Devices:
    - a. All fixtures, terminals, and other devices shall be mounted in a manner that will not compromise ceiling performance in accordance with Section 13.5.6.2.2 Item 5 of ASCE 7 as amended by CBC Section 1616A.1.20 (1616.10.16\*) and ASTM E580/E580M Sections 5.3 and 5.4.
    - b. Ceiling panels shall not support any light fixtures, air terminals or devices.
    - c. Penetrations through the ceiling for sprinkler heads and other similar devices that are not integrally tied to the ceiling system in the lateral direction shall have a 2 inch oversized ring, sleeve or adapter through the ceiling tile to allow free movement of 1 inch in all horizontal directions. Alternatively, per ASTM E580/E580M, Section 5.2.8.5, a flexible sprinkler hose fitting that can accommodate 1 inch of ceiling movement shall be permitted to be used in lieu of the oversized ring, sleeve, or adapter.
    - d. Slack safety wires shall be considered hanger wires for installation and testing requirements.
    - e. Light Fixtures:
      - 1) All light fixtures shall be positively attached to the ceiling suspension systems by mechanical means per CEC Article 410.36 to resist a horizontal force equal to the weight of the fixture. A minimum of two screws or approved fasteners are required at each light fixture, per ASTM E580/E580M, Section 5.3.1.
      - 2) Surface-mounted light fixtures shall be attached to the main runner with at least two positive clamping devices on each fixture. The clamping device shall completely surround the supporting ceiling runner and be made of steel with a minimum thickness of #14 gage. Rotational spring catches do not comply. A #12 gage slack safety wire shall be connected from each clamping device to the

structure above. Provide additional supports when light fixtures are 8 feet or longer or exceed 56 lbs. Maximum spacing between supports shall not exceed 8 feet.

- 3) Light fixtures weighing less than or equal to 10 lbs. shall have a minimum of one (1) #12 gage slack safety wire connected from the fixture housing to the structure above.
  - 4) Light fixtures weighing greater than 10 lbs. but less than or equal to 56 lbs may be supported directly on the ceiling runners, but they shall have a minimum of two (2) #12 gage slack safety wires connected from the fixture housing at diagonal corners to the structure above.
    - (a) Exception: All light fixtures greater than 2 by 4 feet weighing less than 56 lbs. shall have a #12 gage slack safety wire at each corner.
  - 5) All Light fixtures weighing greater than 56 lbs. shall be independently supported by not less than four (4) taut #12 gage hanger wires (one at each corner) attached from the fixture housing to the structure above or other approved hangers. The four (4) taut #12 gage wires or other approved hangers, including their attachment to the structure above, shall be capable of supporting four (4) times the weight of the fixture.
- f. Services within the Ceiling:
- 1) All flexible sprinkler hose fitting mounting brackets, ceiling-mounted air terminals or other services shall be positively attached to the ceiling suspension systems by mechanical means to resist a horizontal force equal to the weight of the component. Screws or approved fasteners are required. A minimum of two attachments are required at each component.
  - 2) Ceiling-mounted air terminals or other services weighing less than or equal to 20 lbs. shall have one (1) #12 gage slack safety wire attached from the terminal or service to the structure above.
  - 3) Flexible sprinkler hose fittings, ceiling-mounted air terminals or other services weighing more than 20 lbs. but less than or equal to 56 lbs. shall have two (2) #12 gage slack safety wires (at diagonal corners) connected from the terminal or service to the structure above.
  - 4) Flexible sprinkler hose fittings, ceiling-mounted air terminals or other services weighing more than 56 lbs. shall be supported directly from the structure above by not less than four (4) taut #12 gage hanger wires attached from the terminal or service to the structure above or other approved hangers. The four (4) taut #12 gage wires or other approved hangers, including their attachment to the structure above, must be capable of supporting four (4) times the weight of the unit.
- g. Other Devices within the Ceiling:
- 1) All lightweight miscellaneous devices, such as strobe lights, occupancy sensors, speakers, exit signs, etc., shall be attached to the ceiling grid per subparagraph 3.04 B.6.f.1 of this Section. In addition, devices weighing more than 10 lbs. shall have a #12 gage slack safety wire anchored to the structure above per subparagraph 3.04 B.6.f.2 of this Section. Devices weighing more than 20 lbs. shall be supported from the structure above using details provided by the registered design professional (RDP).

C. Additional Requirements:

1. Pendant Mounted Light Fixtures:
  - a. Where pendant mounted light fixtures are to be installed in areas with a suspended ceiling, the construction documents shall include complete support details complying with DSA IR 25-2.13 and DSA IR 16-9.
  - b. Support pendant-mounted light fixtures directly from the structure above with hanger wires or cables passing through each pendant hanger and capable of supporting two (2) times the weight of the fixture.
  - c. If a pendant mounted light fixture is directly and independently braced below the ceiling (i.e., aircraft cables to walls), then a brace assembly is not required above the ceiling.
  - d. If a pendant mounted light fixture is free to swing 45 degrees from vertical in all directions, and is not directly and independently braced below the ceiling, then a bracing assembly is only required where the pendant hanger penetrates the ceiling. Special details are required to attach the pendant hanger to the bracing assembly to transmit the horizontal and vertical forces. Exception: Where the weight of the fixture is less than 20 lbs., the vertical component of the brace force need not be considered so no compression strut/post is required.
  - e. Rigid conduit shall not be used for attachment of the fixtures.
2. Acoustical Ceiling Tile Panel Installation
  - a. For ceiling installations utilizing acoustical tile panels of mineral or glass fiber, it is not mandatory to provide 3/4 inch clearance between the acoustical tile panels and the wall on the sides of the ceiling which are free to slip.
3. Other Panel Types:
  - a. Panels weighing more than 1/2 psf, other than mineral fiber and glass fiber acoustical tile, and all metal and wood panels shall be positively attached to the ceiling suspension runners by mechanical means, such as bolts, screws, or rivets, and each attachment shall have the allowable design strength to support 100 percent of the weight of the panel acting in any direction. A minimum of two attachments are required for each panel. For ceiling installations utilizing panels other than mineral or glass fiber, 3/4 inch clearance shall be provided between the ceiling panel and the wall on the sides of the ceiling area which are free to slip, unless otherwise justified by seismic qualification indicated below.
  - b. The use of other types of attachment, such as clips, snap-in devices, perforated lips, clamping devices, or spring loaded devices or hooks, shall be listed per DSA IR A-5 and identified for use with the type of ceiling framing members and panels. The listing shall be seismically qualified in accordance with ASCE 7 Section 13.2.5 or 13.2.6.
  - c. An alternate means of compliance per CAC 4-304 may be proposed and reviewed on a project by project basis when using unlisted means of attachment. The alternate means of attachment shall have the allowable design strength to support 100 percent of the weight of the panel acting in any direction and shall be capable of maintaining that strength if the ceiling grid is distorted or out of level.
  - d. It is also alternately permitted to provide a secondary means of connecting the panel to the grid or structure to retain the panel in case of panel dropout, ceiling grid distortion, and ceiling grid becoming out-of-level. The secondary attachment

shall have the allowable design strength to support two (2) times the weight of the panel acting in any direction, such as a slack wire or cable.

- e. Special attachment details complying with one of the methods outlined above, such as screws or cables, shall be provided at the perimeter of the ceiling, where panels are cut or altered, or where non-standard panel sizes or edge conditions occur.
4. Exitways:
- a. Exitways of essential services buildings shall be installed in accordance with Section 13.5.6.2.2 Item 1 of ASCE 7 as amended by CBC Section 1616A.1.20 (1616.10.16\*). A main or cross runner shall be installed on all sides of each piece of tile, board or panel and each light fixture or grill. Splices or intersection of such runners shall be attached with through connectors such as pop rivets, screws, pins, plates with end tabs or other approved connectors.
5. Free Floating Ceilings:
- a. Free floating ceilings (ceilings not attached to any walls) supported by wires in accordance with DSA IR 25-2.13 shall be braced in accordance with this referenced IR, regardless of the ceiling area, unless it can be demonstrated the anticipated ceiling movement will not cause failure of the ceiling components or failure of mechanical, electrical, plumbing, and fire and life safety components/systems within the ceiling area and within the area of anticipated movement.
  - b. The perimeter of free floating ceilings shall be supported by a continuous runner which is spliced in accordance with ASTM E580/E580M Section 5.1.2.
- D. Ceiling System Alteration: The entire ceiling in the affected space shall be upgraded to meet the current requirements of the CBC and DSA IR 25-2.13, if any portion of the grid system is cut or altered.
- 1. Where the ceiling grid is not cut or altered, and the scope of work includes only the following:
    - a. Replacement of existing ceiling panels with like panels of equal or lesser weight.
    - b. Replacement of light fixtures and/or terminals with like units (units of equal size and of equal or lesser weight) placed in the same location.
    - c. No upgrade to the ceiling grid, suspension system or lateral force brace assemblies is required.
  - 2. Re-Use of Existing Ceiling Hanger Wires and Bracing Wires: Existing ceiling hanger and bracing wires may be reused provided they comply with the following:
    - a. The gage and spacing of the wires must comply with the current applicable codes and DSA IR 25-2.13.
    - b. If a new wire is to be spliced to an existing wire, the architect or structural engineer in general responsible charge must submit to the DSA for approval a detail and specification describing how the splice is to be made. Acceptable wire splice details are provided in Appendix A.
    - c. See Section 7 for testing requirements for the re-use of existing hanger and bracing wire assemblies.
- E. DSA Acceptance of Evaluation Reports:
- 1. Ceiling grid systems or components, with valid evaluation reports issued by qualified evaluation agencies, in accordance with DSA IR A-5, are accepted by the DSA, provided



the system or component meets the requirements of CBC Section 1616A.1.20 (1616.10.16\*), ASTM C635/C635M, ASTM C636/C636M and ASTM E580/E580M. Where a qualified evaluation report is utilized, the installation shall comply with all the requirements specified in the evaluation report, i.e., connections, member sizes, perimeter details, special clips to wall angles, etc.

2. In accordance with DSA IR A-5, DSA will accept OSHPD Preapproved Details (OPD) "2013 CBC Standard Suspended Ceiling Details for Acoustical Tile or Lay-in Panel Ceilings."

### **3.05 INSTALLATION - ACOUSTICAL UNITS**

- A. Install in coordination with suspension system.
- B. Install acoustical units in accordance with manufacturer's instructions.
- C. Fit acoustical units in place, free from damaged edges or other defects detrimental to appearance and function.
- D. Fit border trim neatly against abutting surfaces.
- E. Install units after above-ceiling work is complete.
- F. Install acoustical units level, in uniform plane, and free from twist, warp, and dents.
- G. Cutting Acoustical Units:
  1. Perform all cutting required for fixtures, pipes and other work passing through acoustical tile and panels.
    - a. Neatly and tightly fit units to such work and adjoining work.
    - b. Fit border units neatly and tightly against abutting surfaces.
  2. Scribe and cut panels to fit accurately at borders and at penetrations.
  3. Cut to fit irregular grid and perimeter edge trim.
  4. Make field cut edges of same profile as factory edges.
  5. Double cut and field paint exposed reveal edges.
  6. For reveal edge panels: Cut and reveal or rabbet edges of ceiling panels at border areas and vertical surfaces.
  7. Edges shall be concealed by support of suspension members.
- H. Install hold-down clips on panels within 20 ft of an exterior door.

### **3.06 FIELD QUALITY CONTROL**

- A. See Section 01 45 00 - Quality Control, for additional requirements.
- B. Coordination of Other Tests and Inspections: District will employ independent testing agency to test and/or inspect anchors; provide access and assistance as required to accommodate timely performance.
- C. Testing (per DSA IR 25-2.13): All field testing must be performed in the presence of the project inspector or a special inspector.
  1. New Installations:
    - a. Post-installed anchors in concrete used to support hanger wires shall be tested at a frequency of 10 percent.

- 1) Power actuated fasteners in concrete shall be field tested for 200 lbs. in tension. All other post-installed anchors in concrete shall be tested in accordance with CBC Section 1910A.5.
- b. Post-installed anchors in concrete used to attach bracing wires shall be tested at a frequency of 50 percent in accordance with CBC Section 1910A.5.
2. Re-Use of Existing Ceiling Hanger Wires and Bracing Wires:
  - a. All existing ceiling hanger wire/anchor assemblies must be tested to 200 lbs.
  - b. All existing bracing wire/anchor assemblies must be field tested to 440 lbs.
  - c. Where a new wire is spliced to an existing wire, each spliced wire/anchor assembly must be field tested to the loads given for existing assemblies above.

### **3.07 TOLERANCES**

- A. Maximum Variation from Flat and Level Surface: 1/8 inch in 10 feet.
- B. Maximum Variation from Plumb of Grid Members Caused by Eccentric Loads: 2 degrees.

### **3.08 ADJUSTING AND CLEANING**

- A. Replace loose and damaged tile and panels when directed.
- B. Touch-up all damaged finish.
- C. Leave all surfaces clean and free from markings and other disfigurements.
- D. Remove all debris resulting from the work of this section.

**END OF SECTION**



**SECTION 09 65 00**  
**RESILIENT FLOORING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Resilient sheet flooring.
- B. Resilient tile flooring.
- C. Static control resilient tile flooring.
- D. Resilient base.
- E. Installation accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 09 05 61 - Common Work Results for Flooring Preparation: Removal of existing floor coverings, cleaning, and preparation.
- B. Division 26 - Electrical: Connection of grounding strips to building structure or ground bus.

**1.03 REFERENCE STANDARDS**

- A. ASTM E648 - Standard Test Method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source; 2017.
  - 1. Use 2004 as indicated in 2016 CBC Referenced Standards.
- B. ASTM F1066 - Standard Specification for Vinyl Composition Floor Tile; 2004 (Reapproved 2018).
- C. ASTM F1861 - Standard Specification for Resilient Wall Base; 2016.
- D. ASTM F2034 - Standard Specification for Sheet Linoleum Floor Covering; 2018.
- E. NFPA 253 - Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source; 2015.
- F. RFCI (RWP) - Recommended Work Practices for Removal of Resilient Floor Coverings; 2011.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; including sizes, patterns and colors available; and installation instructions.
- C. Shop Drawings: Indicate seaming plans and floor patterns.
- D. Verification Samples: Submit two samples, 2 by 2 inch in size illustrating color and pattern for each resilient flooring product specified.
- E. Concrete Subfloor Test Report: Submit a copy of the moisture and alkalinity (pH) test reports.
- F. Certification: Prior to installation of flooring, submit written certification by flooring manufacturer and adhesive manufacturer that condition of subfloor is acceptable.
- G. Installer's Qualification Statement.

- H. Maintenance Data: Include maintenance procedures, recommended maintenance materials, and suggested schedule for cleaning, stripping, and re-waxing.
- I. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.
  - 2. Extra Flooring Material: 100 square feet of each type and color.
  - 3. Extra Wall Base: 50 linear feet of each type and color.

### **1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing specified flooring with minimum three years documented experience.
- B. Installer Qualifications: Company specializing in installing specified flooring with minimum three years documented experience.

### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Upon receipt, immediately remove any shrink-wrap and check materials for damage and the correct style, color, quantity and run numbers.
- B. Store all materials off of the floor in an acclimatized, weather-tight space.
- C. Maintain temperature in storage area between 55 degrees F and 90 degrees F.
- D. Protect roll materials from damage by storing on end.

### **1.07 FIELD CONDITIONS**

- A. Store materials for not less than 48 hours prior to installation in area of installation at a temperature of 70 degrees F to achieve temperature stability. Thereafter, maintain conditions above 55 degrees F.

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. Provide products complying with the most stringent requirements of local, state, and federal regulations; where requirements of the contract documents exceed those of regulations, comply with the contract documents.
- B. Requirements for Physically Disabled: Provide flooring meeting slip-resistant requirements of California Code of Regulations (CCR), Title 24, Part 2, Chapter 11B and ADA Accessibility Guidelines for Buildings and Facilities, latest amendment.
  - 1. Flooring surface shall be stable, firm, and slip resistant. CBC Section 11B-302.1 General.
  - 2. Flooring surface shall demonstrate a dynamic coefficient of friction of at least 0.42 per DCOF AcuTest ANSI 137.1 Section 9.6 and ANSI B101.3 (using a BOT-3000 testing unit) will be accepted as meeting the intent of slip resistance; CBC 11B-302 Floor or Ground Surfaces and ADA Standards.
    - a. Ramp surface: Provide DCOF value of 0.46.
- C. Comply with CalGreen Building Standards: 80 percent of the installed resilient flooring shall meet one of the following:

1. VOC Content: Certified as Low Emission by one of the following :
  - a. SCS Floorscore; [www.scs-certified.com](http://www.scs-certified.com). CalGreen 5.504.4.6.1.
  - b. Compliant with the VOC emission limits and testing requirements specified in the California Department of Public Health's 2010 "Standard Method for the Testing and Evaluation Chambers", Version 1.1, February 2010. CalGreen 5.504.4.6.2.
  - c. Compliant with the Collaborative for High Performance Schools California (CA-CHPS) Criteria Interpretation for EQ 7.0 and EQ 7.1 (formerly EQ 2.2) dated July 2012 and listed in the CHPS High Performance Product Database; [www.chps.net/manual/lem\\_table.htm](http://www.chps.net/manual/lem_table.htm). CalGreen 5.504.4.6.3.
  - d. Products certified under UL GreenGuard Gold; [www.greenguard.org](http://www.greenguard.org). CalGreen 5.504.4.6.4.

## 2.02 SHEET FLOORING

- A. Linoleum Sheet Flooring - Type LF-1, LF-2, & LF-3: Homogeneous wear layer bonded to backing, with color and pattern through wear layer thickness.
  1. Basis of Design Product: Harmonium Veneto as manufactured by Johnsonite, or approved equal.
  2. Manufacturers:
    - a. Armstrong World Industries, Inc: [www.armstrong.com/#sle](http://www.armstrong.com/#sle).
    - b. Forbo Flooring, Inc: [www.forboflooringna.com/#sle](http://www.forboflooringna.com/#sle).
    - c. Johnsonite, a Tarkett Company: [www.johnsonite.com/#sle](http://www.johnsonite.com/#sle).
    - d. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
  3. Minimum Requirements: Comply with ASTM F2034, Type corresponding to type specified.
  4. Critical Radiant Flux (CRF): Minimum 0.45 watt per square centimeter, when tested in accordance with ASTM E 648 or NFPA 253.
  5. VOC Content Limits: As specified in CalGreen.
  6. Backing: Jute fabric.
  7. Thickness: 0.100 inch, minimum, excluding backing.
  8. Sheet Width: 78 inch, minimum.
  9. Seams: Heat welded.
  10. Color: As indicated on drawings.
- B. Feature Strips: Of same material as sheet flooring, 4 inch wide.
- C. Welding Rod: Solid bead in material compatible with flooring, produced by flooring manufacturer for heat welding seams, and in color matching field color.

## 2.03 TILE FLOORING

- A. Static Control Tile - Type VCT-1: Homogeneous; color and pattern throughout thickness.
  1. Minimum Requirements: Vinyl composition tile complying with ASTM F1066, Class 2.
  2. Electrical Resistance:

- a. Dissipative Tile: Resistance between 1.0 megohms and 1000 megohms as tested in accordance with ASTM F150.
- 3. Critical Radiant Flux (CRF): Minimum 0.45 watt per square centimeter, when tested in accordance with ASTM E 648 or NFPA 253.
- 4. Tile Size: 12 by 12 inch.
- 5. Color: As indicated on drawings.
- 6. Manufacturers:
  - a. Armstrong World Industries, Inc; Product Static Dissipative Tile:  
www.armstrong.com.

#### **2.04 RESILIENT BASE**

- A. RB-1 Resilient Base: ASTM F1861, Type TS rubber, vulcanized thermoset; top set Style B, Cove.
  - 1. Basis of Design Product: Traditional Wall Base as manufactured by Johnsonite, or approved equal.
  - 2. Critical Radiant Flux (CRF): Minimum 0.22 watt per square centimeter, when tested in accordance with ASTM E 648 or NFPA 253.
  - 3. Height: 6 inch.
  - 4. Thickness: 0.125 inch.
  - 5. Finish: Satin.
  - 6. Length: Roll.
  - 7. Color: As indicated on drawings.
  - 8. Accessories: Premolded external corners and internal corners.

#### **2.05 ACCESSORIES**

- A. Subfloor Filler: White premix latex; type recommended by adhesive material manufacturer.
- B. Primers, Adhesives, and Seam Sealer: Waterproof; types recommended by flooring manufacturer.
- C. Moldings, Transition and Edge Strips: Same material as flooring.
- D. Copper Grounding Strips: Type and size as recommended by static control flooring manufacturer.
- E. Floor Polish for Static Control Flooring: Fluid-applied polish, intended to protect electrical properties of flooring, as recommended by static control flooring manufacturer.
- F. Filler for Coved Base: Plastic.

### **PART 3 EXECUTION**

#### **3.01 EXAMINATION**

- A. Verify that surfaces are flat to tolerances acceptable to flooring manufacturer, free of cracks that might telegraph through flooring, clean, dry, and free of curing compounds, surface hardeners, and other chemicals that might interfere with bonding of flooring to substrate.

- B. Verify that wall surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive resilient base.
- C. Cementitious Subfloor Surfaces: Verify that substrates are ready for resilient flooring installation by testing for moisture and alkalinity (pH).
  - 1. Test in accordance with Section 09 05 61.
  - 2. Obtain instructions if test results are not within limits recommended by resilient flooring manufacturer and adhesive materials manufacturer.
  - 3. Follow moisture and alkalinity remediation procedures in Section 09 05 61.
- D. Environmental Condition: Comply with flooring manufacturer's instructions and recommendations.
  - 1. Verify that ambient and surface temperatures and humidity conditions are in compliance.
- E. Verify that required floor-mounted utilities are in correct location.
- F. Material Inspection:
  - 1. In accordance with manufacturer's installation requirements, visually inspect materials prior to installation.
  - 2. Material with visual defects shall not be installed.
  - 3. Labor costs required to replace material installed with visual defects shall be the responsibility of the installation contractor.

### **3.02 PREPARATION**

- A. Remove subfloor ridges and bumps. Fill minor low spots, cracks, joints, holes, and other defects with subfloor filler to achieve smooth, flat, hard surface.
- B. Prohibit traffic until filler is fully cured.

### **3.03 INSTALLATION - GENERAL**

- A. Starting installation constitutes acceptance of sub-floor conditions. Beginning of installation means acceptance of existing substrate and site conditions and assumes responsibility for correcting unsuitable conditions at no additional cost to the District.
- B. Install in accordance with manufacturer's written instructions.
  - 1. Compliance: Comply with manufacturer's product data, including product technical bulletins, product catalog installation instructions, and product carton instructions for installation.
- C. Adhesive-Applied Installation:
  - 1. Spread only enough adhesive to permit installation of materials before initial set.
  - 2. Place copper grounding strip in conductive adhesive and apply additional adhesive to top side of strip before installing static control flooring. Allow strip to extend beyond flooring in accordance with static control flooring manufacturer's instructions. Refer to Division 26 for grounding and bonding to building grounding system.
  - 3. Fit joints and butt seams tightly.
  - 4. Set flooring in place, press with heavy roller to attain full adhesion.



- D. Where type of floor finish, pattern, or color are different on opposite sides of door, terminate flooring under centerline of door.
- E. Install edge strips at unprotected or exposed edges, where flooring terminates, and where indicated.
  - 1. Metal Strips: Attach to substrate before installation of flooring using stainless steel screws.
  - 2. Resilient Strips: Attach to substrate using adhesive.
- F. Scribe flooring to walls, columns, cabinets, floor outlets, and other appurtenances to produce tight joints.
- G. Install flooring in recessed floor access covers, maintaining floor pattern.

### **3.04 INSTALLATION - SHEET FLOORING**

- A. Lay flooring with joints and seams parallel to longer room dimensions, to produce minimum number of seams. Lay out seams to avoid widths less than 1/3 of roll width; match patterns at seams.
- B. Seams are prohibited in kitchens, toilet rooms, and custodial closets.
- C. Cut sheet at seams in accordance with manufacturer's instructions.
- D. Seal seams by heat welding.
- E. Coved Base: Install as detailed on drawings, using coved base filler as backing at floor to wall junction. Extend sheet flooring vertically to height indicated, and cover top edge with metal cap strip.

### **3.05 INSTALLATION - TILE FLOORING**

- A. Mix tile from container to ensure shade variations are consistent when tile is placed, unless otherwise indicated in manufacturer's installation instructions.
- B. Lay flooring with joints and seams parallel to building lines to produce symmetrical pattern.

### **3.06 INSTALLATION - RESILIENT BASE**

- A. Fit joints tightly and make vertical. Maintain minimum dimension of 18 inches between joints.
- B. Miter internal corners. At external corners, use premolded units. At exposed ends, use premolded units.
- C. Install base on solid backing. Bond tightly to wall and floor surfaces.
- D. Scribe and fit to door frames and other interruptions.

### **3.07 FIELD QUALITY REQUIREMENTS**

- A. Manufacturer's Field Services: Upon District's request and with at least 72 hours notice, provide manufacturer's field service consisting of product use recommendations and periodic site visit for inspection of product installation in accordance with manufacturer's instructions.

### **3.08 CLEANING**

- A. Remove excess adhesive from floor, base, and wall surfaces without damage.
- B. Clean in accordance with manufacturer's written instructions.

- C. Installation Clean-Up: Upon completion of installation in a room or area, clean flooring and adjacent surfaces.
  - 1. Sweep or vacuum floor thoroughly.
  - 2. Do not wash floor until time period recommended by resilient flooring manufacturer has elapsed to allow resilient flooring to become well-sealed in adhesive.
  - 3. Remove excess adhesive or other surface blemishes, using appropriate cleaner recommended by resilient flooring manufacturers.
- D. Initial Cleaning: After adhesive has set but no sooner than 5 days after installation, wash resilient tile flooring with a neutral type cleaning solution in accordance with manufacturer's instructions and recommendations. Rinse thoroughly with clear, cool water but do not flood floor.
  - 1. After completion of installation, apply one coat of polish, if recommended by manufacturer, and buff to even luster.
  - 2. After final cleaning, apply second coat of polish as recommended by tile manufacturer and buff to even luster.
- E. Final Cleaning: Thoroughly clean resilient tile flooring and accessories in accordance with final cleaning specified in Section 01 70 00 - Execution and Closeout Requirements.
  - 1. Clean resilient flooring not more than 4 days prior to date scheduled for inspections intended to establish date of substantial completion in each area of Project.
  - 2. Clean resilient flooring by method recommended by resilient flooring manufacturer, including stripping and application of additional floor polish and buffing to even luster.

### **3.09 PROTECTION**

- A. Prohibit traffic on resilient flooring for 48 hours after installation.
- B. From the time of laying until Acceptance, protect flooring from damage.
  - 1. Lay reinforced kraft paper runners and provide barricades and signs as necessary to prevent construction traffic on completed installations.
  - 2. Protect resilient flooring against damage from rolling loads for initial period following installation by covering with plywood or hardboard. Use dollies to move stationary equipment or furnishings across floors.
  - 3. Remove and replace defects which develop such as damaged, loose or broken tile and resilient accessories.

**END OF SECTION**



**SECTION 09 68 13**  
**TILE CARPETING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Carpet tile, fully adhered.

**1.02 RELATED REQUIREMENTS**

- A. Section 03 30 00 - Cast-in-Place Concrete: Restrictions on curing compounds for concrete slabs and floors.
- B. Section 09 05 61 - Common Work Results for Flooring Preparation: Independent agency testing of concrete slabs, removal of existing floor coverings, cleaning, and preparation.
- C. Section 09 6500 - Resilient Flooring: Topset Base.

**1.03 REFERENCE STANDARDS**

- A. AATCC Test Method 134 - Electrostatic Propensity of Carpets; 2016.
- B. AATCC Test Method 16 - Colorfastness to Light; 2004, with Editorial Revision (2010).
- C. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- D. ASTM D2859 - Standard Test Method for Ignition Characteristics of Finished Textile Floor Covering Materials; 2016.
- E. ASTM E648 - Standard Test Method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source; 2017.
- F. CRI 104 - Standard for Installation of Commercial Carpet; 2015.
- G. CRI (GLP) - Green Label Plus Testing Program - Certified Products; Current Edition.
- H. NFPA 253 - Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source; 2015.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; sizes, patterns, colors available, and method of installation.
- C. Shop Drawings: Indicate layout of joints.
- D. Samples: Submit two carpet tiles illustrating color and pattern design for each carpet color selected.
- E. Submit two, 6 inch long samples of edge strip and base cap.
- F. Manufacturer's Installation Instructions: Indicate special procedures.
- G. Maintenance Data: Include maintenance procedures, recommended maintenance materials, and suggested schedule for cleaning.
- H. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.

2. Extra Carpet Tiles: Quantity equal to 5 percent of total installed of each color and pattern installed.

### **1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing specified carpet tile with minimum three years documented experience.
- B. Installer Qualifications: Company specializing in installing carpet tile with minimum three years documented experience and approved by carpet tile manufacturer.

### **1.06 FIELD CONDITIONS**

- A. Store materials in area of installation for minimum period of 24 hours prior to installation.
  1. Store inside, in well ventilated area, protected from weather, moisture and soiling. Store rolls flat, not standing on end.
- B. Maintain minimum 70 degrees F ambient temperature 24 hours prior to, during and 24 hours after installation.
- C. Deliver carpet materials in original mill protective wrapping with mill register numbers and tags attached.
- D. Ventilate installation area during installation and for 72 hours after installation.

### **1.07 WARRANTY**

- A. Carpet Warranty: Provide 10-year Commercial Limited Warranty.
- B. Extended Warranty: Provide extended warranty covering edge raveling, delamination and wear exceeding 10 percent of face yarn weight for a period of 15 years after "Notice of Completion".

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. All products used for flooring installation shall comply with flammability and smoke classifications for various locations of installation. Comply with applicable requirements of California Building Code (CBC) Chapter 8.
- B. Requirements for Physically Disabled: Provide flooring meeting slip-resistant requirements of California Code of Regulations (CCR), Title 24, Part 2, Chapter 11B and ADA Standards, latest amendment.
  1. Flooring surface shall be stable, firm, and slip resistant. CBC Section 11B-302.1 General.
  2. Flooring surface shall demonstrate a dynamic coefficient of friction of at least 0.42 per DCOF AcuTest ANSI 137.1 Section 9.6 and ANSI B101.3 (using a BOT-3000 testing unit) will be accepted as meeting the intent of slip resistance; CBC 11B-302 Floor or Ground Surfaces and ADA Standards.
    - a. Ramp surface: Provide DCOF value of 0.46.
- C. Comply with CalGreen Building Standards: All installed carpeting shall be low VOC emissions listed. Certified as Low Emission by one of the following:
  1. Carpet and Rug Institute's Green Label Plus Program. CalGreen 5.504.4.4.1

2. Compliant with the VOC emission limits and testing requirements specified in the California Department of Public Health's "Standard Method for the Testing and Evaluation Chambers", Version 1.1, February 2010 or Specification 01350. CalGreen 5.504.4.4.2.
3. NSF/ANSI 140 at Gold level or higher. CalGreen 5.504.4.4.3
4. SCS Floorscore; www.scscertified.com. CalGreen 5.504.4.4.4.
5. Compliant with the Collaborative for High Performance Schools California (CA-CHPS) Criteria Interpretation for EQ 7.0 and EQ 7.1 (formerly EQ 2.2) dated July 2012 and listed in the CHPS High Performance Product Database; www.chps.net/manual/lem\_table.htm. CalGreen 5.504.4.4.5.

## **2.02 MANUFACTURERS**

- A. Tile Carpeting:
1. Basis of Design: Interface, Inc: www.interfaceinc.com, or approved equal.
  2. Lees Carpets: www.leescarpets.com.
  3. Milliken & Company: www.milliken.com.
  4. Tandus: www.tandus.com.
  5. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## **2.03 MATERIALS**

- A. Tile Carpeting: Tufted, Textured Loop, manufactured in one color dye lot.
1. Product: ISO #04536 manufactured by Tandus Centiva.
  2. Tile Size: 19 by 36 inch, nominal.
  3. Thickness: 0.35 inch, nominal.
  4. Color: 48201 Wired.
  5. Pattern: Geometric.
  6. Critical Radiant Flux: Minimum of 0.45 watts/sq cm, when tested in accordance with ASTM E648 or NFPA 253.
  7. Surface Flammability Ignition: Pass ASTM D2859 (the "pill test").
  8. VOC Content: Provide CRI (GLP) certified product; in lieu of labeling, independent test report showing compliance is acceptable.
  9. Indoor Air Quality—CRI Green Label Plus™
  10. Antimicrobial: None.
  11. Maximum Electrostatic Charge: 3.5 Kv. at 20 percent relative humidity, 1.
  12. Gage: 5/64 inch.
  13. Stitches: 10.0 per inch.
  14. Light Fastness: >= 4.0 at 80 Hours, 1.
- B. Tile Carpeting: Tufted, Textured Loop, manufactured in one color dye lot.
1. Product: Detours manufactured by Interface.

2. Tile Size: 19.7 by 19.7 inch, nominal.
3. Thickness: 0.35 inch, nominal.
4. Color: 104717 Onyx.
5. Pattern: Geometric.
6. Critical Radiant Flux: Minimum of 0.45 watts/sq cm, when tested in accordance with ASTM E648 or NFPA 253.
7. Surface Flammability Ignition: Pass ASTM D2859 (the "pill test").
8. VOC Content: Provide CRI (GLP) certified product; in lieu of labeling, independent test report showing compliance is acceptable.
9. Indoor Air Quality—CRI Green Label Plus™
10. Antimicrobial: None.
11. Maximum Electrostatic Charge: 3.5 Kv. at 20 percent relative humidity, 1.
12. Gage: 1/12 inch.
13. Stitches: 8 per inch.
14. Light Fastness: >= 4.0 at 80 Hours, 1.

#### **2.04 ACCESSORIES**

- A. Sub-Floor Filler: White premix latex; type recommended by flooring material manufacturer.
- B. Edge Strips: Rubber, color as selected by Architect.
  1. Reducer, CRS-29-A manufactured by Johnsonite, a Tarkett Company; [www.johnsonite.com](http://www.johnsonite.com); or approved equivalent product.
- C. Adhesives:
  1. Compatible with materials being adhered; maximum VOC content of 50 g/L; CRI (GLP) certified; in lieu of labeled product, independent test report showing compliance is acceptable.
- D. Carpet Tile Adhesive: Recommended by carpet tile manufacturer; releasable type.

### **PART 3 EXECUTION**

#### **3.01 EXAMINATION**

- A. Verify that sub-floor surfaces are smooth and flat within tolerances specified for that type of work and are ready to receive carpet tile.
  1. Maximum variation of 1/8-inch in 10 ft
- B. Verify that sub-floor surfaces are dust-free and free of substances that could impair bonding of adhesive materials to sub-floor surfaces.
- C. Cementitious Sub-floor Surfaces: Verify that substrates are dry enough and ready for flooring installation by testing for moisture and pH.
  1. Test in accordance with Section 09 05 61.
  2. Obtain instructions if test results are not within limits recommended by flooring material manufacturer and adhesive materials manufacturer.

- D. Carpet Verification: Verify carpet match before cutting or placement to ensure minimal variation between dye lots.
- E. Verify that required floor-mounted utilities are in correct location.

### **3.02 PREPARATION**

- A. Prepare floor substrates for installation of flooring in accordance with Section 09 05 61.

### **3.03 INSTALLATION**

- A. Starting installation constitutes acceptance of sub-floor conditions.
- B. Install carpet tile in accordance with manufacturer's instructions and CRI 104 (Commercial).
- C. Blend carpet from different cartons to ensure minimal variation in color match.
- D. Cut carpet tile clean. Fit carpet tight to intersection with vertical surfaces without gaps.
- E. Lay carpet tile in square pattern, with pile direction parallel to next unit, set parallel to building lines.
  - 1. Locate change of color or pattern between rooms under door centerline.
- F. Locate change of color or pattern between rooms under door centerline.
- G. Fully adhere carpet tile to substrate.
- H. Trim carpet tile neatly at walls and around interruptions.
  - 1. Edges: Run carpet under open bottom items and all cabinets and install tight to walls. Neatly trim and secure edge of carpet adjacent to door jambs where no base occurs.
- I. Complete installation of edge strips, concealing exposed edges.
- J. Carpet Finishing: Brush all seams and trim protruding pile tufts level. Remove excess adhesive on the carpet surface and thoroughly vacuum entire area. Leave room clean and ready for use.

### **3.04 PROTECTION**

- A. Cover carpet during construction period with reinforced kraft paper when construction traffic is required to cross carpeted areas.
- B. Remove and replace damaged or improperly installed carpet.

### **3.05 CLEANING**

- A. Remove excess adhesive without damage, from floor, base, and wall surfaces.
- B. Clean and vacuum carpet surfaces.
  - 1. Vacuum and remove all stains from carpet to satisfaction of Owner and in accordance with cleaning specified in Section 01 70 00 - Execution and Closeout Requirements.

**END OF SECTION**





**SECTION 09 84 30**  
**SOUND-ABSORBING WALL AND CEILING UNITS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Sound-absorbing panels.
- B. Mounting accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 06 41 00 - Architectural Wood Casework.

**1.03 REFERENCE STANDARDS**

- A. ASTM C423 - Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method; 2009a.
- B. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2016.
- C. ASTM E795 - Standard Practices for Mounting Test Specimens During Sound Absorption Tests; 2016.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Manufacturer's printed data sheets for products specified.
- C. Shop Drawings: Fabrication and installation details, panel layout, and fabric orientation.
  - 1. Coordination Drawings: Project-specific Coordination Drawings, indicating the following items drawn and coordinated with each other. Include information required by Installers of each item in order to coordinate the Work. Include the following:
    - a. Relationship of items shown on separate Shop Drawings.
    - b. Dimensions and required clearances of adjacent or related work.
    - c. Order of assembly of separate items.
    - d. Information required for interface with other trades and components, including mechanical, electrical, and communication work required for, integrated with, or adjacent to, acoustic panels work.
- D. Selection Samples: Manufacturer's color charts for fabric covering, indicating full range of fabrics, colors, and patterns available.
- E. Verification Samples: Fabricated samples of each type of panel specified; 12 by 12 inch, showing construction, edge details, and fabric covering.
- F. Test Reports: Certified test data from an independent test agency verifying that panels meet specified requirements for acoustical and fire performance.
- G. Manufacturer's Qualification Statement.
- H. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.

2. Extra Panels: Quantity equal to 5 percent of total installed, but not less than one of each type.

#### **1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company with not less than five years of experience in manufacturing acoustical products similar to those specified.

#### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Protect acoustical units from moisture during shipment, storage, and handling. Deliver in factory-wrapped bundles; do not open bundles until units are needed for installation.
- B. Store units flat, in dry, well-ventilated space; do not stand on end.
- C. Protect edges from damage.

#### **1.07 MOCK-UP**

- A. See Section 01 45 00 - Quality Control, for additional mock-up requirements.
- B. Construct mock-up of acoustical units at location as indicated by Architect.
  1. Minimum mock-up dimensions; 96 by 96 inches.
  2. Approved mock-up may remain as part of the Work.

#### **1.08 FIELD CONDITIONS**

- A. Ambient Conditions: Do not install acoustic panels until spaces are enclosed and weatherproof, wet-work in spaces is completed and dry, work above ceilings is complete.
- B. Ambient Conditions: Maintain ambient temperature and humidity conditions at the levels indicated for Project when occupied for its intended use during and after installation of acoustic panels.

#### **1.09 WARRANTY**

- A. Manufacturer's written warranty indicating manufacturer's intent to repair or replace acoustical absorber and diffuser panels that fail in materials or workmanship within 3 years from date of Substantial Completion. Failures are defined to include, but are not limited to, the following:
  1. Fracturing or breaking of unit components which results from normal wear and tear and normal use other than vandalism.
  2. Delamination or other failures of glue bond of components.
  3. Warping of components not resulting from leaks, flooding, or other uncontrolled moisture or humidity.
  4. Failure of unit to perform acoustically in accordance with manufacturer's published data.
- B. Warranties: Provide owner with a (1) year warranty for material and workmanship on all installed products.
  1. Manufacturers: All materials, wood panel and grid, shall be warranted for (1) one year for material and workmanship.
  2. Installer: All work shall be warranted for (1) year from final acceptance of completed work.

## **PART 2 PRODUCTS**

### **2.01 WOOD VENEER SOUND-ABSORBING UNITS**

- A. Manufacturers: Or approved equal.
  - 1. decoustics, division of Certainteed: Quadrillo Wood Panel: [www.decoustics.com](http://www.decoustics.com).
  - 2. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Wood Veneer Acoustical Panels for Walls and Ceilings: Medium Density Fiberboard (MDF) core panels with prime grade finished face veneer and non-woven acoustic material adhered to back of panel.
  - 1. Surface Burning Characteristics: Flame spread index of 25 or less and smoke developed index of 450 or less, when tested in accordance with ASTM E84.
  - 2. Noise Reduction Coefficient (NRC): 0.70 to 0.80 when tested in accordance with ASTM C423 for Type F5 mounting, per ASTM E795.
  - 3. Acoustic Back-Up Material: Compressed fiberglass board, 6-7 lbs/cu ft density, in sizes to fit furring applications.
    - a. Thickness: 1-3/8 inch.
  - 4. Provide MDF with no added urea formaldehyde (NAUF).
  - 5. Panel Weight: 3.50 psf.
  - 6. WP-1 Surface Veneer Species: Oak.
    - a. Grain Direction: Flat.
    - b. Factory Finish: Clear sealer.
  - 7. WP-2 Surface Veneer Species: Walnut.
    - a. Grain Direction: Flat.
    - b. Factory Finish: Clear sealer.

### **2.02 FABRICATION**

- A. Fabric Wrapped, General: Fabricate panels to sizes and configurations as indicated, with fabric facing installed without sagging, wrinkles, blisters, or visible seams.
  - 1. Where radiused or mitered corners are indicated, install fabric to avoid seams or gathering of material.
- B. Tolerances: Fabricate to finished tolerance of plus or minus 1/16 inch for thickness, overall length and width, and squareness from corner to corner.
- C. Factory-applied finishes on wood veneer panels to be uniform, smooth, and without blemishes.

### **2.03 ACCESSORIES**

- A. Back-Mounting Accessories: Manufacturer's standard accessories for concealed support, designed to allow panel removal, and as follows:
  - 1. Two-part clip and base-support bracket system; brackets designed to support full weight of panels and clips designed for lateral support, with one part mechanically attached to back of panel and the other attached to substrate.

- B. Trim Moldings: Manufacturer's standard wood or vinyl trim moldings for concealing panel joints; color as selected from manufacturer's standards.
- C. Fixing Clips: Manufacturers standard for application as indicated.
- D. Furring Strips: 1 by 2 inch wood furring.

### **PART 3 EXECUTION**

#### **3.01 EXAMINATION**

- A. Examine substrates for conditions detrimental to installation of acoustical units. Proceed with installation only after unsatisfactory conditions have been corrected.
- B. Verify blocking, anchorages, and structural supports are in place and adequate to received work.
- C. Verify HVAC and electrical rough-in components are properly located.

#### **3.02 PREPARATION**

- A. Coordinate requirements for blocking required in frame construction to receive acoustic panels.
- B. Coordinate installation of acoustic panels to ensure proper installation and operation of each component and, where applicable, to meet acoustic design requirements of rehearsal and performance spaces containing acoustic panels.
  - 1. Sequencing and scheduling of acoustic panels installation with completion of related and adjacent work.
  - 2. Preparation of openings to receive acoustic panels.
  - 3. Placement of blocking, anchorages, and structural supports required for acoustic panels.
  - 4. Installation of HVAC and electrical rough-in components for connection to acoustic panels.
  - 5. Preparation of Project Record Documents for acoustic panels.
  - 6. Coordinate preparation of operation and maintenance manuals for acoustic panels.
  - 7. Coordinate demonstration and training activities for acoustic panels.

#### **3.03 INSTALLATION**

- A. Install acoustical units in locations as indicated, following manufacturer's installation instructions.
- B. Align panels accurately, with edges plumb and top edges level. Scribe to fit accurately at adjoining work and penetrations.
- C. Install wall-mounted acoustical panels utilizing corner mounting z-brackets or grooved buttons and concealed wall brackets. Where indicated, secure units to wall with fasteners along top of unit.
- D. Do not modify panels in the field.
- E. Install acoustical units to construction tolerances of plus or minus 1/16 inch for the following:
  - 1. Plumb and level.

2. Flatness.
3. Width of joints.

### **3.04 FIELD QUALITY CONTROL**

- A. Should completed installation fail to meet requirements, Contractor shall make modifications necessary to correct performance and retest room as directed by Architect to indicate compliance, at Contractor's expense.

### **3.05 CLEANING**

- A. Repair or replace visual/performance defective work as directed by Architect upon inspection.
- B. Clean fabric facing upon completion of installation from dust and other foreign materials, following manufacturer's instructions.
- C. Clean unit surfaces. Touch up, refinish, or replace damaged components in a manner acceptable to Architect.

### **3.06 PROTECTION**

- A. Provide protection of installed acoustical panels until Date of Substantial Completion.
- B. Replace panels that cannot be cleaned and repaired to satisfaction of the Architect.

**END OF SECTION**



**SECTION 09 91 13**  
**EXTERIOR PAINTING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Surface preparation.
- B. Field application of paints.
- C. Scope: Finish exterior surfaces exposed to view, unless fully factory-finished and unless otherwise indicated, including the following:
  - 1. Both sides and edges of plywood backboards for electrical and telecom equipment before installing equipment.
- D. Do Not Paint or Finish the Following Items:
  - 1. Items factory-finished unless otherwise indicated; materials and products having factory-applied primers are not considered factory finished.
  - 2. Items indicated to receive other finishes.
  - 3. Items indicated to remain unfinished.
  - 4. Fire rating labels, equipment serial number and capacity labels, and operating parts of equipment.
  - 5. Non-metallic roofing and flashing.
  - 6. Stainless steel, anodized aluminum, bronze, terne coated stainless steel, zinc, and lead.
  - 7. Floors, unless specifically indicated.
  - 8. Brick, glass unit masonry, architectural concrete, cast stone, integrally colored plaster and stucco.
  - 9. Glass.
  - 10. Concealed pipes, ducts, and conduits.

**1.02 RELATED REQUIREMENTS**

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 05 50 00 - Metal Fabrications: Shop-primed items.
- C. Section 09 91 23 - Interior Painting.

**1.03 DEFINITIONS**

- A. Comply with ASTM D16 for interpretation of terms used in this section.

**1.04 REFERENCE STANDARDS**

- A. ASTM D16 - Standard Terminology for Paint, Related Coatings, Materials, and Applications; 2016.
- B. MPI (APSM) - Master Painters Institute Architectural Painting Specification Manual; Current Edition.
- C. SCAQMD 1113 - Architectural Coatings; 1977 (Amended 2016).



- D. SSPC-SP 1 - Solvent Cleaning; 2015, with Editorial Revision (2016).
- E. SSPC-SP 2 - Hand Tool Cleaning; 2018.
- F. SSPC-SP 6 - Commercial Blast Cleaning; 2007.

#### **1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide complete list of products to be used, with the following information for each:
  - 1. Manufacturer's name, product name and/or catalog number, and general product category (e.g. "alkyd enamel").
  - 2. MPI product number (e.g. MPI #47).
  - 3. Cross-reference to specified paint system(s) product is to be used in; include description of each system.
- C. Samples: Submit three paper "draw down" samples, 8-1/2 by 11 inches in size, illustrating range of colors available for each finishing product specified.
  - 1. Where sheen is specified, submit samples in only that sheen.
  - 2. Where sheen is not specified, discuss sheen options with Architect before preparing samples, to eliminate sheens definitely not required.
  - 3. Allow 30 days for approval process, after receipt of complete samples by Architect.
  - 4. Paint color submittals will not be considered until color submittals for major materials not to be painted, such as factory finished metals and wood doors, have been approved.
- D. Samples: Submit two paper chip samples, 8 by 8 inch in size illustrating range of colors and textures available for each surface finishing product scheduled.
- E. Certification: By manufacturer that paints and finishes comply with VOC limits specified.
- F. Manufacturer's Instructions: Indicate special surface preparation procedures.
- G. Maintenance Data: Submit data including finish schedule showing where each product/color/finish was used, product technical data sheets, material safety data sheets (MSDS), care and cleaning instructions, touch-up procedures, repair of painted and finished surfaces, and color samples of each color and finish used.
- H. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.
  - 2. Extra Paint and Finish Materials: 1 gallon of each color; from the same product run, store where directed.
  - 3. Label each container with color in addition to the manufacturer's label.

#### **1.06 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified, with minimum three years documented experience.
- B. Applicator Qualifications: Company specializing in performing the type of work specified with minimum three years documented experience and approved by manufacturer.

### **1.07 MOCK-UP**

- A. See Section 01 45 00 - Quality Control, for general requirements for mock-up.
- B. Provide panel, 12 feet high by 8 feet wide, illustrating paint color, texture, and finish.
- C. Provide door and frame assembly illustrating paint color, texture, and finish.
- D. Locate where directed by Architect.
- E. Mock-up may remain as part of the work.

### **1.08 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.
- B. Container Label: Include manufacturer's name, type of paint, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, color designation, and instructions for mixing and reducing.
- C. Paint Materials: Store at minimum ambient temperature of 45 degrees F and a maximum of 90 degrees F, in ventilated area, and as required by manufacturer's instructions.

### **1.09 FIELD CONDITIONS**

- A. Do not apply materials when surface and ambient temperatures are outside the temperature ranges required by the paint product manufacturer.
- B. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.
- C. Do not apply exterior paint and finishes during rain or snow, or when relative humidity is outside the humidity ranges required by the paint product manufacturer.
- D. Provide lighting level of 80 ft candles measured mid-height at substrate surface.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Provide paints and finishes from the same manufacturer to the greatest extent possible.
  - 1. In the event that a single manufacturer cannot provide specified products, minor exceptions will be permitted provided approval by Architect is obtained using the specified procedures for substitutions.
  - 2. Substitution of other products by the same manufacturer is preferred over substitution of products by a different manufacturer.
- B. Paints:
  - 1. Behr Process Corporation: [www.behr.com/#sle](http://www.behr.com/#sle).
    - a. Local representative Jan Piccola (714) 679-5730.
  - 2. Dunn-Edwards Corporation: [www.dunnedwards.com](http://www.dunnedwards.com),
    - a. Local representative Susan Giampietro (714) 469-2502.
    - b. Local representative Wanda Barragan (909) 261-1289.
  - 3. Sherwin-Williams Company: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
    - a. Local representative John Dumesnil (619) 665-9341.

4. Vista Paint; [www.vistapaint.com](http://www.vistapaint.com) .
  - a. Local representative Mark Brower (323) 397-9000.
- C. Primer Sealers: Same manufacturer as top coats.
- D. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## **2.02 PAINTS AND FINISHES - GENERAL**

- A. Paints and Finishes: Ready mixed, unless required to be a field-catalyzed paint.
  1. Provide paints and finishes of a soft paste consistency, capable of being readily and uniformly dispersed to a homogeneous coating, with good flow and brushing properties, and capable of drying or curing free of streaks or sags.
  2. Provide materials that are compatible with one another and the substrates indicated under conditions of service and application, as demonstrated by manufacturer based on testing and field experience.
  3. For opaque finishes, tint each coat including primer coat and intermediate coats, one-half shade lighter than succeeding coat, with final finish coat as base color.
  4. Supply each paint material in quantity required to complete entire project's work from a single production run.
  5. Do not reduce, thin, or dilute paint or finishes or add materials unless such procedure is specifically described in manufacturer's product instructions.
- B. Volatile Organic Compound (VOC) Content: Comply with Section 01 61 16.
  1. Regulatory Requirements: Conform to California Air Resources Board (CARB), and South Coast Air Quality Management District (SCAQMD) and other applicable local air quality regulations for products and application.
- C. Flammability: Comply with applicable code for surface burning characteristics.
- D. Sheens: Provide the sheens specified; where sheen is not specified, sheen will be selected later by Architect from the manufacturer's full line.
- E. Colors: As indicated in Color Schedule.
  1. Extend colors to surface edges; colors may change at any edge as directed by Architect.

## **2.03 PAINT SYSTEMS - EXTERIOR**

- A. Paint E-OP - Exterior Surfaces to be Painted, Unless Otherwise Indicated: Including primed metal.
  1. One or two coats to cover and one coat primer.
  2. Top Coat(s): Exterior Latex.
    - a. Products:
      - 1) Behr Marquee Exterior Semi-Gloss Enamel [No. 5450]. (MPI #11)
      - 2) Behr Premium Plus Exterior Semi-Gloss Enamel [No. 5050].
      - 3) Dunn-Edwards Corp.; 704V Acriflat
      - 4) PPG Paints
      - 5) Sherwin Williams Co; Solo Acrylic Semi-Gloss, A76 Series (MPI #11)
      - 6) Valspar Emblem Exterior Latex, No. 56530 Series, Semi-Gloss. (MPI #11)
      - 7) Vista Paint;

- 8) Substitutions: Section 01 63 00 - Product Substitution Procedures.
3. Top Coat Sheen:
    - a. Semi-Gloss: MPI gloss level 5; use this sheen at all locations.
  4. Primer: As recommended by top coat manufacturer for specific substrate.
- B. Paint CE-OP-3L - Masonry/Concrete, Concrete Tilt-Up, and CMU Opaque, Latex, 3 Coat:
1. One coat of latex primer sealer.
  2. Low-Sheen-Elastomeric: Two coats of latex-acrylic; Behr Paint, 68 Premium Elastomeric Masonry, Stucco & Brick Paint.
  3. Premium Flat: Two coats of latex-acrylic enamel; Behr Paint, 4000 Series Premium Plus Exterior Flat.
- C. Paint ME-OP-3L - Ferrous Metals, Unprimed, Latex, 3 Coat:
1. One coat of latex primer.
  2. Semi-gloss: Two coats of latex enamel; Behr Paint, 5000 Series Premium Plus Exterior Semi-Gloss Enamel.
- D. Paint ME-OP-3A-HP - Ferrous Metals, Unprimed, High-Performance Industrial Maintenance, Acrylic, 3 Coat:
1. One coat of primer: Behr Paint, 436 Multi-Surface Primer & Sealer
  2. Semi-gloss: Two coats of alkyd enamel; Behr Paint, 3200 Premium Direct-To-Metal Semi-Gloss Paint.
- E. Paint ME-OP-2L - Ferrous Metals, Primed, Latex, 2 Coat:
1. Touch-up with rust-inhibitive primer recommended by top coat manufacturer.
  2. Semi-gloss: Two coats of latex enamel.
- F. Paint MgE-OP-3L - Galvanized Metals, Latex, 3 Coat:
1. Pre-Treatment: 991 Behr Premium Concrete Masonry Cleaner & Etcher
  2. One coat galvanize primer.
  3. Gloss: Two coats of latex enamel; 2-8000 Series Premium Plus Interior/Exterior High Gloss Behr Paint, Enamel.
  4. Semi-gloss: Two coats of latex enamel; Behr Paint, 5000 Series Premium Plus Exterior Semi-Gloss Enamel.
- G. Paint MgE-OP-3LA-HP - Ferrous Metals, Unprimed, High-Performance Industrial Maintenance, Latex-Acrylic, 3 Coat:
1. Pre-Treatment: 991 Behr Premium Concrete Masonry Cleaner & Etcher
  2. One coat galvanize primer.
  3. Semi-gloss: Two coats of alkyd enamel; Behr Paint, 3200 Premium Direct-To-Metal Semi-Gloss Paint.

## 2.04 PRIMERS

- A. Primers: Provide the following unless other primer is required or recommended by manufacturer of top coats.

1. Alkali Resistant Water Based Primer; MPI #3.
  - a. Products:
    - 1) Behr Concrete and Masonry Bonding Primer [No. 880].
    - 2) Behr Premium Plus Interior/Exterior Multi-Surface Primer and Sealer [No. 436]. (MPI #3)
    - 3) PPG Paints Seal Grip Acrylic Primer, 17-921 Series. (MPI #3)
    - 4) Valspar Acrylic Alkali-Resistant Masonry Primer, No. 80165.
    - 5) Substitutions: Section 01 63 00 - Product Substitution Procedures.
2. Water Based Primer for Galvanized Metal; MPI #134.
  - a. Products:
    - 1) Behr Premium Plus Interior/Exterior Multi-Surface Primer and Sealer [No. 436]. (MPI #134)
    - 2) Substitutions: Section 01 63 00 - Product Substitution Procedures.

## **2.05 ACCESSORY MATERIALS**

- A. Accessory Materials: Provide primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials as required for final completion of painted surfaces.
- B. Patching Material: Latex filler.
- C. Fastener Head Cover Material: Latex filler.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Do not begin application of paints and finishes until substrates have been properly prepared.
- B. Verify that surfaces are ready to receive work as instructed by the product manufacturer.
- C. Examine surfaces scheduled to be finished prior to commencement of work. Report any condition that may potentially effect proper application.
- D. Test shop-applied primer for compatibility with subsequent cover materials.
- E. Measure moisture content of surfaces using an electronic moisture meter. Do not apply finishes unless moisture content of surfaces are below the following maximums:
  1. Exterior Plaster and Stucco: 12 percent.
  2. Fiber Cement Siding: 12 percent.
  3. Masonry, Concrete, and Concrete Masonry Units: 12 percent.
  4. Concrete Floors and Traffic Surfaces: 8 percent.

### **3.02 PREPARATION**

- A. Clean surfaces thoroughly and correct defects prior to application.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Remove or repair existing paints or finishes that exhibit surface defects.
- D. Remove or mask surface appurtenances, including electrical plates, hardware, light fixture trim, escutcheons, and fittings, prior to preparing surfaces for finishing.

- E. Seal surfaces that might cause bleed through or staining of topcoat.
- F. Remove mildew from impervious surfaces by scrubbing with solution of tetra-sodium phosphate and bleach. Rinse with clean water and allow surface to dry.
- G. Masonry:
  - 1. Remove efflorescence and chalk. Do not coat surfaces if moisture content or alkalinity of surfaces or if alkalinity of mortar joints exceed that permitted in manufacturer's written instructions. Allow to dry.
  - 2. Prepare surface as recommended by top coat manufacturer.
  - 3. Clean surfaces with pressurized water. Use pressure range of 600 to 1,500 psi at 6 to 12 inches. Allow to dry.
- H. Fiber Cement Siding: Remove dirt, dust and other foreign matter with a stiff fiber brush. Do not coat surfaces if moisture content or alkalinity of surfaces to be coated exceeds that permitted in manufacturer's written instructions.
- I. Exterior Plaster: Fill hairline cracks, small holes, and imperfections with exterior patching plaster. Make smooth and flush with adjacent surfaces. Wash and neutralize high alkali surfaces.
- J. Concrete Floors and Traffic Surfaces: Remove contamination, acid etch, and rinse floors with clear water. Verify required acid-alkali balance is achieved. Allow to dry.
- K. Galvanized Surfaces:
  - 1. Prepare surface according to SSPC-SP 2.
- L. Ferrous Metal:
  - 1. Solvent clean according to SSPC-SP 1.
  - 2. Shop-Primed Surfaces: Sand and scrape to remove loose primer and rust. Feather edges to make touch-up patches inconspicuous. Clean surfaces with solvent. Prime bare steel surfaces. Re-prime entire shop-primed item.
  - 3. Remove rust, loose mill scale, and other foreign substances using using methods recommended in writing by paint manufacturer and blast cleaning according to SSPC-SP 6 "Commercial Blast Cleaning". Protect from corrosion until coated.
- M. Metal Doors to be Painted: Prime metal door top and bottom edge surfaces.

### **3.03 APPLICATION**

- A. Remove unfinished louvers, grilles, covers, and access panels on mechanical and electrical components and paint separately.
- B. Apply products in accordance with manufacturer's written instructions.
- C. Where adjacent sealant is to be painted, do not apply finish coats until sealant is applied.
- D. Do not apply finishes to surfaces that are not dry. Allow applied coats to dry before next coat is applied.
- E. Apply each coat to uniform appearance.
- F. Dark Colors and Deep Clear Colors: Regardless of number of coats specified, apply additional coats until complete hide is achieved.
- G. Sand wood and metal surfaces lightly between coats to achieve required finish.

- H. Vacuum clean surfaces of loose particles. Use tack cloth to remove dust and particles just prior to applying next coat.
- I. Reinstall electrical cover plates, hardware, light fixture trim, escutcheons, and fittings removed prior to finishing.

### **3.04 FIELD QUALITY CONTROL**

- A. See Section 01 45 00 - Quality Control, for general requirements for field inspection.
- B. District will provide field inspection.

### **3.05 CLEANING**

- A. Collect waste material that could constitute a fire hazard, place in closed metal containers, and remove daily from site.

### **3.06 PROTECTION**

- A. Protect finishes until completion of project.
- B. Touch-up damaged finishes after Substantial Completion.

### **3.07 SCHEDULE - PAINT SYSTEMS**

- A. Exterior Plaster: Finish surfaces exposed to view.
  - 1. Exterior Soffits: GE-OP-2L, flat.
  - 2. Exterior Walls (Exterior Plaster and Stucco): GE-OP-3L.
- B. Steel Fabrications: Finish surfaces exposed to view.
  - 1. Exterior: ME-OP-3LA-HP, semi-gloss; finish all surfaces, including concealed surfaces, before installation.
- C. Galvanized Steel: Finish surfaces exposed to view.
  - 1. Exterior: Paint MgE-OP-3L, gloss.
- D. Shop-Primed Metal Items: Finish surfaces exposed to view.
  - 1. Exterior: Paint-ME-OP-2A, semi-gloss.

**END OF SECTION**

**SECTION 09 91 23**  
**INTERIOR PAINTING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Surface preparation.
- B. Field application of paints.
- C. Materials for backpriming woodwork.
- D. Scope: Finish interior surfaces exposed to view, unless fully factory-finished and unless otherwise indicated.
  - 1. Both sides and edges of plywood backboards for electrical and telecom equipment before installing equipment.
  - 2. Elevator pit ladders.
  - 3. Mechanical and Electrical:
    - a. In finished areas, paint insulated and exposed pipes, conduit, boxes, insulated and exposed ducts, hangers, brackets, collars and supports, mechanical equipment, and electrical equipment, unless otherwise indicated.
    - b. In finished areas, paint shop-primed items.
    - c. Paint interior surfaces of air ducts that are visible through grilles and louvers with one coat of flat black paint to visible surfaces.
    - d. Paint dampers exposed behind louvers, grilles, to match face panels.
- E. Do Not Paint or Finish the Following Items:
  - 1. Items factory-finished unless otherwise indicated; materials and products having factory-applied primers are not considered factory finished.
  - 2. Items indicated to receive other finishes.
  - 3. Items indicated to remain unfinished.
  - 4. Fire rating labels, equipment serial number and capacity labels, bar code labels, and operating parts of equipment.
  - 5. Floors, unless specifically indicated.
  - 6. Glass.
  - 7. Concealed pipes, ducts, and conduits.

**1.02 RELATED REQUIREMENTS**

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 05 50 00 - Metal Fabrications: Shop-primed items.
- C. Section 05 51 00 - Metal Stairs: Shop-primed items.
- D. Section 09 91 13 - Exterior Painting.
- E. Section 09 96 00 - High-Performance Coatings.
- F. Section 32 17 23.13 - Painted Pavement Markings: Painted pavement markings.



### 1.03 REFERENCE STANDARDS

- A. ASTM D4442 - Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials; 2015.
- B. MPI (APSM) - Master Painters Institute Architectural Painting Specification Manual; Current Edition, [www.paintinfo.com](http://www.paintinfo.com).
- C. SSPC-SP 1 - Solvent Cleaning; 2015.
- D. SSPC-SP 6 - Commercial Blast Cleaning; 2007.

### 1.04 SUBMITTALS

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide complete list of products to be used, with the following information for each:
  - 1. Manufacturer's name, product name and/or catalog number, and general product category (e.g. "alkyd enamel").
  - 2. MPI product number (e.g. MPI #47).
  - 3. Cross-reference to specified paint system(s) product is to be used in; include description of each system.
  - 4. Manufacturer's installation instructions.
  - 5. If proposal of substitutions is allowed under submittal procedures, explanation of substitutions proposed.
- C. Samples: Submit three paper "draw down" samples, 8-1/2 by 11 inches in size, illustrating range of colors available for each finishing product specified.
  - 1. Where sheen is specified, submit samples in only that sheen.
  - 2. Where sheen is not specified, discuss sheen options with Architect before preparing samples, to eliminate sheens definitely not required.
  - 3. Allow 30 days for approval process, after receipt of complete samples by Architect.
  - 4. Paint color submittals will not be considered until color submittals for major materials not to be painted, such as factory finished metals, wood cabinets, and wood doors, have been approved.
- D. Samples: Submit two painted samples, illustrating selected colors and textures for each color and system selected with specified coats cascaded. Submit on aluminum sheet, 8 x 10 inch in size.
- E. Certification: By manufacturer that paints and finishes comply with VOC limits specified.
- F. Manufacturer's Instructions: Indicate special surface preparation procedures.
- G. Maintenance Data: Submit data including finish schedule showing where each product/color/finish was used, product technical data sheets, material safety data sheets (MSDS), care and cleaning instructions, touch-up procedures, repair of painted and finished surfaces, and color samples of each color and finish used.
- H. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.

2. Extra Paint and Finish Materials: 1 gallon of each color; from the same product run, store where directed.
3. Label each container with color in addition to the manufacturer's label.

### **1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified, with minimum three years documented experience.
- B. Applicator Qualifications: Company specializing in performing the type of work specified with minimum three years experience and approved by manufacturer.

### **1.06 MOCK-UP**

- A. See Section 01 45 00 - Quality Control, for general requirements for mock-up.
- B. Provide panel, 9 feet high by 12 feet wide, illustrating paint color, texture, and finish.
- C. Provide door and frame assembly illustrating paint color, texture, and finish.
- D. Locate where directed by Architect.
- E. Mock-up may remain as part of the work.

### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.
- B. Container Label: Include manufacturer's name, type of paint, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, color designation, and instructions for mixing and reducing.
- C. Paint Materials: Store at minimum ambient temperature of 45 degrees F and a maximum of 90 degrees F, in ventilated area, and as required by manufacturer's instructions.

### **1.08 FIELD CONDITIONS**

- A. Do not apply materials when surface and ambient temperatures are outside the temperature ranges required by the paint product manufacturer.
- B. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.
- C. Do not apply materials when relative humidity exceeds 85 percent; at temperatures less than 5 degrees F above the dew point; or to damp or wet surfaces.
- D. Minimum Application Temperatures for Paints: 50 degrees F for interiors unless required otherwise by manufacturer's instructions.
- E. Provide lighting level of 80 ft candles measured mid-height at substrate surface.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Provide paints and finishes from the same manufacturer to the greatest extent possible.

1. In the event that a single manufacturer cannot provide specified products, minor exceptions will be permitted provided approval by Architect is obtained using the specified procedures for substitutions.
  2. Substitution of other products by the same manufacturer is preferred over substitution of products by a different manufacturer.
- B. Paints:
1. Behr Process Corporation: [www.behr.com/#sle](http://www.behr.com/#sle).
    - a. Local representative Jan Piccola (714) 679-5730.
  2. Dunn-Edwards Corporation: [www.dunnedwards.com](http://www.dunnedwards.com),
    - a. Local representative Wanda Barragan (909) 261-1289.
  3. Sherwin-Williams Company: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
    - a. Local representative John Dumesnil (619) 665-9341.
  4. Vista Paint; [www.vistapaint.com](http://www.vistapaint.com) .
    - a. Local representative Mark Brower (323) 397-9000.
- C. Transparent Finishes:
1. Behr Process Corporation: [www.behr.com/#sle](http://www.behr.com/#sle).
  2. PPG Paints Deft Interior Clears/Polyurethanes: [www.ppgpaints.com/#sle](http://www.ppgpaints.com/#sle).
  3. Sherwin-Williams Company: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
- D. Stains:
1. Behr Process Corporation: [www.behr.com/#sle](http://www.behr.com/#sle).
  2. PPG Paints Deft Interior Stains: [www.ppgpaints.com/#sle](http://www.ppgpaints.com/#sle).
  3. Sherwin-Williams Company: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
- E. Primer Sealers: Same manufacturer as top coats.
- F. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## **2.02 PAINTS AND FINISHES - GENERAL**

- A. Paints and Finishes: Ready mixed, unless intended to be a field-catalyzed paint.
1. Provide paints and finishes of a soft paste consistency, capable of being readily and uniformly dispersed to a homogeneous coating, with good flow and brushing properties, and capable of drying or curing free of streaks or sags.
  2. Provide materials that are compatible with one another and the substrates indicated under conditions of service and application, as demonstrated by manufacturer based on testing and field experience.
  3. For opaque finishes, tint each coat including primer coat and intermediate coats, one-half shade lighter than succeeding coat, with final finish coat as base color.
  4. Supply each paint material in quantity required to complete entire project's work from a single production run.
  5. Do not reduce, thin, or dilute paint or finishes or add materials unless such procedure is specifically described in manufacturer's product instructions.
- B. Volatile Organic Compound (VOC) Content: Comply with Section 01 61 16.

1. Regulatory Requirements: Conform to California Air Resources Board (CARB), and South Coast Air Quality Management District (SCAQMD) and other applicable local air quality regulations for products and application.
- C. Flammability: Comply with applicable code for surface burning characteristics.
- D. Sheens: Provide the sheens specified; where sheen is not specified, sheen will be selected later by Architect from the manufacturer's full line.
- E. Colors: As indicated on drawings.
  1. Extend colors to surface edges; colors may change at any edge as directed by Architect.
  2. In finished areas, finish pipes, ducts, conduit, and equipment the same color as the wall/ceiling they are mounted on/under.

### 2.03 PAINT SYSTEMS - INTERIOR

- A. Paint I-OP - Interior Surfaces to be Painted, Unless Otherwise Indicated: Including gypsum board and shop primed steel.
  1. Two top coats and one coat primer.
  2. Top Coat(s): Interior Latex.
    - a. Products:
      - 1) Behr Marquee Interior Eggshell Enamel [No.2450]. (MPI #52)
      - 2) Dunn-Edwards Suprema, Interior Eggshell Paint, SPMA30. (MPI #52)
      - 3) Sherwin-Williams Harmony Interior Acrylic Latex, Eg-Shel. (MPI #44)
      - 4) Vista Paint Vista Carefree, Carefree Eggshell Finish, 8300. (MPI #52)
      - 5) Substitutions: Section 01 63 00 - Product Substitution Procedures.
  3. Top Coat Sheen:
    - a. Eggshell: MPI gloss level 3; use this sheen at all locations.
  4. Primer: As recommended by top coat manufacturer for specific substrate.
- B. Paint I-OP-MD-DT - Medium Duty Door/Trim: For surfaces subject to frequent contact by occupants, including metals:
  1. Medium duty applications include doors and door frames.
  2. Two top coats and one coat primer.
  3. Top Coat(s): Interior Light Industrial Coating, Water Based; MPI #151, 153 or 154.
    - a. Products:
      - 1) Behr Interior/Exterior Direct-To-Metal Paint Semi-Gloss, 3200. (MPI #153)
      - 2) Dunn-Edwards Evershield Exterior/Interior Semi-Gloss, EVSH50-2. (MPI #153)
      - 3) Sherwin-Williams Pro Industrial Acrylic Coating, Semi-Gloss. (MPI #153)
      - 4) Vista Paint Vista Carefree Carefree Semi Gloss Finish, 8400. (MPI #153)
      - 5) Substitutions: Section 01 63 00 - Product Substitution Procedures.
- C. Paint I-OP-MD-WC - Medium Duty Vertical and Overhead: Including gypsum board, concrete, uncoated steel, shop primed steel, galvanized steel, and aluminum.
  1. Two top coats and one coat primer.
  2. Top Coat(s): Interior Light Industrial Coating, Water Based; MPI #151, 153, or 154.
    - a. Products:

- 1) Behr Premium Interior/Exterior Direct-To-Metal Semi-Gloss [No. 3200]. (MPI #153)
  - 2) Sherwin-Williams Pro Industrial Acrylic Coating, Semi-Gloss. (MPI #153)
- D. Paint I-OP-DF - Dry Fall: Metals; exposed structure and overhead-mounted services in utilitarian spaces, including shop primed steel deck, structural steel, metal fabrications, galvanized ducts, galvanized conduit, and galvanized piping.
1. Shop primer by others.
  2. One top coat.
  3. Top Coat: Latex Dry Fall.
    - a. Products:
      - 1) Behr Pro Dryfall, Flat, PR890, MPI #118.
      - 2) Dunn-Edwards, Aquafall, Flat, W6079, MPI #118.
      - 3) Dunn-Edwards, Aquafall, Low Sheen (Gloss Level 3), W6078.
      - 4) Sherwin-Williams Waterborne Acrylic Dryfall, Flat. (MPI #118)
      - 5) Vista Paint, W/B Dry Fall - Flat, DF12, MPI #118.
      - 6) Substitutions: Section 01 63 00 - Product Substitution Procedures.
- E. Paint MI-OP-3L - Ferrous Metals, Unprimed, Latex, 3 Coat:
1. One coat of latex primer.
- F. Paint MI-OP-2L - Ferrous Metals, Primed, Latex, 2 Coat:
1. Touch-up with latex primer.
- G. Paint Mgl-OP-3L - Galvanized Metals, Latex, 3 Coat:
1. One coat galvanize primer.
- H. Paint Mal-OP-3L - Aluminum, Unprimed, Latex, 3 Coat:
1. One coat etching primer.
- I. Paint GI-OP-3A - Gypsum Board/Plaster, Alkyd, 3 Coat:
1. One coat of alkyd primer sealer.
  2. Semi-gloss: Two coats of alkyd enamel; Behr Paint, 3900 Series Interior/Exterior Alkyd Semi-Gloss Enamel.
- J. Paint GI-OP-3LA-VOC - Gypsum Board/Plaster, Latex-Acrylic, 3 Coat, Zero VOC:
1. One coat of latex-acrylic primer sealer.
  2. Semi-gloss: Two coats of latex-acrylic; Behr Paint, 3000 Series Premium Plus Zero VOC Interior Semi-Gloss.
- K. Paint GI-OP-3LA-LV - Gypsum Board/Plaster, Latex-Acrylic, 3 Coat, Low VOC:
1. One coat of latex-acrylic primer sealer.
  2. Gloss: Two coats of latex-acrylic enamel; Behr Paint, 2-8000 Series Premium Plus Interior/Exterior High Gloss Enamel.
- L. Paint GI-OP-3LA - Gypsum Board/Plaster, Latex-Acrylic, 3 Coat:
1. One coat of alkyd primer sealer.
  2. Flat (ceilings): Two coats of latex enamel-acrylic; Behr Paint, 558 Interior Ceiling Flat.

## **2.04 ACCESSORY MATERIALS**

- A. Accessory Materials: Provide primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials as required for final completion of painted surfaces.
- B. Patching Material: Latex filler.
- C. Fastener Head Cover Material: Latex filler.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Do not begin application of paints and finishes until substrates have been properly prepared.
- B. Verify that surfaces are ready to receive work as instructed by the product manufacturer.
- C. Examine surfaces scheduled to be finished prior to commencement of work. Report any condition that may potentially effect proper application.
- D. Test shop-applied primer for compatibility with subsequent cover materials.
- E. Measure moisture content of surfaces using an electronic moisture meter. Do not apply finishes unless moisture content of surfaces are below the following maximums:
  - 1. Gypsum Wallboard: 12 percent.
  - 2. Masonry, Concrete, and Concrete Masonry Units: 12 percent.
  - 3. Interior Wood: 15 percent, measured in accordance with ASTM D4442.

### **3.02 PREPARATION**

- A. Clean surfaces thoroughly and correct defects prior to application.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Remove or mask surface appurtenances, including electrical plates, hardware, light fixture trim, escutcheons, and fittings, prior to preparing surfaces or finishing.
- D. Seal surfaces that might cause bleed through or staining of topcoat.
- E. Concrete:
- F. Gypsum Board: Fill minor defects with filler compound. Spot prime defects after repair.
- G. Aluminum: Remove surface contamination and oils and wash with solvent according to SSPC-SP 1.
- H. Galvanized Surfaces:
- I. Ferrous Metal:
  - 1. Solvent clean according to SSPC-SP 1.
  - 2. Shop-Primed Surfaces: Sand and scrape to remove loose primer and rust. Feather edges to make touch-up patches inconspicuous. Clean surfaces with solvent. Prime bare steel surfaces. Re-prime entire shop-primed item.
  - 3. Remove rust, loose mill scale, and other foreign substances using using methods recommended in writing by paint manufacturer and blast cleaning according to SSPC-SP 6 "Commercial Blast Cleaning". Protect from corrosion until coated.

- J. Wood Surfaces to Receive Opaque Finish: Wipe off dust and grit prior to priming. Seal knots, pitch streaks, and sappy sections with sealer. Fill nail holes and cracks after primer has dried; sand between coats. Back prime concealed surfaces before installation.
- K. Wood Doors to be Field-Finished: Seal wood door top and bottom edge surfaces with tinted primer.
- L. Metal Doors to be Painted: Prime metal door top and bottom edge surfaces.

### **3.03 APPLICATION**

- A. Remove unfinished louvers, grilles, covers, and access panels on mechanical and electrical components and paint separately.
- B. Apply products in accordance with manufacturer's written instructions.
- C. Do not apply finishes to surfaces that are not dry. Allow applied coats to dry before next coat is applied.
- D. Apply each coat to uniform appearance in thicknesses specified by manufacturer.
- E. Sand wood and metal surfaces lightly between coats to achieve required finish.
- F. Vacuum clean surfaces of loose particles. Use tack cloth to remove dust and particles just prior to applying next coat.
- G. Reinstall electrical cover plates, hardware, light fixture trim, escutcheons, and fittings removed prior to finishing.

### **3.04 FIELD QUALITY CONTROL**

- A. See Section 01 45 00 - Quality Control, for general requirements for field inspection.

### **3.05 CLEANING**

- A. Collect waste material that could constitute a fire hazard, place in closed metal containers, and remove daily from site.

### **3.06 PROTECTION**

- A. Protect finishes until completion of project.
- B. Touch-up damaged finishes after Substantial Completion.

## **END OF SECTION**

**SECTION 10 14 00**  
**SIGNAGE**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Room and door signs.
- B. Interior directional and informational signs.
- C. Emergency evacuation maps.

**1.02 RELATED REQUIREMENTS**

- A. Division 26 - Electrical: Exit signs required by code.

**1.03 REFERENCE STANDARDS**

- A. 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines; current edition.
- B. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- C. ASTM D1187/D1187M - Standard Specification for Asphalt-Base Emulsions for Use as Protective Coatings for Metal; 1997 (Reapproved 2018).

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Manufacturer's printed product literature for each type of sign, indicating sign styles, font, foreground and background colors, locations, overall dimensions of each sign.
- C. Signage Schedule: Provide information sufficient to completely define each sign for fabrication, including room number, room name, other text to be applied, sign and letter sizes, fonts, and colors.
  - 1. When room numbers to appear on signs differ from those on drawings, include the drawing room number on schedule.
  - 2. When content of signs is indicated to be determined later, request such information from District through Architect at least 2 months prior to start of fabrication; upon request, submit preliminary schedule.
  - 3. Submit for approval by District through Architect prior to fabrication.
- D. Samples: Submit two samples of each type of sign, of size similar to that required for project, illustrating sign style, font, and method of attachment.
- E. Selection Samples: Where colors are not specified, submit two sets of color selection charts or chips.
- F. Verification Samples: Submit samples showing colors specified.
- G. Manufacturer's Installation Instructions: Include installation templates and attachment devices.
- H. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.



### **1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years of documented experience.

### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Package signs as required to prevent damage before installation.
- B. Package room and door signs in sequential order of installation, labeled by floor or building.
- C. Store tape adhesive at normal room temperature.

### **1.07 FIELD CONDITIONS**

- A. Do not install tape adhesive when ambient temperature is lower than recommended by manufacturer.
- B. Maintain this minimum temperature during and after installation of signs.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Flat Signs:
  - 1. ASI Sign Systems, Inc.: [www.asisignage.com](http://www.asisignage.com).
  - 2. Best Sign Systems, Inc: [www.bestsigns.com](http://www.bestsigns.com).
  - 3. Cosco Industries (ADA signs): [www.coscoarchitecturalsigns.com/#sle](http://www.coscoarchitecturalsigns.com/#sle).
  - 4. Cosco Industries (non-ADA signs): [www.coscoarchitecturalsigns.com/#sle](http://www.coscoarchitecturalsigns.com/#sle).
  - 5. FASTSIGNS: [www.fastsigns.com/#sle](http://www.fastsigns.com/#sle).
  - 6. Inpro: [www.inprocorp.com/#sle](http://www.inprocorp.com/#sle).
  - 7. Mohawk Sign Systems, Inc: [www.mohawksign.com](http://www.mohawksign.com).
  - 8. Quiel Signs: [www.quielsigns.com](http://www.quielsigns.com)
  - 9. Seton Identification Products: [www.seton.com/aec](http://www.seton.com/aec).
  - 10. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Dimensional Letter Signs:
  - 1. ASI Sign Systems, Inc.: [www.asisignage.com](http://www.asisignage.com).
  - 2. Cosco Industries; Cast Aluminum: [www.coscoarchitecturalsigns.com/#sle](http://www.coscoarchitecturalsigns.com/#sle).
  - 3. FASTSIGNS: [www.fastsigns.com/#sle](http://www.fastsigns.com/#sle).
  - 4. Inpro: [www.inprocorp.com/#sle](http://www.inprocorp.com/#sle).
  - 5. Metallic Arts: [www.metallicarts.com](http://www.metallicarts.com)
  - 6. A.R.K. Ramos Signage Systems: [www.arkramos.com](http://www.arkramos.com)
  - 7. Seton Identification Products: [www.seton.com/aec](http://www.seton.com/aec).
  - 8. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

## 2.02 SIGNAGE APPLICATIONS

- A. Accessibility Compliance: Signs are required to comply with ADA Standards and ICC A117.1 and applicable building codes, unless otherwise indicated; in the event of conflicting requirements, comply with the most comprehensive and specific requirements.
1. Requirements for Persons with Disabilities: Provide identifying devices meeting the requirements for the physically disabled of the following codes:
    - a. California Building Code (CBC) Title 24, Part 2; Chapter 11B, Accessibility.
    - b. Code of Federal Regulations 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities.
  2. Raised characters shall comply with CBC 11B-703.2.
    - a. Depth: It shall be 1/32 inch minimum above their background and shall be sans serif uppercase and be duplicated in Braille.
    - b. Height: It shall be 5/8 inch minimum and 2 inches maximum based on the height of the uppercase letter "I". CBC Section 11B-703.2.5
    - c. Finish and contrast: Characters and their background shall have a non-glare finish. Character shall contrast with their background with either light characters on a dark background or dark characters on a light background. CBC Section 11B-703.5.1
    - d. Proportions: It shall be selected from fonts where the width of the uppercase letter "O" is 60 % minimum and 110 % maximum of the height of the uppercase letter "I". Stroke thickness of the uppercase letter "I" shall be 15% maximum of the height of the character. CBC Sections 11B-703.2.4 and 11B-703.2.6.
    - e. Character Spacing: Spacing between individual tactile characters shall comply with CBC Section 11B-703.2.7 and 11B-703.2.8.
    - f. Format: Text shall be in a horizontal format. CBC 11B-703.2.9.
    - g. Braille: It shall be contracted (Grade 2) and shall comply with CBC Sections 11B-703.3 and 11B-703.4. Braille dots shall have a domed and rounded shape and shall comply with CBC Table and Figure 11B-703.3.1.
    - h. Mounting height: Tactile sign on signs shall be located 48 inches minimum to the baseline of the lowest Braille cells and 60 inches maximum to the baseline of the highest line of raised characters above the finish floor or ground surface. CBC Section and Figure 11B-703.4.1.
    - i. Mounting location: A tactile sign shall be located per CBC Section and Figure 11B-703.4.2 as follows:
      - 1) alongside a single door on the latch side.
      - 2) on the inactive leaf of a double door with one active leaf.
      - 3) to the right of the right hand door at double doors with two active leaves.
      - 4) on the nearest adjacent wall where there is no wall space at the latch side of a single door or at the right side of double doors with two active leaves.
      - 5) so that a clear floor space of 18 x 18 inch minimum, centered on the tactile characters, is beyond the arc of any door swing between the closed position and 45 degree open position.
    - j. Visual characters shall comply with CBC Section 11B-703.5 and shall be 40 inches minimum above finish floor or ground.
    - k. Pictograms shall comply with CBC Section 11B-703.6.

- l. Symbol of accessibility shall comply with CBC Section 11B-703. 7.
  - m. Variable message signs shall comply with CBC Section 11B-703.8.
- B. Room and Door Signs: Provide a sign for every doorway, whether it has a door or not, not including corridors, lobbies, and similar open areas.
  - 1. Sign Type: Flat signs with injection molded or etched panel media as specified.
  - 2. Provide "tactile" signage, with letters raised minimum 1/32 inch and Grade II braille.
  - 3. Character Height: 1 inch.
  - 4. Sign Height: 3 inches, unless otherwise indicated.
  - 5. Office Doors: Identify with room numbers to be determined later, not the numbers indicated on drawings; in addition, provide "window" section for replaceable occupant name.
  - 6. Conference and Meeting Rooms: Identify with room numbers to be determined later, not the numbers indicated on drawings; in addition, provide "window" section with sliding "In Use/Vacant" indicator.
  - 7. Service Rooms: Identify with room names and numbers to be determined later, not those indicated on drawings.
  - 8. Rest Rooms: Identify with pictograms, the names "MEN" and "WOMEN", room numbers to be determined later, and braille.
    - a. Identify all single user toilet facilities as gender neutral facilities by a door symbol that complies with CBC Sections 11B-216.8 and 11B-703.2.6.3.
      - 1) No pictogram, text, or braille is required.
      - 2) If tactile jamb signage is provided, signage shall comply with appropriate technical requirements of CBC Section 11B-703.
        - (a) Examples of appropriate designations are "ALL-GENDER RESTROOM", "RESTROOM", or "UNISEX RESTROOM". DSA BU-17.
        - (b) Provide "RESTROOM" as the signage text, unless indicated otherwise on Drawings.
      - 3) See Drawings for actual sign to be provided.
    - b. Geometric Symbols: The symbol color shall contrast with door or wall.
      - 1) Comply with CBC 11B-216.8.1 at the entrances to toilet and bathing rooms.
      - 2) Comply with CBC 11B-703.7.2.6.
        - (a) Men's: An equilateral triangle, ¼ inch thick edges with edges 12 inches long and a vertex pointing upward.
        - (b) Women's: A circle, ¼ inch thick and 12 inches in diameter.
        - (c) Unisex: A circle, ¼ inch thick and 12 inches in diameter with a equilateral triangle, ¼ inch thick edges with edges 12 inches long and a vertex pointing upward, superimposed on and geometrically inscribed within the circle and within the 12 inch diameter. The vertex of the triangle shall be located ¼ inch from the edge of the circle. The triangle shall contrast with the circle symbol, either light on a dark background or dark on a light background. The circle symbol shall contrast with the door.
        - (d) Mount within 1 inch of the centerline of the door at minimum 58 inches and 60 inches maximum from the centerline of the symbol to the finished floor surface.

9. Exits: Provide raised character and Braille exit signs per CBC Section 1013.4 at the following locations:

| <u>Location</u>             | <u>Text</u> |
|-----------------------------|-------------|
| Grade level exit door       | EXIT        |
| Exit door to exit enclosure | EXIT ROUTE  |
| Exit door to exit hallway   | EXIT ROUTE  |

- C. Interior Directional and Informational Signs:
1. Sign Type: Same as room and door signs.
  2. Sizes: As indicated on drawings.
  3. Wording of signs is scheduled on drawings.
- D. Emergency Evacuation Maps:
1. Allow for one map per building.
  2. Map content to be provided by District.
  3. Use clear plastic panel silk-screened on reverse, in brushed aluminum frame, screw-mounted.
- E. Other Dimensional Letter Signs: Wall-mounted.
1. Exterior quantities, wording, and custom logo shapes, as indicated on Drawings.

### **2.03 SIGN TYPES**

- A. Flat Signs: Signage media without frame.
1. Edges: Square.
  2. Corners: Square.
  3. Clear Cover: For customer produced sign media, provide clear cover of polycarbonate plastic, glossy on back, non-glare on front.
  4. Wall Mounting of One-Sided Signs: Tape adhesive.
    - a. Provide visually matching back plate when mounted on a glass surface.
- B. Color and Font: Unless otherwise indicated:
1. Character Font: Helvetica, Arial, or other sans serif font.
  2. Character Case: Upper case only.
  3. Background Color: As scheduled.
  4. Character Color: Contrasting color.

### **2.04 TACTILE SIGNAGE MEDIA**

- A. Engraved Panels: Laminated colored plastic; engraved or photopolymer etched through face to expose core as background color:
1. Interior Basis of Design Product: InTouch™ ADA-Ready™ Sign System with requirements indicated for materials, thickness, finish colors, designs, shapes, sizes and details as manufactured by ASI Sign Systems, Inc., or approved equal.
  2. Total Thickness: 1/8 inch, matte finished acrylic.

3. Fabrication:
  - a. Tactile Graphics and Text:
    - 1) Fabrication process: Provide tactile copy and grade 2 Braille raised 1/32 inch minimum from plaque first surface by manufacturer's photopolymer bonded process. Sign face of single material, tactile characters and Braille integral to photopolymer. Adhesive-fixed characters are not acceptable.
    - 2) Provide lettering and graphics precisely formed, uniformly opaque to comply with relevant ADA regulations and requirements indicated for size, style, spacing, content, position, and colors. Tactile characters to be raised min. 1/32 inch from surface. Computerized translation of sign copy to be responsibility of the manufacturer.
  - b. Letter style[s], color[s], letter size[s] and layout position:
    - 1) As selected by Architect from manufacturer's standard letter style and color charts.
  - c. Text Schedule: As indicated on Drawings.
  - d. Tactile Lettering and Graphics Color Options: As selected by Architect from manufacturer's standard colors.
  - e. Mounting Panel Options:
    - 1) Size:
      - (a) Same size.
  - f. Background Appearance Options:
    - 1) Solid color[s]: As selected by Architect from manufacturer's standard colors.
    - 2) Subsurface custom graphics.
  - g. Overall panel size: As indicated on Drawings.
  - h. Shape: As indicated on Drawings.
- B. Etched Metal Panels: Zinc based panel etched through face to expose core as background color:
  1. Exterior Basis of Design Product: SignEtch™ ADA-Ready™ Sign System with requirements indicated for materials, thickness, finish colors, designs, shapes, sizes and details as manufactured by ASI Sign Systems, Inc., or approved equal.
  2. Total Thickness: 1/8 inch.
  3. Paint: Primer and urethane based color coat, of type standard with manufacturer.
    - a. U.V. resistant clear urethane top coat required for exterior applications.
  4. Fabrication:
    - a. Tactile Graphics and Text:
      - 1) Fabrication process: Provide tactile copy and grade 2 Braille raised 1/32 inch minimum from plaque first surface by manufacturer's photochemical etching.
      - 2) Provide lettering and graphics precisely formed, uniformly opaque to comply with relevant ADA regulations and requirements indicated for size, style, spacing, content, position, and colors.
    - b. Letter style[s], color[s], letter size[s] and layout position:
      - 1) As selected by Architect from manufacturer's standard letter style and color charts.

- c. Raised text and graphic finishes:
  - 1) Colors/Sheen:
    - (a) As selected by Architect from manufacturer's standard colors.
    - (b) Finish: Matte.
- d. Text Schedule: As indicated on Drawings.
- e. Edge Detail: Square.
- f. Edge Finish: Brushed.
- g. Overall panel size: As indicated on Drawings.
- h. Recessed Graphics Color Options:
  - 1) As selected by Architect from manufacturer's standard colors.
- i. Recessed Area Texture Options:
  - 1) Smooth paint.

## **2.05 NON-TACTILE SIGNAGE MEDIA**

- A. Silk Screened Plastic Panels: Letters and graphics silk screened onto reverse side of plastic surface:
  - 1. Sign Color: Clear.
  - 2. Total Thickness: 1/8 inch.

## **2.06 DIMENSIONAL LETTERS**

- A. Fabricated Letters:
  - 1. Height: As indicated on Drawings.
  - 2. Depth: As indicated on Drawings.
  - 3. Letter style: As indicated on Drawings.
- B. Metal Letters:
  - 1. Metal: Stainless steel sheet, formed.
  - 2. Metal Thickness: 1/8 inch minimum.
  - 3. Text and Typeface:
    - a. Character Font: Helvetica, Arial, or other sans serif font.
    - b. Character Case: Upper case only.
    - c. Finish: Brushed, satin.
    - d. Color: To be selected by Architect from full range.
  - 4. Overcoat: Manufacturer's standard baked-on clear coating.
  - 5. Mounting: Projecting Stud Mount.

## **2.07 ACCESSORIES**

- A. Concealed Screws: Stainless steel, galvanized steel, chrome plated, or other non-corroding metal.
- B. Concealed Studs: Concealed (blind), threaded studs welded or brazed to back of sign material, screwed into back of sign assembly, or screwed into tapped lugs cast integrally into back of cast sign material.

- C. Projecting Studs: Threaded studs with sleeve spacer, welded or brazed to back of sign material, screwed into back of sign assembly, or screwed into tapped lugs cast integrally into back of cast sign material.
- D. Through Fasteners: Exposed metal fasteners matching sign finish, with type of head indicated, installed in predrilled holes.
- E. Exposed Screws: Stainless steel.
  - 1. Exposed fasteners are permitted only where specifically indicated, and shall be tamper proof stainless steel, countersunk, and may be painted or finished to match adjacent surfaces.
- F. Tape Adhesive: Double sided tape, permanent adhesive.
- G. Adhesives:
  - 1. Type recommended by the manufacturer of the material specified to be laminated or adhered.
  - 2. No adhesives that fade, discolor or delaminate as a result of proximity to sunlight or heat therefrom shall be used.
  - 3. Adhesives shall not change the color or otherwise deteriorate the materials to which they are to be applied.
  - 4. The adhesives shall be of non-staining, non-yellowing quality.
- H. Bituminous Paint: Cold-applied asphalt emulsion complying with ASTM D1187/D1187M.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that substrate surfaces are ready to receive work.
- B. Do not start work until deficiencies have been corrected. Start of work of this section constitutes acceptance of the surfaces.

### **3.02 INSTALLATION**

- A. Install in accordance with manufacturer's instructions.
- B. Mounting Method:
  - 1. Mount signs to surfaces with a minimum of four countersunk tamperproof stainless steel fasteners.
  - 2. Provide anchorage where necessary for fastening signs securely in place.
    - a. Anchorage not otherwise specified or indicated shall include expansion shields and power-driven fasteners;
      - 1) when approved:
        - (a) for concrete and masonry;
        - (b) toggle or molly bolts to plaster surfaces;
        - (c) full threaded wood screws to wood doors;
        - (d) machine or metal screws to metal doors.
      - b. Provide backing plates for mounting to expanded metal substrates.
  - 3. Adhere signs to glass with adhesive.

- C. Install neatly, with horizontal edges level.
- D. Locate signs and mount at heights indicated on drawings and in accordance with ADA Standards and CBC 11B.
  - 1. Room and Door Signs: Locate on wall at latch side of door a minimum of 48 inches to the baseline of the lowest braille cells; with top of highest line of raised character text at 60 inches above finished floor.
    - a. Comply with CBC 11B-703.4.1
- E. Protect from damage until Substantial Completion; repair or replace damaged items.

### **3.03 ADJUST AND CLEAN**

- A. Repair damage to signs incurred during installation. Replace signs which cannot be repaired to new condition. Clean glass, frames, and other sign surfaces, adjust hardware for proper operation.

**END OF SECTION**





**SECTION 10 14 53**  
**TRAFFIC AND PARKING SIGNAGE**

**PART 1 - GENERAL**

**1.01 SECTION INCLUDES**

- A. Traffic and parking control, plaque, and informational signage.
- B. Sign supports and foundations.

**1.02 RELATED SECTIONS**

- A. Section 10 14 00 - Signage: Informational signage in addition to on-site signage specified in this section.
- B. Section 32 17 23.13 - Pavement Marking: Painted accessibility marking.

**1.03 REFERENCE STANDARDS**

- A. 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines; current edition.
- B. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- C. ASTM C94/C94M - Standard Specification for Ready-Mixed Concrete; 2018.
- D. FED-STD-595C - Colors Used in Government Procurement (Fan Deck); 2008 (Chg Notice 1).

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Manufacturer's printed product literature for each type of sign, indicating sign styles, font, foreground and background colors, locations, overall dimensions of each sign.
- C. Signage Schedule: Provide information sufficient to completely define each sign for fabrication, including location, other text to be applied, sign and letter sizes, fonts, and colors.
  - 1. When content of signs is indicated to be determined later, request such information from District through Architect at least 2 months prior to start of fabrication; upon request, submit preliminary schedule.
  - 2. Submit for approval by District through Architect prior to fabrication.

**1.05 QUALITY ASSURANCE**

- A. Regulatory Requirements: Comply with applicable Codes and regulations of authorities having jurisdiction for accessible parking stall identification, including the following:
  - 1. California Code of Regulations (CCR), Title 24, Parts 2, 3 and 5.
  - 2. California Building Code (CBC) Section 11B-502.6, including amendments and supplements as adopted by Authority Having Jurisdiction (AHJ) as shown on Drawings.
  - 3. Manual on Uniform Traffic Control Devices as adopted by the State Department of Transportation.
    - a. Reflectively requirements

## **PART 2 - PRODUCTS**

### **2.01 TRAFFIC AND PARKING CONTROL SIGNAGE**

- A. Manufacturers:
1. Hawkins Traffic Safety Supply, Inc.: [www.hawkinstraffic.com](http://www.hawkinstraffic.com).
  2. Safeway Sign Company: [www.safewaysign.com](http://www.safewaysign.com).
  3. Western Highway Products, Inc.: [www.westernhighway.com](http://www.westernhighway.com).
- B. Plaque Signs: Provide manufacturer's standard silk-screened signs, baked-on enamel applied over Diamond Grade (DG), (10-year projected life) retro-reflectorized backing; on aluminum or 16 gage galvanized steel sheet. Provide with anti-graffiti protective overlay film. Produce smooth, even, level sign surfaces, constructed to remain flat under installed condition within a tolerance of plus or minus 1/16-inch measured diagonally. Provide two holes for post mounting.
1. Traffic Entry Warning Signs: Sign text, traffic and regular parking control shall comply with requirements of California Code of Regulations (CCR) Title 24, Part 2, Section 11B-502.6 and regulations of local governing authorities.
    - a. Single post mount, not less than 17 x 22 inches with white reflectorized copy on blue background conforming to No. 15090, FED-STD-595C, one inch high letters shall read: "Unauthorized vehicles parked in designated accessible spaces not displaying distinguishing placards or special license plates issued for persons with disabilities will be towed away at the Owner's expense. Towed vehicles may be reclaimed at Campus Police or by telephoning 310.900.1600, ext. 2999."
      - 1) Contractor shall verify the phone numbers or obtain the above missing information from District for permanent inclusion in sign copy, prior to fabrication of the signs.
    - b. Position sign in a conspicuous location immediately adjacent to each entrance to off-street parking facility or immediately adjacent to and visible from each stall or space.
    - c. Sign shall be mounted 60 inches from bottom of sign to the adjacent finish grade when mounted on walls or fence; or 80 inches to pedestrian way or sidewalk or as shown on the drawings.
  2. Parking Stall Signs: Sign text, accessible parking control shall comply with requirements of State of California Code of Regulations (CCR) - Title 24, Part 2, Section 11B-502.6 in addition to requirements of State of California, Department of Transportation (CALTRANS) and regulations of local authorities having jurisdiction.
    - a. Single post mount, not less than 70 square inches with white reflectorized copy on blue background conforming to No. 15090, FED-STD-595C. Sign shall display a profile view of a wheelchair with occupant in white on blue background.
      - 1) Provide an additional sign below the accessible sign with the text "Minimum Fine \$250".
    - b. Position one sign at the end of each parking space designated for disabled usage.

- c. One in every six spaces (CBC 11B-208.2.4), but not less than one, provide a 12 inch by 3-1/4 inch "Van Accessible" sign below the symbol of accessibility, wording per CBC 11B-502.6, 36 CFR 1191, and ADA Standards.
  - d. Sign shall be mounted 80 inches from bottom of sign to finish grade of parking space or centered on wall at interior end of parking space at a minimum height of 60 inches above the parking space, finished grade, ground or sidewalk, to the bottom of the sign.
3. Fire Lane Signs:
- a. Single post mount, of size, color and sign text as shown on site plan or as required by local codes and fire department authority.
  - b. Quantity, location and mounting heights to be determined by local fire department authority.

## **2.02 ACCESSORIES AND FASTENERS**

- A. Accessories: Provide welded galvanized steel fittings and galvanized or cadmium-plated steel bolts, nuts and washers.
- B. Fasteners: Provide tamper-proof galvanized steel fasteners, Tufnut System (714) 962-5838, Allegheny Bolt (Tampruf brand; (516) 568-1052 or equal.

## **2.03 SIGN SUPPORTS AND FOUNDATION**

- A. Support Posts: Galvanized steel pipe, minimum 2-1/2 inch diameter or as indicated, with caps.
- B. Concrete: Ready-mixed, complying with ASTM C94/C94M; normal Portland cement; 2,500 psi strength at 28 days, 3 inch slump; 3/4 inch nominal size aggregate.
- C. Provide other materials as necessary for complete installation, as recommended by manufacturer and selected by Contractor, subject to approval of Architect.

## **2.04 FABRICATION**

- A. Provide signs and supports factory-prefabricated and pre-finished, ready for assembly and installation.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that surfaces are ready to receive work.
- B. Beginning of installation means installer accepts existing surfaces.

### **3.02 INSTALLATION**

- A. Locate accessible car and van parking stall and drive approach signs where shown on Drawings and as required by applicable ordinances and regulations of authorities having jurisdiction. Verify and coordinate sign locations to prevent conflict with underground utilities.
- B. Locate informational signage as verified in field by District. Verify and coordinate sign locations to prevent conflict with underground utilities.

- C. Excavate for sign support footings to depth as shown on Drawings or, if not shown, as recommended by manufacturer. Provide forms for concrete not supported by compacted soil.
- D. Set posts in concrete base, minimum 12 inch diameter and 18 inches deep.
  - 1. Signs set in asphaltic paving surfaces or concrete sidewalks shall be mounted in core drilled holes minimum 8 inch diameter, 18 inches deep with top of base flush to finish.
  - 2. Signs mounted to walls shall be attached firmly with appropriate expansion anchors or bolting, adhesive not permitted.
  - 3. Seal all holes water tight.
- E. Set sign support post plumb and so sign face will be perpendicular to stall or parallel to curb face, as applicable. Set posts into pipe sleeve inserts set and anchored into concrete. Fill annular space between posts and sleeves with grouting compound.
- F. Install plaque signage to posts, with panel facing traffic as necessary.

**END OF SECTION**

**SECTION 10 21 13.17**  
**PHENOLIC TOILET COMPARTMENTS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Phenolic toilet compartments.
- B. Urinal screens.

**1.02 RELATED REQUIREMENTS**

- A. Section 05 50 00 - Metal Fabrications: Concealed steel support members.
- B. Section 06 10 00 - Rough Carpentry: Blocking and supports.
- C. Section 10 28 00 - Toilet Accessories.
- D. California Building Code (CBC) chapter 11B, disabled accessibility regulations.

**1.03 REFERENCE STANDARDS**

- A. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- B. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2015.
- C. NFPA 286 - Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth; 2015.

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Coordination: Coordinate the work with placement of support framing and anchors in walls and ceilings.

**1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide data on panel construction, hardware, and accessories.
- C. Shop Drawings: Indicate partition plan, elevation views, dimensions, details of wall supports, door swings.
  - 1. Show plan and elevation views for each room. Indicate types and thicknesses of materials and assemblies.
  - 2. Attachment details.
- D. Samples: Submit two samples of partition panels, 2 by 2 inch in size illustrating panel finish, color, and sheen.
- E. Working Mock-up: Submit the following.
  - 1. Submit mock-ups of showing specified hardware types.
  - 2. Submit mock-ups of specified and proposed substitute manufacturers.
- F. Manufacturer's Installation Instructions: Indicate special procedures.

## **1.06 SEQUENCING AND SCHEDULING**

- A. Complete tile and painting Work before toilet partition installations.
- B. Coordinate dimensions and locations of cut-outs and panel reinforcement with approved toilet accessories.
- C. Coordinate backing and blocking provisions in walls.

## **1.07 PROJECT CONDITIONS**

- A. Field Measurements: Verify field design and field dimensions before submitting shop drawings and before fabrication.
- B. Environmental Conditions: Maintain humidity and temperature in ranges required by manufacturer.

## **1.08 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. Correct defective Work within a one year period after Date of Substantial Completion.
- C. Provide ten year manufacturer limited warranty for panels, doors and stiles against breakage, corrosion and delamination.

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. Installation shall meet requirements for the physically disabled of the California Code of Regulations (CCR) Title 24 Part 2 and latest amendments to the ADA Standards.
- B. California Building Code (CBC) disabled accessibility regulations.
  - 1. Wheelchair accessible compartment shall comply with CBC Section 11B-604.8.1.
  - 2. Toe clearance for at least one side partition of a wheelchair accessible compartment shall comply with CBC Section and Figure 11B-604.8.1.4.
    - a. It shall be 9 inches high minimum above the finish floor and 6 inches deep minimum beyond the compartment side face of the partition, exclusive of partition support members.
    - b. It shall be 12 inches high minimum above the finish floor for children's use.
    - c. Partition components at toe clearances shall be smooth without sharp edges or abrasive surfaces.
    - d. Toe clearance is not required in a compartment greater than 66 inches wide.
  - 3. Ambulatory accessible compartments shall be provided where there are six or more toilet compartments, or where the combination of of urinals and water closets totals six or more fixtures.
    - a. Such compartment shall be provided in the same quantity as wheelchair accessible compartments per CBC Section 11B-213.3.1 and shall comply with CBC Section 11B-604.8.2.
  - 4. Door and door hardware for accessible compartments shall be self-closing and shall comply with CBC Section 11B-404 except that if the approach is on the latch side of an

ambulatory compartment door, clearance between the door side of the compartment and any obstruction shall be 44 inches minimum. CBC Figure 11B-604.8.2.

5. A door pull complying with CBC Section 11B-404.2.7 shall be placed on both sides of the accessible compartment door near the latch.
6. Ambulatory Accessible Toilet Compartment doors shall not swing into the clear floor space or clearance required for any fixture or into the minimum required compartment area. CBC 11B-604.8.2.2.

## **2.02 RECYCLE CONTENT**

- A. Credit Summary for cumulative total recycled content requirements. This item may contain post-consumer or post-industrial recycled content.
- B. Recycled materials percentage of pre-consumer and post-consumer recycled content per shall be as noted below:
  1. 20% Post-Industrial or Pre-Consumer, (by rule this is reduced by one-half.)
  2. 10% Post-Consumer,
  3. Total 20% by any combination of the above factors.

## **2.03 MANUFACTURERS**

- A. Basis of Design Product: Sierra Series, 1092G.67P as manufactured by Bobrick Washroom Equipment, or approved equal.

## **2.04 PHENOLIC TOILET COMPARTMENTS**

- A. Toilet Compartments: Factory fabricated doors, pilasters, and divider panels made of solid phenolic core panels with integral melamine finish, or Solid Color Reinforced Composite (SCRC), floor-mounted headrail-braced.
  1. Privacy Style Partitions: No sightlines with gap-free interlocking doors and stiles routed 0.3 inch nominal from the edge to allow for 0.175 inch nominal overlap to prevent line-of-sight into the toilet compartment.
    - a. Privacy strips fastened or adhered onto the partition material are not acceptable.
  2. Floor Clearance: 4 inches, nominal.
  3. Color: As selected by Architect from Manufacturers custom palette.
- B. Doors:
  1. Thickness: 3/4 inch.
  2. Width: 24 inch.
  3. Width for Handicapped Use: 36 inch.
  4. Height: 72 inches.
- C. Panels:
  1. Thickness: 1/2 inch.
  2. Height: 72 inches.
  3. Depth: As indicated on drawings.
- D. Pilasters:



1. Thickness: 3/4 inch.
  2. Width: As required to fit space; minimum 3 inch.
- E. Screens: Without doors; to match compartments; mounted to wall with continuous panel brackets with vertical support post/pilaster to ceiling.
1. Urinal Screens: Wall mounted with continuous panel brackets.
    - a. Thickness: 3/4 inch.
    - b. Post to ceiling support.
    - c. Height: 72 inches.
    - d. Floor Clearance: 4 inches, nominal.
    - e. Depth: 24 inches.

## 2.05 FABRICATION

- A. Reinforce panels indicated to receive toilet paper holders or grab bars for mounting of the items required.

## 2.06 ACCESSORIES

- A. Pilaster Shoes: Formed ASTM A666, Type 304 stainless steel with No. 4 finish, 3 inch high, concealing floor fastenings.
1. Provide adjustment for floor variations with screw jack through steel saddles integral with pilaster.
  2. Provide ceiling attachment using two adjustable hanging studs, attached to above-ceiling framing.
- B. Head Rails: Hollow anodized aluminum, 1 inch by 1-1/2 inch size, with anti-grip profile and cast socket wall brackets.
- C. Wall and Pilaster Brackets: Polished stainless steel; manufacturer's standard type for conditions indicated on drawings.
- D. Attachments, Screws, and Bolts: Stainless steel, tamper proof type.
1. For attaching panels and pilasters to brackets: Through-bolts and nuts; tamper proof.
- E. Hardware: Polished stainless steel:
1. Pivot hinges, gravity type, adjustable for door close positioning; two per door.
    - a. Wrap-around, self-closing type, designed to hold door slightly open to indicate vacant compartment.
      - 1) Cam action hinge assembly.
    - b. Emergency Access: Provide by lifting door.
    - c. Plastic inserts and end caps are not acceptable.
    - d. Provide full length hinges on oversize doors.
  2. Door Latch: Slide type with exterior emergency access feature.
    - a. Configuration: Surface mounted and through bolted to door with one way sex bolts
    - b. Material: Cast stainless steel.
  3. Door strike and keeper with rubber bumper; mounted on pilaster in alignment with door latch.

- a. Configuration: Wrap around flange surface mounted and through bolted to pilaster with one way sex bolts
  - b. Material: Cast stainless steel.
  - c. Strikes: 6 inches long.
  - d. Door bumper to accommodate projection of all door hardware and toilet accessories.
4. Coat hook with rubber bumper; one per compartment, mounted on door.
- a. Mount such that no portion is over 47 inches above finish floor.
  - b. Provide only if not provided under Section 10 28 00 - Toilet Accessories. If not otherwise provided or shown on Drawings, provide one at each toilet stall door.
5. Provide door pull for outswinging doors.
- a. Surface mounted U-shaped or wire pulls on both sides of accessible compartment doors.
  - b. Material: Cast stainless steel.
  - c. Basis of Design Product: Guardian #5403 with 3-1/2 inch centers as manufactured by Alan Lewis Inc., or approved equal.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Prior to application of gypsum board tile backing or other wall finishes, inspect framing at toilet compartments and urinal screens and ensure that necessary and proper backing is provided in wall for anchoring of panels.
- B. Verify that field measurements are as indicated on shop drawings.
- C. Verify correct spacing of and between plumbing fixtures.
- D. Verify correct location of built-in framing, anchorage, and bracing.

### **3.02 INSTALLATION**

- A. Install partitions secure, rigid, plumb, and level in accordance with manufacturer's instructions.
- B. Maintain 3/8 inch to 1/2 inch space between wall and panels and between wall and end pilasters.
- C. Attach panel brackets securely to walls using anchor devices.
  - 1. Use fasteners as shown on reviewed shop drawings.
    - a. Where fasteners to substrate are not indicated, provide fasteners as specified in Section 05 05 19 - Post-Installed Concrete Anchors.
  - 2. Secure divider panels to built-in anchorage devices using concealed fasteners. Level, plumb and tighten installation with devices provided.
  - 3. Anchors to Concrete:
    - a. Use stainless steel expansion anchors, or self-threading concrete anchors.
    - b. Power-driven fasteners or lead expansion shields are not acceptable.
  - 4. Anchors to Plaster or Gypsum Wallboard (with and without tile finish):

- a. Use sheet metal screws to metal framing or backing, wood screws to wood framing or backing.
- b. Molly-type fasteners are not acceptable.
- 5. Panel-to-Wall Installation:
  - a. Provide clearances of not more than 1 inch between panels and walls.
  - b. Secure panels to walls with continuous brackets so that holes for wall anchorage occur in masonry or tile joints.
  - c. Secure panels in position with manufacturer's recommended anchoring devices.
- D. Attach panels and pilasters to brackets. Locate head rail joints at pilaster center lines.
- E. Field touch-up of scratches or damaged finish will not be permitted. Replace damaged or scratched materials with new materials.

### **3.03 TOLERANCES**

- A. Maximum Variation From True Position: 1/4 inch.
- B. Maximum Variation From Plumb: 1/8 inch.

### **3.04 ADJUSTING**

- A. Adjust and align hardware to uniform clearance at vertical edge of doors, not exceeding 3/16 inch.
- B. Adjust hinges to position doors in partial opening position when unlatched. Return out-swinging doors to closed position.
- C. Adjust adjacent components for consistency of line or plane.

### **3.05 CLEANING**

- A. Cleaning After Installation: Clean exposed surfaces of panel systems using materials and methods recommended by manufacturer.
- B. Protection: Provide protection as necessary to prevent damage during remainder of construction period.
- C. Final Cleaning: Clean partitions to dust-free condition prior to Final Acceptance.

**END OF SECTION**

**SECTION 10 28 00**  
**TOILET ACCESSORIES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Commercial toilet accessories.
- B. Electric hand/hair dryers.
- C. Diaper changing stations.
- D. Utility room accessories.
- E. Some items are District Furnished and Contractor Installed (OFCI). Accessories and installation materials are the responsibility of the Contractor.
- F. Some items are District Furnished and District Installed (OFOI). Contractor to coordinate installation with related and adjacent work.

**1.02 RELATED REQUIREMENTS**

- A. Section 05 40 00 - Cold-Formed Metal Framing: Concealed supports, included in wall framing and plates.
- B. Section 09 21 16 - Gypsum Board Assemblies: Concealed supports for accessories, including in wall framing and plates and above ceiling framing.
- C. Section 10 21 13.19 - Plastic Toilet Compartments.

**1.03 REFERENCE STANDARDS**

- A. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- B. ASTM A269/A269M - Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service; 2015a.
- C. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2015.
- D. ASTM B456 - Standard Specification for Electrodeposited Coatings of Copper Plus Nickel Plus Chromium and Nickel Plus Chromium; 2017.
- E. ASTM C1036 - Standard Specification for Flat Glass; 2016.
- F. ASTM C1503 - Standard Specification for Silvered Flat Glass Mirror; 2018.
- G. ASTM F2285 - Standard Consumer Safety Performance Specification for Diaper Changing Tables for Commercial Use; 2004, with Editorial Revision (2016).

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Coordinate the work with the placement of internal wall reinforcement, concealed ceiling supports, and reinforcement of toilet partitions to receive anchor attachments.

**1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.

- B. Product Data: Submit data on accessories describing size, finish, details of function, and attachment methods.
- C. Manufacturer's Installation Instructions: Indicate special procedures and conditions requiring special attention.
- D. Maintenance Materials: Furnish the following for District's use in maintenance of project:
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.
  - 2. Tools: One each of every special tool required for maintenance of fasteners and operable parts.

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. Provide toilet accessories meeting the requirements for the physically disabled of the California Building Code (CBC), Title 24 Part 2, and 2010 ADA Standards, as amended.
- B. Accessible requirements:
  - 1. Elements of sanitary facilities shall be mounted at locations in compliance with CBC Sections 11B-602 through 11B-612.
  - 2. Grab bars in toilet facilities and bathing facilities shall comply with CBC Section 11B-609.
    - a. Grab bars and any wall or other surfaces adjacent to grab bars shall be free of sharp or abrasive elements and shall have rounded edges.
    - b. The space around the grab bars shall be as follows:
      - 1) 1-1/2 inches between the grab bar and the wall. CBC Section 11B-609.3.
      - 2) 1-1/2 inches minimum between the grab bar and projecting objects below and at the ends.
      - 3) 12 inches minimum between the grab bar and projecting objects above.
  - 3. Toilet accessories required to be accessible shall be mounted with any operable part at maximum 40 inches above the finish floor. CBC Section 11B-603.5.
  - 4. The grab bar shall not project more than 3 inches into the 48 inches minimum clear space required required in front of the water closet. CBC 11B-609.3.
  - 5. Toilet tissue dispensers are to be continuous flow type. CBC Section 11B-604.7.
  - 6. Toilet paper and feminine napkin disposals located on the grab bar side of the accessible toilet room or stall shall not project more than the grab bar or 3 inches from the finished wall surface nor be located closer than 1-1/2 inches clear of the tangent point of the grab bar. (Legacy DSA Interpretation.)
    - a. Accessories surface mounted above grab bar will restrict usability.
  - 7. All other accessories shall not project more than 4 inches from wall surface, but cannot encroach into any required clear space.

### **2.02 MANUFACTURERS**

- A. Commercial Toilet, Shower, and Bath Accessories:
  - 1. ASI - American Specialties, Inc: [www.americanspecialties.com](http://www.americanspecialties.com).
  - 2. Bobrick Washroom Equipment, Inc.: [www.bobrick.com](http://www.bobrick.com).

3. Bradley Corporation: [www.bradleycorp.com](http://www.bradleycorp.com).
  4. Gamco: [www.gamcousa.com](http://www.gamcousa.com).
  5. Georgia-Pacific Professional: [www.blue-connect.com](http://www.blue-connect.com).
  6. Substitutions: Section 01 63 00 - Product Substitution Procedures.
- B. Provide products of each category type by single manufacturer.

### **2.03 MATERIALS**

- A. Accessories - General: Shop assembled, free of dents and scratches and packaged complete with anchors and fittings, steel anchor plates, adapters, and anchor components for installation.
1. Grind welded joints smooth.
  2. Fabricate units made of metal sheet of seamless sheets, with flat surfaces.
- B. Stainless Steel Sheet: ASTM A666, Type 304.
- C. Stainless Steel Tubing: ASTM A269/A269M, Grade TP304 or TP316.
- D. Mirror Glass: Annealed float glass, ASTM C1036 Type I, Class 1, Quality Q2, with silvering, protective and physical characteristics complying with ASTM C1503.
- E. Adhesive: Two component epoxy type, waterproof.
- F. Fasteners, Screws, and Bolts: Stainless steel except where fully concealed may be hot dip galvanized; tamper-proof; security type.

### **2.04 FINISHES**

- A. Stainless Steel: Satin finish, unless otherwise noted.
- B. Chrome/Nickel Plating: ASTM B456, SC 2, polished finish, unless otherwise noted.

### **2.05 COMMERCIAL TOILET ACCESSORIES**

- A. Toilet Paper Dispenser: Roll-in-reserve type, designed to allow automatic activation of reserve roll when needed, or manual activation by pressing release bar, semi-recessed, stainless steel unit with pivot hinge.
1. Basis of Design Product: B-3888 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.
- B. Mirrors: Stainless steel framed, 1/4 inch thick annealed float glass; ASTM C1036.
1. Annealed Float Glass: Silvering, protective and physical characteristics in compliance with ASTM C1503.
  2. Size: As indicated on drawings.
  3. Frame: 0.05 inch angle shapes, with mitered and welded and ground corners, and tamperproof hanging system; satin finish.
  4. Backing: Full-mirror sized, minimum 0.03 inch galvanized steel sheet and nonabsorptive filler material.
  5. Basis of Design Product: B-290.1836 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.

- C. Seat Cover Dispenser: Stainless steel, recessed, reloading by concealed opening at base, tumbler lock.
  - 1. Minimum capacity: 250 seat covers.
  - 2. Basis of Design Product: B-3013 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.
- D. Grab Bars: Stainless steel, smooth surface.
  - 1. Standard Duty Grab Bars:
    - a. Push/Pull Point Load: 250 pound-force, minimum.
    - b. Dimensions: 1-1/2 inch outside diameter, minimum 0.05 inch wall thickness, exposed flange mounting, 1-1/2 inch clearance between wall and inside of grab bar.
    - c. Length and Configuration: As indicated on drawings.
      - 1) Minimum Length for Side Wall of Water Closet: 48 inches.
      - 2) Minimum Length for Rear Wall of Water Closet: 42 inches.
    - d. Basis of Design Product: Snap Flange B-6806 Series as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.
- E. Clothes Hook and Bumper: Satin stainless steel clothes hook.
  - 1. Mounting: Concealed wall plate.
  - 2. Basis of Design Product: B-233 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.
- F. Sanitary Napkin Disposal Unit: Stainless steel, surface-mounted, self-closing door, locking bottom panel with full-length stainless steel piano-type hinge, removable receptacle.
  - 1. Basis of Design Product: B-353 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.

**2.06 UNDERLAVATORY GUARD:**

- A. Description: Insulating pipe covering for supply and drain piping assemblies that prevent direct contact with and burns from piping; allow service access without removing coverings.
- B. Material and Finish: Antimicrobial, molded plastic, white.
- C. Manufacturers:
  - 1. Plumberex Specialty Products, Inc.; Pro-Extreme: [www.plumberex.com](http://www.plumberex.com).
  - 2. Bradley Corporation : [www.bradleycorp.com](http://www.bradleycorp.com).
  - 3. IPS Corporation Lav Guard 2 Undersink Pipe Covers: [www.ipscorp.com](http://www.ipscorp.com).
  - 4. IPS Corporation TrueBro Lav Shield: [www.ipscorp.com](http://www.ipscorp.com).
  - 5. Substitutions: See Section 01 60 00 - Product Requirements.

**2.07 ELECTRIC HAND/HAIR DRYERS**

- A. Electric Hand Dryers: fan-in-case type, with downward nozzle.
  - 1. Operation: Automatic, sensor-operated on and off.
  - 2. Style: Contemporary styling, fixed nozzle.
  - 3. Mounting: Surface mounted.

4. Cover: Polycarbonate.
  - a. Color: As selected by Architect.
  - b. Tamper-resistant screw attachment of cover to mounting plate.
5. Air Velocity: 36,900 linear feet per minute, minimum, at full power.
6. Total Wattage: 1400 W, maximum.
7. Runtime: Field adjustable, from approximately 10 seconds to approximately 35 seconds
8. Warranty: 3 years.
9. Electric Hand Dryer Products:
  - a. Basis of Design: Dyson, Inc.; AirBlade V: [www.dyson.com/handdryers](http://www.dyson.com/handdryers).
  - b. Substitutions: Section 01 60 00 - Product Requirements.

## **2.08 DIAPER CHANGING STATIONS**

- A. Diaper Changing Station: Wall-mounted folding diaper changing station for use in commercial toilet facilities, meeting or exceeding ASTM F2285.
  1. Material: Polyethylene.
  2. Mounting: Surface.
  3. Color: As selected.
  4. Minimum Rated Load: 250 pounds.
  5. Product: See schedule on Drawings.

## **2.09 UTILITY ROOM ACCESSORIES**

- A. Mop and Broom Holder: 0.05 inch thick stainless steel, Type 304, hat-shaped channel.
- B. Combination Utility Shelf/Mop and Broom Holder: 0.05 inch thick stainless steel, Type 304, with 1/2 inch returned edges, 0.06 inch steel wall brackets.
  1. Drying rod: Stainless steel, 1/4 inch diameter.
  2. Hooks: Two, 0.06 inch stainless steel rag hooks at shelf front.
  3. Mop/broom holders: Three spring-loaded rubber cam holders at shelf front.
  4. Length: 36 inches.
  5. Basis of Design Product: B-224 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify exact location of accessories for installation.
- C. Before covering wall framing with gypsum board, examine framing to ensure that backing plates and grab bar mounting kits have been installed behind surface mounted accessories in such positions as to receive all attachment screws.



- D. Verify that pipes, vents, conduits and other construction features do not protrude into rough wall opening space required for recessed accessories.
- E. For electrically-operated accessories, verify that electrical power connections are ready and in the correct locations.
- F. Verify that field measurements are as indicated on drawings.
- G. See Section 05 40 00 and 09 21 16 for installation of blocking, reinforcing plates, and concealed anchors in walls and ceilings.

### **3.02 PREPARATION**

- A. Deliver inserts and rough-in frames to site for timely installation.
- B. Provide templates and rough-in measurements as required.

### **3.03 INSTALLATION**

- A. Install accessories in accordance with manufacturers' instructions in locations indicated on drawings.
  - 1. Exception: Install surface mounted accessories other than grab bars with screws, molly or toggle bolts only to studs or through backing plates attached directly to studs.
  - 2. At combination units placed behind a grab bar set the perimeter trim tight against the backing board.
    - a. Face of this unit shall not project beyond the tile or applied finish face. Maintain the required 1-1/2 inch clearance.
    - b. Coordinate surrounding finish trim with bullnose tile, radius, or sloped profile trim.
- B. Install plumb and level, securely and rigidly anchored to substrate.
- C. Mounting Heights: As required by accessibility regulations, unless otherwise indicated.
  - 1. Grab Bars: As indicated on drawings.
    - a. Adult mounting height to be between minimum 33 inches to maximum 36 inches to top tangent point. CBC 11B-609.4 Position of Grab Bars.
  - 2. Mirrors: 40 inch maximum , measured to bottom of mirrored surface.
  - 3. Seat Cover Dispenser:
    - a. Shall not be located closer than 1-1/2 inches clear of the tangent point of the grab bar.
    - b. If surface mounted and located under the grab bar provide a minimum 5 inches clear under unit for refilling.
  - 4. Clothes Bumper/Coat Hook: 40 to 48 inches. CBC 11B-603.4 Coat hooks, shelves and medicine cabinets
  - 5. Shelf with Mop and Broom Holders: 40 to 48 inches. CBC 11B-603.4 Coat hooks, shelves and medicine cabinets
  - 6. Electric Hand Dryers: Measured from floor to bottom of nozzle:
    - a. Men: 40 inches.
    - b. Women: 40 inches.
    - c. Handicap: 36 inches.

7. Other Accessories: As indicated on drawings.

#### **3.04 ADJUSTING AND CLEANING**

- A. Adjust toilet accessories for proper operation and verify that mechanisms function smoothly. Replace damaged or defective items.
- B. Clean and polish all exposed surfaces in strict accordance with manufacturer's recommendations after removing temporary labels and protective coatings.

#### **3.05 PROTECTION**

- A. Protect installed accessories from damage due to subsequent construction operations.

**END OF SECTION**



**SECTION 10 44 00**  
**FIRE PROTECTION SPECIALTIES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Fire extinguishers.
- B. Fire extinguisher cabinets.
- C. Accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 09 21 16 - Gypsum Board Assemblies: Finishing at recessed fire extinguisher cabinets.

**1.03 REFERENCE STANDARDS**

- A. ASTM E814 - Standard Test Method for Fire Tests of Penetration Firestop Systems; 2013a.
- B. FM (AG) - FM Approval Guide; current edition.
- C. Fire Extinguishers Standard: California Fire Code (CFC) section 906.
- D. Title 19 California Code of Regulations.
- E. ASTM E119 - Standard Test Methods for Fire Tests of Building Construction and Materials; 2016a.
  - 1. Use 2012a as indicated in 2016 CBC Referenced Standards.
- F. NFPA 10 - Standard for Portable Fire Extinguishers; 2013.
- G. UL (DIR) - Online Certifications Directory; current listings at database.ul.com.

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide extinguisher operational features, extinguisher ratings and classifications, color and finish, anchorage details, and installation instructions.
- C. Shop Drawings: Indicate locations of cabinets and cabinet physical dimensions.
- D. Manufacturer's Installation Instructions: Indicate special criteria and wall opening coordination requirements.
  - 1. Submit for fire extinguishers and cabinets, and indicate compliance with local and State fire regulations for extinguisher mounting heights and locations.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- F. Maintenance Data: Include test, refill or recharge schedules and re-certification requirements.

**1.05 FIELD CONDITIONS**

- A. Do not install extinguishers when ambient temperature may cause freezing of extinguisher ingredients.

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. Conform to all requirements of the local and State Fire Marshal. Conform to all applicable requirements of the California Building Code (CBC), CFC, ADA and Title 19 CCR.
  - 1. Fire Extinguisher cabinets must comply with CBC sections 11B-305 Clear floor or ground space, 11B-307 Protruding Objects, 11B-308 Reach Ranges, 11B-309/811.4 Operable Parts, 11B-403 Walking Surfaces, 11B-811.3 Height.
  - 2. Comply with Section 11B-205 Operable Parts and 309 Operable Parts; Controls and operating mechanisms shall be operable with one hand and shall not require tight grasping, pinching or twisting of the wrist. The force required to activate controls shall be no greater than 5 lbf (22.2 N) of force. CBC Section 11B-309.4 Operation.
- B. Fire Extinguisher Requirements: Conform to NFPA 10, California Fire Code and Title 19 requirements for portable fire extinguishers.
- C. Current listing by California State Fire Marshal.

### **2.02 MANUFACTURERS**

- A. Fire Extinguishers:
  - 1. Activar Construction Products Group; JL Model Cosmic Series: [www.activarcpg.com/#sle](http://www.activarcpg.com/#sle).
  - 2. Amerex; [www.amerex-fire.com](http://www.amerex-fire.com).
  - 3. Ansul, Inc. Sentry: [www.ansul.com](http://www.ansul.com).
  - 4. Kidde, a unit of United Technologies Corp: [www.kidde.com](http://www.kidde.com).
  - 5. Larsen's Manufacturing Co; Product Model No. MP5: [www.larsensmfg.com](http://www.larsensmfg.com).
  - 6. Nystrom, Inc: [www.nystrom.com/sle](http://www.nystrom.com/sle).
  - 7. Potter-Roemer; Product Model No. 300S: [www.potterroemer.com](http://www.potterroemer.com).
  - 8. Pyro-Chem, a Tyco Business: [www.pyrochem.com/#sle](http://www.pyrochem.com/#sle).
  - 9. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Fire Extinguisher Cabinets and Accessories:
  - 1. Activar Construction Products Group; CS Series - Heavy Duty School Fire Extinguisher Cabinets: [www.activarcpg.com/#sle](http://www.activarcpg.com/#sle).
  - 2. Ansul, a Tyco Business: [www.ansul.com/#sle](http://www.ansul.com/#sle).
  - 3. Kidde, a unit of United Technologies Corp: [www.kidde.com](http://www.kidde.com).
  - 4. Larsen's Manufacturing Co: [www.larsensmfg.com](http://www.larsensmfg.com).
  - 5. Nystrom, Inc: [www.nystrom.com](http://www.nystrom.com).
  - 6. Potter-Roemer; Alta Series: [www.potterroemer.com/#sle](http://www.potterroemer.com/#sle).
  - 7. Pyro-Chem, a Tyco Business: [www.pyrochem.com/#sle](http://www.pyrochem.com/#sle).
  - 8. Strike First Corporation of America: [www.strikefirstusa.com](http://www.strikefirstusa.com).
  - 9. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

### **2.03 FIRE EXTINGUISHERS**

- A. Fire Extinguishers - General: Comply with product requirements of NFPA 10 and applicable codes, whichever is more stringent.
  - 1. Provide extinguishers labeled by UL (DIR) or FM (AG) for purpose specified and as indicated.
- B. Dry Chemical Type Fire Extinguishers: Carbon steel tank, with pressure gage. Fully serviced and tagged.
  - 1. Stored Pressure Operated: Deep Drawn.
  - 2. Class: 2-A:B:C.
  - 3. Size: 2.5 pound.
  - 4. Size and classification as scheduled.
  - 5. Finish: Baked polyester powder coat, color as selected.
- C. Dry Chemical Type Fire Extinguishers: Stainless steel tank, with pressure gauge.
  - 1. Class: K type.
  - 2. Size: 1.6 gallons.
  - 3. Size and classification as scheduled.
  - 4. Finish: Polished stainless steel.
  - 5. Temperature range: 32 degrees F to 120 degrees F.

### **2.04 FIRE EXTINGUISHER CABINETS**

- A. Fire Rating: Listed and labeled in accordance with ASTM E814 and ASTM E119 requirements for fire resistance rating of walls where being installed.
- B. Cabinet Construction: Non-fire rated.
  - 1. Formed primed steel sheet; 0.036 inch thick base metal.
- C. Fire Rated Cabinet Construction: One-hour fire rated.
  - 1. Steel; double wall or outer and inner boxes with 5/8 inch thick fire barrier material.
- D. Cabinet Configuration: Semi-recessed type.
  - 1. Size to accommodate accessories.
  - 2. Trim: Flat square edge, with 1 inch wide face.
  - 3. Projected Trim: Returned to wall surface, with 2-1/2 inch projection, and 2-1/2 inch wide face.
  - 4. Provide cabinet enclosure with right angle inside corners and seams, and with formed perimeter trim and door stiles.
- E. Door: 0.036 inch metal thickness, reinforced for flatness and rigidity with nylon catch. Hinge doors for 180 degree opening with two butt hinge.
  - 1. Provide manufacturer's option for compliance with Americans with Disabilities Act (ADA) projection criteria and accessible handle.

2. Latching and locking hardware operable with a single effort by lever-type hardware or other type hardware not requiring ability to grasp opening hardware and not requiring an opening force greater than 5 pounds.
- F. Door Style: Slot glazed style duo-panel with glazing, continuous hinge, roller catch, zinc plated pull handle and cylinder lock.
  1. Door Glazing: Float glass, clear, 1/8 inch thick, and set in resilient channel glazing gasket.
  2. Door Glazing: Acrylic plastic, clear, 1/8 inch thick, flat shape and set in resilient channel glazing gasket.
- G. Cabinet Mounting Hardware: Appropriate to cabinet, with pre-drilled holes for placement of anchors.
- H. Weld, fill, and grind components smooth.
- I. Finish of Cabinet Exterior Trim and Door: No. 4 - Brushed stainless steel.
- J. Finish of Cabinet Interior: White colored enamel.

## **2.05 ACCESSORIES**

- A. Extinguisher Brackets: Formed steel, chrome-plated.
  1. Provide brackets with 3-point connection within cabinets and for locations where fire extinguisher is wall-mounted without cabinet.
    - a. Bracket design shall prevent accidental dislodgement of extinguisher.
    - b. Provide size required for type and capacity of specified extinguisher.
- B. Cabinet Signage:....
  1. Identify extinguisher locations with red lettered white decals spelling "FIRE EXTINGUISHER INSIDE" applied to wall or exterior door surface outside each room housing a fire extinguisher. Letter size, style and location as selected by Architect, to comply with local fire authority requirements.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify rough openings for cabinet are correctly sized and located.

### **3.02 INSTALLATION**

- A. Install in accordance with manufacturer's instructions.
- B. Install cabinets in prepared recesses in walls. Verify recess dimensions for standard non-rated and fire rated where required.
- C. Install cabinets plumb and level in wall openings, 24 inches from finished floor to inside bottom of cabinet.
  1. Cabinet installation shall conform to requirements of the Fire Marshal, CBC, and ADA for location and height of extinguisher.
  2. Place cabinet to position the extinguisher handle at maximum 48 inches AFF.










3. Place Cabinet 40 inches (1,016 mm) AFF to centerline of cabinet handle.
- D. Secure rigidly in place.
  1. Use oval head fasteners with exposed surfaces of same finish as cabinet.
  2. Fasten cabinets to wood studs with full threaded wood screws or with sheet metal screws.
- E. Maintain acoustical integrity of walls by filling cavity around box with unfaced fiberglass insulation or by applying electrical outlet box acoustical sheeting to the back, top, bottom and sides.
- F. Place extinguishers in cabinets and on wall brackets.
  1. Mount freestanding fire extinguishers on steel brackets on walls at locations indicated on drawings, with fire extinguisher handle located maximum 48-inches above finish floor. Mount steel brackets to solid backing.
  2. Mount fire extinguishers to brackets in all cabinets.
  3. Place fire extinguishers immediately prior to issuance of "Notice of Completion" or sooner if directed by Fire Marshal or District.

### **3.03 SCHEDULES**

- A. All extinguishers and cabinets shall be quantities and locations as indicated per Drawings or as indicated by field inspection by Fire Marshall.
- B. Place the fire extinguishers based on the allowable maximum travel distance to extinguisher as indicated on Drawing and as follows:
  1. Class A = 75 feet
  2. Class B = 50 Feet
  3. Class C = 50 Feet
  4. Class K = 30 Feet
- C. General Use: 1 Dry Chemical Type 2A-10BC, 10 lb. capacity, baked enamel finish extinguisher placed in specified cabinet. Ansul Sentry 10 Model No. AA10S.

### **3.04 TYPES**



| Fire Class | Geometric Symbol  | Pictogram   | Intended Use                   | Mnemonic         |
|------------|---|---|--------------------------------|------------------|
| A          |  |  | Ordinary solid combustibles    | A for "Ash"      |
| B          |  |  | Flammable liquids and gases    | B for "Barrel"   |
| C          |  |  | Energized electrical equipment | C for "Current"  |
| D          |  | (none)  | Combustible metals             | D for "Dynamite" |
| K          |  |  | Oils and fats                  | K for "Kitchen"  |

Fire extinguishing capacity is rated in accordance with ANSI/UL 711: Rating and Fire Testing of Fire Extinguishers.

The ratings are described using numbers preceding the class letter, such as 1-A:10-B:C.

The number preceding the A multiplied by 1.25 gives the equivalent extinguishing capability in gallons of water.

The number preceding the B indicates the size of fire in square feet that an ordinary user should be able to extinguish.

There is no additional rating for class C, as it only indicates that the extinguishing agent will not conduct electricity, and an extinguisher will never have a rating of just C.

**END OF SECTION**

**SECTION 12 24 00**  
**WINDOW SHADES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Window shades and accessories.
- B. Contractor to provide concealed fascia integrated in finished ceilings, support backing for mounting, power, conduit, raceways and switchboxes.

**1.02 RELATED REQUIREMENTS**

- A. Section 08 43 13 - Aluminum Framed Storefronts: Substrate for window shade systems.
- B. Section 09 21 16 - Gypsum Board Assemblies: Substrate for window shade systems.
- C. Section 09 51 00 - Suspended Acoustical Ceilings: Shade Pockets, pocket closures and accessories.

**1.03 REFERENCE STANDARDS**

- A. ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi; 2015.
- B. CA Article 3.08, Title 19 - Title 19 California Code of Regulations, Subchapter 1, Article 3.08 Decorative Materials; current edition.
- C. NFPA 701 - Standard Methods of Fire Tests for Flame Propagation of Textiles and Films; 2015.
- D. UL 325 - Standard for Door, Drapery, Gate, Louver, and Window Operators and Systems; Current Edition, Including All Revisions.

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Coordination:
  - 1. Where motorized shades are to be controlled by control systems provided under other sections, coordinate the work with other trades to provide compatible products.
  - 2. Coordinate the work with other trades to provide rough-in of electrical wiring as required for installation of hardwired motorized shades.
- B. Preinstallation Meeting: Convene one week prior to commencing work related to products of this section; require attendance of all affected installers.
- C. Sequencing:
  - 1. Do not fabricate shades until field dimensions for each opening have been taken.
  - 2. Do not install shades until final surface finishes and painting are complete.

**1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets including materials, finishes, fabrication details, dimensions, profiles, mounting requirements, and accessories.

- C. Shop Drawings: Include shade schedule indicating size, location and keys to details.
- D. Certificates: Manufacturer's documentation that line voltage components are UL listed or UL recognized.
- E. Source Quality Control Submittals: Provide test reports indicating compliance with specified fabric properties.
- F. Verification Samples: Minimum size 6 inches square, representing actual materials, color and pattern.
- G. Manufacturer's Instructions: Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- H. Project Record Documents: Record actual locations of control systems and show interconnecting wiring.
- I. Operation and Maintenance Data: List of all components with part numbers, sources of supply, and operation and maintenance instructions; include copy of shop drawings.
- J. Warranty: Submit sample of manufacturer's warranty and documentation of final executed warranty completed in District's name and registered with manufacturer.

#### **1.06 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than five years of documented experience.
- B. Installer Qualifications: Company specializing in performing work of this type with minimum three years of documented experience and approved by manufacturer.
  - 1. Factory training and demonstrated experience.

#### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver shades in manufacturer's unopened packaging, labeled to identify each shade for each opening.
- B. Handle and store shades in accordance with manufacturer's recommendations.

#### **1.08 FIELD CONDITIONS**

- A. Do not install products under environmental conditions outside manufacturer's absolute limits.

#### **1.09 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. Provide manufacturer's warranty from Date of Substantial Completion, covering the following:
  - 1. Shade Hardware: One year.
  - 2. Fabric: One year.
  - 3. Aluminum and Steel Coatings: One year.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Interior Manually Operated Roller Shades:
  - 1. Draper, Inc; Clutch Operated FlexShade: [www.draperinc.com](http://www.draperinc.com): Kathy Greenway (951) 304-9286.
  - 2. Hunter Douglas Architectural; RB500 Manual Roller Shades: [www.hunterdouglasarchitectural.com/#sle](http://www.hunterdouglasarchitectural.com/#sle).
  - 3. Mechoshade; Mecho/5 pocket with fascia: [www.mechoshade.com](http://www.mechoshade.com): Carlos Herrera (626) 369-7777.
  - 4. Skyco Shading; [www.skycoshade.com](http://www.skycoshade.com): (714) 552-4064.
  - 5. Substitutions: See Section 01 63 00 - Product Substitution Procedures.
- B. Source Limitations: Furnish products produced by a single manufacturer and obtained from a single supplier.

### **2.02 WINDOW SHADE APPLICATIONS**

- A. Interior Roller Shades: Privacy shades.
  - 1. Type: Roll down, closed position is at window sill.
  - 2. Fabric: As selected by Architect from manufacturer's full range.
  - 3. Color: As selected by Architect from manufacturer's full range of colors.
  - 4. Mounting: Inside and outside, where indicated on drawings.
  - 5. Operation: Manual.

### **2.03 ROLLER SHADES**

- A. Roller Shades: Fabric roller shades complete with mounting brackets, roller tubes, hembars, hardware and accessories.
  - 1. Drop: Regular roll.
  - 2. Size: As indicated on drawings.
- B. Fabric: Non-flammable, color-fast, impervious to heat and moisture, and able to retain its shape under normal operation.
  - 1. Privacy Shades: Soften the light yet still reveal some details to the outside; moderate privacy; Openness Factor approximately equal to 1 percent.
  - 2. Flammability: Pass NFPA 701 large and small tests. Comply with CA Article 3.08, Title 19.
  - 3. Fungal Resistance: No growth when tested according to ASTM G21.
- C. Roller Tubes: As required for type of operation.
  - 1. Material: Extruded aluminum or galvanized steel; as required for shade location.
  - 2. Size: Manufacturer's standard, selected for suitability for installation conditions, span, and weight of shades.

3. Fabric Attachment: Utilize extruded channel in tube to accept vinyl spline welded to fabric edge or double sided adhesive tape.
  4. Finish: Clear anodized.
- D. Hembars: Designed for weight requirements and adaptation to uneven surfaces, to maintain bottom of shade straight and flat.
1. Style: Half wrap fabric covered bottom bar, flat profile with closed ends.
  2. Finish: Painted.
  3. Color: As selected from manufacturer's standard colors.
  4. Blackout Shades: Provide a slot in bottom bar with wool-pile light seal.
- E. Manual Operation: Clutch operated continuous loop; beaded ball chain. Chain length shall extend below shade to 39 inches AFF.

#### **2.04 ACCESSORIES**

- A. Fascias: Size as required to conceal shade mounting.
1. Style: As selected by Architect from shade manufacturer's full selection.
  2. Material and Color: To match shade.
- B. Brackets and Mounting Hardware: As recommended by manufacturer for mounting configuration and span indicated.
- C. Interior Side Channels: As required for light sealing blackout shade applications.
- D. Fasteners: Non-corrosive, and as recommended by shade manufacturer.

#### **2.05 FABRICATION**

- A. Field measure finished openings prior to ordering or fabrication.
- B. Fabricate shades to fit openings within specified tolerances.
1. Vertical Dimensions: Fill openings from head to sill with 1/2 inch space between bottom bar and window stool.
  2. Horizontal Dimensions - Inside Mounting: Fill openings from jamb to jamb.
  3. Horizontal Dimensions - Inside Mounting: Provide symmetrical light gaps on both sides of shade not to exceed 3/4 inch total.
  4. Horizontal Dimensions - Outside Mounting: Cover window frames, trim, and casings completely.
- C. Dimensional Tolerances: As recommended in writing by manufacturer.
- D. At openings requiring continuous multiple shade units with separate rollers, locate roller joints at window mullion centers; butt rollers end-to-end.

### **PART 3 EXECUTION**

#### **3.01 EXAMINATION**

- A. Examine finished openings for deficiencies that may preclude satisfactory installation.

- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.
- C. Start of installation shall be considered acceptance of substrates.

### **3.02 PREPARATION**

- A. Prepare surfaces using methods recommended by manufacturer for achieving best result for substrate under the project conditions.
- B. Coordinate with window installation and placement of concealed blocking to support shades.

### **3.03 INSTALLATION**

- A. Install in accordance with manufacturer's instructions and approved shop drawings, using mounting devices as indicated.
- B. Installation Tolerances:
  - 1. Inside Mounting: Maximum space between shade and jamb when closed of 1/16 inch.
  - 2. Maximum Offset From Level: 1/16 inch.
- C. Replace shades that exceed specified dimensional tolerances at no extra cost to District.
- D. Adjust level, projection and shade centering from mounting bracket. Verify there is no telescoping of shade fabric. Ensure smooth shade operation.

### **3.04 CLEANING**

- A. Clean soiled shades and exposed components as recommended by manufacturer.
- B. Replace shades that cannot be cleaned to "like new" condition.

### **3.05 CLOSEOUT ACTIVITIES**

- A. See Section 01 77 00 - Closeout Procedures, for closeout submittals.
- B. Demonstration: Demonstrate operation and maintenance of window shade system to District's personnel.

### **3.06 PROTECTION**

- A. Protect installed products from subsequent construction operations.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

### **3.07 MAINTENANCE**

- A. See Section 01 70 00 - Execution and Closeout Requirements, for additional requirements relating to maintenance service.

**END OF SECTION**



**SECTION 12 36 00**  
**COUNTERTOPS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Countertops for architectural cabinetwork.
- B. Wall-hung counters.

**1.02 RELATED REQUIREMENTS**

- A. Section 06 41 00 - Architectural Wood Casework.
- B. Section 09 21 16 - Gypsum Board Assemblies: Support framing, grounds, and concealed blocking.
- C. Division 22 - Plumbing: Sinks.

**1.03 REFERENCE STANDARDS**

- A. ANSI A208.2 - American National Standard for Medium Density Fiberboard for Interior Use; 2009.
- B. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2016.
- C. AWI/AWMAC/WI (AWS) - Architectural Woodwork Standards; 2014.
- D. AWMAC/WI (NAAWS) - North American Architectural Woodwork Standards, U.S. Version 3.0; 2016.
- E. ISFA 2-01 - Classification and Standards for Solid Surfacing Material; 2013.
- F. NEMA LD 3 - High-Pressure Decorative Laminates; 2005.
- G. PS 1 - Structural Plywood; 2009.
- H. WI (MCP) - Monitored Compliance Program (MCP); current edition at [www.woodworkinstitute.com](http://www.woodworkinstitute.com).

**1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
  - 1. Preparation instructions and recommendations.
  - 2. Storage and handling requirements and recommendations.
  - 3. Specimen warranty.
- C. Shop Drawings: Complete details of materials and installation.
  - 1. Provide the information required by AWMAC/WI (NAAWS) Architectural Woodwork Standards.
  - 2. Provide a Woodwork Institute Certified Compliance Label on the first page of the shop drawings.



- D. Selection Samples: For each finish product specified, color chips representing manufacturer's full range of available colors and patterns.
- E. Verification Samples: For each finish product specified, minimum size 6 inches square, representing actual product, color, and patterns.
- F. Test Reports: Chemical resistance testing, showing compliance with specified requirements.
- G. Certificate: Submit labels and certificates required by quality assurance and quality control programs.
- H. Installation Instructions: Manufacturer's installation instructions and recommendations.
- I. Maintenance Data: Manufacturer's instructions and recommendations for maintenance and repair of countertop surfaces.

### **1.05 QUALITY ASSURANCE**

- A. Installer Qualifications: Company specializing in performing work of the type specified in this section, with not less than three years of documented experience.
- B. Quality Certification: Provide WI (MCP) inspection report and quality certification of completed work.
  - 1. Provide labels or certificates indicating that the installed work complies with AWMAC/WI (NAAWS) requirements for grade or grades specified.
  - 2. Provide designated labels on shop drawings as required by certification program.
  - 3. Provide designated labels on installed products as required by certification program.
    - a. Before delivery to the jobsite the woodwork supplier shall provide a Woodwork Institute Certified Compliance Certificate indicating the millwork products being supplied and Certifying that these products fully meet the requirements of the Grade or Grades specified.
    - b. Provide a Woodwork Institute Certified Compliance Label on each Plastic Laminate, Solid Surface, and Solid Phenolic Core countertop.
  - 4. Submit certifications upon completion of installation that verifies this work is in compliance with specified requirements.
    - a. At completion of installation the woodwork installer shall provide a Woodwork Institute Certified Compliance Certificate indicating the products installed, and Certifying that the installation of these products fully meets the requirements of the Grade or Grades specified.
  - 5. All fees charged by the Woodwork Institute for their Certified Compliance program are the responsibility of the millwork manufacturer and/or installer and shall be included in the bid.

### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

## 1.07 FIELD CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

## 1.08 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Correct defective Work within a one year period after Date of Substantial Completion.
- C. Provide five year manufacturer warranty for material defects.

## PART 2 PRODUCTS

### 2.01 COUNTERTOPS

- A. Quality Standard: Custom Grade, in accordance with AWMAC/WI (NAAWS), unless noted otherwise.
- B. Solid Surfacing Countertops: Solid surfacing sheet or plastic resin casting over continuous substrate.
  - 1. Flat Sheet Thickness: 1/2 inch, minimum.
  - 2. Solid Surfacing Sheet and Plastic Resin Castings: Complying with ISFA 2-01 and NEMA LD 3; acrylic or polyester resin, mineral filler, and pigments; homogenous, non-porous and capable of being worked and repaired using standard woodworking tools; no surface coating; color and pattern consistent throughout thickness.
    - a. Basis of Design Product: Solid Surface as manufactured by Formica, or approved equal.
    - b. Manufacturers:
      - 1) Avonite Surfaces: [www.avonitesurfaces.com](http://www.avonitesurfaces.com).
      - 2) Dupont: [www.corian.com](http://www.corian.com).
      - 3) Formica Corporation: [www.formica.com](http://www.formica.com).
      - 4) Wilsonart: [www.wilsonart.com](http://www.wilsonart.com).
      - 5) Panolam Industries International, Inc.(Nevamar): [www.nevamar.com](http://www.nevamar.com).
      - 6) Substitutions: See Section 01 63 00 - Product Substitution Procedures.
    - c. Surface Burning Characteristics: Flame spread index of 25, maximum; smoke developed index of 450, maximum; when tested in accordance with ASTM E84.
    - d. NSF approved for food contact.
    - e. Finish on Exposed Surfaces: Matte, gloss rating of 5 to 20.
    - f. Color and Pattern: As selected by Architect from manufacturer's full line.
  - 3. Other Components Thickness: 1/2 inch, minimum.
  - 4. Exposed Edge Treatment: Built up to minimum 1-1/4 inch thick; bullnosed edge.
  - 5. Back and End Splashes: Same sheet material, square top; minimum 4 inches high.
  - 6. Skirts: As indicated on drawings.

## 2.02 MATERIALS

- A. Plywood for Supporting Substrate: PS 1 Exterior Grade, A-C veneer grade, minimum 5-ply; minimum 3/4 inch thick; join lengths using metal splines.
- B. Medium Density Fiberboard for Supporting Substrate: ANSI A208.2.
- C. Adhesives: Chemical resistant waterproof adhesive as recommended by manufacturer of materials being joined.
- D. Cleaning Agents: Non-abrasive, soft-scrub type kitchen cleansers.
- E. Joint Sealant: Mildew-resistant silicone sealant, clear.

## 2.03 FABRICATION

- A. Fabricate according to Architectural Woodwork Standards Custom Grade.
- B. Fabricate tops and splashes in the largest sections practicable, with top surface of joints flush.
  - 1. Join lengths of tops using best method recommended by manufacturer.
  - 2. Fabricate to overhang fronts and ends of cabinets 1 inch except where top butts against cabinet or wall.
  - 3. Prepare all cutouts accurately to size; replace tops having improperly dimensioned or unnecessary cutouts or fixture holes.
- C. Provide back/end splash wherever counter edge abuts vertical surface unless otherwise indicated.
  - 1. Secure to countertop with concealed fasteners and with contact surfaces set in waterproof glue.
  - 2. Height: 4 inches, unless otherwise indicated.
- D. Wall-Mounted Counters: Provide brackets and braces as indicated on drawings.
  - 1. Mounting: Inside wall to side of stud.
  - 2. Finish: As selected from the manufacturer's standard range.
  - 3. Counter Support Bracket: Unless indicated otherwise on Drawings.
    - a. Basis of Design Product: Inside Wall - Flush Mount or EH-1818 and 2 x 2 x 1/8 inch aluminium angle Cleat Stock as manufactured by Rakks/Rangine Corporation, rakks.com, or approved equal.

## PART 3 EXECUTION

### 3.01 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
  - 1. Verify dimensions by field measurements prior to fabrication.
  - 2. Base Cabinets: Cabinet units shall be securely fixed to adjoining units and structure.
- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.
- C. Verify that wall surfaces have been finished and mechanical and electrical services and outlets are installed in proper locations.

- D. Inspect finished surfaces for damage. Do not install until damage materials have been repaired in an acceptable manner or replaced.

### **3.02 PREPARATION**

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Protect finished surfaces against scratches. Apply masking where necessary. Guard against grit, dust, and other trades.

### **3.03 INSTALLATION**

- A. Securely attach countertops to cabinets using concealed fasteners. Make flat surfaces level; shim where required.
- B. Seal joint between back/end splashes and vertical surfaces.

### **3.04 TOLERANCES**

- A. Variation From Horizontal: 1/16 inch in 1/16 feet, maximum.
- B. Offset From Wall, Countertops: 1/8 inch maximum; 1/16 inch minimum.
- C. Field Joints: 1/8 inch wide, maximum.
  - 1. Joints between backsplashes and countertops: Seal joints with silicone sealer.
  - 2. Joints Between Adjacent Pieces of Quartz Surfacing:
    - a. Joints shall be flush, tight fitting, level, and neat.
    - b. Securely join with stone adhesive. Fill joints level with quartz surfacing.
    - c. Clamp or brace quartz surfacing in position until adhesive sets.

### **3.05 CLEANING**

- A. Remove masking and excess adhesives and sealants. Clean exposed surfaces.
- B. Clean countertops surfaces thoroughly.

### **3.06 PROTECTION**

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Date of Substantial Completion.

## **END OF SECTION**



**SECTION 22 00 50**  
**COMMON WORK RESULTS FOR PLUMBING SYSTEMS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. General requirements applicable to all Division 22 Sections.

**1.02 RELATED REQUIREMENTS**

- A. This Section is a part of each Division 22 Section.
- B. Section 23 11 23, Facility Natural Gas Piping: Requirements for natural gas piping system.

**1.03 ADDITIONAL REQUIREMENTS**

- A. Furnish and install any incidental work not shown or specified which is necessary to provide a complete and workable system.
- B. Make all temporary connections required to maintain services during the course of this Contract without additional cost to the Owner. Notify the Owner seven days in advance before disturbing services.
- C. All plumbing work required by Contract Documents shall be performed in strict accordance with all codes and regulations. Plumbing work done under this Contract shall not adversely affect the operation of the existing plumbing systems.

**1.04 REFERENCES AND STANDARDS**

- A. Where material or equipment is specified to conform to referenced standards, it shall be assumed that the most recent edition of the standard in effect at the time of bid shall be used.
  - 1. CSA – Canadian Standards Association International.
  - 2. ANSI - American National Standards Institute.
  - 3. ASTM - American Society for Testing and Materials.
  - 4. CCR - California Code of Regulations.
    - a. Title 8 - Division of Industrial Safety, Subchapter 7; General Industry Safety Orders, Articles 31 through 36.
  - 5. NCPWB - National Certified Pipe Welding Bureau.
  - 6. CEC - California Electrical Code.
  - 7. NEMA - National Electrical Manufacturers' Association.
  - 8. NFPA - National Fire Protection Association.
  - 9. OSHA - Occupational Safety and Health Act.
  - 10. UL - Underwriters' Laboratories, Inc.
- B. Requirements of Regulatory Agencies:

1. The publications listed below form part of this specification; comply with provisions of these publications except as otherwise shown or specified.
2. Code editions shall be as noted on Drawings, as adopted by the California Division of the State Architect (DSA).
  - a. California Building Code.
  - b. California Electrical Code.
  - c. California Energy Code.
  - d. California Fire Code.
  - e. California Green Building Standards Code.
  - f. California Mechanical Code.]
  - g. California Plumbing Code.]
  - h. California Code of Regulations, Title 24.
  - i. California Health and Safety Code.
  - j. CAL-OSHA.
  - k. California State Fire Marshal, Title 19 CCR.
  - l. National Fire Protection Association.
  - m. Occupational Safety and Health Administration.
  - n. Other applicable state laws.
3. Nothing in Drawings or specifications shall be construed to permit work not conforming to these codes, or to requirements of authorities having jurisdiction. It is not the intent of Drawings or specifications to repeat requirements of codes except where necessary for clarity.

#### **1.05 DRAWINGS**

- A. Examine Contract Documents prior to bidding of work and report discrepancies in writing to Architect.
- B. Drawings showing location of equipment and materials are diagrammatic and job conditions will not always permit installation in location shown. The Plumbing Drawings show general arrangement of equipment and materials, etc., and shall be followed as closely as existing conditions, actual building construction, and work of other trades permit.
  1. Architectural and Structural Drawings shall be considered part of the Work. These Drawings furnish Contractor with information relating to design and construction of the Project. Architectural Drawings take precedence over Plumbing Drawings.
  2. Because of the small scale of Plumbing Drawings, not all offsets, fittings, and accessories required are shown. Investigate structural and finish conditions affecting the Work and arrange Work accordingly. Provide offsets, fittings, and accessories required to meet conditions. Inform Architect immediately when job conditions do not permit installation of equipment and materials in the locations shown. Obtain the Architects approval prior to relocation of equipment and materials.

3. Relocate equipment and materials installed without prior approval of the Architect. Remove and relocate equipment and materials at Contractors' expense upon Architects' direction.
  4. Minor changes in locations of equipment, piping, etc., from locations shown shall be made when directed by the Architect at no additional cost to the Owner providing such change is ordered before such items of work, or work directly connected to same are installed and providing no additional material is required.
- C. Execute work mentioned in Specifications and not shown on Drawings, or vice versa, the same as if specifically mentioned or shown in both.

#### **1.06 FEES AND PERMITS**

- A. Obtain and pay for all permits and service required in installation of this work; arrange for required inspections and secure approvals from authorities having jurisdiction. Comply with requirements of Division 01.
- B. Arrange for utility connections and pay charges incurred, including excess service charges.
1. Contractor shall bear the cost of construction related to utility services, from point of connection to utility services shown on Contract Documents. This includes piping, excavation, backfill, meters, boxes, check valves, backflow prevention devices, general service valves, concrete work, and the like, whether or not Work is performed by Contractor, local water/sanitation district, public utility, other governmental agencies or agencies' assigns.

#### **1.07 ADMINISTRATIVE REQUIREMENTS**

- A. Submittal Procedures:
1. Submittals shall be submitted in accordance with the requirements of Section 01 33 00, Submittal Procedures.
  2. Closeout Submittals shall be submitted in accordance with the requirements of Section 01 77 00, Closeout Procedures.
- B. Coordination:
1. General:
    - a. Coordinate plumbing Work with trades covered in other Specifications Sections to provide a complete, operable and sanitary installation of the highest quality workmanship.
  2. Electrical Coordination:
    - a. Refer to Section 26 05 30, "Conduit and Wire," for service voltage and power feed wiring for equipment specified under this section. Contractor has full responsibility for the following items of work:
      - 1) Review the Electrical Drawings and Division 26 Specifications to verify that electrical services provided are adequate and compatible with equipment requirements.



- 2) If additional electrical services are required above that indicated on Electrical Drawings and in Division 26, such as more control interlock conductors, larger feeder, or separate 120 volt control power source, include cost to furnish and install additional electrical services as part of the bid.
  - 3) Prior to proceeding with installation of additional electrical work, submit detailed drawings indicating exact scope of additional electrical work.
3. Mechanical Coordination:
- a. Arrange for pipe spaces, chases, slots and openings in building structure during progress of construction, to accommodate mechanical system installation.
  - b. Coordinate installation of supporting devices. Set sleeves in poured-in-place concrete and other structural components during progress of construction.
  - c. Coordinate requirements for access panels and doors for mechanical items requiring access where concealed behind finished surfaces.
  - d. Coordinate with other trades equipment locations, pipe, duct and conduit runs, electrical outlets and fixtures, air inlets and outlets, and structural and architectural features. Provide information on location of piping and seismic bracing to other trades as required for a completely coordinated project.

#### **1.08 SUBMITTALS - GENERAL**

- A. Submittal packages may be submitted via email as PDF electronic files, or as printed packages. PDFs shall be legible at actual size (100 percent). Provide seven copies of printed submittal packages.
- B. Provide submittal of materials proposed for use as part of this Project. Product names in Specifications and on Drawings are used as standards of quality. Furnish standard items on specified equipment at no extra cost to the Contract regardless of disposition of submittal data. Other materials or methods shall not be used unless approved in writing by Architect. Architect's review will be required even though "or equal" or synonymous terms are used. Refer to Division 01 for complete instructions.
  1. Partial or incomplete submittals will not be considered.
  2. Quantities are Contractor's responsibility and will not be reviewed.
  3. Provide materials of the same brand or manufacturer for each class of equipment or material.
  4. Identify each item by manufacturer, brand, trade name, number, size, rating, or other data necessary to properly identify and review materials and equipment. Words "as specified" are not sufficient identification.
  5. Identify each submittal item by reference to items' Specification Section number and paragraph, by Drawing and detail number, and by unit tag number.
  6. Organize submittals in same sequence as in Specification Sections.
  7. Show physical arrangement, construction details, finishes, materials used in fabrications, provisions for piping entrance, access requirements for installation and maintenance, physical size, mechanical characteristics, foundation and support details, and weight.

- a. Submit Shop Drawings, performance curves, and other pertinent data, showing size and capacity of proposed materials.
  - b. Specifically indicate, by drawn detail or note, that equipment complies with each specifically stated requirement of Contract Documents.
  - c. Drawings shall be drawn to scale and dimensioned (except schematic diagrams). Drawings may be prepared by vendor but must be submitted as instruments of Contractor, thoroughly checked and signed by Contractor before submission to Architect for review.
  - d. Catalog cuts and published material may be included with supplemental scaled drawings.
- C. Review of submittals will be only for general conformance with design concept and general compliance with information given in Contract Documents. Review will not include quantities, dimensions, weights or gauges, fabrication processes, construction methods, coordination with work of other trades, or construction safety precautions, which are sole responsibility of Contractor. Review of a component of an assembly does not indicate acceptance of an assembly. Deviations from Contract Documents not clearly identified by Contractor are Contractor's responsibility and will not be reviewed by Architect.
- D. Within reasonable time after award of contract and in ample time to avoid delay of construction, submit to Architect Shop Drawings or submittals on all items of equipment and materials provided. Provide submittal in at least seven copies and in complete package.
- 1. Shop Drawings and submittals shall include Specification Section, Paragraph number, and Drawing unit symbol or detail number for reference. Organize submittals into booklets for each Specification section and submit in loose-leaf binders with index. Deviations from the Contract Documents shall be prominently displayed in the front of the submittal package and referenced to the applicable Contract requirement.
- E. Furnish to the Project Inspector complete installation instructions on material and equipment before starting installation.

**1.09 ACTION SUBMITTALS**

- A. Product Data: Submit manufacturer's technical product data and installation instructions for plumbing systems materials and products.
- B. Shop Drawings.
- C. Provide product data for insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings, indicating compliance with requirement that these products contain less than 0.1 percent (by mass) polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations.
- D. Sustainable Design Submittals:
  - 1. Product Data: For adhesives and sealants, documentation of compliance including printed statement of VOC content and chemical components.
- E. Pipe, pipe or plumbing fittings, fixtures, solder and flux installed in a system providing water for human consumption shall comply with lead free requirements of the California Health and Safety Code Section 116875. Provide submittal information for products third-party certified

by an approved laboratory as complying with California Health and Safety Code Section 116875.

#### **1.10 INFORMATIONAL SUBMITTALS**

- A. Provide layouts for plumbing systems, for inclusion in coordinated layout specified in Section 23 31 13, "Metal Ducts." Comply with requirements for layouts specified in Section 23 31 13.
- B. Equipment training session agenda.

#### **1.11 CLOSEOUT SUBMITTALS**

##### A. Operation and Maintenance Data:

- 1. Refer to Section 01 78 50, Operating and Maintenance Data, for complete instructions. Requirements given below are in addition to or are intended to amplify Division 01 requirements. In case of conflict between requirements given in this Section and those of Division 01, Division 01 requirements shall apply.
- 2. Furnish three complete sets of Operation and Maintenance Manual bound in hardboard binder, and one compact disc containing complete Operation and Maintenance Manual in searchable PDF format. Provide Table of Contents. Provide index tabs for each piece of equipment in binder and disc. Begin compiling data upon approval of submittals.

##### a. Sets shall incorporate the following:

- 1) Product Data.
- 2) Shop Drawings.
- 3) Record Drawings.
- 4) Service telephone number, address and contact person for each category of equipment or system.
- 5) Complete operating and maintenance instructions for each item of plumbing equipment and systems.
- 6) Copies of guarantees/warranties for each item of equipment and systems.
- 7) Test data and system balancing reports.
- 8) Typewritten maintenance instructions for each item of equipment listing lubricants to be used, frequency of lubrication, inspections required, adjustment, etc.
- 9) Manufacturers' bulletins with parts numbers, instructions, etc., for each item of equipment.
- 10) Control diagrams and literature.
- 11) Check test and start reports for each piece of plumbing equipment provided as part of the Work.
- 12) Commissioning and Preliminary Operation Tests required as part of the Work.

##### b. Post service telephone numbers and/or addresses in an appropriate place as designated by the Architect.

##### B. Record Drawings:

- 1. Refer to Section 01 78 20, Project Record Documents, for requirements governing Work specified herein.

2. Upon completion of the work, deliver to Architect the following:
  - a. Originals of drawings showing the Work exactly as installed.
  - b. One complete set of reproducible drawings showing the Work exactly as installed.
  - c. One compact disc with complete set of drawings in PDF format showing the Work exactly as installed.
  - d. Provide Contractor's signature, verifying accuracy of record drawings.
3. Obtain the signature of the Project Inspector of Record for record drawings.

### **1.12 SUBSTITUTIONS**

- A. Refer to Division 01 Specifications for complete instructions. Requirements given below are in addition to or are intended to amplify Division 01 requirements. In case of conflict between requirements given in this Section and those of Division 01, Division 01 requirements shall apply.
- B. It is the responsibility of Contractor to assume costs incurred because of additional work and or changes required to incorporate proposed substitute into the Project. Refer to Division 01 for complete instructions.
- C. Substitutions will be interpreted to be all manufacturers other than those specifically listed in the Contract Documents by brand name, model or catalog number.
- D. Only one request for substitution will be considered for each item of equipment or material.
- E. Substitution requests shall include the following:
  1. Reason for substitution request.
  2. Complete submittal information as described herein; see "Submittals."
  3. Coordinated scale layout drawings depicting position of substituted equipment in relation to other work, with required clearances for operation, maintenance and replacement.
  4. List optional features required for substituted equipment to meet functional requirements of the system as indicated in Contract Documents.
  5. Explanation of impact on connected utilities.
  6. Explanation of impact on structural supports.
- F. Installation of reviewed substitution is the Contractors' responsibility. Any mechanical, electrical, structural, or other changes required for installation of reviewed substituted equipment or material must be made by the Contractor without additional cost to the Owner. Review by the Architect of the substituted equipment or material, including dimensioned Drawings will not waive these requirements.
- G. Contractor may be required to compensate the Architect for costs related to substituted equipment or material.

### **1.13 QUALITY ASSURANCE**

- A. Manufacturer's Qualifications: Firms regularly engaged in manufacture of plumbing systems products, of types, materials, and sizes required, whose products have been in satisfactory use in similar service for not less than 5 years.

- B. Contractor's Qualifications: Firm with at least 5 years of successful installation experience on projects with plumbing systems work similar to that required for this Project.
- C. Comply with applicable portions of California Plumbing Code pertaining to selection and installation of plumbing materials and products.
- D. All materials and products shall be new and shall match existing.

#### **1.14 DELIVERY, STORAGE, AND HANDLING**

- A. Protect equipment and piping delivered to Project site from weather, humidity and temperature variations, dirt, dust and other contaminants.

#### **1.15 FIELD CONDITIONS**

- A. Contractor shall visit Project site and examine existing conditions in order to become familiar with Project scope. Verify dimensions shown on Drawings at Project site. Bring discrepancies to the attention of Architect. Failure to examine Project site shall not constitute basis for claims for additional work because of lack of knowledge or location of hidden conditions that affect Project scope.
- B. Information on Drawings relative to existing conditions is approximate. Deviations from Drawings necessary during progress of construction to conform to actual conditions shall be approved by the Architect and shall be made without additional cost to the Owner. The Contractor shall be held responsible for damage caused to existing services. Promptly notify the Architect if services are found which are not shown on Drawings.

#### **1.16 WARRANTY**

- A. Refer to Division 01 Specifications for warranty requirements, including effective date of warranty. Refer to specific items of equipment specified herein for warranty duration if different from that specified in Division 01.
- B. Repair or replace defective work, material, or part that appears within the warranty period, including damage caused by leaks.
- C. On failure to comply with the above warranty within a reasonable length of time after notification is given, the Architect/Owner shall have the repairs made at the Contractor's expense.

### **PART 2 - PRODUCTS**

#### **2.01 GENERAL**

- A. Materials or equipment of the same type shall be of the same brand wherever possible. All materials shall be new and in first class condition.
- B. All sizes, capacities, and efficiency ratings shown are minimum, except that gas capacity is maximum available.
- C. Refer to Division 22 technical Sections for specific system piping materials.

#### **2.02 MATERIALS**

- A. No material installed as part of this Work shall contain asbestos.

- B. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).

### **2.03 MOTOR STARTERS**

- A. Square D, Allen Bradley, or equal, in NEMA Type 1 enclosure, unless otherwise specified or required. Minimum starter size shall be Size 1. Provide NEMA 3R enclosure where exposed to outdoors.
- B. Provide magnetic motor starters for equipment provided under the Mechanical Work. Starters shall be non-combination type. Provide part winding or reduced voltage start motors where shown or as hereinafter specified. Minimum size starter shall be Size 1.
  - 1. All starters shall have the following:
    - a. Cover mounted hand-off-automatic switch. Starters installed exposed in occupied spaces shall have key operated HOA switch.
    - b. Ambient compensated thermal overload.
    - c. Fused control transformer (for 120 or 24 volt service).
    - d. Pilot lights, integral with the starters. Starters located outdoors shall be in NEMA IIIR enclosures.
  - 2. Where three phase motors are provided for two-speed operation, provide two speed motor starters.
  - 3. Starters for single-phase motors shall have thermal overloads. NEMA I enclosure for starters located indoors, NEMA IIIR enclosure for starters located outdoors.
  - 4. Provide OSHA label indicating the device starts automatically.

### **2.04 VALVE BOXES**

- A. General:
  - 1. Where several valves or other equipment are grouped together, provide larger boxes of rectangular "vault" type adequately sized for condition and similar in construction to those specified above.
  - 2. Provide valve box extensions as required to set bottom of valve box tight up to top of piping in which valve is installed.
  - 3. Provide a tee handle wrench for each size, Alhambra Foundry Co. #A-3008, or equal.
- B. Valve Boxes in Traffic Areas: Provide Christy No. G5 traffic valve box, Brooks, or equal, 10-3/8 inches inside diameter with extensions to suit conditions, with cast iron or steel locking cover. Provide Owner with set of special wrenches or tools as required for operation of valves.
- C. Valve Boxes in Non-Traffic Areas: Provide Christy No. F22, Brooks, or equal, 8 inches inside diameter by 30 inches long, with cast iron or steel locking cover. Provide Owner with set of special wrenches or tools as required for operation of valves. Cut bottom of plastic body for operation of valves.
- D. Valve Box (Rectangular Vault Type): Precast concrete or cast iron with cast iron or steel locking type covers lettered to suit service – Brooks No. 3-TL, Christy No. B3, Fraser No. 3,

Alhambra A-3004 or A-3005, Alhambra E-2202, or E-2702, or equal, with extension to suit conditions.

## **2.05 ACCESS DOORS**

- A. Where floors, walls, or ceilings must be penetrated for access to mechanical equipment, provide access doors, 14 inch by 14 inch minimum size in usable opening. Where entrance of a serviceman may be required, provide 20 inch by 30 inch minimum usable opening. Locate access doors/panels for non-obstructed and easy reach.
  - 1. All access doors less than 7'-0" above floors and exposed to public access shall have keyed locks.
- B. Access doors shall match those supplied in Section 08 31 00, "Access Doors and Panels," except as noted in this Section.
- C. Provide stainless steel access doors for use in toilet rooms, shower rooms, kitchens and other damp areas. Provide steel access doors with prime coat of baked-on paint for all other areas.
- D. Do not locate access doors in highly visible public areas such as lobbies, waiting areas, and primary entrance areas. Coordinate with the Architect when access is required in these areas.
- E. Where specific information or details relating to access panels different from the above is shown or given on the Drawings or other Divisions of work, then that information shall supersede this specification.
- F. Manufacturers: Subject to compliance with requirements, available manufacturers offering products which may be incorporated into the Work include Milcor, Karp, Nystrom, or Cesco, equal to the following:
  - 1. Milcor
    - a. Style K (plaster).
    - b. Style DW (gypsum board).
    - c. Style M (Masonry).
    - d. Style "Fire Rated" where required.

## **PART 3 - EXECUTION**

### **3.01 FRAMING, CUTTING AND PATCHING**

- A. Special framing, recesses, chases and backing for Work of this Section, unless otherwise specified, are covered under other Specification Sections.
- B. Contractor is responsible for placement of pipe sleeves, hangers, inserts, supports, and location of openings for the Work.

### **3.02 ELECTRICAL REQUIREMENTS**

- A. Provide adequate working space around electrical equipment in compliance with the California Electrical Code. Coordinate the Mechanical Work with the Electrical Work to comply.
- B. Furnish necessary control diagrams and instructions for the controls. Before permitting operation of any equipment which is furnished, installed, or modified under this Section, review all associated electrical work, including overload protection devices, and assume

complete responsibility for the correctness of the electrical connections and protective devices. Motors and control equipment shall conform to the Standards of the National Electrical Manufacturers' Association. All equipment and connections exposed to the weather shall be NEMA IIR with factory-wired strip heaters in each starter enclosure and temperature control panel where required to inhibit condensation.

- C. All line voltage and low voltage wiring and conduit associated with the Temperature Control System are included in this Section. Wiring and conduit shall comply with Division 26.

### **3.03 PIPING SYSTEM REQUIREMENTS**

- A. Drawing plans, schematic and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on coordination drawings.

### **3.04 INSTALLATION OF PIPING SYSTEMS**

- A. At time of final connection, and prior to opening valve to allow pressurization of water and gas piping from existing systems, on site or off site, perform a pressure test to indicate static pressure of existing systems. If pressure on water piping is greater than 80 psi, or gas pressure is not as indicated on Contract Documents, inform Architect immediately. Do not allow piping systems to be pressurized without written consent of the Architect.

- B. General:

1. All piping shall be concealed unless shown or otherwise directed. Allow sufficient space for ceiling panel removal.
2. Installation of piping shall be made with appropriate fittings. Bending of piping will not be accepted.
3. Install piping to permit application of insulation and to allow valve servicing.
4. Where piping or conduit is left exposed within a room, the same shall be run true to plumb, horizontal, or intended planes. Where possible, uniform margins are to be maintained between parallel lines and/or adjacent wall, floor, or ceiling surfaces.
5. Horizontal runs of pipes and/or electrical conduit suspended from ceilings shall provide for a maximum headroom clearance. The clearance shall not be less than 6'-6" without written approval from the Architect.
6. Close ends of pipe immediately after installation. Leave closure in place until removal is necessary for completion of installation.
7. Each piping system shall be thoroughly flushed and proved clean before connection to equipment.
8. Pipe the discharge of each relief valve, air vent, backflow preventer, and similar device to floor sink or drain.
9. Install exposed polished or enameled connections with special care showing no tool marks or threads at fittings.
10. Install horizontal valves with valve stem above horizontal.
11. Use reducing fittings; bushings shall not be allowed. Use eccentric reducing fittings wherever necessary to provide free drainage of lines and passage of air.



12. Verify final equipment locations for roughing-in.
13. Sanitary Sewer and Storm Drain: Grade piping inside building uniformly 1/4 inch per foot if possible but not less than 1/8 inch per foot. Run piping as straight as possible. Make piping connections between building piping and outside service pipe with cast iron reducers or increasers. Slope sewers uniformly between given elevations where invert elevations are shown.
14. Where piping is installed in walls within one inch of the face of stud, provide a 16 gauge sheet metal shield plate on the face of the stud. The shield plate shall extend a minimum of 1-1/2 inches beyond the outside diameter of the pipe.

### **3.05 ACCESS DOORS**

- A. Furnish and install access doors wherever required whether shown or not for easy maintenance of mechanical systems; for example, at concealed valves, strainers, traps, cleanouts, dampers, motors, controls, operating equipment, etc. Access doors shall provide for complete removal and replacement of equipment.

### **3.06 EXPANSION ANCHORS IN HARDENED CONCRETE**

- A. Refer to Structural Drawings.

### **3.07 OPERATION OF SYSTEMS**

- A. Do not operate any plumbing equipment for any purpose, temporary or permanent, until all of the following has been completed:
  1. Complete all requirements listed under "Check, Test and Start Requirements."
  2. Piping has been properly cleaned. Piping systems shall be flushed and treated prior to operation.
  3. Filters, strainers etc. are in place.
  4. Bearings have been lubricated, and alignment of rotating equipment has been checked.
  5. Equipment has been run under observation, and is operating in a satisfactory manner.
- B. Provide test and balance agency with one set of Contract Drawings, Specifications, Addenda, Change orders issued, applicable shop drawings and submittals and temperature control drawings.

### **3.08 CHECK, TEST AND START REQUIREMENTS**

- A. An authorized representative of the equipment manufacturer shall perform check, test and start of each piece of plumbing equipment. The representative may be an employee of the equipment manufacturer, or a manufacturer-certified contractor. Submit written certification from the manufacturer stating that the representative is qualified to perform the check test and start of the equipment.
  1. As part of the submittal process, provide a copy of each manufacturer's printed startup form to be used.
  2. Some items of specified equipment may require that check, test and start of equipment must be performed by the manufacturer, using manufacturer's employees. See specific equipment Articles in these Specifications for this requirement.

3. Provide all personnel, test instruments, and equipment to properly perform the check, test and start work.
  4. When work has been completed, provide copies of reports for review, prior to final observation of work.
- B. Provide copies of the completed check, test and start report of each item of equipment, bound with the Operation and Maintenance Manual.
- C. Upon completion of the work, provide a schedule of planned maintenance for each piece of equipment. Indicate frequency of service, recommended spare parts (including filters and lubricants), and methods for adjustment and alignment of all equipment components. Provide a copy of the schedule with each operating and maintenance manual. Provide a copy of certification from the Owner's representative indicating that they have been properly instructed in maintenance requirements for the equipment installed.

### **3.09 PRELIMINARY OPERATIONAL REQUIREMENTS AND TESTS**

- A. Prior to observation to determine final acceptance, put all mechanical systems into service and check that work required for that purpose has been done, including but not limited to the following condensed check list. Provide indexed report to tabulating the results of all work.
1. Refer to Division 22 technical Sections for specific testing requirements.
  2. All equipment has been started, checked, lubricated and adjusted in accordance with the manufacturer's recommendations.
  3. Correct rotation of motors and ratings of overload heaters are verified.
  4. Specified filters are installed and spare filters have been turned over to Owner.
  5. All manufacturers' certificates of start-up specified have been delivered to the Owner.
  6. All equipment has been cleaned, and damaged painted finishes touched up.
  7. Missing or damaged parts have been replaced.
  8. Flushing and chemical treatment of piping systems has been completed and water treatment equipment, where specified, is in operation.
  9. Equipment labels, pipe marker labels, ceiling markers and valve tags are installed.
  10. Valve tag schedules, corrected control diagrams, sequence of operation lists and start-stop instructions have been posted.
  11. Preliminary test and balance work is complete, and reports have been forwarded for review.
  12. Automatic control set points are as designated and performance of controls checks out to agree with the sequence of operation.
  13. Operation and Maintenance Manuals have been delivered and instructions to the operating personnel have been made.
- B. Prior to the observation to determine final acceptance, operate all mechanical systems as required to demonstrate that the installation and performance of these systems conform to the requirements of these specifications.

1. Operate and test all mechanical equipment and systems for a period of at least five consecutive 8 hour days to demonstrate the satisfactory overall operation of the project as a complete unit.
  2. Commence tests after preliminary balancing and adjustments to equipment have been checked. Immediately before starting tests, install air filters and lubricate all running equipment. Notify the Architect at least seven calendar days in advance of starting the above tests.
  3. During the test period, make final adjustments and balancing of equipment, systems controls, and circuits so that all are placed in first class operating condition.
- C. Review of Contractor's Tests:
1. All tests made by the Contractor or manufacturers' representatives are subject to observation and review by the Owner. Provide timely notice prior to start of each test, in order to allow for observation of testing. Upon the completion of all tests, provide report to confirm that all testing has been successful.
- D. Test Logs:
1. Maintain test logs listing the tests on all mechanical systems showing dates, items tested, inspectors' names, remarks on success or failure of the tests.
- E. Preliminary Operation:
1. The Owner reserves the right to operate portions of the plumbing system on a preliminary basis without voiding the guarantee.

### **3.10 CERTIFICATES OF INSTALLATION**

- A. Contractor shall complete applicable "Certificates of Installation" forms contained in the California Building Energy Efficiency Standards and submit to the authorities having jurisdiction for approval and issuance of final occupancy permit, as described in the California Energy Code.

### **3.11 DEMONSTRATION AND TRAINING**

- A. An authorized representative of the equipment manufacturer shall train Owner-designated personnel in maintenance and adjustment of equipment. The representative may be an employee of the equipment manufacturer, or a manufacturer-certified contractor. Submit written certification from the manufacturer stating that the representative is qualified to perform the Owner training for the equipment installed.
1. As part of the submittal process, provide a training agenda outlining major topics and time allowed for each topic.
  2. Some items of specified equipment require that training must be performed by the manufacturer, using manufacturer's employees. See specific equipment Articles in these Specifications for this requirement.
  3. Contractor shall provide three copies of certification by Contractor that training has been completed, signed by Owner's representative, for inclusion in Operation and Maintenance Manual. Certificates shall include:

- a. Listing of Owner-designated personnel completing training, by name and title.
  - b. Name and title of training instructor.
  - c. Date(s) of training.
  - d. List of topics covered in training sessions.
4. Refer to specific equipment Sections for minimum training period duration for each piece of equipment.

### **3.12 COMMISSIONING**

- A. This Project will be commissioned by a third-party Commissioning Agent. In addition to the requirements of this Section, comply with the requirements of Section 01 81 00, "Commissioning."

END OF SECTION



**SECTION 22 05 13**  
**COMMON MOTOR REQUIREMENTS FOR PLUMBING EQUIPMENT**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section includes general requirements for single-phase and polyphase, general-purpose, horizontal, small and medium, squirrel-cage induction motors for use on alternating-current power systems up to 600 V and installed at equipment manufacturer's factory or shipped separately by equipment manufacturer for field installation.

**1.02 COORDINATION**

- A. Coordinate features of motors, installed units, and accessory devices to be compatible with the following:
  - 1. Motor controllers.
  - 2. Torque, speed, and horsepower requirements of the load.
  - 3. Ratings and characteristics of supply circuit and required control sequence.
  - 4. Ambient and environmental conditions of installation location.

**PART 2 - PRODUCTS**

**2.01 GENERAL MOTOR REQUIREMENTS**

- A. Comply with NEMA MG 1 unless otherwise indicated.
- B. Comply with IEEE 841 for severe-duty motors.

**2.02 MOTOR CHARACTERISTICS**

- A. Duty: Continuous duty at ambient temperature of 40 deg C and at altitude of 3300 feet above sea level.
- B. Capacity and Torque Characteristics: Sufficient to start, accelerate, and operate connected loads at designated speeds, at installed altitude and environment, with indicated operating sequence, and without exceeding nameplate ratings or considering service factor.

**2.03 POLYPHASE MOTORS**

- A. Description: NEMA MG 1, Design B, medium induction motor.
- B. Efficiency: Premium efficient, as defined in NEMA MG 1.
- C. Service Factor: 1.15.
- D. Multispeed Motors: Variable torque.
  - 1. For motors with 2:1 speed ratio, consequent pole, single winding.
  - 2. For motors with other than 2:1 speed ratio, separate winding for each speed.
- E. Multispeed Motors: Separate winding for each speed.
- F. Rotor: Random-wound, squirrel cage.
- G. Bearings: Regreasable, shielded, antifriction ball bearings suitable for radial and thrust loading.

- H. Temperature Rise: Match insulation rating.
- I. Insulation: Class F.
- J. Code Letter Designation:
  1. Motors 15 HP and Larger: NEMA starting Code F or Code G.
  2. Motors Smaller Than 15 HP: Manufacturer's standard starting characteristic.
- K. Enclosure Material: Cast iron for motor frame sizes 324T and larger; rolled steel for motor frame sizes smaller than 324T.

#### **2.04 ADDITIONAL REQUIREMENTS FOR POLYPHASE MOTORS**

- A. Motors Used with Reduced-Voltage and Multispeed Controllers: Match wiring connection requirements for controller with required motor leads. Provide terminals in motor terminal box, suited to control method.
- B. Motors Used with Variable-Frequency Controllers: Ratings, characteristics, and features coordinated with and approved by controller manufacturer.
  1. Windings: Copper magnet wire with moisture-resistant insulation varnish, designed and tested to resist transient spikes, high frequencies, and short time rise pulses produced by pulse-width-modulated inverters.
  2. Energy and Premium-Efficient Motors – Class B temperature rise; Class F insulation.
  3. Inverter-Duty Motors: Class F temperature rise; Class H insulation.
  4. Thermal Protection: Comply with NEMA MG 1 requirements for thermally protected motors.
  5. Each motor shall be provided with a shaft grounding device for stray current protection.
- C. Severe-Duty Motors: Comply with IEEE 841, with 1.15 minimum service factor.

#### **2.05 SINGLE-PHASE MOTORS**

- A. Motors larger than 1/20 hp shall be one of the following, to suit starting torque and requirements of specific motor application:
  1. Permanent-split capacitor.
  2. Split phase.
  3. Capacitor start, inductor run.
  4. Capacitor start, capacitor run.
- B. Multispeed Motors: Variable-torque, permanent-split-capacitor type.
- C. Bearings: Prelubricated, antifriction ball bearings or sleeve bearings suitable for radial and thrust loading.
- D. Motors 1/20 HP and Smaller: Shaded-pole type.
- E. Thermal Protection: Internal protection to automatically open power supply circuit to motor when winding temperature exceeds a safe value calibrated to temperature rating of motor insulation. Thermal-protection device shall automatically reset when motor temperature returns to normal range.

**PART 3 - EXECUTION (Not Applicable)**

END OF SECTION





**SECTION 22 05 17**  
**SLEEVES AND SLEEVE SEALS FOR PLUMBING PIPING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Sleeves.
  - 2. Sleeve-seal systems.
  - 3. Sleeve-seal fittings.
  - 4. Grout.
  - 5. Silicone sealants.
- B. Related Requirements:
  - 1. Section 078400 "Firestopping" for penetration firestopping installed in fire-resistance-rated walls, horizontal assemblies, and smoke barriers, with and without penetrating items.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
- B. Sustainable Design Submittals:
  - 1. Product Data: For sealants, indicating VOC content.
  - 2. Laboratory Test Reports: For sealants, indicating compliance with requirements for low-emitting materials.

**PART 2 - PRODUCTS**

**2.01 SLEEVES**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Advance Products & Systems, Inc.
  - 2. CALPICO, Inc.
  - 3. GPT; an EnPro Industries company.
- B. Steel Pipe Sleeves: ASTM A 53/A 53M, Type E, Grade B, Schedule 40, [galvanizedzinc coated, with plain ends.
- C. Galvanized-Steel Sheet Sleeves: 0.0239-inch minimum thickness; round tube closed with welded longitudinal joint.

**2.02 SLEEVE-SEAL SYSTEMS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Advance Products & Systems, Inc.

2. CALPICO, Inc.
  3. GPT; an EnPro Industries company.
  4. Metraflex Company (The).
  5. Proco Products, Inc.
- B. Description:
1. Modular sealing-element unit, designed for field assembly, for filling annular space between piping and sleeve.
  2. Sealing Elements: EPDM-rubber interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size of pipe.
  3. Pressure Plates: Carbon steel.
  4. Connecting Bolts and Nuts: Carbon steel, with corrosion-resistant coating, ASTM B 633 of length required to secure pressure plates to sealing elements.

### **2.03 GROUT**

- A. Description: Nonshrink, for interior and exterior sealing openings in non-fire-rated walls or floors.
- B. Standard: ASTM C 1107/C 1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- C. Design Mix: 5000-psi, 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

## **PART 3 - EXECUTION**

### **3.01 SLEEVE INSTALLATION**

- A. Install sleeves for piping passing through penetrations in floors, partitions, roofs, and walls.
- B. For sleeves that will have sleeve-seal system installed, select sleeves of size large enough to provide 1-inch annular clear space between piping and concrete slabs and walls.
  1. Sleeves are not required for core-drilled holes.
- C. Install sleeves in concrete floors, concrete roof slabs, and concrete walls as new slabs and walls are constructed.
  1. Cut sleeves to length for mounting flush with both surfaces.
    - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches above finished floor level.
  2. Using grout, seal the space outside of sleeves in slabs and walls without sleeve-seal system.
- D. Install sleeves for pipes passing through interior partitions.
  1. Cut sleeves to length for mounting flush with both surfaces.
  2. Install sleeves that are large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation.

3. Seal annular space between sleeve and piping or piping insulation; use joint sealants appropriate for size, depth, and location of joint. Comply with requirements for sealants specified in Section 079200, "Joint Sealants."
- E. Fire-Resistance-Rated Penetrations, Horizontal Assembly Penetrations, and Smoke Barrier Penetrations: Maintain indicated fire or smoke rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with fire- and smoke-stop materials. Comply with requirements for firestopping and fill materials specified in Section 078400 " Firestopping."

### **3.02 SLEEVE-SEAL-SYSTEM INSTALLATION**

- A. Install sleeve-seal systems in sleeves in exterior concrete walls and slabs-on-grade at service piping entries into building.
- B. Select type, size, and number of sealing elements required for piping material and size and for sleeve ID or hole size. Position piping in center of sleeve. Center piping in penetration, assemble sleeve-seal system components, and install in annular space between piping and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make a watertight seal.

### **3.03 SLEEVE AND SLEEVE-SEAL SCHEDULE**

- A. Use sleeves and sleeve seals for the following piping-penetration applications:
  1. Exterior Concrete Walls above Grade:
    - a. Piping Smaller Than NPS 6: Steel pipe sleeves.
    - b. Piping NPS 6 and Larger: Steel pipe sleeves.
  2. Exterior Concrete Walls below Grade:
    - a. Piping Smaller Than NPS 6: Steel pipe sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
    - b. Piping NPS 6 and Larger: Steel pipe sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
  3. Concrete Slabs-on-Grade:
    - a. Piping Smaller Than NPS 6: Steel pipe sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
    - b. Piping NPS 6 and Larger: Steel pipe sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
  4. Interior Partitions:
    - a. Piping Smaller Than NPS 6: Steel pipe sleeves.
    - b. Piping NPS 6 and Larger: Galvanized-steel sheet sleeves.

END OF SECTION



**SECTION 22 05 18**  
**ESCUTCHEONS FOR PLUMBING PIPING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Escutcheons.
  - 2. Floor plates.

**1.02 DEFINITIONS**

- A. Existing Piping to Remain: Existing piping that is not to be removed and that is not otherwise indicated to be removed and salvaged, or removed and reinstalled.

**1.03 ACTION SUBMITTALS**

- A. Product Data: For each type of product.

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. BrassCraft Manufacturing Co.; a Masco company.
  - 2. Dearborn Brass.

**2.02 ESCUTCHEONS**

- A. One-Piece, Cast-Brass Type: With polished, chrome-plated finish and setscrew fastener.
- B. One-Piece, Deep-Pattern Type: Deep-drawn, box-shaped brass with polished, chrome-plated finish and spring-clip fasteners.
- C. One-Piece, Stamped-Steel Type: With polished, chrome-plated finish and spring-clip fasteners.

**2.03 FLOOR PLATES**

- A. Split Floor Plates: Cast brass with concealed hinge.

**PART 3 - EXECUTION**

**3.01 INSTALLATION**

- A. Install escutcheons for piping penetrations of walls, ceilings, and finished floors.
- B. Install escutcheons with ID to closely fit around pipe, tube, and insulation of insulated piping and with OD that completely covers opening.
  - 1. Escutcheons for New Piping:

- a. Piping with Fitting or Sleeve Protruding from Wall: One-piece, deep pattern.
  - b. Insulated Piping: One-piece stamped steel with polished, chrome-plated finish.
  - c. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece cast brass with polished, chrome-plated finish.
  - d. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece cast brass with polished, chrome-plated finish.
  - e. Bare Piping in Unfinished Service Spaces: One-piece stamped steel with polished, chrome-plated finish.
  - f. Bare Piping in Equipment Rooms: One-piece stamped steel with polished, chrome-plated finish.
- C. Install floor plates for piping penetrations of equipment-room floors.
  - D. Install floor plates with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
    - 1. New Piping: One-piece, floor plate. Cast-iron flange with holes for fasteners.

### **3.02 FIELD QUALITY CONTROL**

- A. Using new materials, replace broken and damaged escutcheons and floor plates.

END OF SECTION

**SECTION 22 05 19**  
**METERS AND GAGES FOR PLUMBING PIPING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Bimetallic-actuated thermometers.
  - 2. Thermowells.
  - 3. Dial-type pressure gages.
  - 4. Gage attachments.
  - 5. Test plugs.
  - 6. Test-plug kits.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.

**1.03 INFORMATIONAL SUBMITTALS**

- A. Product Certificates: For each type of meter and gage.

**1.04 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For meters and gages to include in operation and maintenance manuals.

**PART 2 - PRODUCTS**

**2.01 BIMETALLIC-ACTUATED THERMOMETERS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Ashcroft Inc.
  - 2. Marsh Bellofram.
  - 3. Miljoco Corporation.
  - 4. Palmer Wahl Instrumentation Group.
  - 5. REOTEMP Instrument Corporation.
  - 6. Trerice, H. O. Co.
  - 7. Weiss Instruments, Inc.
- B. Standard: ASME B40.200.
- C. Case: sealed type(s); stainless steel with 5-inch nominal diameter.
- D. Dial: Nonreflective aluminum with permanently etched scale markings and scales in deg F.



- E. Connector Type(s): Union joint, adjustable angle, with unified-inch screw threads.
- F. Connector Size: 1/2 inch, with ASME B1.1 screw threads.
- G. Stem: 0.25 or 0.375 inch in diameter; stainless steel.
- H. Window: Plain glass.
- I. Ring: Stainless steel.
- J. Element: Bimetal coil.
- K. Pointer: Dark-colored metal.
- L. Accuracy: Plus or minus 1 percent of scale range.

## 2.02 THERMOWELLS

- A. Thermowells:
  - 1. Standard: ASME B40.200.
  - 2. Description: Pressure-tight, socket-type fitting made for insertion into piping tee fitting.
  - 3. Material for Use with Copper Tubing: CNR or CUNI.
  - 4. Type: Stepped shank unless straight or tapered shank is indicated.
  - 5. External Threads: NPS 1/2, NPS 3/4, or NPS 1, ASME B1.20.1 pipe threads.
  - 6. Internal Threads: 1/2, 3/4, and 1 inch, with ASME B1.1 screw threads.
  - 7. Bore: Diameter required to match thermometer bulb or stem.
  - 8. Insertion Length: Length required to match thermometer bulb or stem.
  - 9. Lagging Extension: Include on thermowells for insulated piping and tubing.
  - 10. Bushings: For converting size of thermowell's internal screw thread to size of thermometer connection.
- B. Heat-Transfer Medium: Mixture of graphite and glycerin.

## 2.03 PRESSURE GAGES

- A. Direct-Mounted, Metal-Case, Dial-Type Pressure Gages:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Flo Fab Inc.
    - b. Miljoco Corporation.
    - c. REOTEMP Instrument Corporation.
    - d. Weiss Instruments, Inc.
    - e. Weksler Glass Thermometer Corp.
  - 2. Standard: ASME B40.100.
  - 3. Case: Liquid-filled type(s); cast aluminum or drawn steel; 4-1/2-inch nominal diameter.
  - 4. Pressure-Element Assembly: Bourdon tube unless otherwise indicated.

5. Pressure Connection: Brass, with NPS 1/4, ASME B1.20.1 pipe threads and bottom-outlet type unless back-outlet type is indicated.
6. Movement: Mechanical, with link to pressure element and connection to pointer.
7. Dial: Nonreflective aluminum with permanently etched scale markings graduated in psi.
8. Pointer: Dark-colored metal.
9. Window: Glass.
10. Ring: Metal.
11. Accuracy: Grade A, plus or minus 1 percent of middle half of scale range.

#### **2.04 GAGE ATTACHMENTS**

- A. Snubbers: ASME B40.100, brass; with NPS 1/4, ASME B1.20.1 pipe threads and piston-type surge-dampening device. Include extension for use on insulated piping.
- B. Valves: Brass ball, with NPS 1/4, ASME B1.20.1 pipe threads.

#### **2.05 TEST PLUGS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. Flow Design, Inc.
  2. Miljoco Corporation.
  3. WATTS.
  4. Weiss Instruments, Inc.
  5. Weksler Glass Thermometer Corp.
- B. Description: Test-station fitting made for insertion into piping tee fitting.
- C. Body: Brass or stainless steel with core inserts and gasketed and threaded cap. Include extended stem on units to be installed in insulated piping.
- D. Thread Size: NPS 1/4, ASME B1.20.1 pipe thread.
- E. Minimum Pressure and Temperature Rating: 500 psig at 200 deg F.
- F. Core Inserts: EPDM self-sealing rubber.

#### **2.06 TEST-PLUG KITS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. Flow Design, Inc.
  2. Miljoco Corporation.
  3. WATTS.
  4. Weiss Instruments, Inc.
- B. Furnish one test-plug kit(s) containing one thermometer(s), one pressure gage and adapter, and carrying case. Thermometer sensing elements, pressure gage, and adapter probes shall be of diameter to fit test plugs and of length to project into piping.

- C. Low-Range Thermometer: Small, bimetallic insertion type with 1- to 2-inch-diameter dial and tapered-end sensing element. Dial range shall be at least 25 to 125 deg F.
- D. High-Range Thermometer: Small, bimetallic insertion type with 1- to 2-inch-diameter dial and tapered-end sensing element. Dial range shall be at least 0 to 220 deg F.
- E. Pressure Gage: Small, Bourdon-tube insertion type with 2- to 3-inch-diameter dial and probe. Dial range shall be at least 0 to 200 psig.
- F. Carrying Case: Metal or plastic, with formed instrument padding.

### **PART 3 - EXECUTION**

#### **3.01 INSTALLATION**

- A. Install thermowells with socket extending one-third of pipe diameter and in vertical position in piping tees.
- B. Install thermowells of sizes required to match thermometer connectors. Include bushings if required to match sizes.
- C. Install thermowells with extension on insulated piping.
- D. Fill thermowells with heat-transfer medium.
- E. Install direct-mounted thermometers in thermowells and adjust vertical and tilted positions.
- F. Install direct-mounted pressure gages in piping tees with pressure gage located on pipe at the most readable position.
- G. Install valve and snubber in piping for each pressure gage for fluids.
- H. Install test plugs in piping tees.
- I. Install thermometers in the following locations:
  - 1. Inlet and outlet of each water heater.
- J. Install pressure gages in the following locations:
  - 1. Suction and discharge of each domestic water pump.

#### **3.02 CONNECTIONS**

- A. Install meters and gages adjacent to machines and equipment to allow service and maintenance of meters, gages, machines, and equipment.

#### **3.03 ADJUSTING**

- A. Adjust faces of meters and gages to proper angle for best visibility.

#### **3.04 THERMOMETER SCHEDULE**

- A. Thermometers at inlet and outlet of each domestic water heater shall be the following:
  - 1. Sealed, bimetallic-actuated type.
  - 2. Test plug with chlorosulfonated polyethylene synthetic self-sealing rubber inserts.
- B. Thermometer stems shall be of length to match thermowell insertion length.

### **3.05 THERMOMETER SCALE-RANGE SCHEDULE**

- A. Scale Range for Domestic Hot-Water Piping: 0 to 250 deg F.

### **3.06 PRESSURE-GAGE SCHEDULE**

- A. Pressure gages at suction and discharge of each domestic water pump shall be the following:
  - 1. Sealed, direct-mounted, metal case.
  - 2. Test plug with chlorosulfonated polyethylene synthetic self-sealing rubber inserts.

### **3.07 PRESSURE-GAGE SCALE-RANGE SCHEDULE**

- A. Scale Range for Domestic Water Piping: 0 to 160 psi.

END OF SECTION



**SECTION 22 05 23**  
**GENERAL-DUTY VALVES FOR PLUMBING PIPING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Brass ball valves.
  - 2. Bronze ball valves.
  - 3. Steel ball valves.
  - 4. Iron ball valves.
  - 5. Bronze swing check valves.
  - 6. Bronze gate valves.

**1.02 DEFINITIONS**

- A. CWP: Cold working pressure.
- B. EPDM: Ethylene propylene copolymer rubber.
- C. NBR: Acrylonitrile-butadiene, Buna-N, or nitrile rubber.
- D. NRS: Nonrising stem.
- E. RS: Rising stem.

**1.03 ACTION SUBMITTALS**

- A. Product Data: For each type of valve.
- B. Pipe, pipe or plumbing fittings, fixtures, solder and flux installed in a system providing water for human consumption shall comply with lead free requirements of California Health and Safety Code Section 116875. Provide submittal information for products third-party certified by an approved laboratory as complying with California Health and Safety Code Section 116875.
  - 1. Certification that products comply with NSF 61 Annex G and NSF 372.

**1.04 DELIVERY, STORAGE, AND HANDLING**

- A. Prepare valves for shipping as follows:
  - 1. Protect internal parts against rust and corrosion.
  - 2. Protect threads, flange faces, grooves, and weld ends.
  - 3. Set gate valves closed to prevent rattling.
  - 4. Set ball valves open to minimize exposure of functional surfaces.
  - 5. Set butterfly valves closed or slightly open.
  - 6. Block check valves in either closed or open position.
- B. Use the following precautions during storage:
  - 1. Maintain valve end protection.

2. Store valves indoors and maintain at higher than ambient dew point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.
- C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use handwheels or stems as lifting or rigging points.

## **PART 2 - PRODUCTS**

### **2.01 GENERAL REQUIREMENTS FOR VALVES**

- A. Source Limitations for Valves: Obtain each type of valve from single source from single manufacturer.
- B. ASME Compliance:
1. ASME B1.20.1 for threads for threaded end valves.
  2. ASME B16.1 for flanges on iron valves.
  3. ASME B16.5 for flanges on steel valves.
  4. ASME B16.10 and ASME B16.34 for ferrous valve dimensions and design criteria.
  5. ASME B16.18 for solder-joint connections.
  6. ASME B31.9 for building services piping valves.
- C. California Health and Safety Code Compliance: HSC 116875 for valves for potable water service. Valves for potable water service shall be third-party certified by an approved laboratory as complying with California Health and Safety Code Section 116875.
1. NSF Compliance: NSF 61 Annex G and NSF 372 for valve materials for potable-water service.
- D. Bronze valves shall be made with dezincification-resistant materials. Bronze valves made with copper alloy (brass) containing more than 15 percent zinc are not permitted.
- E. Valve Pressure-Temperature Ratings: Not less than indicated and as required for system pressures and temperatures.
- F. Valve Sizes: Same as upstream piping unless otherwise indicated.
- G. Valve Actuator Types:
1. Gear Actuator: For quarter-turn valves NPS 4 and larger.
  2. Handlever: For quarter-turn valves smaller than NPS 4.
- H. Valves in Insulated Piping:
1. Include 2-inch stem extensions.
  2. Extended operating handles of nonthermal-conductive material and protective sleeves that allow operation of valves without breaking vapor seals or disturbing insulation.
  3. Memory stops that are fully adjustable after insulation is applied.

### **2.02 BRASS BALL VALVES**

- A. Brass Ball Valves, Two-Piece with Full Port and Brass Trim:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:

- a. American Valve, Inc.
  - b. Crane; Crane Energy Flow Solutions.
  - c. Milwaukee Valve Company.
  - d. NIBCO INC.
  - e. Watts; a Watts Water Technologies company.
2. Description:
- a. Standard: MSS SP-110.
  - b. CWP Rating: 600 psig.
  - c. Body Design: Two piece.
  - d. Body Material: Forged brass.
  - e. Ends: Threaded and soldered. See valve schedule articles.
  - f. Seats: PTFE.
  - g. Stem: Brass.
  - h. Ball: Chrome-plated brass.
  - i. Port: Full.
- B. Brass Ball Valves, Two-Piece with Full Port and Stainless-Steel Trim:
- 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Apollo Valves; Conbraco Industries, Inc.
    - b. FNW; Ferguson Enterprises, Inc.
    - c. Jomar Valve.
    - d. KITZ Corporation.
    - e. Marwin Valve; Richards Industries.
    - f. Milwaukee Valve Company.
  - 2. Description:
    - a. Standard: MSS SP-110.
    - b. CWP Rating: 600 psig.
    - c. Body Design: Two piece.
    - d. Body Material: Forged brass.
    - e. Ends: Threaded and soldered. See valve schedule articles.
    - f. Seats: PTFE.
    - g. Stem: Stainless steel.
    - h. Ball: Stainless steel, vented.
    - i. Port: Full.
- C. Brass Ball Valves, Three-Piece with Full Port and Brass Trim:



1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Jomar Valve.
  - b. KITZ Corporation.
  - c. Watts; a Watts Water Technologies company.
2. Description:
  - a. Standard: MSS SP-110.
  - b. CWP Rating: 600 psig.
  - c. Body Design: Three piece.
  - d. Body Material: Forged brass.
  - e. Ends: Threaded and soldered. See valve schedule articles.
  - f. Seats: PTFE.
  - g. Stem: Brass.
  - h. Ball: Chrome-plated brass.
  - i. Port: Full.

### **2.03 BRONZE BALL VALVES**

#### **A. Bronze Ball Valves, Two-Piece with Full Port, and Bronze or Brass Trim:**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Crane; Crane Energy Flow Solutions.
  - b. Milwaukee Valve Company.
  - c. NIBCO INC.
  - d. Watts; a Watts Water Technologies company.
  - e. Zurn Industries, LLC.
2. Description:
  - a. Standard: MSS SP-110.
  - b. CWP Rating: 600 psig.
  - c. Body Design: Two piece.
  - d. Body Material: Bronze.
  - e. Ends: Threaded and soldered. See valve schedule articles.
  - f. Seats: PTFE.
  - g. Stem: Bronze or brass.
  - h. Ball: Chrome-plated brass.
  - i. Port: Full.

#### **B. Bronze Ball Valves, Three-Piece with Full Port and Bronze or Brass Trim:**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Milwaukee Valve Company.
  - b. NIBCO INC.
  - c. Watts; a Watts Water Technologies company.
2. Description:
  - a. Standard: MSS SP-110.
  - b. CWP Rating: 600 psig.
  - c. Body Design: Three piece.
  - d. Body Material: Bronze.
  - e. Ends: Threaded and soldered. See valve schedule articles.
  - f. Seats: PTFE.
  - g. Stem: Bronze or brass.
  - h. Ball: Chrome-plated brass.
  - i. Port: Full.

#### **2.04 STEEL BALL VALVES**

##### **A. Steel Ball Valves with Full Port, Class 150:**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Apollo Valves; Conbraco Industries, Inc.
  - b. Jamesbury; Metso.
  - c. NIBCO INC.
2. Description:
  - a. Standard: MSS SP-72.
  - b. CWP Rating: 285 psig.
  - c. Body Design: Split body.
  - d. Body Material: Carbon steel, ASTM A 216, Type WCB.
  - e. Ends: Flanged or threaded. See valve schedule articles.
  - f. Seats: PTFE.
  - g. Stem: Stainless steel.
  - h. Ball: Stainless steel, vented.
  - i. Port: Full.

#### **2.05 IRON BALL VALVES**

##### **A. Iron Ball Valves, Class 125:**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Apollo Valves; Conbraco Industries, Inc.
  - b. Conbraco Industries, Inc.
  - c. KITZ Corporation.
  - d. Watts; a Watts Water Technologies company.
  - e. Zurn Industries, LLC.
2. Description:
  - a. Standard: MSS SP-72.
  - b. CWP Rating: 200 psig.
  - c. Body Design: Split body.
  - d. Body Material: ASTM A 126, gray iron.
  - e. Ends: Flanged or threaded . See valve schedule articles.
  - f. Seats: PTFE.
  - g. Stem: Stainless steel.
  - h. Ball: Stainless steel.
  - i. Port: Full.

## **2.06 BRONZE SWING CHECK VALVES**

### **A. Bronze Swing Check Valves with Bronze Disc, Class 125:**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. American Valve, Inc.
  - b. Crane; Crane Energy Flow Solutions.
  - c. Jenkins Valves; Crane Energy Flow Solutions.
  - d. KITZ Corporation.
  - e. NIBCO INC.
  - f. Watts; a Watts Water Technologies company.
2. Description:
  - a. Standard: MSS SP-80, Type 3.
  - b. CWP Rating: 200 psig.
  - c. Body Design: Horizontal flow.
  - d. Body Material: ASTM B 62, bronze.
  - e. Ends: Threaded or soldered. See valve schedule articles.
  - f. Disc: Bronze.

## **2.07 BRONZE GATE VALVES**

- A. Bronze Gate Valves, RS, Class 125:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Apollo Valves; Conbraco Industries, Inc.
    - b. Milwaukee Valve Company.
    - c. NIBCO INC.
    - d. Watts; a Watts Water Technologies company.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 1.
    - b. CWP Rating: 200 psig.
    - c. Body Material: ASTM B 62, bronze with integral seat and screw-in bonnet.
    - d. Ends: Threaded or solder joint.
    - e. Stem: Bronze.
    - f. Disc: Solid wedge; bronze.
    - g. Packing: Asbestos free.
    - h. Handwheel: Malleable iron, bronze, or aluminum.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.
- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.
- C. Examine threads on valve and mating pipe for form and cleanliness.
- D. Examine mating flange faces for conditions that might cause leakage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- E. Do not attempt to repair defective valves; replace with new valves.

### **3.02 VALVE INSTALLATION**

- A. Install valves with unions or flanges at each piece of equipment arranged to allow service, maintenance, and equipment removal without system shutdown.
- B. Locate valves for easy access and provide separate support where necessary.
- C. Install valves in horizontal piping with stem at or above center of pipe.
- D. Install valves in position to allow full stem movement.
- E. Install check valves for proper direction of flow and as follows:
  - 1. Swing Check Valves: In horizontal position with hinge pin level.

- F. Install valve tags. Comply with requirements in Section 220553 "Identification for Plumbing Piping and Equipment" for valve tags and schedules.

### **3.03 ADJUSTING**

- A. Adjust or replace valve packing after piping systems have been tested and put into service but before final adjusting and balancing. Replace valves if persistent leaking occurs.

### **3.04 GENERAL REQUIREMENTS FOR VALVE APPLICATIONS**

- A. Use gate valves only where shown on Drawings. Include hose-end connection if applicable for drain service.
- B. If valve applications are not indicated, use the following:
  - 1. Shutoff Service: Ball valves.
  - 2. Pump-Discharge Check Valves:
    - a. NPS 2 and Smaller: Bronze swing check valves with bronze disc.
- C. If valves with specified CWP ratings are not available, the same types of valves with higher CWP ratings may be substituted.
- D. Select valves with the following end connections:
  - 1. For Copper Tubing, NPS 2 and Smaller: Threaded ends except where solder-joint valve-end option is indicated in valve schedules below.
  - 2. For Copper Tubing, NPS 2-1/2 to NPS 4: Flanged ends except where threaded valve-end option is indicated in valve schedules below.

### **3.05 DOMESTIC, HOT- AND COLD-WATER VALVE SCHEDULE**

- A. Pipe NPS 2 and Smaller:
  - 1. Bronze and Brass Valves: May be provided with solder-joint ends instead of threaded ends.
  - 2. Ball Valves: Two and Three piece, full port, brass or bronze with brass or bronze trim.
  - 3. Bronze Swing Check Valves: Class 125, bronze disc.
- B. Pipe NPS 2-1/2 and Larger:
  - 1. Steel and Iron Valves, NPS 2-1/2 to NPS 4: May be provided with threaded ends instead of flanged ends.
  - 2. Class 150, steel ball valves with full port.
  - 3. Iron Ball Valves: Class 125.

END OF SECTION

**SECTION 22 05 29**  
**HANGERS AND SUPPORTS FOR PLUMBING PIPING AND EQUIPMENT**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Metal pipe hangers and supports.
  - 2. Trapeze pipe hangers.
  - 3. Metal framing systems.
  - 4. Fastener systems.
  - 5. Pipe stands.
  - 6. Pipe-positioning systems.
  - 7. Equipment supports.
- B. Related Requirements:
  - 1. Section 055000 "Metal Fabrications" for structural-steel shapes and plates for trapeze hangers for pipe and equipment supports.
  - 2. Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment" for vibration isolation devices.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
  - 1. Product Data: For recycled content, indicating postconsumer and preconsumer recycled content and cost.
  - 2. Environmental Product Declaration: For each product.
  - 3. Health Product Declaration: For each product.
  - 4. Sourcing of Raw Materials: Corporate sustainability report for each manufacturer.
- B. Shop Drawings: Signed and sealed by a qualified professional engineer. Show fabrication and installation details and include calculations for the following:
  - 1. Trapeze pipe hangers.
  - 2. Metal framing systems.
  - 3. Pipe stands.
  - 4. Equipment supports.
- C. Delegated-Design Submittal: For trapeze hangers indicated to comply with performance requirements and design criteria, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
  - 1. Detail fabrication and assembly of trapeze hangers.
  - 2. Include design calculations for designing trapeze hangers.

### **1.03 INFORMATIONAL SUBMITTALS**

- A. Welding certificates.

### **1.04 QUALITY ASSURANCE**

- A. Structural-Steel Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M.
- B. Pipe Welding Qualifications: Qualify procedures and operators according to 2015 ASME Boiler and Pressure Vessel Code, Section IX.

## **PART 2 - PRODUCTS**

### **2.01 PERFORMANCE REQUIREMENTS**

- A. Structural Performance: Hangers and supports for plumbing piping and equipment shall withstand the effects of gravity loads and stresses within limits and under conditions indicated according to CBC and ASCE/SEI 7 as referenced by the CBC.
  - 1. Design supports for multiple pipes, including pipe stands, capable of supporting combined weight of supported systems, system contents, and test water.
  - 2. Design equipment supports capable of supporting combined operating weight of supported equipment and connected systems and components.

### **2.02 METAL PIPE HANGERS AND SUPPORTS**

- A. Carbon-Steel Pipe Hangers and Supports:
  - 1. Description: MSS SP-58, Types 1 through 58, factory-fabricated components.
  - 2. Galvanized Metallic Coatings: Pregalvanized, hot-dip galvanized, or electro-galvanized.
  - 3. Nonmetallic Coatings: Plastic coated or epoxy powder coated.
  - 4. Padded Hangers: Hanger with fiberglass or other pipe insulation pad or cushion to support bearing surface of piping.
  - 5. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
- B. Copper Pipe and Tube Hangers:
  - 1. Description: MSS SP-58, Types 1 through 58, copper-coated-steel, factory-fabricated components.
  - 2. Hanger Rods: Continuous-thread rod, nuts, and washer made of copper-coated steel.

### **2.03 TRAPEZE PIPE HANGERS**

- A. Description: MSS SP-58, Type 59, shop- or field-fabricated pipe-support assembly, made from structural-carbon-steel shapes, with MSS SP-58 carbon-steel hanger rods, nuts, saddles, and U-bolts.

### **2.04 METAL FRAMING SYSTEMS**

- A. MFMA Manufacturer Metal Framing Systems:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:

- a. B-line, an Eaton business.
  - b. Flex-Strut Inc.
  - c. Thomas & Betts Corporation; A Member of the ABB Group.
  - d. Unistrut; Part of Atkore International.
  - e. Wesanco, Inc.
2. Description: Shop- or field-fabricated pipe-support assembly, made of steel channels, accessories, fittings, and other components for supporting multiple parallel pipes.
  3. Standard: Comply with MFMA-4, factory-fabricated components for field assembly.
  4. Channels: Continuous slotted carbon-steel channel with inturned lips.
  5. Channel Width: Selected for applicable load criteria.
  6. Channel Nuts: Formed or stamped nuts or other devices designed to fit into channel slot and, when tightened, prevent slipping along channel.
  7. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
  8. Metallic Coating: Electroplated zinc.

## **2.05 THERMAL HANGER-SHIELD INSERTS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. Carpenter & Paterson, Inc.
  2. Clement Support Services.
  3. ERICO International Corporation.
  4. National Pipe Hanger Corporation.
  5. Pipe Shields Inc.
  6. Piping Technology & Products, Inc.
  7. Rilco Manufacturing Co., Inc.
  8. Value Engineered Products, Inc.
- B. Insulation-Insert Material for Cold Piping: ASTM C552, Type II cellular glass with 100-psig or ASTM C 591, Type VI, Grade 1 polyisocyanurate with 125-psig minimum compressive strength and vapor barrier. .
- C. Insulation-Insert Material for Hot Piping: Water-repellent-treated, ASTM C533, Type I calcium silicate with 100-psig minimum compressive strength.
- D. For Trapeze or Clamped Systems: Insert and shield shall cover entire circumference of pipe.
- E. For Clevis or Band Hangers: Insert and shield shall cover lower 180 degrees of pipe.
- F. Insert Length: Extend 2 inches beyond sheet metal shield for piping operating below ambient air temperature.

## **2.06 FASTENER SYSTEMS**

- A. Mechanical-Expansion Anchors: Insert-wedge-type anchors, for use in hardened portland cement concrete, with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used. Refer to structural Drawings.



1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. B-line, an Eaton business.
  - b. Empire Tool and Manufacturing Co., Inc.
  - c. Hilti, Inc.
  - d. ITW Ramset/Red Head; Illinois Tool Works, Inc.
  - e. MKT Fastening, LLC.
2. Indoor Applications: Zinc-coated steel.
3. Outdoor Applications: Stainless steel.

## **2.07 PIPE STANDS**

- A. General Requirements for Pipe Stands: Shop- or field-fabricated assemblies made of manufactured corrosion-resistant components to support roof-mounted piping.
- B. High-Profile, Single-Base, Single-Pipe Stand:
  1. Description: Single base, vertical and horizontal members, and pipe support, for roof installation without membrane penetration.
  2. Base: Single vulcanized rubber or molded polypropylene.
  3. Vertical Members: Two galvanized-steel, continuous-thread, 1/2-inch rods.
  4. Horizontal Member: One adjustable-height, galvanized-steel, pipe-support slotted channel or plate.
  5. Pipe Supports: Galvanized steel clevis hanger.
  6. Hardware: Stainless steel.
- C. High-Profile, Multiple-Pipe Stand:
  1. Description: Assembly of bases, vertical and horizontal members, and pipe supports, for roof installation without membrane penetration.
  2. Bases: Two or more; vulcanized rubber or molded polypropylene.
  3. Horizontal Members: One or more, adjustable-height, galvanized-steel pipe support.
  4. Pipe Supports: Galvanized steel clevis hanger.
  5. Hardware: Stainless steel.
- D. Curb-Mounted-Type Pipe Stands: Shop- or field-fabricated pipe supports made from structural-steel shapes, continuous-thread rods, and rollers, for mounting on permanent stationary roof curb.

## **2.08 PIPE-POSITIONING SYSTEMS**

- A. Description: IAPMO PS 42 positioning system composed of metal brackets, clips, and straps for positioning piping in pipe spaces; for plumbing fixtures in commercial applications.

## **2.09 EQUIPMENT SUPPORTS**

- A. Description: Welded, shop- or field-fabricated equipment support made from structural-carbon-steel shapes.

## 2.10 MATERIALS

- A. Aluminum: ASTM B221.
- B. Carbon Steel: ASTM A1011/A1011M.
- C. Structural Steel: ASTM A36/A36M carbon-steel plates, shapes, and bars; black and galvanized.
- D. Stainless Steel: ASTM A240/A240M.
- E. Grout: ASTM C1107/C1107M, factory-mixed and -packaged, dry, hydraulic-cement, nonshrink and nonmetallic grout; suitable for interior and exterior applications.
  - 1. Properties: Nonstaining, noncorrosive, and nongaseous.
  - 2. Design Mix: 5000-psi, 28-day compressive strength.

## PART 3 - EXECUTION

### 3.01 APPLICATION

- A. Comply with requirements in Section 078400 "Firestopping" for firestopping materials and installation, for penetrations through fire-rated walls, ceilings, and assemblies.

### 3.02 HANGER AND SUPPORT INSTALLATION

- A. Metal Pipe-Hanger Installation: Comply with MSS SP-58. Install hangers, supports, clamps, and attachments as required to properly support piping from building structure.
- B. Metal Trapeze Pipe-Hanger Installation: Comply with MSS SP-58. Arrange for grouping of parallel runs of horizontal piping, and support together on field-fabricated trapeze pipe hangers.
  - 1. Pipes of Various Sizes: Support together and space trapezes for smallest pipe size, or install intermediate supports for smaller-diameter pipes as specified for individual pipe hangers.
  - 2. Field fabricate from ASTM A36/A36M carbon-steel shapes selected for loads being supported. Weld steel according to AWS D1.1/D1.1M.
- C. Metal Framing System Installation: Arrange for grouping of parallel runs of piping, and support together on field-assembled metal framing systems.
- D. Thermal Hanger-Shield Installation: Install in pipe hanger or shield for insulated piping.
- E. Fastener System Installation:
  - 1. Install mechanical-expansion anchors in concrete, after concrete is placed and completely cured. Install fasteners according to manufacturer's written instructions.
- F. Pipe Stand Installation:
  - 1. Pipe Stand Types, except Curb-Mounted Type: Assemble components and mount on smooth roof surface. Do not penetrate roof membrane.
  - 2. Curb-Mounted-Type Pipe Stands: Assemble components or fabricate pipe stand and mount on permanent, stationary roof curb. See Section 077200 "Roof Accessories" for curbs.
- G. Pipe-Positioning-System Installation: Install support devices to make rigid supply and waste piping connections to each plumbing fixture.

- H. Install hangers and supports complete with necessary attachments, inserts, bolts, rods, nuts, washers, and other accessories.
- I. Equipment Support Installation: Fabricate from welded-structural-steel shapes.
- J. Install hangers and supports to allow controlled thermal and seismic movement of piping systems, to permit freedom of movement between pipe anchors, and to facilitate action of expansion joints, expansion loops, expansion bends, and similar units.
- K. Install lateral bracing with pipe hangers and supports to prevent swaying.
- L. Install building attachments within concrete slabs or attach to structural steel. Install additional attachments at concentrated loads, including valves, flanges, and strainers, NPS 2-1/2 and larger and at changes in direction of piping. Install concrete inserts before concrete is placed; fasten inserts to forms, and install reinforcing bars through openings at top of inserts.
- M. Load Distribution: Install hangers and supports, so that piping live and dead loads and stresses from movement will not be transmitted to connected equipment.
- N. Pipe Slopes: Install hangers and supports to provide indicated pipe slopes and to not exceed maximum pipe deflections allowed by ASME B31.9 for building services piping.
- O. Insulated Piping:
  - 1. Attach clamps and spacers to piping.
    - a. Piping Operating Above Ambient Air Temperature: Clamp may project through insulation.
    - b. Piping Operating Below Ambient Air Temperature: Use thermal hanger-shield insert with clamp sized to match OD of insert.
    - c. Do not exceed pipe stress limits allowed by ASME B31.9 for building services piping.
  - 2. Install MSS SP-58, Type 39 protection saddles if insulation without vapor barrier is indicated. Fill interior voids with insulation that matches adjoining insulation.
    - a. Option: Thermal hanger-shield inserts may be used. Include steel weight-distribution plate for pipe NPS 4 and larger if pipe is installed on rollers.
  - 3. Install MSS SP-58, Type 40 protective shields on cold piping with vapor barrier. Shields shall span an arc of 180 degrees.
    - a. Option: Thermal hanger-shield inserts may be used. Include steel weight-distribution plate for pipe NPS 4 and larger if pipe is installed on rollers.
  - 4. Shield Dimensions for Pipe: Not less than the following:
    - a. NPS 1/4 to NPS 3-1/2: 12 inches long and 0.048 inch thick.
    - b. NPS 4: 12 inches long and 0.06 inch thick.
    - c. NPS 5 and NPS 6: 18 inches long and 0.06 inch thick.
    - d. NPS 8 to NPS 14: 24 inches long and 0.075 inch thick.
  - 5. Pipes NPS 8 and Larger: Include reinforced calcium-silicate-insulation inserts of length at least as long as protective shield.
  - 6. Thermal Hanger Shields: Install with insulation of same thickness as piping insulation.

### **3.03 EQUIPMENT SUPPORTS**

- A. Fabricate structural-steel stands to suspend equipment from structure overhead or to support equipment above floor.
- B. Grouting: Place grout under supports for equipment, and make bearing surface smooth.
- C. Provide lateral bracing, to prevent swaying, for equipment supports.

### **3.04 METAL FABRICATIONS**

- A. Cut, drill, and fit miscellaneous metal fabrications for trapeze pipe hangers and equipment supports.
- B. Fit exposed connections together to form hairline joints. Field weld connections that cannot be shop welded because of shipping size limitations.
- C. Field Welding: Comply with AWS D1.1/D1.1M procedures for shielded, metal arc welding; appearance and quality of welds; and methods used in correcting welding work; and with the following:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. Finish welds at exposed connections, so no roughness shows after finishing and so contours of welded surfaces match adjacent contours.

### **3.05 ADJUSTING**

- A. Hanger Adjustments: Adjust hangers to distribute loads equally on attachments and to achieve indicated slope of pipe.
- B. Trim excess length of continuous-thread hanger and support rods to 1-1/2 inches.

### **3.06 PAINTING**

- A. Touchup: Clean field welds and abraded, shop-painted areas. Paint exposed areas immediately after erecting hangers and supports. Use same materials as those used for shop painting. Comply with SSPC-PA 1 requirements for touching up field-painted surfaces.
  - 1. Apply paint by brush or spray to provide a minimum dry film thickness of 2.0 mils.
- B. Touchup: Cleaning and touchup painting of field welds, bolted connections, and abraded, shop-painted areas on miscellaneous metal are specified in Section 099123 "Interior Painting." And Section 099600 "High-Performance Coatings."
- C. Galvanized Surfaces: Clean welds, bolted connections, and abraded areas, and apply galvanizing-repair paint to comply with ASTM A780/A780M.

### **3.07 HANGER AND SUPPORT SCHEDULE**

- A. Specific hanger and support requirements are in Sections specifying piping systems and equipment.
- B. Comply with MSS SP-58 for pipe-hanger selections and applications that are not specified in piping system Sections.

- C. Use hangers and supports with galvanized metallic coatings for piping and equipment that will not have field-applied finishes.
- D. Use nonmetallic coatings on attachments for electrolytic protection where attachments are in direct contact with copper tubing.
- E. Use carbon-steel pipe hangers and supports, metal trapeze pipe hangers and metal framing systems and attachments for general service applications.
- F. Use copper-plated pipe hangers and copper attachments for copper piping and tubing.
- G. Use padded hangers for piping that is subject to scratching.
- H. Use thermal hanger-shield inserts for insulated piping and tubing.
- I. Horizontal-Piping Hangers and Supports: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  1. Adjustable, Steel Clevis Hangers (MSS Type 1): For suspension of noninsulated or insulated, stationary pipes NPS 1/2 to NPS 30.
  2. Yoke-Type Pipe Clamps (MSS Type 2): For suspension of up to 1050 deg F pipes NPS 4 to NPS 24, requiring up to 4 inches of insulation.
  3. Carbon- or Alloy-Steel, Double-Bolt Pipe Clamps (MSS Type 3): For suspension of pipes NPS 3/4 to NPS 36, requiring clamp flexibility and up to 4 inches of insulation.
  4. Steel Pipe Clamps (MSS Type 4): For suspension of cold and hot pipes NPS 1/2 to NPS 24 if little or no insulation is required.
  5. Pipe Hangers (MSS Type 5): For suspension of pipes NPS 1/2 to NPS 4, to allow off-center closure for hanger installation before pipe erection.
  6. Adjustable, Swivel Split- or Solid-Ring Hangers (MSS Type 6): For suspension of noninsulated, stationary pipes NPS 3/4 to NPS 8.
  7. Adjustable, Steel Band Hangers (MSS Type 7): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
  8. Adjustable Band Hangers (MSS Type 9): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
  9. Adjustable, Swivel-Ring Band Hangers (MSS Type 10): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
  10. Split Pipe Ring with or without Turnbuckle Hangers (MSS Type 11): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 8.
  11. Extension Hinged or Two-Bolt Split Pipe Clamps (MSS Type 12): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 3.
  12. U-Bolts (MSS Type 24): For support of heavy pipes NPS 1/2 to NPS 30.
  13. Clips (MSS Type 26): For support of insulated pipes not subject to expansion or contraction.
  14. Pipe Saddle Supports (MSS Type 36): For support of pipes NPS 4 to NPS 36, with steel-pipe base stanchion support and cast-iron floor flange or carbon-steel plate.
  15. Pipe Stanchion Saddles (MSS Type 37): For support of pipes NPS 4 to NPS 36, with steel-pipe base stanchion support and cast-iron floor flange or carbon-steel plate, and with U-bolt to retain pipe.

16. Adjustable Pipe Saddle Supports (MSS Type 38): For stanchion-type support for pipes NPS 2-1/2 to NPS 36 if vertical adjustment is required, with steel-pipe base stanchion support and cast-iron floor flange.
  17. Single-Pipe Rolls (MSS Type 41): For suspension of pipes NPS 1 to NPS 30, from two rods if longitudinal movement caused by expansion and contraction occurs.
  18. Adjustable Roller Hangers (MSS Type 43): For suspension of pipes NPS 2-1/2 to NPS 24, from single rod if horizontal movement caused by expansion and contraction occurs.
  19. Complete Pipe Rolls (MSS Type 44): For support of pipes NPS 2 to NPS 42 if longitudinal movement caused by expansion and contraction occurs but vertical adjustment is unnecessary.
  20. Pipe Roll and Plate Units (MSS Type 45): For support of pipes NPS 2 to NPS 24 if small horizontal movement caused by expansion and contraction occurs and vertical adjustment is unnecessary.
  21. Adjustable Pipe Roll and Base Units (MSS Type 46): For support of pipes NPS 2 to NPS 30 if vertical and lateral adjustment during installation, in addition to expansion and contraction, is required.
- J. Vertical-Piping Clamps: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Extension Pipe or Riser Clamps (MSS Type 8): For support of pipe risers NPS 3/4 to NPS 24.
  2. Carbon- or Alloy-Steel Riser Clamps (MSS Type 42): For support of pipe risers NPS 3/4 to NPS 24 if longer ends are required for riser clamps.
- K. Hanger-Rod Attachments: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Steel Turnbuckles (MSS Type 13): For adjustment of up to 6 inches for heavy loads.
  2. Steel Clevises (MSS Type 14): For 120 to 450 deg F piping installations.
  3. Swivel Turnbuckles (MSS Type 15): For use with MSS Type 11 split pipe rings.
  4. Malleable-Iron Sockets (MSS Type 16): For attaching hanger rods to various types of building attachments.
  5. Steel Weldless Eye Nuts (MSS Type 17): For 120 to 450 deg F piping installations.
- L. Building Attachments: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Steel or Malleable-Concrete Inserts (MSS Type 18): For upper attachment to suspend pipe hangers from concrete ceiling.
  2. Top-Beam C-Clamps (MSS Type 19): For use under roof installations with bar-joint construction, to attach to top flange of structural shape.
  3. Side-Beam or Channel Clamps (MSS Type 20): For attaching to bottom flange of beams, channels, or angles.
  4. Center-Beam Clamps (MSS Type 21): For attaching to center of bottom flange of beams.
  5. Welded Beam Attachments (MSS Type 22): For attaching to bottom of beams if loads are considerable and rod sizes are large.
  6. C-Clamps (MSS Type 23): For structural shapes.

7. Top-Beam Clamps (MSS Type 25): For top of beams if hanger rod is required tangent to flange edge.
  8. Side-Beam Clamps (MSS Type 27): For bottom of steel I-beams.
  9. Steel-Beam Clamps with Eye Nuts (MSS Type 28): For attaching to bottom of steel I-beams for heavy loads.
  10. Linked-Steel Clamps with Eye Nuts (MSS Type 29): For attaching to bottom of steel I-beams for heavy loads, with link extensions.
  11. Malleable-Beam Clamps with Extension Pieces (MSS Type 30): For attaching to structural steel.
  12. Welded-Steel Brackets: For support of pipes from below or for suspending from above by using clip and rod. Use one of the following for indicated loads:
    - a. Light (MSS Type 31): 750 lb.
    - b. Medium (MSS Type 32): 1500 lb.
    - c. Heavy (MSS Type 33): 3000 lb.
  13. Side-Beam Brackets (MSS Type 34): For sides of steel or wooden beams.
  14. Plate Lugs (MSS Type 57): For attaching to steel beams if flexibility at beam is required.
  15. Horizontal Travelers (MSS Type 58): For supporting piping systems subject to linear horizontal movement where headroom is limited.
- M. Saddles and Shields: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Steel-Pipe-Covering Protection Saddles (MSS Type 39): To fill interior voids with insulation that matches adjoining insulation.
  2. Protection Shields (MSS Type 40): Of length recommended in writing by manufacturer to prevent crushing insulation.
  3. Thermal Hanger-Shield Inserts: For supporting insulated pipe.
- N. Spring Hangers and Supports: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Restraint-Control Devices (MSS Type 47): Where indicated to control piping movement.
  2. Spring Cushions (MSS Type 48): For light loads if vertical movement does not exceed 1-1/4 inches.
  3. Spring-Cushion Roll Hangers (MSS Type 49): For equipping Type 41 roll hanger with springs.
  4. Spring Sway Braces (MSS Type 50): To retard sway, shock, vibration, or thermal expansion in piping systems.
  5. Variable-Spring Hangers (MSS Type 51): Preset to indicated load, and limit variability factor to 25 percent to allow expansion and contraction of piping system from hanger.
  6. Variable-Spring Base Supports (MSS Type 52): Preset to indicated load, and limit variability factor to 25 percent to allow expansion and contraction of piping system from base support.

7. Variable-Spring Trapeze Hangers (MSS Type 53): Preset to indicated load, and limit variability factor to 25 percent to allow expansion and contraction of piping system from trapeze support.
8. Constant Supports: For critical piping stress and if necessary to avoid transfer of stress from one support to another support, critical terminal, or connected equipment. Include auxiliary stops for erection, hydrostatic test, and load-adjustment capability. These supports include the following types:
  - a. Horizontal (MSS Type 54): Mounted horizontally.
  - b. Vertical (MSS Type 55): Mounted vertically.
  - c. Trapeze (MSS Type 56): Two vertical-type supports and one trapeze member.
- O. Comply with MSS SP-58 for trapeze pipe-hanger selections and applications that are not specified in piping system Sections.
- P. Comply with MFMA-103 for metal framing system selections and applications that are not specified in piping system Sections.
- Q. Use mechanical-expansion anchors instead of building attachments where required in concrete construction.
- R. Use pipe-positioning systems in pipe spaces behind plumbing fixtures to support supply and waste piping for plumbing fixtures.

END OF SECTION





## SECTION 220548

### VIBRATION AND SEISMIC CONTROLS FOR PLUMBING PIPING AND EQUIPMENT

#### PART 1 - GENERAL

##### 1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

##### 1.02 SUMMARY

- A. Section Includes:

1. Elastomeric isolation pads.
2. Elastomeric isolation mounts.
3. Restrained elastomeric isolation mounts.
4. Open-spring isolators.
5. Housed-spring isolators.
6. Restrained-spring isolators.
7. Housed-restrained-spring isolators.
8. Pipe-riser resilient supports.
9. Resilient pipe guides.
10. Elastomeric hangers.
11. Spring hangers.
12. Snubbers.
13. Restraint channel bracings.
14. Restraint cables.
15. Seismic-restraint accessories.
16. Mechanical anchor bolts.

- B. Related Requirements:

1. Section 210548 "Vibration and Seismic Controls for Fire-Suppression Piping and Equipment" for devices for fire-suppression equipment and systems.
2. Section 230548 "Vibration and Seismic Controls for HVAC" for devices for HVAC equipment and systems.

##### 1.03 DEFINITIONS

- A. OSHPD: Office of Statewide Health Planning & Development (for the State of California).

##### 1.04 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1. Include rated load, rated deflection, and overload capacity for each vibration isolation device.
  2. Illustrate and indicate style, material, strength, fastening provision, and finish for each type and size of vibration isolation device and seismic-restraint component required.
    - a. Tabulate types and sizes of seismic restraints, complete with report numbers and rated strength in tension and shear as evaluated by OSHPD.
    - b. Annotate to indicate application of each product submitted and compliance with requirements.
  3. Interlocking Snubbers: Include ratings for horizontal, vertical, and combined loads.
- B. Shop Drawings:
1. Detail fabrication and assembly of equipment bases. Detail fabrication including anchorages and attachments to structure and to supported equipment.
- C. Delegated-Design Submittal: For each vibration isolation and seismic-restraint device.
1. Calculations performed for use in selection of seismic supports, anchorages, and restraints shall utilize criteria indicated in Structural Contract Documents.
  2. Supports, anchorage and restraints for piping, ductwork, and equipment shall be an OSHPD pre-approved system such as Tolco, ISAT, Mason, or equal. Pipes, ducts and equipment shall be seismically restrained in accordance with requirements of current edition of California Building Code. System shall have current OPM number and shall meet additional requirements of authority having jurisdiction. Provide supporting documentation required by the reviewing authority and the Architect and Engineer. Provide layout drawings showing piping, ductwork and restraint locations.
    - a. Bracing of Piping and Equipment: Specifically state how bracing attachment to structure is accomplished. Provide shop drawings indicating seismic restraints, including details of anchorage to building. In-line equipment must be braced independently of piping, and in conformance with applicable building codes. Provide calculations to show that pre-approval numbers have been correctly applied in accordance with general information notes of pre-approval documentation. Gas pipe bracing shall be designed in accordance with California Building Code Section 1615A.1.22 and ASCE 7-10 Section 13.6. Coefficient  $I_p = 1.5$  shall be used for gas piping bracing calculations.
  3. In lieu of the above or for non-standard installations not covered in the above pre-approved systems, Contractor shall provide layout drawings showing piping, ductwork, and restraint locations, and detail supports, attachments and restraints, and furnish supporting calculations and legible details sealed by a California registered structural engineer, in accordance with 2016 California Building Code
  4. Additional Requirements: In addition to the above, conform to all state and local requirements.

### 1.05 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Show coordination of vibration isolation device installation and seismic bracing for plumbing piping and equipment with other systems and equipment in the vicinity, including other supports and restraints, if any. Refer to Section 22 00 50, "Common Work Results for Plumbing Systems for additional requirements.
- B. Qualification Data: For professional engineer and testing agency.
- C. Welding certificates.
- D. Field quality-control reports.

### 1.06 QUALITY ASSURANCE

- A. Testing Agency Qualifications: An independent agency, with the experience and capability to conduct the testing indicated, that is an NRTL as defined by OSHA in 29 CFR 1910.7 and that is acceptable to authorities having jurisdiction.
- B. Comply with seismic-restraint requirements in the CBC unless requirements in this Section are more stringent.
- C. Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code - Steel."
- D. Seismic-restraint devices shall have horizontal and vertical load testing and analysis and shall bear anchorage preapproval OPM number from OSHPD, showing maximum seismic-restraint ratings. For additional requirements, refer to article, Action Submittals.

## PART 2 - PRODUCTS

### 2.01 PERFORMANCE REQUIREMENTS

- A. See structural documents for wind and seismic restraint loads.
- B. Rated strengths, features, and applications shall be as defined in reports by OSHPD or provide calculations, signed and sealed by a qualified structural engineer registered in the State of California.

### 2.02 ELASTOMERIC ISOLATION PADS

- A. Elastomeric Isolation Pads: .
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Kinetics Noise Control, Inc.
    - b. Mason Industries, Inc.
    - c. Vibration Isolation.
    - d. Vibration Mountings & Controls, Inc.
  - 2. Fabrication: Single or multiple layers of sufficient durometer stiffness for uniform loading over pad area.
  - 3. Size: Factory or field cut to match requirements of supported equipment.
  - 4. Pad Material: Oil and water resistant with elastomeric properties.

5. Surface Pattern: Smooth pattern.
6. Infused nonwoven cotton or synthetic fibers.
7. Load-bearing metal plates adhered to pads.
8. Sandwich-Core Material: Resilient and elastomeric.
  - a. Surface Pattern: Smooth pattern.
  - b. Infused nonwoven cotton or synthetic fibers.

### **2.03 ELASTOMERIC ISOLATION MOUNTS**

#### **A. Double-Deflection, Elastomeric Isolation Mounts: .**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Kinetics Noise Control, Inc.
  - b. Mason Industries, Inc.
  - c. Vibration Isolation.
  - d. Vibration Mountings & Controls, Inc.
2. Mounting Plates:
  - a. Top Plate: Encapsulated steel load transfer top plates, factory drilled and threaded with threaded studs or bolts.
  - b. Baseplate: Encapsulated steel bottom plates with holes provided for anchoring to support structure.
3. Elastomeric Material: Molded, oil-resistant rubber, neoprene, or other elastomeric material.

### **2.04 RESTRAINED ELASTOMERIC ISOLATION MOUNTS**

#### **A. Restrained Elastomeric Isolation Mounts: .**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Kinetics Noise Control, Inc.
  - b. Mason Industries, Inc.
  - c. Vibration Isolation.
  - d. Vibration Mountings & Controls, Inc.
2. Description: All-directional isolator with seismic restraints containing two separate and opposing elastomeric elements that prevent central threaded element and attachment hardware from contacting the housing during normal operation.

- a. Housing: Cast-ductile iron or welded steel.
- b. Elastomeric Material: Molded, oil-resistant rubber, neoprene, or other elastomeric material.

## **2.05 OPEN-SPRING ISOLATORS**

### **A. Freestanding, Laterally Stable, Open-Spring Isolators: .**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Kinetics Noise Control, Inc.
  - b. Mason Industries, Inc.
  - c. Vibration Isolation.
  - d. Vibration Mountings & Controls, Inc.
2. Outside Spring Diameter: Not less than 80 percent of the compressed height of the spring at rated load.
3. Minimum Additional Travel: 50 percent of the required deflection at rated load.
4. Lateral Stiffness: More than 80 percent of rated vertical stiffness.
5. Overload Capacity: Support 200 percent of rated load, fully compressed, without deformation or failure.
6. Baseplates: Factory-drilled steel plate for bolting to structure with an elastomeric isolator pad attached to the underside. Baseplates shall limit floor load to 500 psig.
7. Top Plate and Adjustment Bolt: Threaded top plate with adjustment bolt and cap screw to fasten and level equipment.

## **2.06 HOUSED-SPRING ISOLATORS**

### **A. Freestanding, Laterally Stable, Open-Spring Isolators in Two-Part Telescoping Housing: .**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Kinetics Noise Control, Inc.
  - b. Mason Industries, Inc.
  - c. Vibration Isolation.
  - d. Vibration Mountings & Controls, Inc.
2. Outside Spring Diameter: Not less than 80 percent of the compressed height of the spring at rated load.
3. Minimum Additional Travel: 50 percent of the required deflection at rated load.
4. Lateral Stiffness: More than 80 percent of rated vertical stiffness.
5. Overload Capacity: Support 200 percent of rated load, fully compressed, without deformation or failure.

6. Two-Part Telescoping Housing: A steel top and bottom frame separated by an elastomeric material and enclosing the spring isolators.
  - a. Drilled base housing for bolting to structure with an elastomeric isolator pad attached to the underside. Bases shall limit floor load to 500 psig.
  - b. Top housing with attachment and leveling bolt.

## **2.07 RESTRAINED-SPRING ISOLATORS**

### **A. Freestanding, Laterally Stable, Open-Spring Isolators with Vertical-Limit Stop Restraint: .**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Kinetics Noise Control, Inc.
  - b. Mason Industries, Inc.
  - c. Vibration Isolation.
  - d. Vibration Mountings & Controls, Inc.
2. Housing: Steel housing with vertical-limit stops to prevent spring extension due to weight being removed.
  - a. Base with holes for bolting to structure with an elastomeric isolator pad attached to the underside. Bases shall limit floor load to 500 psig.
  - b. Top plate with threaded mounting holes.
  - c. Internal leveling bolt that acts as blocking during installation.
3. Restraint: Limit stop as required for equipment and authorities having jurisdiction.
4. Outside Spring Diameter: Not less than 80 percent of the compressed height of the spring at rated load.
5. Minimum Additional Travel: 50 percent of the required deflection at rated load.
6. Lateral Stiffness: More than 80 percent of rated vertical stiffness.
7. Overload Capacity: Support 200 percent of rated load, fully compressed, without deformation or failure.

## **2.08 HOUSED-RESTRAINED-SPRING ISOLATORS**

### **A. Freestanding, Steel, Open-Spring Isolators with Vertical-Limit Stop Restraint in Two-Part Telescoping Housing: .**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Ace Mountings Co., Inc.
  - b. California Dynamics Corporation.
  - c. Isolation Technology, Inc.

- d. Kinetics Noise Control, Inc.
  - e. Mason Industries, Inc.
  - f. Vibration Eliminator Co., Inc.
  - g. Vibration Isolation.
  - h. Vibration Mountings & Controls, Inc.
2. Two-Part Telescoping Housing: A steel top and bottom frame separated by an elastomeric material and enclosing the spring isolators. Housings are equipped with adjustable snubbers to limit vertical movement.
    - a. Drilled base housing for bolting to structure with an elastomeric isolator pad attached to the underside. Bases shall limit floor load to 500 psig.
    - b. Threaded top housing with adjustment bolt and cap screw to fasten and level equipment.
  3. Outside Spring Diameter: Not less than 80 percent of the compressed height of the spring at rated load.
  4. Minimum Additional Travel: 50 percent of the required deflection at rated load.
  5. Lateral Stiffness: More than 80 percent of rated vertical stiffness.
  6. Overload Capacity: Support 200 percent of rated load, fully compressed, without deformation or failure.

## **2.09 PIPE-RISER RESILIENT SUPPORT**

- A. Description: All-directional, acoustical pipe anchor consisting of two steel tubes separated by a minimum 1/2-inch-thick neoprene.
  1. Vertical-Limit Stops: Steel and neoprene vertical-limit stops arranged to prevent vertical travel in both directions.
  2. Maximum Load Per Support: 500 psig on isolation material providing equal isolation in all directions.

## **2.10 RESILIENT PIPE GUIDES**

- A. Description: Telescopic arrangement of two steel tubes or post and sleeve arrangement separated by a minimum 1/2-inch-thick neoprene.
  1. Factory-Set Height Guide with Shear Pin: Shear pin shall be removable and reinsertable to allow for selection of pipe movement. Guides shall be capable of motion to meet location requirements.

## **2.11 ELASTOMERIC HANGERS**

- A. Elastomeric Mount in a Steel Frame with Upper and Lower Steel Hanger Rods: .
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Kinetics Noise Control, Inc.



- b. Mason Industries, Inc.
  - c. Vibration Eliminator Co., Inc.
  - d. Vibration Mountings & Controls, Inc.
2. Frame: Steel, fabricated with a connection for an upper threaded hanger rod and an opening on the underside to allow for a maximum of 30 degrees of angular lower hanger-rod misalignment without binding or reducing isolation efficiency.
  3. Dampening Element: Molded, oil-resistant rubber, neoprene, or other elastomeric material with a projecting bushing for the underside opening preventing steel to steel contact.

## 2.12 SPRING HANGERS

### A. Combination Coil-Spring and Elastomeric-Insert Hanger with Spring and Insert in Compression:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Kinetics Noise Control, Inc.
  - b. Mason Industries, Inc.
  - c. Vibration Isolation.
  - d. Vibration Mountings & Controls, Inc.
2. Frame: Steel, fabricated for connection to threaded hanger rods and to allow for a maximum of 30 degrees of angular hanger-rod misalignment without binding or reducing isolation efficiency.
3. Outside Spring Diameter: Not less than 80 percent of the compressed height of the spring at rated load.
4. Minimum Additional Travel: 50 percent of the required deflection at rated load.
5. Lateral Stiffness: More than 80 percent of rated vertical stiffness.
6. Overload Capacity: Support 200 percent of rated load, fully compressed, without deformation or failure.
7. Elastomeric Element: Molded, oil-resistant rubber or neoprene. Steel-washer-reinforced cup to support spring and bushing projecting through bottom of frame.
8. Adjustable Vertical Stop: Steel washer with neoprene washer "up-stop" on lower threaded rod.
9. Self-centering hanger-rod cap to ensure concentricity between hanger rod and support spring coil.

## 2.13 SNUBBERS

### A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:

1. Kinetics Noise Control, Inc.

2. Mason Industries, Inc.
  3. Vibration Mountings & Controls, Inc.
- B. Description: Factory fabricated using welded structural-steel shapes and plates, anchor bolts, and replaceable resilient isolation washers and bushings.
1. Anchor bolts for attaching to concrete shall be seismic-rated, drill-in, and stud-wedge or female-wedge type.
  2. Resilient Isolation Washers and Bushings: Oil- and water-resistant neoprene.
  3. Maximum 1/4-inch air gap, and minimum 1/4-inch-thick resilient cushion.

#### **2.14 RESTRAINT CHANNEL BRACINGS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
1. B-line, an Eaton business.
  2. Hilti, Inc.
  3. Mason Industries, Inc.
  4. Unistrut; Part of Atkore International.
- B. Description: MFMA-4, shop- or field-fabricated bracing assembly made of slotted steel channels with accessories for attachment to braced component at one end and to building structure at the other end and other matching components and with corrosion-resistant coating; rated in tension, compression, and torsion forces.

#### **2.15 RESTRAINT CABLES**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
1. Kinetics Noise Control, Inc.
  2. Mason Industries, Inc.
  3. Vibration Mountings & Controls, Inc.
- B. Restraint Cables: ASTM A 603 galvanized-steel cables. End connections made of steel assemblies with thimbles, brackets, swivel, and bolts designed for restraining cable service; with a minimum of two clamping bolts for cable engagement.

#### **2.16 SEISMIC-RESTRAINT ACCESSORIES**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
1. B-line, an Eaton business.
  2. Kinetics Noise Control, Inc.
  3. Mason Industries, Inc.
  4. TOLCO.
- B. Hanger-Rod Stiffener: Steel tube or steel slotted-support-system sleeve with internally bolted connections or reinforcing steel angle clamped to hanger rod.

- C. Hinged and Swivel Brace Attachments: Multifunctional steel connectors for attaching hangers to rigid channel bracings and restraint cables.
- D. Bushings for Floor-Mounted Equipment Anchor Bolts: Neoprene bushings designed for rigid equipment mountings, and matched to type and size of anchor bolts and studs.
- E. Bushing Assemblies for Wall-Mounted Equipment Anchorage: Assemblies of neoprene elements and steel sleeves designed for rigid equipment mountings, and matched to type and size of attachment devices used.
- F. Resilient Isolation Washers and Bushings: One-piece, molded, oil- and water-resistant neoprene, with a flat washer face.

### **2.17 MECHANICAL ANCHOR BOLTS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. B-line, an Eaton business.
  - 2. Hilti, Inc.
  - 3. Kinetics Noise Control, Inc.
  - 4. Mason Industries, Inc.
- B. Mechanical Anchor Bolts: Drilled-in and stud-wedge or female-wedge type in zinc-coated steel for interior applications and stainless steel for exterior applications. Select anchor bolts with strength required for anchor and as tested according to ASTM E 488.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine areas and equipment to receive vibration isolation and seismic-control devices for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine roughing-in of reinforcement and cast-in-place anchors to verify actual locations before installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 APPLICATIONS**

- A. Multiple Pipe Supports: Secure pipes to trapeze member with clamps approved for application by OSHPD.
- B. Hanger-Rod Stiffeners: Install hanger-rod stiffeners where indicated or scheduled on Drawings to receive them and where required to prevent buckling of hanger rods due to seismic forces.
- C. Strength of Support and Seismic-Restraint Assemblies: Where not indicated, select sizes of components so strength is adequate to carry present and future static and seismic loads within specified loading limits.

### 3.03 VIBRATION CONTROL AND SEISMIC-RESTRAINT DEVICE INSTALLATION

- A. Coordinate the location of embedded connection hardware with supported equipment attachment and mounting points and with requirements for concrete reinforcement and formwork specified in Section 033000 "Cast-in-Place Concrete."
- B. Installation of vibration isolators must not cause any change of position of equipment, piping, or ductwork resulting in stresses or misalignment.
- C. Comply with requirements in Section 077200 "Roof Accessories" for installation of roof curbs, equipment supports, and roof penetrations.
- D. Equipment Restraints:
  - 1. Install seismic snubbers on plumbing equipment mounted on vibration isolators. Locate snubbers as close as possible to vibration isolators and bolt to equipment base and supporting structure.
  - 2. Install resilient bolt isolation washers on equipment anchor bolts where clearance between anchor and adjacent surface exceeds 0.125 inch.
  - 3. Install seismic-restraint devices using methods approved by OSHPD.
- E. Piping Restraints:
  - 1. Comply with requirements in MSS SP-127.
  - 2. Space lateral supports a maximum of 40 feet o.c., and longitudinal supports a maximum of 80 feet o.c.
  - 3. Brace a change of direction longer than 12 feet.
- F. Install cables so they do not bend across edges of adjacent equipment or building structure.
- G. Install seismic-restraint devices using methods approved by OSHPD.
- H. Install bushing assemblies for anchor bolts for floor-mounted equipment, arranged to provide resilient media between anchor bolt and mounting hole in concrete base.
- I. Install bushing assemblies for mounting bolts for wall-mounted equipment, arranged to provide resilient media where equipment or equipment-mounting channels are attached to wall.
- J. Attachment to Structure: If specific attachment is not indicated, anchor bracing to structure at flanges of beams, at upper truss chords of bar joists, or at concrete members.
- K. Drilled-in Anchors:
  - 1. Identify position of reinforcing steel and other embedded items prior to drilling holes for anchors. Do not damage existing reinforcing or embedded items during coring or drilling. Notify the structural engineer if reinforcing steel or other embedded items are encountered during drilling. Locate and avoid prestressed tendons, electrical and telecommunications conduit, and gas lines.
  - 2. Do not drill holes in concrete or masonry until concrete, mortar, or grout has achieved full design strength.
  - 3. Wedge Anchors: Protect threads from damage during anchor installation. Heavy-duty sleeve anchors shall be installed with sleeve fully engaged in the structural element to which anchor is to be fastened.

4. Set anchors to manufacturer's recommended torque, using a torque wrench.
5. Install zinc-coated steel anchors for interior and stainless-steel anchors for exterior applications.

### **3.04 ACCOMMODATION OF DIFFERENTIAL SEISMIC MOTION**

- A. Install flexible connections in piping where adjacent sections or branches are supported by different structural elements, and where the connections terminate with connection to equipment that is anchored to a different structural element from the one supporting the connections as they approach equipment. Comply with requirements in Section 221116 "Domestic Water Piping" for piping flexible connections.

### **3.05 FIELD QUALITY CONTROL**

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Perform tests and inspections.
- C. Tests and Inspections:
  1. Provide evidence of recent calibration of test equipment by a testing agency acceptable to authorities having jurisdiction.
  2. Schedule test with Owner, through Architect, before connecting anchorage device to restrained component (unless postconnection testing has been approved), and with at least seven days' advance notice.
  3. Obtain Architect's approval before transmitting test loads to structure. Provide temporary load-spreading members.
  4. Test at least four of each type and size of installed anchors and fasteners selected by Architect.
  5. Test to 90 percent of rated proof load of device.
  6. Measure isolator restraint clearance.
  7. Measure isolator deflection.
  8. Verify snubber minimum clearances.
- D. Remove and replace malfunctioning units and retest as specified above.
- E. Prepare test and inspection reports.

### **3.06 ADJUSTING**

- A. Adjust isolators after piping system is at operating weight.
- B. Adjust limit stops on restrained-spring isolators to mount equipment at normal operating height. After equipment installation is complete, adjust limit stops so they are out of contact during normal operation.

END OF SECTION

**SECTION 22 05 53**  
**IDENTIFICATION FOR PLUMBING PIPING AND EQUIPMENT**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Equipment labels.
  - 2. Warning signs and labels.
  - 3. Pipe labels.
  - 4. Stencils.
  - 5. Valve tags.
  - 6. Warning tags.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product indicated.
- B. Equipment Label Schedule: Include a listing of all equipment to be labeled with the proposed content for each label.
- C. Valve numbering scheme.
- D. Valve Schedules: For each piping system to include in maintenance manuals.

**PART 2 - PRODUCTS**

**2.01 EQUIPMENT LABELS**

- A. Metal Labels for Equipment:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Brimar Industries, Inc.
    - b. Craftmark Pipe Markers.
    - c. Marking Services, Inc.
    - d. Seton Identification Products.
  - 2. Material and Thickness: Brass, 0.032-inch minimum thickness, and having predrilled or stamped holes for attachment hardware.
  - 3. Letter Color: White.
  - 4. Background Color: Black.
  - 5. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
  - 6. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for

greater viewing distances. Include secondary lettering two-thirds to three-quarters the size of principal lettering.

7. Fasteners: Stainless-steel rivets or self-tapping screws.
  8. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- B. Plastic Labels for Equipment:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Brimar Industries, Inc.
    - b. Craftmark Pipe Markers.
    - c. Marking Services, Inc.
    - d. Seton Identification Products.
  2. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, and having predrilled holes for attachment hardware.
  3. Letter Color: White.
  4. Background Color: Black.
  5. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
  6. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
  7. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-quarters the size of principal lettering.
  8. Fasteners: Stainless-steel rivets or self-tapping screws.
  9. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- C. Label Content: Include equipment's Drawing designation or unique equipment number, Drawing numbers where equipment is indicated (plans, details, and schedules), and the Specification Section number and title where equipment is specified.
- D. Equipment Label Schedule: For each item of equipment to be labeled, on 8-1/2-by-11-inch bond paper. Tabulate equipment identification number, and identify Drawing numbers where equipment is indicated (plans, details, and schedules) and the Specification Section number and title where equipment is specified. Equipment schedule shall be included in operation and maintenance data.

## **2.02 WARNING SIGNS AND LABELS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
1. Brimar Industries, Inc.
  2. Craftmark Pipe Markers.
  3. Marking Services Inc.
  4. National Marker Company.

- 5. Seton Identification Products.
- 6. Stranco, Inc.
- B. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, and having predrilled holes for attachment hardware.
- C. Letter Color: Red.
- D. Background Color: Yellow.
- E. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
- F. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
- G. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-quarters the size of principal lettering.
- H. Fasteners: Stainless-steel rivets or self-tapping screws.
- I. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- J. Label Content: Include caution and warning information plus emergency notification instructions.

### **2.03 PIPE LABELS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Brimar Industries, Inc.
  - 2. Craftmark Pipe Markers.
  - 3. Marking Services Inc.
  - 4. Seton Identification Products.
- B. General Requirements for Manufactured Pipe Labels: Preprinted, color-coded, with lettering indicating service, and showing flow direction.
- C. Pretensioned Pipe Labels: Precoiled, semirigid plastic formed to cover full circumference of pipe and to attach to pipe without fasteners or adhesive.
- D. Self-Adhesive Pipe Labels: Printed plastic with contact-type, permanent-adhesive backing.
- E. Pipe Label Contents: Include identification of piping service using same designations or abbreviations as used on Drawings; also include pipe size and an arrow indicating flow direction.
  - 1. Flow-Direction Arrows: Integral with piping-system service lettering to accommodate both directions or as separate unit on each pipe label to indicate flow direction.
  - 2. At least 1/2 inch for viewing distances up to 72 inches and proportionately larger lettering for greater viewing distances.

### **2.04 STENCILS**

- A. Stencils for Piping:



1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Brimar Industries, Inc.
  - b. Carlton Industries, LP.
  - c. Champion America.
  - d. Craftmark Pipe Markers.
  - e. Kolbi Pipe Marker Co.
  - f. Marking Services Inc.
2. Lettering Size: Size letters according to ASME A13.1 for piping.
3. Stencil Material: Aluminum.
4. Stencil Paint: Exterior, gloss, acrylic enamel in colors complying with recommendations in ASME A13.1 unless otherwise indicated. Paint may be in pressurized spray-can form.
5. Identification Paint: Exterior, acrylic enamel in colors according to ASME A13.1 unless otherwise indicated. Paint may be in pressurized spray-can form.

## **2.05 VALVE TAGS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. Brimar Industries, Inc.
  2. Craftmark Pipe Markers.
  3. Marking Services Inc.
  4. Seton Identification Products.
- B. Valve Tags: Stamped or engraved with 1/4-inch letters for piping system abbreviation and 1/2-inch numbers.
  1. Tag Material: Brass, 0.032-inch minimum thickness, and having predrilled or stamped holes for attachment hardware.
  2. Fasteners: Brass wire-link chain.
- C. Valve Schedules: For each piping system, on 8-1/2-by-11-inch bond paper. Tabulate valve number, piping system, system abbreviation (as shown on valve tag), location of valve (room or space), normal-operating position (open, closed, or modulating), and variations for identification. Mark valves for emergency shutoff and similar special uses.
  1. Valve-tag schedule shall be included in operation and maintenance data.

## **2.06 WARNING TAGS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. Brimar Industries, Inc.
  2. Craftmark Pipe Markers.
  3. Marking Services Inc.
  4. Seton Identification Products.

- B. Description: Preprinted or partially preprinted accident-prevention tags of plasticized card stock with matte finish suitable for writing.
  - 1. Size: 3 by 5-1/4 inches minimum.
  - 2. Fasteners: Brass grommet and wire.
  - 3. Nomenclature: Large-size primary caption such as "DANGER," "CAUTION," or "DO NOT OPERATE."
  - 4. Color: Safety yellow background with black lettering.

## **PART 3 - EXECUTION**

### **3.01 PREPARATION**

- A. Clean piping and equipment surfaces of substances that could impair bond of identification devices, including dirt, oil, grease, release agents, and incompatible primers, paints, and encapsulants.

### **3.02 GENERAL INSTALLATION REQUIREMENTS**

- A. Coordinate installation of identifying devices with completion of covering and painting of surfaces where devices are to be applied.
- B. Coordinate installation of identifying devices with locations of access panels and doors.
- C. Install identifying devices before installing acoustical ceilings and similar concealment.

### **3.03 EQUIPMENT LABEL INSTALLATION**

- A. Install or permanently fasten labels on each major item of mechanical equipment.
- B. Locate equipment labels where accessible and visible.

### **3.04 PIPE LABEL INSTALLATION**

- A. Piping Color Coding: Painting of piping is specified in Section 099123 "Interior Painting" and Section 099600 "High-Performance Coatings."
- B. Stenciled Pipe Label Option: Stenciled labels may be provided instead of manufactured pipe labels, at Installer's option. Install stenciled pipe labels, complying with ASME A13.1, with painted, color-coded bands or rectangles on each piping system.
  - 1. Identification Paint: Use for contrasting background.
  - 2. Stencil Paint: Use for pipe marking.
- C. Pipe Label Locations: Locate pipe labels where piping is exposed or above accessible ceilings in finished spaces; machine rooms; accessible maintenance spaces such as shafts, tunnels, and plenums; and exterior exposed locations as follows:
  - 1. Near each valve and control device.
  - 2. Near each branch connection, excluding short takeoffs for fixtures and terminal units. Where flow pattern is not obvious, mark each pipe at branch.
  - 3. Near penetrations through walls, floors, ceilings, and inaccessible enclosures.
  - 4. At access doors, manholes, and similar access points that permit view of concealed piping.

5. Near major equipment items and other points of origination and termination.
  6. Spaced at maximum intervals of 50 feet along each run. Reduce intervals to 25 feet in areas of congested piping and equipment.
  7. On piping above removable acoustical ceilings. Omit intermediately spaced labels.
- D. Directional Flow Arrows: Arrows shall be used to indicate direction of flow in pipes, including pipes where flow is allowed in both directions.
- E. Pipe Label Color Schedule:
1. Domestic Water Piping
    - a. Background: Safety green.
    - b. Letter Colors: White.
  2. Sanitary Waste and Storm Drainage Piping:
    - a. Background Color: Safety black.
    - b. Letter Color: White.

### **3.05 VALVE-TAG INSTALLATION**

- A. Install tags on valves and control devices in piping systems, except check valves, valves within factory-fabricated equipment units, shutoff valves, faucets, convenience and lawn-watering hose connections, and similar roughing-in connections of end-use fixtures and units. List tagged valves in a valve schedule.
- B. Valve-Tag Application Schedule: Tag valves according to size, shape, and color scheme and with captions similar to those indicated in the following subparagraphs:
1. Valve-Tag Size and Shape:
    - a. Cold Water: 1-1/2 inches, round.
    - b. Hot Water: 1-1/2 inches, round.
    - c. Gas: 1-1/2 inches, round.
  2. Valve-Tag Colors:
    - a. Cold Water: Natural.
    - b. Hot Water: Natural.
  3. Letter Colors:
    - a. Cold Water: White.
    - b. Hot Water: White.

### **3.06 WARNING-TAG INSTALLATION**

- A. Write required message on, and attach warning tags to, equipment and other items where required.

END OF SECTION

**SECTION 220719**  
**PLUMBING PIPING INSULATION**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section includes insulating the following plumbing piping services:
  - 1. Domestic cold-water piping outside building thermal envelope.
  - 2. Domestic hot-water piping.
  - 3. Domestic recirculating hot-water piping.
  - 4. Supplies and drains for handicap-accessible lavatories and sinks.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product indicated. Include thermal conductivity, water-vapor permeance thickness, and jackets (both factory- and field-applied, if any).
- B. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Detail application of protective shields, saddles, and inserts at hangers for each type of insulation and hanger.
  - 2. Detail insulation application at pipe expansion joints for each type of insulation.
  - 3. Detail insulation application at elbows, fittings, flanges, valves, and specialties for each type of insulation.
  - 4. Detail removable insulation at piping specialties, equipment connections, and access panels.
  - 5. Detail application of field-applied jackets.
  - 6. Detail application at linkages of control devices.
- C. Product Data for California Green Building Standards Code Compliance: For adhesives and sealants, including primers, documentation of compliance including printed statement of VOC content and chemical components.
- D. Product data for insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings, indicating compliance with requirement that these products contain less than 0.1 percent (by mass) polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations.

**1.03 INFORMATIONAL SUBMITTALS**

- A. Qualification Data: For qualified Installer.
- B. Material Test Reports: From a qualified testing agency acceptable to authorities having jurisdiction indicating, interpreting, and certifying test results for compliance of insulation materials, sealers, attachments, cements, and jackets, with requirements indicated. Include dates of tests and test methods employed.
- C. Field quality-control reports.

#### **1.04 QUALITY ASSURANCE**

- A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or another craft training program certified by the Department of Labor, Bureau of Apprenticeship and Training.
- B. Surface-Burning Characteristics: For insulation and related materials, as determined by testing identical products according to ASTM E 84 by a testing agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing agency.
  - 1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.
  - 2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.
- C. Comply with the following applicable standards and other requirements specified for miscellaneous components:
  - 1. Supply and Drain Protective Shielding Guards: ICC A117.1.

#### **1.05 DELIVERY, STORAGE, AND HANDLING**

- A. Packaging: Insulation material containers shall be marked by manufacturer with appropriate ASTM standard designation, type and grade, and maximum use temperature.

#### **1.06 COORDINATION**

- A. Coordinate sizes and locations of supports, hangers, and insulation shields specified in Section 220529 "Hangers and Supports for Plumbing Piping and Equipment."
- B. Coordinate clearance requirements with piping Installer for piping insulation application. Before preparing piping Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes and for space required for maintenance.

#### **1.07 SCHEDULING**

- A. Schedule insulation application after pressure testing systems. Insulation application may begin on segments that have satisfactory test results.
- B. Complete installation and concealment of plastic materials as rapidly as possible in each area of construction.

### **PART 2 - PRODUCTS**

#### **2.01 INSULATION MATERIALS**

- A. Comply with requirements in "Piping Insulation Schedule, General," "Indoor Piping Insulation Schedule," "Outdoor, Aboveground Piping Insulation Schedule," and "Outdoor, Underground Piping Insulation Schedule" articles for where insulating materials shall be applied.
- B. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).
- C. Products shall not contain asbestos, lead, mercury, or mercury compounds.

- D. Products that come in contact with stainless steel shall have a leachable chloride content of less than 50 ppm when tested according to ASTM C 871.
- E. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C 795.
- F. Foam insulation materials shall not use CFC or HCFC blowing agents in the manufacturing process.
- G. Cellular Glass: Inorganic, incombustible, foamed or cellulated glass with annealed, rigid, hermetically sealed cells. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Pittsburgh Corning Corporation.
  - 2. Block Insulation: ASTM C 552, Type I.
  - 3. Special-Shaped Insulation: ASTM C 552, Type III.
  - 4. Preformed Pipe Insulation without Jacket: Comply with ASTM C 552, Type II, Class 1.
  - 5. Preformed Pipe Insulation with Factory-Applied ASJ-SSL: Comply with ASTM C 552, Type II, Class 2.
  - 6. Factory fabricate shapes according to ASTM C 450 and ASTM C 585.
- H. Flexible Elastomeric Insulation: Closed-cell, sponge- or expanded-rubber materials. Comply with ASTM C 534, Type I for tubular materials.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Aeroflex USA, Inc.
    - b. Armacell LLC.
    - c. K-Flex USA.
- I. Mineral-Fiber, Preformed Pipe Insulation:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Johns Manville; a Berkshire Hathaway company.
    - b. Knauf Insulation.
    - c. Manson Insulation Inc.
    - d. Owens Corning.
  - 2. Type I, 850 Deg F Materials: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 547, Type I, Grade A, with factory-applied ASJ-SSL. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.

## 2.02 INSULATING CEMENTS

- A. Mineral-Fiber Insulating Cement: Comply with ASTM C 195.

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Ramco Insulation, Inc.
- B. Expanded or Exfoliated Vermiculite Insulating Cement: Comply with ASTM C 196.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Ramco Insulation, Inc.
- C. Mineral-Fiber, Hydraulic-Setting Insulating and Finishing Cement: Comply with ASTM C 449.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Ramco Insulation, Inc.

### 2.03 ADHESIVES

- A. Materials shall be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated, unless otherwise indicated.
- B. Cellular-Glass Adhesive: Two-component, thermosetting urethane adhesive containing no flammable solvents, with a service temperature range of minus 100 to plus 200 deg F.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Foster Brand; H. B. Fuller Construction Products.
  2. Adhesive: As recommended by cellular glass manufacturer and with a VOC content of 80 g/L or less.
  3. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- C. Flexible Elastomeric Adhesive: Comply with MIL-A-24179A, Type II, Class I.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Aeroflex USA, Inc.
    - b. Armacell LLC.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. K-Flex USA.
  2. Adhesive: As recommended by flexible elastomeric manufacturer and with a VOC content of 80 g/L or less.
  3. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- D. Mineral-Fiber Adhesive: Comply with MIL-A-3316C, Class 2, Grade A.

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. Mon-Eco Industries, Inc.
  2. Adhesive: As recommended by mineral fiber manufacturer and with a VOC content of 80 g/L or less.
  3. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- E. ASJ Adhesive: Comply with MIL-A-3316C, Class 2, Grade A for bonding insulation jacket lap seams and joints.
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. Mon-Eco Industries, Inc.
  2. Adhesives shall have a VOC content of 80 g/L or less.
  3. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- F. PVC Jacket Adhesive: Compatible with PVC jacket.
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Dow Corning Corporation.
    - b. Johns Manville; a Berkshire Hathaway company.
    - c. P.I.C. Plastics, Inc.
    - d. Speedline Corporation.
  2. Adhesive: As recommended by Adhesive - PVC Jacket manufacturer and with a VOC content of 50 g/L or less.
  3. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.

## 2.04 MASTICS

- A. Materials shall be compatible with insulation materials, jackets, and substrates; comply with MIL-PRF-19565C, Type II.
1. Mastics: As recommended by insulation manufacturer and with a VOC content of 50 g/L or less.



- B. Vapor-Barrier Mastic: Water based; suitable for indoor use on below-ambient services.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Foster Brand; H. B. Fuller Construction Products.
    - b. Knauf Insulation.
    - c. Vimasco Corporation.
  - 2. Water-Vapor Permeance: ASTM E 96/E 96M, Procedure B, 0.013 perm at 43-mil dry film thickness.
  - 3. Service Temperature Range: Minus 20 to plus 180 deg F.
  - 4. Solids Content: ASTM D 1644, 58 percent by volume and 70 percent by weight.
  - 5. Color: White.
- C. Vapor-Barrier Mastic: Solvent based; suitable for outdoor use on below-ambient services.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
  - 2. Water-Vapor Permeance: ASTM F 1249, 0.05 perm at 30-mil dry film thickness.
  - 3. Service Temperature Range: Minus 50 to plus 220 deg F.
  - 4. Solids Content: ASTM D 1644, 33 percent by volume and 46 percent by weight.
  - 5. Color: White.
- D. Breather Mastic: Water based; suitable for indoor and outdoor use on above-ambient services.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. Knauf Insulation.
    - e. Mon-Eco Industries, Inc.
    - f. Vimasco Corporation.
  - 2. Water-Vapor Permeance: ASTM F 1249, 1.8 perms at 0.0625-inch dry film thickness.
  - 3. Service Temperature Range: Minus 20 to plus 180 deg F.
  - 4. Solids Content: 60 percent by volume and 66 percent by weight.
  - 5. Color: White.

## 2.05 LAGGING ADHESIVES

- A. Description: Comply with MIL-A-3316C, Class I, Grade A, and shall be compatible with insulation materials, jackets, and substrates.
  - 1. For indoor applications, use lagging adhesives that have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 2. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
  - 3. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Foster Brand; H. B. Fuller Construction Products.
    - c. Vimasco Corporation.
  - 4. Fire-resistant, water-based lagging adhesive and coating for use indoors to adhere fire-resistant lagging cloths over pipe insulation.
  - 5. Service Temperature Range: 0 to plus 180 deg F.
  - 6. Color: White.

## 2.06 SEALANTS

- A. Joint Sealants for Cellular-Glass Products:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. Mon-Eco Industries, Inc.
    - e. Pittsburgh Corning Corporation.
  - 2. Sealant shall have a VOC content of 420 g/L or less.
  - 3. Sealant shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- B. Metal Jacket Flashing Sealants:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. Mon-Eco Industries, Inc.
  - 2. Materials shall be compatible with insulation materials, jackets, and substrates.

3. Fire- and water-resistant, flexible, elastomeric sealant.
  4. Service Temperature Range: Minus 40 to plus 250 deg F.
  5. Color: Aluminum.
  6. Sealant shall have a VOC content of 420 g/L or less.
  7. Sealant shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- C. ASJ Flashing Sealants, and PVC Jacket Flashing Sealants:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
  2. Materials shall be compatible with insulation materials, jackets, and substrates.
  3. Fire- and water-resistant, flexible, elastomeric sealant.
  4. Service Temperature Range: Minus 40 to plus 250 deg F.
  5. Color: White.
  6. Sealant shall have a VOC content of 420 g/L or less.
  7. Sealant shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.

## **2.07 FACTORY-APPLIED JACKETS**

- A. Insulation system schedules indicate factory-applied jackets on various applications. When factory-applied jackets are indicated, comply with the following:
1. ASJ-SSL: ASJ with self-sealing, pressure-sensitive, acrylic-based adhesive covered by a removable protective strip; complying with ASTM C 1136, Type I.

## **2.08 FIELD-APPLIED FABRIC-REINFORCING MESH**

- A. Woven Glass-Fiber Fabric: Approximately 2 oz./sq. yd. with a thread count of 10 strands by 10 strands/sq. in. for covering pipe and pipe fittings.
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
- B. Woven Polyester Fabric: Approximately 1 oz./sq. yd. with a thread count of 10 strands by 10 strands/sq. in., in a Leno weave, for pipe.
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Foster Brand; H. B. Fuller Construction Products.
    - b. Vimasco Corporation.

## 2.09 FIELD-APPLIED CLOTHS

- A. Woven Glass-Fiber Fabric: Comply with MIL-C-20079H, Type I, plain weave, and presized a minimum of 8 oz./sq. yd..
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Alpha Associates, Inc.

## 2.10 FIELD-APPLIED JACKETS

- A. Field-applied jackets shall comply with ASTM C 921, Type I, unless otherwise indicated.
- B. PVC Jacket: High-impact-resistant, UV-resistant PVC complying with ASTM D 1784, Class 16354-C; thickness as scheduled; roll stock ready for shop or field cutting and forming. Thickness is indicated in field-applied jacket schedules.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Johns Manville; a Berkshire Hathaway company.
    - b. P.I.C. Plastics, Inc.
    - c. Proto Corporation.
    - d. Speedline Corporation.
  - 2. Adhesive: As recommended by jacket material manufacturer.
  - 3. Color: White.
  - 4. Factory-fabricated fitting covers to match jacket if available; otherwise, field fabricate.
    - a. Shapes: 45- and 90-degree, short- and long-radius elbows, tees, valves, flanges, unions, reducers, end caps, soil-pipe hubs, traps, mechanical joints, and P-trap and supply covers for lavatories.
- C. Metal Jacket:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. ITW Insulation Systems; Illinois Tool Works, Inc.
    - c. RPR Products, Inc.
  - 2. Aluminum Jacket: Comply with ASTM B 209, Alloy 3003, 3005, 3105, or 5005, Temper H-14.
    - a. Sheet and roll stock ready for shop or field sizing or Factory cut and rolled to size.
    - b. Finish and thickness are indicated in field-applied jacket schedules.
    - c. Moisture Barrier for Indoor Applications: 1-mil-thick, heat-bonded polyethylene and kraft paper.
    - d. Moisture Barrier for Outdoor Applications: 2.5-mil-thick polysurlyn.

- e. Factory-Fabricated Fitting Covers:
  - 1) Same material, finish, and thickness as jacket.
  - 2) Preformed 2-piece or gore, 45- and 90-degree, short- and long-radius elbows.
  - 3) Tee covers.
  - 4) Flange and union covers.
  - 5) End caps.
  - 6) Beveled collars.
  - 7) Valve covers.
  - 8) Field fabricate fitting covers only if factory-fabricated fitting covers are not available.

## 2.11 TAPES

- A. ASJ Tape: White vapor-retarder tape matching factory-applied jacket with acrylic adhesive, complying with ASTM C 1136.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Avery Dennison Corporation, Specialty Tapes Division.
    - b. Compac Corporation.
    - c. Ideal Tape Co., Inc.; an American Biltrite company.
    - d. Knauf Insulation.
    - e. Venture Tape.
  - 2. Width: 3 inches.
  - 3. Thickness: 11.5 mils.
  - 4. Adhesion: 90 ounces force/inch in width.
  - 5. Elongation: 2 percent.
  - 6. Tensile Strength: 40 lbf/inch in width.
  - 7. ASJ Tape Disks and Squares: Precut disks or squares of ASJ tape.
- B. PVC Tape: White vapor-retarder tape matching field-applied PVC jacket with acrylic adhesive; suitable for indoor and outdoor applications.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Compac Corporation.
    - b. Ideal Tape Co., Inc.; an American Biltrite company.
    - c. Venture Tape.
  - 2. Width: 2 inches.
  - 3. Thickness: 6 mils.
  - 4. Adhesion: 64 ounces force/inch in width.

5. Elongation: 500 percent.
  6. Tensile Strength: 18 lbf/inch in width.
- C. Aluminum-Foil Tape: Vapor-retarder tape with acrylic adhesive.
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Avery Dennison Corporation, Specialty Tapes Division.
    - b. Compac Corporation.
    - c. Ideal Tape Co., Inc.; an American Biltrite company.
    - d. Knauf Insulation.
    - e. Venture Tape.
  2. Width: 2 inches.
  3. Thickness: 3.7 mils.
  4. Adhesion: 100 ounces force/inch in width.
  5. Elongation: 5 percent.
  6. Tensile Strength: 34 lbf/inch in width.

## 2.12 SECUREMENTS

- A. Bands:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. ITW Insulation Systems; Illinois Tool Works, Inc.
    - b. RPR Products, Inc.
- B. Staples: Outward-clinching insulation staples, nominal 3/4-inch-wide, stainless steel or Monel.
- C. Wire: 0.062-inch soft-annealed, stainless steel.
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. C & F Wire.

## 2.13 PROTECTIVE SHIELDING GUARDS

- A. Protective Shielding Pipe Covers:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Engineered Brass Company.
    - b. Insul-Tect Products Co.
    - c. McGuire Manufacturing.
    - d. Plumberex Specialty Products, Inc.

- e. Truebro.
  - f. Zurn Industries, LLC.
2. Description: Manufactured plastic wraps for covering plumbing fixture hot- and cold-water supplies and trap and drain piping. Comply with Americans with Disabilities Act (ADA) requirements.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine substrates and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of insulation application.
  - 1. Verify that systems to be insulated have been tested and are free of defects.
  - 2. Verify that surfaces to be insulated are clean and dry.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 PREPARATION**

- A. Surface Preparation: Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.
- B. Mix insulating cements with clean potable water; if insulating cements are to be in contact with stainless-steel surfaces, use demineralized water.

### **3.03 GENERAL INSTALLATION REQUIREMENTS**

- A. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of piping including fittings, valves, and specialties.
- B. Install insulation materials, forms, vapor barriers or retarders, jackets, and thicknesses required for each item of pipe system as specified in insulation system schedules.
- C. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, soften, or otherwise attack insulation or jacket in either wet or dry state.
- D. Install insulation with longitudinal seams at top and bottom of horizontal runs.
- E. Install multiple layers of insulation with longitudinal and end seams staggered.
- F. Do not weld brackets, clips, or other attachment devices to piping, fittings, and specialties.
- G. Keep insulation materials dry during application and finishing.
- H. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- I. Install insulation with least number of joints practical.
- J. Where vapor barrier is indicated, seal joints, seams, and penetrations in insulation at hangers, supports, anchors, and other projections with vapor-barrier mastic.
  - 1. Install insulation continuously through hangers and around anchor attachments.
  - 2. For insulation application where vapor barriers are indicated, extend insulation on anchor legs from point of attachment to supported item to point of attachment to structure. Taper and seal ends at attachment to structure with vapor-barrier mastic.

3. Install insert materials and install insulation to tightly join the insert. Seal insulation to insulation inserts with adhesive or sealing compound recommended by insulation material manufacturer.
  4. Cover inserts with jacket material matching adjacent pipe insulation. Install shields over jacket, arranged to protect jacket from tear or puncture by hanger, support, and shield.
- K. Apply adhesives, mastics, and sealants at manufacturer's recommended coverage rate and wet and dry film thicknesses.
- L. Install insulation with factory-applied jackets as follows:
1. Draw jacket tight and smooth.
  2. Cover circumferential joints with 3-inch-wide strips, of same material as insulation jacket. Secure strips with adhesive and outward clinching staples along both edges of strip, spaced 4 inches o.c.
  3. Overlap jacket longitudinal seams at least 1-1/2 inches. Install insulation with longitudinal seams at bottom of pipe. Clean and dry surface to receive self-sealing lap. Staple laps with outward clinching staples along edge at 2 inches o.c.
    - a. For below-ambient services, apply vapor-barrier mastic over staples.
  4. Cover joints and seams with tape, according to insulation material manufacturer's written instructions, to maintain vapor seal.
  5. Where vapor barriers are indicated, apply vapor-barrier mastic on seams and joints and at ends adjacent to pipe flanges and fittings.
- M. Cut insulation in a manner to avoid compressing insulation more than 75 percent of its nominal thickness.
- N. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- O. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches beyond damaged areas. Adhere, staple, and seal patches similar to butt joints.
- P. For above-ambient services, do not install insulation to the following:
1. Vibration-control devices.
  2. Testing agency labels and stamps.
  3. Nameplates and data plates.
  4. Cleanouts.

### **3.04 PENETRATIONS**

- A. Insulation Installation at Roof Penetrations: Install insulation continuously through roof penetrations.
1. Seal penetrations with flashing sealant.
  2. For applications requiring only indoor insulation, terminate insulation above roof surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.



3. Extend jacket of outdoor insulation outside roof flashing at least 2 inches below top of roof flashing.
  4. Seal jacket to roof flashing with flashing sealant.
- B. Insulation Installation at Aboveground Exterior Wall Penetrations: Install insulation continuously through wall penetrations.
1. Seal penetrations with flashing sealant.
  2. For applications requiring only indoor insulation, terminate insulation inside wall surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
  3. Extend jacket of outdoor insulation outside wall flashing and overlap wall flashing at least 2 inches.
  4. Seal jacket to wall flashing with flashing sealant.
- C. Insulation Installation at Interior Wall and Partition Penetrations (That Are Not Fire Rated): Install insulation continuously through walls and partitions.
- D. Insulation Installation at Fire-Rated Wall and Partition Penetrations: Install insulation continuously through penetrations of fire-rated walls and partitions.
1. Comply with requirements in Section 078400 "Firestopping" for firestopping and fire-resistive joint sealers.
- E. Insulation Installation at Floor Penetrations:
1. Pipe: Install insulation continuously through floor penetrations.
  2. Seal penetrations through fire-rated assemblies. Comply with requirements in Section 078413 "Penetration Firestopping."

### **3.05 GENERAL PIPE INSULATION INSTALLATION**

- A. Requirements in this article generally apply to all insulation materials except where more specific requirements are specified in various pipe insulation material installation articles.
- B. Insulation Installation on Fittings, Valves, Strainers, Flanges, and Unions:
1. Install insulation over fittings, valves, strainers, flanges, unions, and other specialties with continuous thermal and vapor-retarder integrity unless otherwise indicated.
  2. Insulate pipe elbows using preformed fitting insulation or mitered fittings made from same material and density as adjacent pipe insulation. Each piece shall be butted tightly against adjoining piece and bonded with adhesive. Fill joints, seams, voids, and irregular surfaces with insulating cement finished to a smooth, hard, and uniform contour that is uniform with adjoining pipe insulation.
  3. Insulate tee fittings with preformed fitting insulation or sectional pipe insulation of same material and thickness as used for adjacent pipe. Cut sectional pipe insulation to fit. Butt each section closely to the next and hold in place with tie wire. Bond pieces with adhesive.
  4. Insulate valves using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. For valves, insulate up to and including the bonnets, valve

stuffing-box studs, bolts, and nuts. Fill joints, seams, and irregular surfaces with insulating cement.

5. Insulate strainers using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. Fill joints, seams, and irregular surfaces with insulating cement. Insulate strainers so strainer basket flange or plug can be easily removed and replaced without damaging the insulation and jacket. Provide a removable reusable insulation cover. For below-ambient services, provide a design that maintains vapor barrier.
  6. Insulate flanges and unions using a section of oversized preformed pipe insulation. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker.
  7. Cover segmented insulated surfaces with a layer of finishing cement and coat with a mastic. Install vapor-barrier mastic for below-ambient services and a breather mastic for above-ambient services. Reinforce the mastic with fabric-reinforcing mesh. Trowel the mastic to a smooth and well-shaped contour.
  8. For services not specified to receive a field-applied jacket except for flexible elastomeric, install fitted PVC cover over elbows, tees, strainers, valves, flanges, and unions. Terminate ends with PVC end caps. Tape PVC covers to adjoining insulation facing using PVC tape.
  9. Stencil or label the outside insulation jacket of each union with the word "union." Match size and color of pipe labels.
- C. Insulate instrument connections for thermometers, pressure gages, pressure temperature taps, test connections, flow meters, sensors, switches, and transmitters on insulated pipes. Shape insulation at these connections by tapering it to and around the connection with insulating cement and finish with finishing cement, mastic, and flashing sealant.
- D. Install removable insulation covers at locations indicated. Installation shall conform to the following:
1. Make removable flange and union insulation from sectional pipe insulation of same thickness as that on adjoining pipe. Install same insulation jacket as adjoining pipe insulation.
  2. When flange and union covers are made from sectional pipe insulation, extend insulation from flanges or union long at least two times the insulation thickness over adjacent pipe insulation on each side of flange or union. Secure flange cover in place with stainless-steel or aluminum bands. Select band material compatible with insulation and jacket.
  3. Construct removable valve insulation covers in same manner as for flanges, except divide the two-part section on the vertical center line of valve body.
  4. When covers are made from block insulation, make two halves, each consisting of mitered blocks wired to stainless-steel fabric. Secure this wire frame, with its attached insulation, to flanges with tie wire. Extend insulation at least 2 inches over adjacent pipe insulation on each side of valve. Fill space between flange or union cover and pipe insulation with insulating cement. Finish cover assembly with insulating cement applied in two coats. After first coat is dry, apply and trowel second coat to a smooth finish.

5. Unless a PVC jacket is indicated in field-applied jacket schedules, finish exposed surfaces with a metal jacket.

### **3.06 INSTALLATION OF CELLULAR-GLASS INSULATION**

- A. Insulation Installation on Straight Pipes and Tubes:
  1. Secure each layer of insulation to pipe with wire or bands and tighten bands without deforming insulation materials.
  2. Where vapor barriers are indicated, seal longitudinal seams, end joints, and protrusions with vapor-barrier mastic and joint sealant.
  3. For insulation with factory-applied jackets on above-ambient services, secure laps with outward clinched staples at 6 inches o.c.
  4. For insulation with factory-applied jackets on below-ambient services, do not staple longitudinal tabs. Instead, secure tabs with additional adhesive as recommended by insulation material manufacturer and seal with vapor-barrier mastic and flashing sealant.
- B. Insulation Installation on Pipe Flanges:
  1. Install preformed pipe insulation to outer diameter of pipe flange.
  2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
  3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of cellular-glass block insulation of same thickness as pipe insulation.
  4. Install jacket material with manufacturer's recommended adhesive, overlap seams at least 1 inch, and seal joints with flashing sealant.
- C. Insulation Installation on Pipe Fittings and Elbows:
  1. Install preformed sections of same material as straight segments of pipe insulation when available. Secure according to manufacturer's written instructions.
  2. When preformed sections of insulation are not available, install mitered sections of cellular-glass insulation. Secure insulation materials with wire or bands.
- D. Insulation Installation on Valves and Pipe Specialties:
  1. Install preformed sections of cellular-glass insulation to valve body.
  2. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  3. Install insulation to flanges as specified for flange insulation application.

### **3.07 INSTALLATION OF FLEXIBLE ELASTOMERIC INSULATION**

- A. Seal longitudinal seams and end joints with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- B. Insulation Installation on Pipe Flanges:
  1. Install pipe insulation to outer diameter of pipe flange.
  2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.

3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of sheet insulation of same thickness as pipe insulation.
  4. Secure insulation to flanges and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- C. Insulation Installation on Pipe Fittings and Elbows:
1. Install mitered sections of pipe insulation.
  2. Secure insulation materials and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- D. Insulation Installation on Valves and Pipe Specialties:
1. Install preformed valve covers manufactured of same material as pipe insulation when available.
  2. When preformed valve covers are not available, install cut sections of pipe and sheet insulation to valve body. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  3. Install insulation to flanges as specified for flange insulation application.
  4. Secure insulation to valves and specialties and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

### **3.08 INSTALLATION OF MINERAL-FIBER INSULATION**

- A. Insulation Installation on Straight Pipes and Tubes:
1. Secure each layer of preformed pipe insulation to pipe with wire or bands and tighten bands without deforming insulation materials.
  2. Where vapor barriers are indicated, seal longitudinal seams, end joints, and protrusions with vapor-barrier mastic and joint sealant.
  3. For insulation with factory-applied jackets on above-ambient surfaces, secure laps with outward clinched staples at 6 inches o.c.
  4. For insulation with factory-applied jackets on below-ambient surfaces, do not staple longitudinal tabs. Instead, secure tabs with additional adhesive as recommended by insulation material manufacturer and seal with vapor-barrier mastic and flashing sealant.
- B. Insulation Installation on Pipe Flanges:
1. Install preformed pipe insulation to outer diameter of pipe flange.
  2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
  3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with mineral-fiber blanket insulation.
  4. Install jacket material with manufacturer's recommended adhesive, overlap seams at least 1 inch, and seal joints with flashing sealant.
- C. Insulation Installation on Pipe Fittings and Elbows:
1. Install preformed sections of same material as straight segments of pipe insulation when available.

2. When preformed insulation elbows and fittings are not available, install mitered sections of pipe insulation, to a thickness equal to adjoining pipe insulation. Secure insulation materials with wire or bands.
- D. Insulation Installation on Valves and Pipe Specialties:
1. Install preformed sections of same material as straight segments of pipe insulation when available.
  2. When preformed sections are not available, install mitered sections of pipe insulation to valve body.
  3. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  4. Install insulation to flanges as specified for flange insulation application.

### **3.09 FIELD-APPLIED JACKET INSTALLATION**

- A. Where PVC jackets are indicated, install with 1-inch overlap at longitudinal seams and end joints. Seal with manufacturer's recommended adhesive.
1. Apply two continuous beads of adhesive to seams and joints, one bead under lap and the finish bead along seam and joint edge.
- B. Where metal jackets are indicated, install with 2-inch overlap at longitudinal seams and end joints. Overlap longitudinal seams arranged to shed water. Seal end joints with weatherproof sealant recommended by insulation manufacturer. Secure jacket with stainless-steel bands 12 inches o.c. and at end joints.

### **3.10 FINISHES**

- A. Insulation with ASJ, Glass-Cloth, or Other Paintable Jacket Material: Paint jacket with paint system identified below and as specified in Section 099123 "Interior Painting, and Section 099600, "High Performance Coatings"
1. Flat Acrylic Finish: Two finish coats over a primer that is compatible with jacket material and finish coat paint. Add fungicidal agent to render fabric mildew proof.
    - a. Finish Coat Material: Interior, flat, latex-emulsion size.
- B. Flexible Elastomeric Thermal Insulation: After adhesive has fully cured, apply two coats of insulation manufacturer's recommended protective coating.
- C. Color: Final color as selected by Architect. Vary first and second coats to allow visual inspection of the completed Work.
- D. Do not field paint aluminum jackets.

### **3.11 FIELD QUALITY CONTROL**

- A. Testing Agency: Owner will engage a qualified testing agency to perform tests and inspections.
- B. Tests and Inspections:
1. Inspect pipe, fittings, strainers, and valves, randomly selected by Architect, by removing field-applied jacket and insulation in layers in reverse order of their installation. Extent of inspection shall be limited to three locations of straight pipe, three locations of threaded fittings, three locations of welded fittings, two locations of threaded strainers, two locations of welded strainers, three locations of threaded valves, and three locations of

flanged valves for each pipe service defined in the "Piping Insulation Schedule, General" Article.

- C. All insulation applications will be considered defective Work if sample inspection reveals noncompliance with requirements.

### **3.12 PIPING INSULATION SCHEDULE, GENERAL**

- A. Acceptable preformed pipe and tubular insulation materials and thicknesses are identified for each piping system and pipe size range. If more than one material is listed for a piping system, selection from materials listed is Contractor's option.
- B. Items Not Insulated: Unless otherwise indicated, do not install insulation on the following:
  - 1. Drainage piping located in crawl spaces.
  - 2. Underground piping.
  - 3. Chrome-plated pipes and fittings unless there is a potential for personnel injury.

### **3.13 INDOOR PIPING INSULATION SCHEDULE**

- A. Domestic Cold Water and Industrial Cold Water Outside Building Thermal Envelope:
  - 1. All Sizes: Insulation shall be one of the following:
    - a. Cellular Glass: 1-1/2 inches thick.
    - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1 inch thick.
- B. Domestic Hot and Recirculated Hot Water:
  - 1. NPS 3/4 and Smaller: Insulation shall be one of the following:
    - a. Cellular Glass: 2 inches thick.
    - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1 inch thick.
  - 2. NPS 1 and Larger: Insulation shall be one of the following:
    - a. Cellular Glass: 3 inches thick.
    - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1-1/2 inch thick.
- C. Exposed Sanitary Drains, Domestic Water, Domestic Hot Water, and Stops for Plumbing Fixtures for People with Disabilities:
  - 1. All Pipe Sizes: Insulation shall be the following:
    - a. Flexible Elastomeric: 1 inch thick.
- D. Floor Drains, Traps, and Sanitary Drain Piping within 10 Feet of Drain Receiving Condensate and Equipment Drain Water below 60 Deg F:
  - 1. All Pipe Sizes: Insulation shall be the following:
    - a. Flexible Elastomeric: 1 inch thick.
- E. Hot Service Drains:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Cellular Glass: 1-1/2 inches thick.
    - b. Mineral-Fiber, Preformed Pipe, Type I or II: 1 inch thick.

### **3.14 OUTDOOR, ABOVEGROUND PIPING INSULATION SCHEDULE**

- A. Domestic Water Piping:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Cellular Glass: 2 inches thick.
    - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 2 inches thick.

### **3.15 INDOOR, FIELD-APPLIED JACKET SCHEDULE**

- A. Install jacket over insulation material. For insulation with factory-applied jacket, install the field-applied jacket over the factory-applied jacket.
- B. If more than one material is listed, selection from materials listed is Contractor's option.
- C. Piping, Concealed:
  - 1. None.
- D. Piping, Exposed:
  - 1. PVC: 30 mils thick.

### **3.16 OUTDOOR, FIELD-APPLIED JACKET SCHEDULE**

- A. Install jacket over insulation material. For insulation with factory-applied jacket, install the field-applied jacket over the factory-applied jacket.
- B. If more than one material is listed, selection from materials listed is Contractor's option.
- C. Piping, Exposed:
  - 1. Painted Aluminum, Smooth with Z-Shaped Locking Seam: 0.024 inch thick.

END OF SECTION

**SECTION 22 11 16**  
**DOMESTIC WATER PIPING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

A. Section Includes:

1. Copper tube and fittings.
2. Piping joining materials.
3. Encasement for piping.
4. Transition fittings.
5. Dielectric fittings.

B. Related Requirements:

1. Section 331116 "Site Water Distribution Piping" for water-service piping outside the building from source to the point where water-service piping enters the building.

**1.02 ACTION SUBMITTALS**

A. Product Data: For transition fittings and dielectric fittings.

B. Pipe, pipe or plumbing fittings, fixtures, solder and flux installed in a system providing water for human consumption shall comply with lead free requirements of California Health and Safety Code Section 116875. Provide submittal information for products third-party certified by an approved laboratory as complying with California Health and Safety Code Section 116875.

1. Certification that products comply with NSF 61 Annex G and NSF 372.

C. Sustainable Design Submittals:

1. Product Data: For adhesives, indicating VOC content.

**1.03 INFORMATIONAL SUBMITTALS**

A. System purging and disinfecting activities report.

B. Field quality-control reports.

**1.04 QUALITY ASSURANCE**

A. California Health and Safety Code Compliance: For products covered under the scope of HSC 116875 for potable water service. Products for potable water service shall be third-party certified by an approved laboratory as complying with California Health and Safety Code Section 116875.

**1.05 FIELD CONDITIONS**

A. Interruption of Existing Water Service: Do not interrupt water service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary water service according to requirements indicated:



1. Notify Owner and Construction Manager no fewer than two days in advance of proposed interruption of water service.
2. Do not interrupt water service without Owner's and Construction Manager 's written permission.

## **PART 2 - PRODUCTS**

### **2.01 PIPING MATERIALS**

- A. Comply with requirements in "Piping Schedule" Article for applications of pipe, tube, fitting materials, and joining methods for specific services, service locations, and pipe sizes.
- B. Potable-water piping and components shall comply with NSF 61 Annex G.
- C. Comply with NSF Standard 372 for low lead.

### **2.02 COPPER TUBE AND FITTINGS**

- A. Hard Copper Tube: ASTM B 88, Type L and ASTM B 88, Type M water tube, drawn temper.
- B. Soft Copper Tube: ASTM B 88, Type K water tube, annealed temper.
- C. Cast-Copper, Solder-Joint Fittings: ASME B16.18, pressure fittings.
- D. Wrought-Copper, Solder-Joint Fittings: ASME B16.22, wrought-copper pressure fittings.
- E. Bronze Flanges: ASME B16.24, Class 150, with solder-joint ends.
- F. Copper Unions:
  1. MSS SP-123.
  2. Cast-copper-alloy, hexagonal-stock body.
  3. Ball-and-socket, metal-to-metal seating surfaces.
  4. Solder-joint or threaded ends.

### **2.03 PIPING JOINING MATERIALS**

- A. Pipe-Flange Gasket Materials:
  1. AWWA C110/A21.10, rubber, flat face, 1/8 inch thick or ASME B16.21, nonmetallic and asbestos free unless otherwise indicated.
  2. Full-face or ring type unless otherwise indicated.
- B. Metal, Pipe-Flange Bolts and Nuts: ASME B18.2.1, carbon steel unless otherwise indicated.
- C. Solder Filler Metals: ASTM B 32, lead-free alloys.
- D. Flux: ASTM B 813, water flushable.
- E. Brazing Filler Metals: AWS A5.8M/A5.8, BCuP Series, copper-phosphorus alloys for general-duty brazing unless otherwise indicated.

### **2.04 ENCASUREMENT FOR PIPING**

- A. Standard: ASTM A 674 or AWWA C105/A21.5.
- B. Form: Sheet or tube.
- C. Color: Black or natural.

## 2.05 TRANSITION FITTINGS

- A. General Requirements:
  - 1. Same size as pipes to be joined.
  - 2. Pressure rating at least equal to pipes to be joined.
  - 3. End connections compatible with pipes to be joined.
- B. Fitting-Type Transition Couplings: Manufactured piping coupling or specified piping system fitting.
- C. Sleeve-Type Transition Coupling: AWWA C219.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Cascade Waterworks Mfg. Co.
    - b. Dresser, Inc.
    - c. Ford Meter Box Company, Inc. (The).
    - d. Jay R. Smith Mfg. Co.
    - e. JCM Industries, Inc.
    - f. Romac Industries, Inc.
    - g. Smith-Blair, Inc.
    - h. Viking Johnson.
- D. Plastic-to-Metal Transition Fittings:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Charlotte Pipe and Foundry Company.
    - b. Harvel Plastics, Inc.
    - c. Spears Manufacturing Company.
    - d. Uponor.
  - 2. Description:
    - a. CPVC or PVC one-piece fitting with manufacturer's Schedule 80 equivalent dimensions.
    - b. One end with threaded brass insert and one solvent-cement-socket or threaded end.
- E. Plastic-to-Metal Transition Unions:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Colonial Engineering, Inc.
    - b. NIBCO INC.
    - c. Spears Manufacturing Company.
  - 2. Description:

- a. CPVC or PVC four-part union.
- b. Brass or stainless-steel threaded end.
- c. Solvent-cement-joint or threaded plastic end.
- d. Rubber O-ring.
- e. Union nut.

## 2.06 DIELECTRIC FITTINGS

- A. General Requirements: Assembly of copper alloy and ferrous materials with separating nonconductive insulating material. Include end connections compatible with pipes to be joined.
- B. Dielectric Unions:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. A.Y. McDonald Mfg. Co.
    - b. Capitol Manufacturing Company.
    - c. Central Plastics Company.
    - d. HART Industrial Unions, LLC.
    - e. Jomar Valve.
    - f. Matco-Norca.
    - g. Watts; a Watts Water Technologies company.
    - h. Wilkins.
    - i. Zurn Industries, LLC.
  - 2. Standard: ASSE 1079.
  - 3. Pressure Rating: 125 psig minimum at 180 deg F.
  - 4. End Connections: Solder-joint copper alloy and threaded ferrous.
- C. Dielectric Flanges:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Capitol Manufacturing Company.
    - b. Central Plastics Company.
    - c. Matco-Norca.
    - d. Watts; a Watts Water Technologies company.
    - e. Wilkins.
    - f. Zurn Industries, LLC.
  - 2. Standard: ASSE 1079.
  - 3. Factory-fabricated, bolted, companion-flange assembly.
  - 4. Pressure Rating: 125 psig minimum at 180 deg F.

5. End Connections: Solder-joint copper alloy and threaded ferrous; threaded solder-joint copper alloy and threaded ferrous.
- D. Dielectric-Flange Insulating Kits:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Advance Products & Systems, Inc.
    - b. Calpico, Inc.
    - c. Central Plastics Company.
    - d. Pipeline Seal and Insulator, Inc.
  2. Nonconducting materials for field assembly of companion flanges.
  3. Pressure Rating: 150 psig.
  4. Gasket: Neoprene or phenolic.
  5. Bolt Sleeves: Phenolic or polyethylene.
  6. Washers: Phenolic with steel backing washers.
- E. Dielectric Nipples:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Elster Perfection Corporation.
    - b. Grinnell Mechanical Products.
    - c. Matco-Norca.
    - d. Precision Plumbing Products.
    - e. Victaulic Company.
  2. Standard: IAPMO PS 66.
  3. Electroplated steel nipple complying with ASTM F 1545.
  4. Pressure Rating and Temperature: 300 psig at 225 deg F.
  5. End Connections: Male threaded or grooved.
  6. Lining: Inert and noncorrosive, propylene.

## **PART 3 - EXECUTION**

### **3.01 EARTH MOVING**

- A. Comply with requirements for excavating, trenching, and backfilling specified in Section 312000 "Earthwork."

### **3.02 PIPING INSTALLATION**

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of domestic water piping. Indicated locations and arrangements are used to size pipe and

calculate friction loss, expansion, and other design considerations. Install piping as indicated unless deviations to layout are approved on coordination drawings.

- B. Install copper tubing under building slab according to CDA's "Copper Tube Handbook."
- C. Install underground copper tube in PE encasement according to ASTM A 674 or AWWA C105/A21.5.
- D. Install shutoff valve immediately upstream of each dielectric fitting.
- E. Install domestic water piping level and plumb.
- F. Install seismic restraints on piping. Comply with requirements for seismic-restraint devices in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- G. Install piping concealed from view and protected from physical contact by building occupants unless otherwise indicated and except in equipment rooms and service areas.
- H. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- I. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal, and coordinate with other services occupying that space.
- J. Install piping to permit valve servicing.
- K. Install nipples, unions, special fittings, and valves with pressure ratings the same as or higher than the system pressure rating used in applications below unless otherwise indicated.
- L. Install piping free of sags and bends.
- M. Install fittings for changes in direction and branch connections.
- N. Install unions in copper tubing at final connection to each piece of equipment, machine, and specialty.
- O. Install pressure gages on suction and discharge piping for each plumbing pump and packaged booster pump. Comply with requirements for pressure gages in Section 220519 "Meters and Gages for Plumbing Piping."
- P. Install thermostats in hot-water circulation piping. Comply with requirements for thermostats in Section 221123 "Domestic Water Pumps."
- Q. Install thermometers on outlet piping from each water heater. Comply with requirements for thermometers in Section 220519 "Meters and Gages for Plumbing Piping."
- R. Install sleeves for piping penetrations of walls, ceilings, and floors. Comply with requirements for sleeves specified in Section 220517 "Sleeves and Sleeve Seals for Plumbing Piping."
- S. Install sleeve seals for piping penetrations of concrete walls and slabs. Comply with requirements for sleeve seals specified in Section 220517 "Sleeves and Sleeve Seals for Plumbing Piping."
- T. Install escutcheons for piping penetrations of walls, ceilings, and floors. Comply with requirements for escutcheons specified in Section 220518 "Escutcheons for Plumbing Piping."

### **3.03 JOINT CONSTRUCTION**

- A. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- B. Remove scale, slag, dirt, and debris from inside and outside of pipes, tubes, and fittings before assembly.

- C. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
  - 1. Apply appropriate tape or thread compound to external pipe threads.
  - 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged.
- D. Soldered Joints for Copper Tubing: Apply ASTM B 813, water-flushable flux to end of tube. Join copper tube and fittings according to ASTM B 828 or CDA's "Copper Tube Handbook."
- E. Brazed Joints for Copper Tubing: Comply with CDA's "Copper Tube Handbook," "Brazed Joints" chapter.
- F. Flanged Joints: Select appropriate asbestos-free, nonmetallic gasket material in size, type, and thickness suitable for domestic water service. Join flanges with gasket and bolts according to ASME B31.9.
- G. Joints for Dissimilar-Material Piping: Make joints using adapters compatible with materials of both piping systems.

#### **3.04 TRANSITION FITTING INSTALLATION**

- A. Install transition couplings at joints of dissimilar piping.
- B. Transition Fittings in Underground Domestic Water Piping:
  - 1. Fittings for NPS 1-1/2 and Smaller: Fitting-type coupling.
  - 2. Fittings for NPS 2 and Larger: Sleeve-type coupling.
- C. Transition Fittings in Aboveground Domestic Water Piping NPS 2 and Smaller: Plastic-to-metal transition fittings or unions.

#### **3.05 DIELECTRIC FITTING INSTALLATION**

- A. Install dielectric fittings in piping at connections of dissimilar metal piping and tubing.
- B. Dielectric Fittings for NPS 2 and Smaller: Use dielectric couplings.
- C. Dielectric Fittings for NPS 2-1/2 to NPS 4: Use dielectric flanges.
- D. Dielectric Fittings for NPS 5 and Larger: Use dielectric flange kits.

#### **3.06 HANGER AND SUPPORT INSTALLATION**

- A. Comply with requirements for seismic-restraint devices in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- B. Comply with requirements for pipe hanger, support products, and installation in Section 220529 "Hangers and Supports for Plumbing Piping and Equipment."
  - 1. Vertical Piping: MSS Type 8 or 42, clamps.
  - 2. Individual, Straight, Horizontal Piping Runs:
    - a. 100 Feet and Less: MSS Type 1, adjustable, steel clevis hangers.
    - b. Longer Than 100 Feet: MSS Type 43, adjustable roller hangers.
    - c. Longer Than 100 Feet if Indicated: MSS Type 49, spring cushion rolls.

3. Multiple, Straight, Horizontal Piping Runs 100 Feet or Longer: MSS Type 44, pipe rolls. Support pipe rolls on trapeze.
  4. Base of Vertical Piping: MSS Type 52, spring hangers.
- C. Support vertical piping and tubing at base and at each floor.
- D. Install hangers for copper tubing with the following maximum horizontal spacing and minimum rod diameters:
1. NPS 3/4 and Smaller: 60 inches with 3/8-inch rod.
  2. NPS 1 and NPS 1-1/4: 72 inches with 3/8-inch rod.
  3. NPS 1-1/2 and NPS 2: 96 inches with 3/8-inch rod.
  4. NPS 2-1/2: 108 inches with 1/2-inch rod.
  5. NPS 3 to NPS 5: 10 feet with 1/2-inch rod.
  6. NPS 8: 10 feet with 3/4-inch rod.
- E. Install supports for vertical copper tubing every 10 feet.
- F. Support piping and tubing not listed in this article according to MSS SP-58 and manufacturer's written instructions.

### **3.07 CONNECTIONS**

- A. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. When installing piping adjacent to equipment and machines, allow space for service and maintenance.
- C. Connect domestic water piping to exterior water-service piping. Use transition fitting to join dissimilar piping materials.
- D. Connect domestic water piping to water-service piping with shutoff valve; extend and connect to the following:
1. Water Heaters: Cold-water inlet and hot-water outlet piping in sizes indicated, but not smaller than sizes of water heater connections.
  2. Plumbing Fixtures: Cold- and hot-water-supply piping in sizes indicated, but not smaller than that required by plumbing code.
  3. Equipment: Cold- and hot-water-supply piping as indicated, but not smaller than equipment connections. Provide shutoff valve and union for each connection. Use flanges instead of unions for NPS 2-1/2 and larger.

### **3.08 IDENTIFICATION**

- A. Identify system components. Comply with requirements for identification materials and installation in Section 220553 "Identification for Plumbing Piping and Equipment."
- B. Label pressure piping with system operating pressure.

### **3.09 FIELD QUALITY CONTROL**

- A. Perform the following tests and inspections:
1. Piping Inspections:

- a. Do not enclose, cover, or put piping into operation until it has been inspected and approved by authorities having jurisdiction.
  - b. During installation, notify authorities having jurisdiction at least one day before inspection must be made. Perform tests specified below in presence of authorities having jurisdiction:
    - 1) Roughing-in Inspection: Arrange for inspection of piping before concealing or closing in after roughing in and before setting fixtures.
    - 2) Final Inspection: Arrange for authorities having jurisdiction to observe tests specified in "Piping Tests" Subparagraph below and to ensure compliance with requirements.
  - c. Reinspection: If authorities having jurisdiction find that piping will not pass tests or inspections, make required corrections and arrange for reinspection.
  - d. Reports: Prepare inspection reports and have them signed by authorities having jurisdiction.
2. Piping Tests:
- a. Fill domestic water piping. Check components to determine that they are not air bound and that piping is full of water.
  - b. Test for leaks and defects in new piping and parts of existing piping that have been altered, extended, or repaired. If testing is performed in segments, submit a separate report for each test, complete with diagram of portion of piping tested.
  - c. Leave new, altered, extended, or replaced domestic water piping uncovered and unconcealed until it has been tested and approved. Expose work that was covered or concealed before it was tested.
  - d. Cap and subject piping to static water pressure of 50 psig above operating pressure, without exceeding pressure rating of piping system materials. Isolate test source and allow it to stand for four hours. Leaks and loss in test pressure constitute defects that must be repaired.
  - e. Repair leaks and defects with new materials, and retest piping or portion thereof until satisfactory results are obtained.
  - f. Prepare reports for tests and for corrective action required.
- B. Domestic water piping will be considered defective if it does not pass tests and inspections.
- C. Prepare test and inspection reports.

### **3.10 ADJUSTING**

- A. Perform the following adjustments before operation:
  - 1. Close drain valves, hydrants, and hose bibbs.
  - 2. Open shutoff valves to fully open position.
  - 3. Open throttling valves to proper setting.
  - 4. Adjust balancing valves in hot-water-circulation return piping to provide adequate flow.
    - a. Adjust calibrated balancing valves to flows indicated.



5. Remove plugs used during testing of piping and for temporary sealing of piping during installation.
6. Remove and clean strainer screens. Close drain valves and replace drain plugs.
7. Remove filter cartridges from housings and verify that cartridges are as specified for application where used and are clean and ready for use.
8. Check plumbing specialties and verify proper settings, adjustments, and operation.

### **3.11 CLEANING**

- A. Clean and disinfect potable domestic water piping as follows:
  1. Purge new piping and parts of existing piping that have been altered, extended, or repaired before using.
  2. Use purging and disinfecting procedures prescribed by authorities having jurisdiction; if methods are not prescribed, use procedures described in either AWWA C651 or AWWA C652 or follow procedures described below:
    - a. Flush piping system with clean, potable water until dirty water does not appear at outlets.
    - b. Fill and isolate system according to either of the following:
      - 1) Fill system or part thereof with water/chlorine solution with at least 50 ppm of chlorine. Isolate with valves and allow to stand for 24 hours.
      - 2) Fill system or part thereof with water/chlorine solution with at least 200 ppm of chlorine. Isolate and allow to stand for three hours.
    - c. Flush system with clean, potable water until no chlorine is in water coming from system after the standing time.
    - d. Repeat procedures if biological examination shows contamination.
    - e. Submit water samples in sterile bottles to authorities having jurisdiction.
- B. Clean non-potable domestic water piping as follows:
  1. Purge new piping and parts of existing piping that have been altered, extended, or repaired before using.
  2. Use purging procedures prescribed by authorities having jurisdiction or; if methods are not prescribed, follow procedures described below:
    - a. Flush piping system with clean, potable water until dirty water does not appear at outlets.
    - b. Submit water samples in sterile bottles to authorities having jurisdiction. Repeat procedures if biological examination shows contamination.
- C. Prepare and submit reports of purging and disinfecting activities. Include copies of water-sample approvals from authorities having jurisdiction.
- D. Clean interior of domestic water piping system. Remove dirt and debris as work progresses.

### **3.12 PIPING SCHEDULE**

- A. Transition and special fittings with pressure ratings at least equal to piping rating may be used in applications below unless otherwise indicated.

- B. Flanges and unions may be used for aboveground piping joints unless otherwise indicated.
- C. Under-building-slab, domestic water, building-service piping, NPS 3 and smaller, shall be the following:
  - 1. Soft copper tube, ASTM B 88, Type K; wrought-copper, solder-joint fittings; and brazed joints.
- D. Under-building-slab, domestic water piping, NPS 2 and smaller, shall be the following:
  - 1. Soft copper tube, ASTM B 88, Type L; wrought-copper, solder-joint fittings; and brazed joints.
- E. Aboveground domestic water piping, NPS 1-1/4 and smaller, shall be the following:
  - 1. Hard copper tube, ASTM B 88, Type L; cast- or wrought-copper, solder-joint fittings; and soldered joints.
- F. Aboveground domestic water piping, NPS 1-1/2 and larger shall be the following:
  - 1. Hard copper tube, ASTM B 88, Type L; cast- or wrought-copper, solder-joint fittings; and brazed joints.

### **3.13 VALVE SCHEDULE**

- A. Drawings indicate valve types to be used. Where specific valve types are not indicated, the following requirements apply:
  - 1. Shutoff Duty: Use ball for piping NPS 2 and smaller. Use butterfly, ball, or gate valves with flanged ends for piping NPS 2-1/2 and larger.
  - 2. Throttling Duty: Use ball valves for piping NPS 2 and smaller. Use butterfly or ball valves with flanged ends for piping NPS 2-1/2 and larger.
  - 3. Hot-Water Circulation Piping, Balancing Duty: Calibrated balancing valves.
  - 4. Drain Duty: Hose-end drain valves.
- B. Use check valves to maintain correct direction of domestic water flow to and from equipment.

END OF SECTION



**SECTION 22 11 19**  
**DOMESTIC WATER PIPING SPECIALTIES**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Vacuum breakers.
  - 2. Balancing valves.
  - 3. Temperature-actuated, water mixing valves.
  - 4. Strainers.
  - 5. Hose bibbs.
  - 6. Drain valves.
  - 7. Water-hammer arresters.
  - 8. Air vents.
  - 9. Trap-seal primer valves.
  - 10. Flexible connectors.
- B. Related Requirements:
  - 1. Section 220519 "Meters and Gages for Plumbing Piping" for thermometers and pressure gages in domestic water piping.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
- B. Pipe, pipe or plumbing fittings, fixtures, solder and flux installed in a system providing water for human consumption shall comply with lead free requirements of California Health and Safety Code Section 116875. Provide submittal information for products third-party certified by an approved laboratory as complying with California Health and Safety Code Section 116875.
  - 1. Certification that products comply with NSF 61 Annex G and NSF 372.
- C. Shop Drawings: For domestic water piping specialties.
  - 1. Include diagrams for power, signal, and control wiring.
- D. Sustainable Design Submittals:
  - 1. Product Data: For water consumption.

**1.03 INFORMATIONAL SUBMITTALS**

- A. Field quality-control reports.

**1.04 QUALITY ASSURANCE**

- A. California Health and Safety Code Compliance: For products covered under the scope of HSC 116875 for potable water service. Products for potable water service shall be third-party

certified by an approved laboratory as complying with California Health and Safety Code Section 116875.

### **1.05 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For domestic water piping specialties to include in emergency, operation, and maintenance manuals.

## **PART 2 - PRODUCTS**

### **2.01 GENERAL REQUIREMENTS FOR PIPING SPECIALTIES**

- A. Potable-water piping and components shall comply with NSF 61 Annex G, and NSF 372.

### **2.02 PERFORMANCE REQUIREMENTS**

- A. Minimum Working Pressure for Domestic Water Piping Specialties: 125 psig unless otherwise indicated.

### **2.03 VACUUM BREAKERS**

- A. Pipe-Applied, Atmospheric-Type Vacuum Breakers:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Apollo Valves; Conbraco Industries, Inc.
    - b. FEBCO.
    - c. Watts; a Watts Water Technologies company.
    - d. Zurn Industries, LLC.
  - 2. Standard: ASSE 1001.
  - 3. Size: NPS 1/4 to NPS 3, as required to match connected piping.
  - 4. Body: Bronze.
  - 5. Inlet and Outlet Connections: Threaded.
  - 6. Finish: Chrome plated.
- B. Hose-Connection Vacuum Breakers:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Apollo Valves; Conbraco Industries, Inc.
    - b. Arrowhead Brass Products.
    - c. Cash Acme.
    - d. Legend Valve & Fitting, Inc.
    - e. MIFAB, Inc.
    - f. Prier Products, Inc.
    - g. Watts; a Watts Water Technologies company.

- h. Woodford Manufacturing Company.
- i. Zurn Industries, LLC.
- 2. Standard: ASSE 1011.
- 3. Body: Bronze, nonremovable, with manual drain.
- 4. Outlet Connection: Garden-hose threaded complying with ASME B1.20.7.
- 5. Finish: Chrome or nickel plated.

#### **2.04 BALANCING VALVES**

- A. Copper-Alloy Calibrated Balancing Valves:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. ITT Corporation.
    - b. NIBCO INC.
    - c. Watts; a Watts Water Technologies company.
  - 2. Type: Ball valve with two readout ports and memory-setting indicator.
  - 3. Body: bronze.
  - 4. Size: Same as connected piping, but not larger than NPS 2.
  - 5. Accessories: Meter hoses, fittings, valves, differential pressure meter, and carrying case.
- B. Accessories: Meter hoses, fittings, valves, differential pressure meter, and carrying case.

#### **2.05 TEMPERATURE-ACTUATED, WATER MIXING VALVES**

- A. Water-Temperature Limiting Devices:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Leonard Valve Company.
    - b. Powers.
    - c. Watts; a Watts Water Technologies company.
    - d. Zurn Industries, LLC.
  - 2. Standard: ASSE 1017.
  - 3. Pressure Rating: 125 psig.
  - 4. Type: Thermostatically controlled, water mixing valve.
  - 5. Material: Bronze body with corrosion-resistant interior components.
  - 6. Connections: Threaded union inlets and outlet.
  - 7. Accessories: Check stops on hot- and cold-water supplies, and adjustable, temperature-control handle.
  - 8. Tempered-Water Setting: 120 deg. F.
  - 9. Valve Finish: Chrome plated.

B. Individual-Fixture, Water Tempering Valves:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Leonard Valve Company.
  - b. Powers.
  - c. Watts; a Watts Water Technologies company.
  - d. Zurn Industries, LLC.
2. Standard: ASSE 1016, thermostatically controlled, water tempering valve.
3. Pressure Rating: 125 psig minimum unless otherwise indicated.
4. Body: Bronze body with corrosion-resistant interior components.
5. Temperature Control: Adjustable.
6. Inlets and Outlet: Threaded.
7. Finish: Rough or chrome-plated bronze.
8. Tempered-Water Setting: 110 deg. F.

## 2.06 STRAINERS FOR DOMESTIC WATER PIPING

A. Y-Pattern Strainers:

1. Pressure Rating: 125 psig minimum unless otherwise indicated.
2. Body: Bronze for NPS 2 and smaller; cast iron with interior lining that complies with AWWA C550 or that is FDA approved, epoxy coated and for NPS 2-1/2 and larger.
3. End Connections: Threaded for NPS 2 and smaller
4. Screen: Stainless steel with round perforations unless otherwise indicated.
5. Perforation Size:
  - a. Strainers NPS 2 and Smaller: 0.062 inch.
6. Drain: Factory-installed, hose-end drain valve.

## 2.07 HOSE BIBBS

A. Hose Bibbs:

1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
  - a. Jay R. Smith Mfg. Co.
  - b. Josam Company.
  - c. MIFAB, Inc.
  - d. Woodford Manufacturing Company.
2. Standard: ASME A112.18.1 for sediment faucets.
3. Body Material: Bronze.
4. Seat: Bronze, replaceable.

5. Supply Connections: NPS 1/2 or NPS 3/4 threaded or solder-joint inlet.
6. Outlet Connection: Garden-hose thread complying with ASME B1.20.7.
7. Pressure Rating: 125 psig.
8. Vacuum Breaker: Integral nonremovable, drainable, hose-connection vacuum breaker complying with ASSE 1011.
9. Finish for Equipment Rooms: Rough bronze, or chrome or nickel plated.
10. Finish for Service Areas: Chrome or nickel plated.
11. Finish for Finished Rooms: Chrome or nickel plated.
12. Operation for Equipment Rooms: Wheel handle or operating key.
13. Operation for Service Areas: Operating key.
14. Operation for Finished Rooms: Operating key.
15. Include operating key with each operating-key hose bibb.
16. Include integral wall flange with each chrome- or nickel-plated hose bibb.

## **2.08 DRAIN VALVES**

- A. Ball-Valve-Type, Hose-End Drain Valves:
  1. Standard: MSS SP-110 for standard-port, two-piece ball valves.
  2. Pressure Rating: 400-psig minimum CWP.
  3. Size: NPS 3/4.
  4. Body: Copper alloy.
  5. Ball: Chrome-plated brass.
  6. Seats and Seals: Replaceable.
  7. Handle: Vinyl-covered steel.
  8. Inlet: Threaded or solder joint.
  9. Outlet: Threaded, short nipple with garden-hose thread complying with ASME B1.20.7 and cap with brass chain.
- B. Stop-and-Waste Drain Valves:
  1. Standard: MSS SP-110 for ball valves or MSS SP-80 for gate valves.
  2. Pressure Rating: 200-psig minimum CWP or Class 125.
  3. Size: NPS 3/4.
  4. Body: Copper alloy or ASTM B 62 bronze.
  5. Drain: NPS 1/8 side outlet with cap.

## **2.09 WATER-HAMMER ARRESTERS**

- A. Water-Hammer Arresters:
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. AMTROL, Inc.



- b. Josam Company.
  - c. MIFAB, Inc.
  - d. Precision Plumbing Products, Inc.
  - e. Sioux Chief Manufacturing Company, Inc.
2. Standard: ASSE 1010 or PDI-WH 201.
  3. Type: Metal bellows.
  4. Size: ASSE 1010, Sizes AA and A through F, or PDI-WH 201, Sizes A through F.

## **2.10 TRAP-SEAL PRIMER DEVICE**

- A. Supply-Type, Trap-Seal Primer Device:
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. MIFAB, Inc.
    - b. Precision Plumbing Products.
    - c. Sioux Chief Manufacturing Company, Inc.
  2. Standard: ASSE 1018.
  3. Pressure Rating: 125 psig minimum.
  4. Body: Bronze.
  5. Inlet and Outlet Connections: NPS 1/2 threaded, union, or solder joint.
  6. Gravity Drain Outlet Connection: NPS 1/2 threaded or solder joint.
  7. Finish: Chrome plated, or rough bronze for units used with pipe or tube that is not chrome finished.

## **2.11 FLEXIBLE CONNECTORS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. Flex-Hose Co., Inc.
  2. Flexicraft Industries.
  3. Hyspan Precision Products, Inc.
  4. Metraflex Company (The).
- B. Bronze-Hose Flexible Connectors: Corrugated-bronze tubing with bronze wire-braid covering and ends brazed to inner tubing.
  1. Working-Pressure Rating: Minimum 200 psig.
  2. End Connections NPS 2 and Smaller: Threaded copper pipe or plain-end copper tube.
  3. End Connections NPS 2-1/2 and Larger: Flanged copper alloy.
- C. Stainless-Steel-Hose Flexible Connectors: Corrugated-stainless-steel tubing with stainless-steel wire-braid covering and ends welded to inner tubing.
  1. Working-Pressure Rating: Minimum 200 psig.

2. End Connections NPS 2 and Smaller: Threaded steel-pipe nipple.
3. End Connections NPS 2-1/2 and Larger: Flanged steel nipple.

## **PART 3 - EXECUTION**

### **3.01 INSTALLATION**

- A. Install balancing valves in locations where they can easily be adjusted.
- B. Install temperature-actuated, water mixing valves with check stops or shutoff valves on inlets and with shutoff valve on outlet.
  1. Install cabinet-type units recessed in or surface mounted on wall as specified.
- C. Install Y-pattern strainers for water on supply side of each control valve and pump.
- D. Install water-hammer arresters in water piping according to PDI-WH 201.
- E. Install supply-type, trap-seal primer valves with outlet piping pitched down toward drain trap a minimum of 1 percent, and connect to floor-drain body, trap, or inlet fitting. Adjust valve for proper flow.

### **3.02 CONNECTIONS**

- A. Comply with requirements for ground equipment in Section 260501 "Basic Electrical Materials and Methods."
- B. Fire-retardant-treated-wood blocking is specified in Section 260530 "Conduit and Wire" for electrical connections.

### **3.03 LABELING AND IDENTIFYING**

- A. Equipment Nameplates and Signs: Install engraved plastic-laminate equipment nameplate or sign on or near each of the following:
  1. Calibrated balancing valves.
  2. Supply-type, trap-seal primer valves.
- B. Distinguish among multiple units, inform operator of operational requirements, indicate safety and emergency precautions, and warn of hazards and improper operations, in addition to identifying unit. Nameplates and signs are specified in Section 220553 "Identification for Plumbing Piping and Equipment."

### **3.04 ADJUSTING**

- A. Set field-adjustable flow set points of balancing valves.
- B. Set field-adjustable temperature set points of temperature-actuated, water mixing valves.

END OF SECTION



**SECTION 22 11 23**  
**DOMESTIC WATER PUMPS**

**PART 1 GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. In-line, sealless centrifugal pumps.

**1.02 DEFINITIONS**

- A. Low Voltage: As defined in NFPA 70 for circuits and equipment operating at less than 50 V or for remote-control, signaling power-limited circuits.

**1.03 SUBMITTALS**

- A. Product Data: For each type of product indicated. Include materials of construction, rated capacities, certified performance curves with operating points plotted on curves, operating characteristics, electrical characteristics, and furnished specialties and accessories.
- B. Pipe, pipe or plumbing fittings, fixtures, solder and flux installed in a system providing water for human consumption shall comply with lead free requirements of California Health and Safety Code Section 11 68 75. Provide submittal information for products third-party certified by an approved laboratory as complying with California Health and Safety Code Section 11 68 75.

**1.04 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For domestic water pumps to include in operation and maintenance manuals.

**1.05 QUALITY ASSURANCE**

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. UL Compliance: Comply with UL 778 for motor-operated water pumps.
- C. California Health and Safety Code Compliance: HSC 116875 for pumps for potable water service. Pumps for potable water service shall be third-party certified by an approved laboratory as complying with California Health and Safety Code Section 11 68 75.

**1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Retain shipping flange protective covers and protective coatings during storage.
- B. Protect bearings and couplings against damage.
- C. Comply with pump manufacturer's written rigging instructions for handling.

**1.07 COORDINATION**

- A. Coordinate sizes and locations of concrete bases with actual equipment provided.

## **PART 2 PRODUCTS**

### **2.01 IN-LINE, SEALLESS CENTRIFUGAL PUMPS**

- A. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
  - 1. TACO Comfort Solutions, Inc.
  - 2. WILO USA LLC - WILO Canada Inc.
- B. Description: Factory-assembled and -tested, in-line, close-coupled, canned-motor, sealless, overhung-impeller centrifugal pumps.
- C. Pump Construction:
  - 1. Pump and Motor Assembly: Hermetically sealed, replaceable-cartridge type with motor and impeller on common shaft and designed for installation with pump and motor shaft horizontal.
  - 2. Casing: Bronze, with threaded or companion-flange connections.
  - 3. Shaft and bearing rings: Ceramic.
  - 4. Impeller: Plastic.
  - 5. Motor: Single speed, unless otherwise indicated.
- D. Controls:
  - 1. Illuminated display showing energy consumption, flow, and operating mode.
  - 2. Minimum 3 constant pressure control modes of operation.
- E. Capacities and Characteristics:
  - 1. Capacity: Refer to schedules.
  - 2. Total Dynamic Head: Refer to schedules.
  - 3. Minimum Working Pressure: 125 psig.
  - 4. Maximum Continuous Operating Temperature: 220 deg F.
  - 5. Inlet and Outlet Size: Refer to schedules.
  - 6. Pump Speed: Refer to schedules.
  - 7. Pump Control: Aquastat.
  - 8. Motor Horsepower: Refer to schedules.
  - 9. Electrical Characteristics:
    - a. Volts: 120.
    - b. Phases: Single.
    - c. Hertz: 60.

### **2.02 MOTORS**

- A. Comply with NEMA designation, temperature rating, service factor, enclosure type, and efficiency requirements for motors specified in Section 22 05 13 "Common Motor Requirements for Plumbing Equipment."
  - 1. Electrically commutated motor.

2. Motor Sizes: Minimum size as indicated. If not indicated, large enough so driven load will not require motor to operate in service factor range above 1.0.

### **2.03 CONTROLS**

- A. Thermostats: Electric; adjustable for control of hot-water circulation pump.
  1. Type: Water-immersion temperature sensor, for installation in piping.
  2. Range: 50 to 125 deg F.
  3. Enclosure: NEMA 250, Type 4X.
  4. Operation of Pump: On or off.
  5. Transformer: Provide if required.
  6. Power Requirement: 120 V, ac.
  
- B. Timers: Electric, for control of hot-water circulation pump.
  1. Type: Programmable, seven-day clock with manual override on-off switch.
  2. Enclosure: NEMA 250, Type 1, suitable for wall mounting.
  3. Operation of Pump: On or off.
  4. Transformer: Provide if required.
  5. Power Requirement: 120-V ac.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Examine roughing-in of domestic-water-piping system to verify actual locations of connections before pump installation.

### **3.02 PUMP INSTALLATION**

- A. Comply with HI 1.4.
- B. Install in-line, sealless centrifugal pumps with shaft horizontal unless otherwise indicated.
- C. Install thermostats in hot-water return piping.

### **3.03 CONNECTIONS**

- A. Comply with requirements for piping specified in Section 22 11 16 "Domestic Water Piping." Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Install piping adjacent to pumps to allow service and maintenance.
- C. Connect domestic water piping to pumps. Install suction and discharge piping equal to or greater than size of pump nozzles.
  1. Install flexible connectors adjacent to pumps in suction and discharge piping of the following pumps:
    - a. Horizontally mounted, in-line, separately coupled centrifugal pumps.
- D. Install shutoff valve and strainer on suction side of each pump, and check, shutoff, and throttling valves on discharge side of each pump. Install valves same size as connected piping. Comply with requirements for valves specified in 220523 General-Duty Valves for Plumbing

Piping," and comply with requirements for strainers specified in Section 22 11 19 "Domestic Water Piping Specialties."

- E. Connect thermostats to pumps that they control.

### **3.04 IDENTIFICATION**

- A. Comply with requirements for identification specified in Section 22 05 53 "Identification for Plumbing Piping and Equipment" for identification of pumps.

### **3.05 STARTUP SERVICE**

- A. Engage a factory-authorized service representative to perform startup service.
  - 1. Complete installation and startup checks according to manufacturer's written instructions.
  - 2. Check piping connections for tightness.
  - 3. Clean strainers on suction piping.
  - 4. Set thermostats for automatic starting and stopping operation of pumps.
  - 5. Perform the following startup checks for each pump before starting:
    - a. Verify bearing lubrication.
    - b. Verify that pump is free to rotate by hand and that pump for handling hot liquid is free to rotate with pump hot and cold. If pump is bound or drags, do not operate until cause of trouble is determined and corrected.
    - c. Verify that pump is rotating in the correct direction.
  - 6. Prime pump by opening suction valves and closing drains, and prepare pump for operation.
  - 7. Start motor.
  - 8. Open discharge valve slowly.
  - 9. Adjust temperature settings on thermostats.
  - 10. Adjust timer settings.

### **3.06 ADJUSTING**

- A. Adjust domestic water pumps to function smoothly, and lubricate as recommended by manufacturer.
- B. Adjust initial temperature set points.
- C. Set field-adjustable switches and circuit-breaker trip ranges as indicated.

END OF SECTION

**SECTION 22 13 16**  
**SANITARY WASTE AND VENT PIPING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

A. Section Includes:

1. Pipe, tube, and fittings.
2. Specialty pipe fittings.
3. Encasement for underground metal piping.

B. Related Requirements:

1. Section 333111 "Site Sanitary Sewer System" for sanitary sewerage piping and structures outside the building.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.

**1.03 INFORMATIONAL SUBMITTALS**

- A. Field quality-control reports.

**1.04 FIELD CONDITIONS**

- A. Interruption of Existing Sanitary Waste Service: Do not interrupt service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary service according to requirements indicated:
1. Notify Owner and Construction Manager no fewer than two days in advance of proposed interruption of sanitary waste service.
  2. Do not proceed with interruption of sanitary waste service without Owner's and Construction Manager's written permission.

**PART 2 - PRODUCTS**

**2.01 PERFORMANCE REQUIREMENTS**

- A. Components and installation shall be capable of withstanding the following minimum working pressure unless otherwise indicated:
1. Soil, Waste, and Vent Piping: 10-foot head of water.

**2.02 PIPING MATERIALS**

- A. Piping materials shall bear label, stamp, or other markings of specified testing agency.
- B. Comply with requirements in "Piping Schedule" Article for applications of pipe, tube, fitting materials, and joining methods for specific services, service locations, and pipe sizes.



### **2.03 HUB-AND-SPIGOT, CAST-IRON SOIL PIPE AND FITTINGS**

- A. Pipe and Fittings: ASTM A 74, Service and Extra Heavy class(es).
- B. Gaskets: ASTM C 564, rubber.
- C. Calking Materials: ASTM B 29, pure lead and oakum or hemp fiber.

### **2.04 HUBLESS, CAST-IRON SOIL PIPE AND FITTINGS**

- A. Pipe and Fittings: ASTM A 888 or CISPI 301.
- B. CISPI, Hubless-Piping Couplings:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. ANACO-Husky.
    - b. MIFAB, Inc.
    - c. Tyler Pipe; a subsidiary of McWane Inc.
  - 2. Standards: ASTM C 1277 and CISPI 310.
  - 3. Description: Stainless-steel corrugated shield with stainless-steel bands and tightening devices; and ASTM C 564, rubber sleeve with integral, center pipe stop.
- C. Heavy-Duty, Hubless-Piping Couplings:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. ANACO-Husky.
    - b. MIFAB, Inc.
    - c. Tyler Pipe; a subsidiary of McWane Inc.
  - 2. Standards: ASTM C 1277 and ASTM C 1540.
  - 3. Description: Stainless-steel shield with stainless-steel bands and tightening devices; and ASTM C 564, rubber sleeve with integral, center pipe stop.

### **2.05 GALVANIZED-STEEL PIPE AND FITTINGS**

- A. Galvanized-Steel Pipe: ASTM A 53/A 53M, Type E, Standard Weight class. Include square-cut-grooved or threaded ends matching joining method.
- B. Galvanized-Cast-Iron Drainage Fittings: ASME B16.12, threaded.
- C. Steel Pipe Pressure Fittings:
  - 1. Galvanized-Steel Pipe Nipples: ASTM A 733, made of ASTM A 53/A 53M or ASTM A 106/A 106M, Schedule 40, seamless steel pipe. Include ends matching joining method.
  - 2. Malleable-Iron Unions: ASME B16.39; Class 150; hexagonal-stock body with ball-and-socket, metal-to-metal, bronze seating surface; and female threaded ends.

3. Galvanized-Gray-Iron, Threaded Fittings: ASME B16.4, Class 125, standard pattern.

## **2.06 COPPER TUBE AND FITTINGS**

- A. Copper Type DWV Tube: ASTM B 306, drainage tube, drawn temper.
- B. Copper Drainage Fittings: ASME B16.23, cast copper or ASME B16.29, wrought copper, solder-joint fittings.
- C. Hard Copper Tube: ASTM B 88, Type L and Type M, water tube, drawn temper.
- D. Soft Copper Tube: ASTM B 88, Type L, water tube, annealed temper.
- E. Copper Pressure Fittings:
  1. Copper Fittings: ASME B16.18, cast-copper-alloy or ASME B16.22, wrought-copper, solder-joint fittings. Furnish wrought-copper fittings if indicated.
  2. Copper Unions: MSS SP-123, copper-alloy, hexagonal-stock body with ball-and-socket, metal-to-metal seating surfaces, and solder-joint or threaded ends.
- F. Copper Flanges: ASME B16.24, Class 150, cast copper with solder-joint end.
  1. Flange Gasket Materials: ASME B16.21, full-face, flat, nonmetallic, asbestos-free, 1/8-inch maximum thickness unless thickness or specific material is indicated.
  2. Flange Bolts and Nuts: ASME B18.2.1, carbon steel unless otherwise indicated.
- G. Solder: ASTM B 32, lead free with ASTM B 813, water-flushable flux.

## **2.07 SPECIALTY PIPE FITTINGS**

- A. Transition Couplings:
  1. General Requirements: Fitting or device for joining piping with small differences in OD's or of different materials. Include end connections same size as and compatible with pipes to be joined.
  2. Fitting-Type Transition Couplings: Manufactured piping coupling or specified piping system fitting.
  3. Unshielded, Nonpressure Transition Couplings:
    - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
      - 1) Dallas Specialty & Mfg. Co.
      - 2) Fernco Inc.
      - 3) Froet Industries LLC.
      - 4) Mission Rubber Company, LLC; a division of MCP Industries.
    - b. Standard: ASTM C 1173.
    - c. Description: Elastomeric, sleeve-type, reducing or transition pattern. Include shear ring and corrosion-resistant-metal tension band and tightening mechanism on each end.
    - d. End Connections: Same size as and compatible with pipes to be joined.
    - e. Sleeve Materials:
      - 1) For Cast-Iron Soil Pipes: ASTM C 564, rubber.

- 2) For Dissimilar Pipes: ASTM D 5926, PVC or other material compatible with pipe materials being joined.
4. Shielded, Nonpressure Transition Couplings:
    - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
      - 1) Cascade Waterworks Mfg. Co.
      - 2) Mission Rubber Company, LLC; a division of MCP Industries.
    - b. Standard: ASTM C 1460.
    - c. Description: Elastomeric or rubber sleeve with full-length, corrosion-resistant outer shield and corrosion-resistant-metal tension band and tightening mechanism on each end.
    - d. End Connections: Same size as and compatible with pipes to be joined.
- B. Dielectric Fittings:
1. Dielectric Unions:
    - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
      - 1) A.Y. McDonald Mfg. Co.
      - 2) Capitol Manufacturing Company.
      - 3) Central Plastics Company.
      - 4) HART Industrial Unions, LLC.
      - 5) Jomar Valve.
      - 6) Matco-Norca.
      - 7) Watts; a Watts Water Technologies company.
      - 8) Wilkins.
      - 9) Zurn Industries, LLC.
    - b. Description:
      - 1) Standard: ASSE 1079.
      - 2) Pressure Rating: 150 psig.
      - 3) End Connections: Solder-joint copper alloy and threaded ferrous.
  2. Dielectric Flanges:
    - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
      - 1) Capitol Manufacturing Company.
      - 2) Central Plastics Company.
      - 3) Matco-Norca.
      - 4) Watts; a Watts Water Technologies company.

- 5) Wilkins.
- 6) Zurn Industries, LLC.
- b. Description:
  - 1) Standard: ASSE 1079.
  - 2) Factory-fabricated, bolted, companion-flange assembly.
  - 3) Pressure Rating: 150 psig.
  - 4) End Connections: Solder-joint copper alloy and threaded ferrous; threaded solder-joint copper alloy and threaded ferrous.
- 3. Dielectric-Flange Insulating Kits:
  - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - 1) Advance Products & Systems, Inc.
    - 2) Calpico, Inc.
    - 3) Central Plastics Company.
    - 4) Pipeline Seal and Insulator, Inc.
  - b. Description:
    - 1) Nonconducting materials for field assembly of companion flanges.
    - 2) Pressure Rating: 150 psig.
    - 3) Gasket: Neoprene or phenolic.
    - 4) Bolt Sleeves: Phenolic or polyethylene.
    - 5) Washers: Phenolic with steel backing washers.
- 4. Dielectric Nipples:
  - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - 1) Elster Perfection Corporation.
    - 2) Matco-Norca.
    - 3) Precision Plumbing Products.
  - b. Description:
    - 1) Standard: IAPMO PS 66.
    - 2) Electroplated steel nipple.
    - 3) Pressure Rating: 300 psig at 225 deg F.
    - 4) End Connections: Male threaded or grooved.
    - 5) Lining: Inert and noncorrosive, propylene.

## **2.08 ENCASEMENT FOR UNDERGROUND METAL PIPING**

- A. Standard: ASTM A 674 or AWWA C105/A 21.5.

- B. Material: Linear low-density polyethylene film of 0.008-inch or high-density, cross-laminated polyethylene film of 0.004-inch minimum thickness.
- C. Form: Sheet or tube.
- D. Color: Black or natural.

## **PART 3 - EXECUTION**

### **3.01 EARTH MOVING**

- A. Comply with requirements for excavating, trenching, and backfilling specified in Section 312000 "Earthwork."

### **3.02 PIPING INSTALLATION**

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems.
  - 1. Indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations.
  - 2. Install piping as indicated unless deviations to layout are approved on coordination drawings.
- B. Install piping in concealed locations unless otherwise indicated and except in equipment rooms and service areas.
- C. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- D. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- E. Install piping to permit valve servicing.
- F. Install piping at indicated slopes.
- G. Install piping free of sags and bends.
- H. Install fittings for changes in direction and branch connections.
- I. Install piping to allow application of insulation.
- J. Install seismic restraints on piping. Comply with requirements for seismic-restraint devices specified in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- K. Make changes in direction for soil and waste drainage and vent piping using appropriate branches, bends, and long-sweep bends.
  - 1. Sanitary tees and short-sweep 1/4 bends may be used on vertical stacks if change in direction of flow is from horizontal to vertical.
  - 2. Use long-turn, double Y-branch and 1/8-bend fittings if two fixtures are installed back to back or side by side with common drain pipe.
    - a. Straight tees, elbows, and crosses may be used on vent lines.
  - 3. Do not change direction of flow more than 90 degrees.
  - 4. Use proper size of standard increasers and reducers if pipes of different sizes are connected.

- a. Reducing size of waste piping in direction of flow is prohibited.
- L. Lay buried building waste piping beginning at low point of each system.
  - 1. Install true to grades and alignment indicated, with unbroken continuity of invert. Place hub ends of piping upstream.
  - 2. Install required gaskets according to manufacturer's written instructions for use of lubricants, cements, and other installation requirements.
  - 3. Maintain swab in piping and pull past each joint as completed.
- M. Install soil and waste and vent piping at the following minimum slopes unless otherwise indicated:
  - 1. Building Sanitary Waste: 2 percent downward in direction of flow for piping NPS 3 and smaller; 2 percent downward in direction of flow for piping NPS 4 and larger.
  - 2. Horizontal Sanitary Waste Piping: 2 percent downward in direction of flow.
  - 3. Vent Piping: 1 percent down toward vertical fixture vent or toward vent stack.
- N. Install cast-iron soil piping according to CISPI's "Cast Iron Soil Pipe and Fittings Handbook," Chapter IV, "Installation of Cast Iron Soil Pipe and Fittings."
  - 1. Install encasement on underground piping according to ASTM A 674 or AWWA C105/A 21.5.
- O. Install aboveground copper tubing according to CDA's "Copper Tube Handbook."
- P. Plumbing Specialties:
  - 1. Install cleanouts at grade and extend to where building sanitary drains connect to building sanitary sewers in sanitary waste gravity-flow piping.
    - a. Install cleanout fitting with closure plug inside the building in sanitary drainage force-main piping.
    - b. Comply with requirements for cleanouts specified in Section 221319 "Sanitary Waste Piping Specialties."
  - 2. Install drains in sanitary waste gravity-flow piping.
    - a. Comply with requirements for drains specified in Section 221319 "Sanitary Waste Piping Specialties."
- Q. Do not enclose, cover, or put piping into operation until it is inspected and approved by authorities having jurisdiction.
- R. Install sleeves for piping penetrations of walls, ceilings, and floors.
  - 1. Comply with requirements for sleeves specified in Section 220517 "Sleeves and Sleeve Seals for Plumbing Piping."
- S. Install sleeve seals for piping penetrations of concrete walls and slabs.
  - 1. Comply with requirements for sleeve seals specified in Section 220517 "Sleeves and Sleeve Seals for Plumbing Piping."
- T. Install escutcheons for piping penetrations of walls, ceilings, and floors.
  - 1. Comply with requirements for escutcheons specified in Section 220518 "Escutcheons for Plumbing Piping."

### 3.03 JOINT CONSTRUCTION

- A. Join hub-and-spigot, cast-iron soil piping with gasket joints according to CISPI's "Cast Iron Soil Pipe and Fittings Handbook" for compression joints.
- B. Join hubless, cast-iron soil piping according to CISPI 310 and CISPI's "Cast Iron Soil Pipe and Fittings Handbook" for hubless-piping coupling joints.
- C. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1.
  - 1. Cut threads full and clean using sharp dies.
  - 2. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
    - a. Apply appropriate tape or thread compound to external pipe threads unless dry seal threading is specified.
    - b. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged.
    - c. Do not use pipe sections that have cracked or open welds.
- D. Join copper tube and fittings with soldered joints according to ASTM B 828. Use ASTM B 813, water-flushable, lead-free flux and ASTM B 32, lead-free-alloy solder.
- E. Flanged Joints: Align bolt holes. Select appropriate gasket material, size, type, and thickness. Install gasket concentrically positioned. Use suitable lubricants on bolt threads. Torque bolts in cross pattern.

### 3.04 SPECIALTY PIPE FITTING INSTALLATION

- A. Transition Couplings:
  - 1. Install transition couplings at joints of piping with small differences in ODs.
  - 2. In Waste Drainage Piping: Unshielded, nonpressure transition couplings.
- B. Dielectric Fittings:
  - 1. Install dielectric fittings in piping at connections of dissimilar metal piping and tubing.
  - 2. Dielectric Fittings for NPS 2 and Smaller: Use dielectric unions.
  - 3. Dielectric Fittings for NPS 2-1/2 to NPS 4: Use dielectric flanges.
  - 4. Dielectric Fittings for NPS 5 and Larger: Use dielectric flange kits.

### 3.05 HANGER AND SUPPORT INSTALLATION

- A. Comply with requirements for seismic-restraint devices specified in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- B. Comply with requirements for pipe hanger and support devices and installation specified in Section 220529 "Hangers and Supports for Plumbing Piping and Equipment."
  - 1. Install carbon-steel pipe hangers for horizontal piping in noncorrosive environments.
  - 2. Install carbon-steel pipe support clamps for vertical piping in noncorrosive environments.
  - 3. Vertical Piping: MSS Type 8 or Type 42, clamps.
  - 4. Install individual, straight, horizontal piping runs:
    - a. 100 Feet and Less: MSS Type 1, adjustable, steel clevis hangers.

- b. Longer Than 100 Feet: MSS Type 43, adjustable roller hangers.
  - c. Longer Than 100 Feet if Indicated: MSS Type 49, spring cushion rolls.
- 5. Multiple, Straight, Horizontal Piping Runs 100 Feet or Longer: MSS Type 44, pipe rolls. Support pipe rolls on trapeze.
- 6. Base of Vertical Piping: MSS Type 52, spring hangers.
- C. Support horizontal piping and tubing within 12 inches of each fitting, valve, and coupling.
- D. Support vertical piping and tubing at base and at each floor.
- E. Install hangers for cast-iron soil piping with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 1-1/2 and NPS 2: 60 inches with 3/8-inch rod.
  - 2. NPS 3: 60 inches with 1/2-inch rod.
  - 3. NPS 4 and NPS 5: 60 inches with 5/8-inch rod.
  - 4. NPS 6 and NPS 8: 60 inches with 3/4-inch rod.
- F. Install supports for vertical cast-iron soil piping every 15 feet.
- G. Install hangers for copper tubing with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 1-1/4: 72 inches with 3/8-inch rod.
  - 2. NPS 1-1/2 and NPS 2: 96 inches with 3/8-inch rod.
  - 3. NPS 2-1/2: 108 inches with 1/2-inch rod.
  - 4. NPS 3 - NPS 5: 10 feet with 1/2-inch rod.
- H. Install supports for vertical copper tubing every 10 feet.
- I. Support piping and tubing not listed above according to MSS SP-58 and manufacturer's written instructions.

### 3.06 CONNECTIONS

- A. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Connect soil and waste piping to exterior sanitary sewerage piping. Use transition fitting to join dissimilar piping materials.
- C. Connect waste and vent piping to the following:
  - 1. Plumbing Fixtures: Connect waste piping in sizes indicated, but not smaller than required by plumbing code.
  - 2. Plumbing Fixtures and Equipment: Connect atmospheric vent piping in sizes indicated, but not smaller than required by authorities having jurisdiction.
  - 3. Plumbing Specialties: Connect waste and vent piping in sizes indicated, but not smaller than required by plumbing code.
  - 4. Install test tees (wall cleanouts) in conductors near floor and floor cleanouts with cover flush with floor.
  - 5. Comply with requirements for cleanouts and drains specified in Section 221319 "Sanitary Waste Piping Specialties."
  - 6. Equipment: Connect waste piping as indicated.



- a. Provide shutoff valve if indicated and union for each connection.
  - b. Use flanges instead of unions for connections NPS 2-1/2 and larger.
- D. Where installing piping adjacent to equipment, allow space for service and maintenance of equipment.
- E. Make connections according to the following unless otherwise indicated:
  - 1. Install unions, in piping NPS 2 and smaller, adjacent to each valve and at final connection to each piece of equipment.
  - 2. Install flanges, in piping NPS 2-1/2 and larger, adjacent to flanged valves and at final connection to each piece of equipment.

### **3.07 IDENTIFICATION**

- A. Identify exposed sanitary waste and vent piping.
- B. Comply with requirements for identification specified in Section 220553 "Identification for Plumbing Piping and Equipment."

### **3.08 FIELD QUALITY CONTROL**

- A. During installation, notify authorities having jurisdiction at least 24 hours before inspection must be made. Perform tests specified below in presence of authorities having jurisdiction.
  - 1. Roughing-in Inspection: Arrange for inspection of piping before concealing or closing-in after roughing-in and before setting fixtures.
  - 2. Final Inspection: Arrange for final inspection by authorities having jurisdiction to observe tests specified below and to ensure compliance with requirements.
- B. Reinspection: If authorities having jurisdiction find that piping will not pass test or inspection, make required corrections and arrange for reinspection.
- C. Reports: Prepare inspection reports and have them signed by authorities having jurisdiction.
- D. Test sanitary waste and vent piping according to procedures of authorities having jurisdiction or, in absence of published procedures, as follows:
  - 1. Test for leaks and defects in new piping and parts of existing piping that have been altered, extended, or repaired.
    - a. If testing is performed in segments, submit separate report for each test, complete with diagram of portion of piping tested.
  - 2. Leave uncovered and unconcealed new, altered, extended, or replaced waste and vent piping until it has been tested and approved.
    - a. Expose work that was covered or concealed before it was tested.
  - 3. Roughing-in Plumbing Test Procedure: Test waste and vent piping except outside leaders on completion of roughing-in.
    - a. Close openings in piping system and fill with water to point of overflow, but not less than 10-foot head of water. Maintain pressure for four hours.
    - b. From 15 minutes before inspection starts to completion of inspection, water level must not drop.
    - c. Inspect joints for leaks.

4. Finished Plumbing Test Procedure: After plumbing fixtures have been set and traps filled with water, test connections and prove they are gastight and watertight.
  - a. Plug vent-stack openings on roof and building drains where they leave building. Introduce air into piping system equal to pressure of 1-inch wg.
  - b. Use U-tube or manometer inserted in trap of water closet to measure this pressure.
  - c. Air pressure must remain constant without introducing additional air throughout period of inspection.
  - d. Inspect plumbing fixture connections for gas and water leaks.
5. Repair leaks and defects with new materials and retest piping, or portion thereof, until satisfactory results are obtained.
6. Prepare reports for tests and required corrective action.
7. Repair leaks and defects with new materials and retest piping, or portion thereof, until satisfactory results are obtained.
8. Prepare reports for tests and required corrective action.

### **3.09 CLEANING AND PROTECTION**

- A. Clean interior of piping. Remove dirt and debris as work progresses.
- B. Protect sanitary waste and vent piping during remainder of construction period to avoid clogging with dirt and debris and to prevent damage from traffic and construction work.
- C. Place plugs in ends of uncompleted piping at end of day and when work stops.
- D. Repair damage to adjacent materials caused by waste and vent piping installation.

### **3.10 PIPING SCHEDULE**

- A. Flanges and unions may be used on aboveground pressure piping unless otherwise indicated.
- B. Aboveground, soil and waste piping shall be any of the following:
  1. Service class, cast-iron soil pipe and fittings; gaskets; and gasketed joints.
  2. Hubless, cast-iron soil pipe and fittings; CISPI hubless-piping couplings; and coupled joints.
  3. Hubless, cast-iron soil pipe and fittings; heavy-duty hubless-piping couplings; and coupled joints shall be installed where piping will be located over critical areas including food preparation, food storage, food serving, dining areas, nurseries, and other sensitive areas.
  4. In addition to materials listed above, vertical waste piping from lavatories, sinks, and drinking fountains may be any of the following:
    - a. Galvanized-steel pipe, drainage fittings, and threaded joints.
    - b. Copper DWV tube, copper drainage fittings, and soldered joints.
  5. Dissimilar Pipe-Material Couplings: Unshielded, nonpressure transition couplings.
- C. Aboveground, vent piping NPS 4 and smaller shall be any of the following:
  1. Service class, cast-iron soil pipe and fittings; gaskets; and gasketed joints.
  2. Hubless, cast-iron soil pipe and fittings; CISPI hubless-piping couplings; and coupled joints.

3. Copper Type DWV tube, copper drainage fittings, and soldered joints.
    - a. Option for Vent Piping, NPS 2-1/2 and NPS 3-1/2: Hard copper tube, Type M; copper pressure fittings; and soldered joints.
  4. Dissimilar Pipe-Material Couplings: Shielded, nonpressure transition couplings.
- D. Underground, soil, waste, and vent piping NPS 4 and smaller shall be any of the following:
1. Extra Heavy class, cast-iron soil piping; gaskets; and gasketed joints.
  2. Hubless, cast-iron soil pipe and fittings; heavy-duty hubless-piping couplings; and coupled joints.
  3. Dissimilar Pipe-Material Couplings: Unshielded, nonpressure transition couplings.
- E. Underground, soil and waste piping NPS 5 and larger shall be any of the following:
1. Extra Heavy class, cast-iron soil piping; gaskets; and gasketed joints.
  2. Hubless, cast-iron soil pipe and fittings; heavy-duty hubless-piping couplings; coupled joints.
  3. Dissimilar Pipe-Material Couplings: Shielded, nonpressure transition couplings.

END OF SECTION

**SECTION 22 13 19.13**  
**SANITARY DRAINS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Floor drains.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.

**PART 2 - PRODUCTS**

**2.01 DRAIN ASSEMBLIES**

- A. Sanitary drains shall bear label, stamp, or other markings of specified testing agency.

**2.02 FLOOR DRAINS**

- A. Cast-Iron Floor Drains:
  - 1. Basis-of-Design Product: Subject to compliance with requirements, provide products specified on Drawings, or comparable product by one of the following:
    - a. Josam Company.
    - b. Watts.
    - c. Zurn.
    - d. Or equal.
  - 2. Standard: ASME A112.6.3.
  - 3. Pattern: Floor drain.
  - 4. Body Material: Gray iron.
  - 5. Seepage Flange: Required.
  - 6. Anchor Flange: Required.
  - 7. Clamping Device: Required.
  - 8. Outlet: Bottom.
  - 9. Backwater Valve: Not required.
  - 10. Coating on Interior and Exposed Exterior Surfaces: Manufacturer's standard coating.
  - 11. Strainer Types by Drain Location: Refer to schedule on Drawings.
  - 12. Top or Strainer Material: Nickel bronze.
  - 13. Top of Body and Strainer Finish: Polished Nickel bronze.
  - 14. Top Shape: Round or Square.
  - 15. Top Loading Classification: Medium Duty.

16. Inlet Fitting: Gray iron, with threaded inlet and threaded or spigot outlet, and trap-seal primer valve connection.
17. Trap Material: Cast iron or Copper.
18. Trap Pattern: Standard P-trap.

## **PART 3 - EXECUTION**

### **3.01 INSTALLATION**

- A. Install floor drains at low points of surface areas to be drained. Set grates of drains flush with finished floor, unless otherwise indicated.
  1. Position floor drains for easy access and maintenance.
  2. Set floor drains below elevation of surrounding finished floor to allow floor drainage.
  3. Set with grates depressed according to the following drainage area radii:
    - a. Radius, 30 Inches or Less: Equivalent to 1 percent slope, but not less than 1/4-inch total depression.
    - b. Radius, 30 to 60 Inches: Equivalent to 1 percent slope.
    - c. Radius, 60 Inches or Larger: Equivalent to 1 percent slope, but not greater than 1-inch total depression.
  4. Install floor-drain flashing collar or flange, so no leakage occurs between drain and adjoining flooring.
    - a. Maintain integrity of waterproof membranes where penetrated.
  5. Install individual traps for floor drains connected to sanitary building drain, unless otherwise indicated.

### **3.02 CONNECTIONS**

- A. Comply with requirements in Section 221316 "Sanitary Waste and Vent Piping" for piping installation requirements. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Comply with requirements in Section 221319 "Sanitary Waste Piping Specialties" for miscellaneous sanitary drainage piping specialties.
- C. Install piping adjacent to equipment to allow service and maintenance.

### **3.03 LABELING AND IDENTIFYING**

- A. Distinguish among multiple units, inform operator of operational requirements, indicate safety and emergency precautions, and warn of hazards and improper operations, in addition to identifying unit. Nameplates and signs are specified in Section 220553 "Identification for Plumbing Piping and Equipment."

### **3.04 PROTECTION**

- A. Protect drains during remainder of construction period to avoid clogging with dirt or debris and to prevent damage from traffic or construction work.
- B. Place plugs in ends of uncompleted piping at end of each day or when work stops.

END OF SECTION



**SECTION 22 13 19**  
**SANITARY WASTE PIPING SPECIALTIES**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Cleanouts.
  - 2. Roof flashing assemblies.
  - 3. Miscellaneous sanitary drainage piping specialties.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.

**1.03 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For sanitary waste piping specialties to include in emergency, operation, and maintenance manuals.

**PART 2 - PRODUCTS**

**2.01 ASSEMBLY DESCRIPTIONS**

- A. Sanitary waste piping specialties shall bear label, stamp, or other markings of specified testing agency.

**2.02 CLEANOUTS**

- A. Cast-Iron Exposed Cleanouts:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Jay R. Smith Mfg. Co.
    - b. Josam Company.
    - c. Watts; a Watts Water Technologies company.
    - d. Zurn Industries, LLC.
  - 2. Standard: ASME A112.36.2M.
  - 3. Size: Same as connected drainage piping
  - 4. Body Material: Hub-and-spigot, cast-iron soil pipe T-branch or Hubless, cast-iron soil pipe test tee as required to match connected piping.
  - 5. Closure: Countersunk or raised-head, brass or cast-iron plug.
  - 6. Closure Plug Size: Same as or not more than one size smaller than cleanout size.
- B. Cast-Iron Exposed Floor Cleanouts:



1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Jay R. Smith Mfg. Co.
    - b. Josam Company.
    - c. Watts; a Watts Water Technologies company.
    - d. Zurn Industries, LLC.
  2. Standard: ASME A112.36.2M for threaded, adjustable housing cleanout.
  3. Size: Same as connected branch.
  4. Type: Threaded, adjustable housing.
  5. Body or Ferrule: Cast iron.
  6. Clamping Device: Required.
  7. Outlet Connection: Inside caulk or Spigot.
  8. Closure: Brass plug with straight threads and gasket.
  9. Adjustable Housing Material: Cast iron with threads.
  10. Frame and Cover Material and Finish: Nickel-bronze, copper alloy.
  11. Frame and Cover Shape: Round.
  12. Top Loading Classification: Medium Duty.
  13. Riser: ASTM A 74, Service class, cast-iron drainage pipe fitting and riser to cleanout.
- C. Cast-Iron Wall Cleanouts:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Jay R. Smith Mfg. Co.
    - b. Josam Company.
    - c. MIFAB, Inc.
    - d. Tyler Pipe; a subsidiary of McWane Inc.
    - e. Watts; a Watts Water Technologies company.
    - f. Zurn Industries, LLC.
  2. Standard: ASME A112.36.2M. Include wall access.
  3. Size: Same as connected drainage piping.
  4. Body: Hub-and-spigot, cast-iron soil pipe T-branch or Hubless, cast-iron soil pipe test tee as required to match connected piping.
  5. Closure Plug:
    - a. Brass or Cast iron.
    - b. Countersunk or raised head.
    - c. Drilled and threaded for cover attachment screw.
    - d. Size: Same as or not more than one size smaller than cleanout size.

6. Wall Access: Round, flat, chrome-plated brass or stainless-steel cover plate with screw.
7. Wall Access: Round, nickel-bronze, copper-alloy, or stainless-steel wall-installation frame and cover.

### **2.03 ROOF FLASHING ASSEMBLIES**

#### **A. Roof Flashing Assemblies:**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Acorn Engineering Company.
  - b. Zurn Industries, LLC.
2. Description: Manufactured assembly made of 4.0-lb/sq. ft., 0.0625-inch- thick, lead flashing collar and skirt extending at least 6 inches from pipe, with galvanized-steel boot reinforcement and counterflashing fitting.
  - a. Low-Silhouette Vent Cap: With vandal-proof vent cap.

### **2.04 MISCELLANEOUS SANITARY DRAINAGE PIPING SPECIALTIES**

#### **A. Floor-Drain, Trap-Seal Primer Fittings:**

1. Description: Cast iron, with threaded inlet and threaded or spigot outlet, and trap-seal primer valve connection.
2. Size: Same as floor drain outlet with NPS 1/2 side inlet.

#### **B. Air-Gap Fittings:**

1. Standard: ASME A112.1.2, for fitting designed to ensure fixed, positive air gap between installed inlet and outlet piping.
2. Body: Bronze or cast iron.
3. Inlet: Opening in top of body.
4. Outlet: Larger than inlet.
5. Size: Same as connected waste piping and with inlet large enough for associated indirect waste piping.

#### **C. Sleeve Flashing Device:**

1. Description: Manufactured, cast-iron fitting, with clamping device that forms sleeve for pipe floor penetrations of floor membrane. Include galvanized-steel pipe extension in top of fitting that will extend 1 inch above finished floor and galvanized-steel pipe extension in bottom of fitting that will extend through floor slab.
2. Size: As required for close fit to riser or stack piping.

#### **D. Vent Caps:**

1. Description: Cast-iron body with threaded or hub inlet and vandal-proof design. Include vented hood and setscrews to secure to vent pipe.
2. Size: Same as connected stack vent or vent stack.

#### **E. Expansion Joints:**

1. Standard: ASME A112.6.4.

2. Body: Cast iron with bronze sleeve, packing, and gland.
3. End Connections: Matching connected piping.
4. Size: Same as connected soil, waste, or vent piping.

## **2.05 FLASHING MATERIALS**

- A. Lead Sheet: ASTM B 749, Type L51121, copper bearing, with the following minimum weights and thicknesses, unless otherwise indicated:
  1. General Use: 4.0-lb/sq. ft., 0.0625-inch thickness.
  2. Vent Pipe Flashing: 3.0-lb/sq. ft., 0.0469-inch thickness.
  3. Burning: 6-lb/sq. ft., 0.0938-inch thickness.
- B. Copper Sheet: ASTM B 152/B 152M, of the following minimum weights and thicknesses, unless otherwise indicated:
  1. General Applications: 12 oz./sq. ft..
  2. Vent Pipe Flashing: 8 oz./sq. ft..
- C. Zinc-Coated Steel Sheet: ASTM A 653/A 653M, with 0.20 percent copper content and 0.04-inch minimum thickness, unless otherwise indicated. Include G90 hot-dip galvanized, mill-phosphatized finish for painting if indicated.
- D. Elastic Membrane Sheet: ASTM D 4068, flexible, chlorinated polyethylene, 40-mil minimum thickness.
- E. Fasteners: Metal compatible with material and substrate being fastened.
- F. Metal Accessories: Sheet metal strips, clamps, anchoring devices, and similar accessory units required for installation; matching or compatible with material being installed.
- G. Solder: ASTM B 32, lead-free alloy.
- H. Bituminous Coating: SSPC-Paint 12, solvent-type, bituminous mastic.

## **PART 3 - EXECUTION**

### **3.01 INSTALLATION**

1. Comply with requirements for vibration-isolation and seismic-control devices specified in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- B. Install cleanouts in aboveground piping and building drain piping according to the following, unless otherwise indicated:
  1. Size same as drainage piping up to NPS 4. Use NPS 4 for larger drainage piping unless larger cleanout is indicated.
  2. Locate at each change in direction of piping greater than 45 degrees.
  3. Locate at minimum intervals of 50 feet for piping NPS 4 and smaller and 100 feet for larger piping.
  4. Locate at base of each vertical soil and waste stack.
- C. For floor cleanouts for piping below floors, install cleanout deck plates with top flush with finished floor.

- D. For cleanouts located in concealed piping, install cleanout wall access covers, of types indicated, with frame and cover flush with finished wall.
- E. Install roof flashing assemblies on sanitary stack vents and vent stacks that extend through roof. Comply with requirements in Section 076200 "Sheet Metal Flashing and Trim."
- F. Install flashing fittings on sanitary stack vents and vent stacks that extend through roof. Comply with requirements in Section 076200 "Sheet Metal Flashing and Trim."
- G. Install deep-seal traps on floor drains and other waste outlets, if indicated.
- H. Install floor-drain, trap-seal primer fittings on inlet to floor drains that require trap-seal primer connection.
  - 1. Exception: Fitting may be omitted if trap has trap-seal primer connection.
  - 2. Size: Same as floor drain inlet.
- I. Install air-gap fittings on draining-type backflow preventers and on indirect-waste piping discharge into sanitary drainage system.
- J. Install sleeve and sleeve seals with each riser and stack passing through floors with waterproof membrane.
- K. Install vent caps on each vent pipe passing through roof.
- L. Install expansion joints on vertical stacks and conductors. Position expansion joints for easy access and maintenance.
- M. Install wood-blocking reinforcement for wall-mounting-type specialties.
- N. Install traps on plumbing specialty drain outlets. Omit traps on indirect wastes unless trap is indicated.

### **3.02 CONNECTIONS**

- A. Comply with requirements in Section 221316 "Sanitary Waste and Vent Piping" for piping installation requirements. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Install piping adjacent to equipment to allow service and maintenance.
- C. Ground equipment according to Section 260530 "Conduit and Wire."
- D. Connect wiring according to Section 260530 "Conduit and Wire."

### **3.03 FLASHING INSTALLATION**

- A. Comply with requirements in Section 076200 "Sheet Metal Flashing and Trim."
- B. Fabricate flashing from single piece unless large pans, sumps, or other drainage shapes are required.
- C. Install sheet flashing on pipes, sleeves, and specialties passing through or embedded in floors and roofs with waterproof membrane.
  - 1. Pipe Flashing: Sleeve type, matching pipe size, with minimum length of 10 inches, and skirt or flange extending at least 8 inches around pipe.
  - 2. Sleeve Flashing: Flat sheet, with skirt or flange extending at least 8 inches around sleeve.
  - 3. Embedded Specialty Flashing: Flat sheet, with skirt or flange extending at least 8 inches around specialty.

- D. Set flashing on floors and roofs in solid coating of bituminous cement.
- E. Secure flashing into sleeve and specialty clamping ring or device.
- F. Install flashing for piping passing through roofs with counterflashing or commercially made flashing fittings, according to Section 076200 "Sheet Metal Flashing and Trim."
- G. Extend flashing up vent pipe passing through roofs and turn down into pipe, or secure flashing into cast-iron sleeve having calking recess.

#### **3.04 PROTECTION**

- A. Protect drains during remainder of construction period to avoid clogging with dirt or debris and to prevent damage from traffic or construction work.
- B. Place plugs in ends of uncompleted piping at end of each day or when work stops.

END OF SECTION

**SECTION 22 34 00**  
**FUEL-FIRED, DOMESTIC-WATER HEATERS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Commercial, gas-fired, high-efficiency, storage, domestic-water heaters.
  - 2. Domestic-water heater accessories.

**1.02 SUBMITTALS**

- A. Product Data: For each type and size of domestic-water heater indicated. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.
- B. Sustainable Design Submittals:
  - 1. Product Data: For energy efficiency.
- C. Shop Drawings:
  - 1. Wiring Diagrams: For power, signal, and control wiring.

**1.03 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For fuel-fired, domestic-water heaters to include in emergency, operation, and maintenance manuals.

**1.04 QUALITY ASSURANCE**

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. ASHRAE/IESNA Compliance: Fabricate and label fuel-fired, domestic-water heaters to comply with ASHRAE/IESNA 90.1.
  - 1. Comply with efficiency requirements in ASHRAE 189.1, which supersede requirements in ASHRAE/IESNA 90.1.
- C. ASME Compliance:
  - 1. Where ASME-code construction is indicated, fabricate and label commercial, domestic-water heater storage tanks to comply with ASME Boiler and Pressure Vessel Code: Section VIII, Division 1.
- D. NSF Compliance: Fabricate and label equipment components that will be in contact with potable water to comply with NSF 61 Annex G, "Drinking Water System Components - Health Effects."
- E. Water Heater shall comply with the Low-NOx requirements of SCAQMD rule 1146.2, for less than 14 ng/j, or 20 ppm.

**1.05 COORDINATION**

- A. Coordinate sizes and locations of concrete bases with actual equipment provided.

## 1.06 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of fuel-fired, domestic-water heaters that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Structural failures including storage tank and supports.
    - b. Faulty operation of controls.
    - c. Deterioration of metals, metal finishes, and other materials beyond normal use.
  - 2. Warranty Periods: From date of Substantial Completion.
    - a. Commercial, Gas-Fired, Storage, Domestic-Water Heaters:
      - 1) Storage Tank: Three years.
      - 2) Controls and Other Components: One year(s).

## PART 2 - PRODUCTS

### 2.01 MATERIALS

- A. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).

### 2.02 COMMERCIAL, POWER-BURNER, GAS-FIRED, STORAGE, DOMESTIC-WATER HEATERS

- A. Commercial, Power Burner, Gas-Fired, High-Efficiency, Storage, Domestic-Water Heaters:
  - 1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
    - a. Bradford White Corporation.
    - b. PVI Industries, LLC.
    - c. Smith, A. O. Corporation.
  - 2. Standard: ANSI Z21.10.3/CSA 4.3.
  - 3. Description: Manufacturer's proprietary design to provide at least 80 percent thermal efficiency at optimum operating conditions.
  - 4. Storage-Tank Construction: ASME-code steel with 150-psig minimum working-pressure rating.
    - a. Tappings: Factory fabricated of materials compatible with tank. Attach tappings to tank before testing.
      - 1) NPS 2 and Smaller: Threaded ends according to ASME B1.20.1.
      - 2) NPS 2-1/2 and Larger: Flanged ends according to ASME B16.5 for steel and stainless-steel flanges and according to ASME B16.24 for copper and copper-alloy flanges.
    - b. Lining: Glass complying with NSF 61 Annex G barrier materials for potable-water tank linings, including extending lining into and through tank fittings and outlets.
  - 5. Factory-Installed Storage-Tank Appurtenances:

- a. Anode Rod: Replaceable magnesium.
  - b. Dip Tube: Required unless cold-water inlet is near bottom of tank.
  - c. Drain Valve: Corrosion-resistant metal complying with ASSE 1005.
  - d. Insulation: Comply with ASHRAE/IESNA 90.1. Surround entire storage tank except connections and controls.
  - e. Jacket: Steel with enameled finish.
  - f. Burner: UL 795 for power-burner, gas-fired, domestic-water heaters and natural-gas fuel.
  - g. Automatic Ignition: ANSI Z21.20/CSA C22.2 No. 199, electric, automatic, gas-ignition system.
  - h. Temperature Control: Adjustable thermostat.
  - i. Safety Controls: Automatic, high-temperature-limit and low-water cutoff devices or systems.
  - j. Combination Temperature-and-Pressure Relief Valves: ANSI Z21.22/CSA 4.4-M. Include one or more relief valves with total relieving capacity at least as great as heat input, and include pressure setting less than domestic-water heater working-pressure rating. Select one relief valve with sensing element that extends into storage tank.
6. Draft Hood: Draft diverter, complying with ANSI Z21.12.
- B. Capacity and Characteristics: Refer to schedules on Drawings.

### **2.03 DOMESTIC-WATER HEATER ACCESSORIES**

- A. Domestic-Water Compression Tanks:
- 1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
    - a. Honeywell Water Controls.
    - b. Pentair Pump Group.
  - 2. Description: Steel, pressure-rated tank constructed with welded joints and factory-installed butyl-rubber bladder. Include air precharge to minimum system-operating pressure at tank.
  - 3. Construction:
    - a. Tappings: Factory-fabricated steel, welded to tank before testing and labeling. Include ASME B1.20.1 pipe thread.
    - b. Interior Finish: Comply with NSF 61 Annex G barrier materials for potable-water tank linings, including extending finish into and through tank fittings and outlets.
    - c. Air-Charging Valve: Factory installed.
  - 4. Capacity and Characteristics:
    - a. Working-Pressure Rating: 150 psig.
    - b. Capacity Acceptable: Refer to schedule on Drawings.
    - c. Air Precharge Pressure.



- B. Drain Pans: Corrosion-resistant metal with raised edge. Comply with ANSI/CSA LC 3. Include dimensions not less than base of domestic-water heater, and include drain outlet not less than NPS 3/4 with ASME B1.20.1 pipe threads or with ASME B1.20.7 garden-hose threads.
- C. Piping-Type Heat Traps: Field-fabricated piping arrangement according to ASHRAE/IESNA 90.1 or ASHRAE 90.2.
- D. Heat-Trap Fittings: ASHRAE 90.2.
- E. Comply with requirements for ball- or butterfly-, shutoff valves specified in Section 22 05 23 "General-Duty Valves for Plumbing Piping."
  - 1. Comply with requirements for balancing valves specified in Section 22 11 19 "Domestic Water Piping Specialties."
- F. Gas Shutoff Valves: ANSI Z21.15/CSA 9.1-M, manually operated. Furnish for installation in piping.
- G. Combination Temperature-and-Pressure Relief Valves: Include relieving capacity at least as great as heat input, and include pressure setting less than domestic-water heater working-pressure rating. Select relief valves with sensing element that extends into storage tank.
  - 1. Gas-Fired, Domestic-Water Heaters: ANSI Z21.22/CSA 4.4-M.

#### **2.04 SOURCE QUALITY CONTROL**

- A. Factory Tests: Test and inspect assembled domestic-water heaters and storage tanks specified to be ASME-code construction, according to ASME Boiler and Pressure Vessel Code.
- B. Hydrostatically test commercial domestic-water heaters and storage tanks to minimum of one and one-half times pressure rating before shipment.
- C. Domestic-water heaters will be considered defective if they do not pass tests and inspections. Comply with requirements in Section 01 45 00 "Quality Control" for retesting, reinspecting, and correcting the Work.
- D. Prepare test and inspection reports.

### **PART 3 - EXECUTION**

#### **3.01 DOMESTIC-WATER HEATER INSTALLATION**

- A. Commercial, Domestic-Water Heater Mounting: Install commercial domestic-water heaters on concrete base. Comply with requirements for concrete base specified in Section 03 30 00 "Cast-in-Place Concrete."
  - 1. Exception: Omit concrete bases for commercial domestic-water heaters if installation on stand, bracket, suspended platform, or directly on floor is indicated.
  - 2. Maintain manufacturer's recommended clearances.
  - 3. Arrange units so controls and devices that require servicing are accessible.
- B. Install domestic-water heaters level and plumb, according to layout drawings, original design, and referenced standards. Maintain manufacturer's recommended clearances. Arrange units so controls and devices needing service are accessible.
  - 1. Install shutoff valves on domestic-water-supply piping to domestic-water heaters and on domestic-hot-water outlet piping. Comply with requirements for shutoff valves specified in Section 22 05 23 "General-Duty Valves for Plumbing Piping."

- C. Install gas-fired, domestic-water heaters according to NFPA 54.
  - 1. Install gas shutoff valves on gas supply piping to gas-fired, domestic-water heaters without shutoff valves.
  - 2. Install gas pressure regulators on gas supplies to gas-fired, domestic-water heaters without gas pressure regulators if gas pressure regulators are required to reduce gas pressure at burner.
  - 3. Comply with requirements for gas shutoff valves, gas pressure regulators, and automatic gas valves specified in Section 23 11 23 "Facility Natural-Gas Piping."
- D. Install commercial domestic-water heaters with seismic-restraint devices. Comply with requirements for seismic-restraint devices specified in Section 22 05 48 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- E. Install double-wall vent. Refer to Section 23 51 23, "Gas Vents."
- F. Install combination temperature-and-pressure relief valves in top portion of storage tanks. Use relief valves with sensing elements that extend into tanks. Extend commercial-water-heater relief-valve outlet, with drain piping same as domestic-water piping in continuous downward pitch, and discharge by positive air gap onto closest floor sink.
- G. Install water-heater drain piping as indirect waste to spill by positive air gap into open drains or over floor sinks. Install hose-end drain valves at low points in water piping for domestic-water heaters that do not have tank drains. Comply with requirements for hose-end drain valves specified in Section 22 11 19 "Domestic Water Piping Specialties."
- H. Install thermometer on outlet piping of domestic-water heaters. Comply with requirements for thermometers specified in Section 22 05 19 "Meters and Gages for Plumbing Piping."
- I. Install piping-type heat traps on inlet and outlet piping of domestic-water heater storage tanks without integral or fitting-type heat traps.
- J. Fill domestic-water heaters with water.
- K. Charge domestic-water compression tanks with air.

### **3.02 CONNECTIONS**

- A. Comply with requirements for domestic-water piping specified in Section 22 11 16 "Domestic Water Piping."
- B. Comply with requirements for gas piping specified in Section 23 11 23 "Facility Natural-Gas Piping."
- C. Drawings indicate general arrangement of piping, fittings, and specialties.
- D. Where installing piping adjacent to fuel-fired, domestic-water heaters, allow space for service and maintenance of water heaters. Arrange piping for easy removal of domestic-water heaters.

### **3.03 IDENTIFICATION**

- A. Identify system components. Comply with requirements for identification specified in Section 22 05 53 "Identification for Plumbing Piping and Equipment."

### **3.04 FIELD QUALITY CONTROL**

- A. Perform tests and inspections.

1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect components, assemblies, and equipment installations, including connections, and to assist in testing.
  2. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
  3. Operational Test: After electrical circuitry has been energized, start units to confirm proper operation.
  4. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- B. Domestic-water heaters will be considered defective if they do not pass tests and inspections. Comply with requirements in Division 01 Specifications for retesting and reinspecting requirements and Division 01 Specifications for requirements for correcting the Work.
- C. Prepare test and inspection reports.

### **3.05 DEMONSTRATION**

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain commercial, gas-fired, storage, domestic-water heaters.

END OF SECTION

**SECTION 22 42 13.13**  
**COMMERCIAL WATER CLOSETS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Water closets.
  - 2. Flushometer valves.
  - 3. Toilet seats.
  - 4. Supports.

**1.02 DEFINITIONS**

- A. Effective Flush Volume: Average of two reduced flushes and one full flush per fixture.
- B. Remote Water Closet: Located more than 30 feet from other drain line connections or fixture and where less than 1.5 drainage fixture units are upstream of the drain line connection.
- C. Related Requirements:

**1.03 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for water closets.
  - 2. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.
- B. Shop Drawings: Include diagrams for power, signal, and control wiring.

**1.04 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For flushometer valves to include in operation and maintenance manuals.

**1.05 MAINTENANCE MATERIAL SUBMITTALS**

- A. Furnish extra materials that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Flushometer-Valve Repair Kits: No fewer than one of each type.

**PART 2 - PRODUCTS**

**2.01 WALL-MOUNTED WATER CLOSETS**

- A. Water Closets: Wall mounted, top spud, standard and accessible.
  - 1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
    - a. American Standard America.

2. Bowl:
  - a. Standards: ASME A112.19.2/CSA B45.1 and ASME A112.19.5.
  - b. Material: Vitreous china.
  - c. Type: Siphon jet.
  - d. Style: Flushometer valve.
  - e. Height: Standard.
  - f. Rim Contour: Elongated.
  - g. Water Consumption: 1.28 gal. per flush.
  - h. Spud Size and Location: NPS 1-1/2; top.
3. Flushometer Valve: Refer to article, Flushometer Valves.
4. Toilet Seat: Refer to article, Toilet Seats.
5. Support: Water closet carrier.
6. Water-Closet Mounting Height: Refer to schedule on Drawings.

## **2.02 FLUSHOMETER VALVES**

- A. Lever-Handle, Diaphragm Flushometer Valves:
  1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
    - a. Zurn Industries, LLC.
  2. Standard: ASSE 1037.
  3. Minimum Pressure Rating: 125 psig.
  4. Features: Include integral check stop and backflow-prevention device.
  5. Material: Brass body with corrosion-resistant components.
  6. Exposed Flushometer-Valve Finish: Chrome plated.
  7. Panel Finish: Chrome plated or stainless steel.
  8. Style: Exposed.
  9. Minimum Inlet: NPS 1.
  10. Minimum Outlet: NPS 1-1/4.

## **2.03 TOILET SEATS**

- A. Toilet Seats:
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. American Standard America.
    - b. Bemis Manufacturing Company.
    - c. Kohler Co.
    - d. Olsonite Seat Co.
  2. Standard: IAPMO/ANSI Z124.5.

3. Material: Plastic.
4. Type: Commercial (Heavy duty).
5. Shape: .
6. Hinge: Self-sustaining.
7. Hinge Material: Noncorroding metal.
8. Seat Cover: Not required.
9. Color: White.

## **2.04 SUPPORTS**

### **A. Water Closet Carrier:**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Zurn Industries, LLC.
2. Standard: ASME A112.6.1M.
3. Description: Waste-fitting assembly, as required to match drainage piping material and arrangement with faceplates, couplings gaskets, and feet; bolts and hardware matching fixture.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine roughing-in of water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before water-closet installation.
- B. Examine walls and floors for suitable conditions where water closets will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 INSTALLATION**

#### **A. Water-Closet Installation:**

1. Install level and plumb according to roughing-in drawings.
2. Install accessible, wall-mounted water closets at adult mounting height, according to CBC 11B.

#### **B. Support Installation:**

1. Install supports, affixed to building substrate, for floor-mounted, back-outlet water closets.
2. Use carrier supports with waste-fitting assembly and seal.
3. Install wall-mounted, back-outlet water-closet supports with waste-fitting assembly and waste-fitting seals; and affix to building substrate.

#### **C. Flushometer-Valve Installation:**

1. Install flushometer-valve, water-supply fitting on each supply to each water closet.
2. Attach supply piping to supports or substrate within pipe spaces behind fixtures.

3. Install lever-handle flushometer valves for accessible water closets with handle mounted on open side of water closet.
  4. Install actuators in locations that are easy for people with disabilities to reach.
- D. Install toilet seats on water closets.
- E. Wall Flange and Escutcheon Installation:
1. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations and within cabinets and millwork.
  2. Install deep-pattern escutcheons if required to conceal protruding fittings.
  3. Comply with escutcheon requirements specified in Section 220518 "Escutcheons for Plumbing Piping."
- F. Joint Sealing:
1. Seal joints between water closets and walls using sanitary-type, one-part, mildew-resistant silicone sealant.
  2. Match sealant color to water-closet color.
  3. Comply with sealant requirements specified in Section 079200 "Joint Sealants."

### **3.03 CONNECTIONS**

- A. Connect water closets with water supplies and soil, waste, and vent piping. Use size fittings required to match water closets.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Comply with soil and waste piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."
- D. Where installing piping adjacent to water closets, allow space for service and maintenance.

### **3.04 ADJUSTING**

- A. Operate and adjust water closets and controls. Replace damaged and malfunctioning water closets, fittings, and controls.
- B. Adjust water pressure at flushometer valves to produce proper flow.

### **3.05 CLEANING AND PROTECTION**

- A. Clean water closets and fittings with manufacturers' recommended cleaning methods and materials.
- B. Install protective covering for installed water closets and fittings.
- C. Do not allow use of water closets for temporary facilities unless approved in writing by Owner.

END OF SECTION

**SECTION 22 42 13.16**  
**COMMERCIAL URINALS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Urinals.
  - 2. Flushometer valves.
  - 3. Supports.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for urinals.
  - 2. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.
- B. Shop Drawings: Include diagrams for power, signal, and control wiring.

**1.03 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For flushometer valves and electronic sensors to include in operation and maintenance manuals.

**1.04 MAINTENANCE MATERIAL SUBMITTALS**

- A. Furnish extra materials that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Flushometer-Valve Repair Kits: No fewer than one of each type.

**PART 2 - PRODUCTS**

**2.01 WALL-HUNG URINALS**

- A. Urinals: Wall hung, back outlet, washout, accessible.
  - 1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
    - a. American Standard America.
    - b. Zurn Industries, LLC.
  - 2. Fixture:
    - a. Standards: ASME A112.19.2/CSA B45.1 and ASME A112.19.5.
    - b. Material: Vitreous china.
    - c. Type: Washout with extended shields.
    - d. Strainer or Trapway: Manufacturer's standard strainer with integral trap.



- e. Water Consumption: Low.
  - f. Spud Size and Location: NPS 3/4, top.
  - g. Outlet Size and Location: NPS 2, back.
  - h. Color: White.
3. Flushometer Valve: Refer to article, Flushometer Valves.
  4. Waste Fitting:
    - a. Standard: ASME A112.18.2/CSA B125.2 for coupling.
    - b. Size: NPS 2.
  5. Support: Type I Urinal Carrier with fixture support plates and coupling with seal and fixture bolts and hardware matching fixture.
  6. Urinal Mounting Height: Refer to Drawings.

## **2.02 URINAL FLUSHOMETER VALVES**

- A. Lever-Handle, Diaphragm Flushometer Valves:
  1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
    - a. Zurn Industries, LLC.
  2. Standard: ASSE 1037.
  3. Minimum Pressure Rating: 125 psig.
  4. Features: Include integral check stop and backflow-prevention device.
  5. Material: Brass body with corrosion-resistant components.
  6. Exposed Flushometer-Valve Finish: Chrome plated.
  7. Panel Finish: Chrome plated or stainless steel.
  8. Style: Exposed.
  9. Consumption: 0.125 gal. per flush.
  10. Minimum Inlet: NPS 3/4.
  11. Minimum Outlet: NPS 3/4.

## **2.03 SUPPORTS**

- A. Type I Urinal Carrier:
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Jay R. Smith Mfg. Co.
    - b. Zurn Industries, LLC.
  2. Standard: ASME A112.6.1M.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine roughing-in of water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before urinal installation.
- B. Examine walls and floors for suitable conditions where urinals will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 INSTALLATION**

- A. Urinal Installation:
  - 1. Install urinals level and plumb according to roughing-in drawings.
  - 2. Install wall-hung, back-outlet urinals onto waste fitting seals and attached to supports.
  - 3. Install accessible, wall-mounted urinals at adult mounting height, according to CBC 11B.
- B. Support Installation:
  - 1. Install supports, affixed to building substrate, for wall-hung urinals.
  - 2. Use off-floor carriers with waste fitting and seal for back-outlet urinals.
  - 3. Use chair-type carrier supports with rectangular steel uprights for accessible urinals.
- C. Flushometer-Valve Installation:
  - 1. Install flushometer-valve water-supply fitting on each supply to each urinal.
  - 2. Attach supply piping to supports or substrate within pipe spaces behind fixtures.
  - 3. Install lever-handle flushometer valves for accessible urinals with handle mounted on open side of compartment.
- D. Wall Flange and Escutcheon Installation:
  - 1. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations.
  - 2. Install deep-pattern escutcheons if required to conceal protruding fittings.
  - 3. Comply with escutcheon requirements specified in Section 220518 "Escutcheons for Plumbing Piping."
- E. Joint Sealing:
  - 1. Seal joints between urinals and walls and floors using sanitary-type, one-part, mildew-resistant silicone sealant.
  - 2. Match sealant color to urinal color.
  - 3. Comply with sealant requirements specified in Section 079200 "Joint Sealants."

### **3.03 CONNECTIONS**

- A. Connect urinals with water supplies and soil, waste, and vent piping. Use size fittings required to match urinals.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Comply with soil and waste piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."

- D. Where installing piping adjacent to urinals, allow space for service and maintenance.

**3.04 ADJUSTING**

- A. Operate and adjust urinals and controls. Replace damaged and malfunctioning urinals, fittings, and controls.
- B. Adjust water pressure at flushometer valves to produce proper flow.

**3.05 CLEANING AND PROTECTION**

- A. Clean urinals and fittings with manufacturers' recommended cleaning methods and materials.
- B. Install protective covering for installed urinals and fittings.
- C. Do not allow use of urinals for temporary facilities unless approved in writing by Owner.

END OF SECTION

**SECTION 22 42 16.13**  
**COMMERCIAL LAVATORIES**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Lavatories.
  - 2. Faucets.
  - 3. Supports.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for lavatories.
  - 2. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.
- B. Shop Drawings: Include diagrams for power, signal, and control wiring of automatic faucets.
- C. Pipe, pipe or plumbing fittings, fixtures, solder and flux installed in a system providing water for human consumption shall comply with lead free requirements of California Health and Safety Code Section 116875. Provide submittal information for products third-party certified by an approved laboratory as complying with California Health and Safety Code Section 116875.

**1.03 INFORMATIONAL SUBMITTALS**

- A. Coordination Drawings: Counter cutout templates for mounting of counter-mounted lavatories.

**1.04 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For lavatories and faucets to include in operation and maintenance manuals.

**1.05 MAINTENANCE MATERIAL SUBMITTALS**

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Faucet Washers and O-Rings: Equal to 10 percent of amount of each type and size installed.
  - 2. Faucet Cartridges and O-Rings: Equal to 5 percent of amount of each type and size installed.

**1.06 QUALITY ASSURANCE**

- A. California Health and Safety Code Compliance: For products covered under the scope of HSC 116875 for potable water service. Products for potable water service shall be third-party

certified by an approved laboratory as complying with California Health and Safety Code Section 116875.

## **PART 2 - PRODUCTS**

### **2.01 VITREOUS-CHINA, WALL-MOUNTED LAVATORIES**

- A. Lavatory: Vitreous china, wall mounted, with back.
  - 1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
    - a. American Standard America.
  - 2. Fixture:
    - a. Standard: ASME A112.19.2/CSA B45.1.
    - b. Type: For wall hanging.
    - c. Faucet-Hole Punching: Three holes, 4-inch centers.
    - d. Faucet-Hole Location: Top.
    - e. Color: White.
    - f. Mounting Material: Chair carrier.
  - 3. Faucet: Refer to article, "Solid-Brass, Manually Operated Faucets".
  - 4. Support: Type II, concealed-arm lavatory carrier. Include rectangular, steel uprights.
  - 5. Lavatory Mounting Height: Refer to Drawings.

### **2.02 SOLID-BRASS, MANUALLY OPERATED FAUCETS**

- A. NSF Standard: Comply with NSF/ANSI 61 Annex G, "Drinking Water System Components - Health Effects," for faucet materials that will be in contact with potable water.
- B. Lavatory Faucets: Manual-type, single-control mixing two-handle mixing, commercial, solid-brass valve.
  - 1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
    - a. American Standard America.
  - 2. Standard: ASME A112.18.1/CSA B125.1.
  - 3. General: Include hot- and cold-water indicators; coordinate faucet inlets with supplies and fixture hole punchings; coordinate outlet with spout and fixture receptor.
  - 4. Body Type: Centerset.
  - 5. Body Material: Commercial, solid brass.
  - 6. Finish: Polished chrome plate.
  - 7. Maximum Flow Rate: 0.5 gpm.
  - 8. Maximum Flow: 0.25 gal. per metering cycle.
  - 9. Mounting Type: Deck, exposed.
  - 10. Valve Handle(s): Push button.
  - 11. Spout: Rigid type.

12. Spout Outlet: Aerator.
13. Operation: Compression, manual.
14. Drain: Not part of faucet.

### **2.03 SUPPORTS**

- A. Type II Lavatory Carrier:
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Josam Company.
    - b. MIFAB, Inc.
    - c. Wade Drains.
    - d. Watts; a Watts Water Technologies company.
    - e. Zurn Industries, LLC.
  2. Standard: ASME A112.6.1M.

### **2.04 SUPPLY FITTINGS**

- A. NSF Standard: Comply with NSF/ANSI 61 Annex G, "Drinking Water System Components - Health Effects," for supply-fitting materials that will be in contact with potable water.
- B. Standard: ASME A112.18.1/CSA B125.1.
- C. Supply Piping: Chrome-plated-brass pipe or chrome-plated copper tube matching water-supply piping size. Include chrome-plated-brass or stainless-steel wall flange.
- D. Supply Stops: Chrome-plated-brass, one-quarter-turn, ball-type or compression valve with female threaded inlet connection matching supply piping.
- E. Operation: Loose key.
- F. Risers:
  1. NPS 1/2.
  2. ASME A112.18.6, braided- or corrugated-stainless-steel, flexible hose riser, integral to faucet.

### **2.05 WASTE FITTINGS**

- A. Standard: ASME A112.18.2/CSA B125.2.
- B. Drain: Grid type with NPS 1-1/4 offset and straight tailpiece.
- C. Trap:
  1. Size: NPS 1-1/2 by NPS 1-1/4.
  2. Material: Chrome-plated, two-piece, cast-brass trap and swivel elbow with 0.032-inch-thick brass tube to wall; and chrome-plated, brass or steel wall flange.
  3. Material: Stainless-steel, two-piece trap and swivel elbow with 0.012-inch-thick stainless-steel tube to wall; and stainless-steel wall flange.

## **2.06 SUPPORTS**

- A. Type II Lavatory Carrier:
  - 1. Standard: ASME A112.6.1M.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine roughing-in of water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before lavatory installation.
- B. Examine walls for suitable conditions where lavatories will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 INSTALLATION**

- A. Install lavatories level and plumb according to roughing-in drawings.
- B. Install supports, affixed to building substrate, for wall-mounted lavatories.
- C. Install accessible wall-mounted lavatories at adult mounting height, according to CBC 11B.
- D. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons if required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 220518 "Escutcheons for Plumbing Piping."
- E. Seal joints between lavatories, counters, and walls using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."
- F. Install protective shielding pipe covers and enclosures on exposed supplies and waste piping of accessible lavatories. Comply with requirements in Section 220719 "Plumbing Piping Insulation."

### **3.03 CONNECTIONS**

- A. Connect fixtures with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Comply with soil and waste piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."

### **3.04 ADJUSTING**

- A. Operate and adjust lavatories and controls. Replace damaged and malfunctioning lavatories, fittings, and controls.
- B. Adjust water pressure at faucets to produce proper flow.

### **3.05 CLEANING AND PROTECTION**

- A. After completing installation of lavatories, inspect and repair damaged finishes.
- B. Clean lavatories, faucets, and other fittings with manufacturers' recommended cleaning methods and materials.
- C. Provide protective covering for installed lavatories and fittings.

D. Do not allow use of lavatories for temporary facilities unless approved in writing by Owner.

END OF SECTION





**SECTION 22 42 16.16**  
**COMMERCIAL SINKS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Service basins.
  - 2. Stainless Steel Sinks.
  - 3. Sink faucets.
  - 4. Supply fittings.
  - 5. Waste fittings.

**1.02 SUBMITTALS**

- A. Product Data: For each type of product.
- B. Pipe, pipe or plumbing fittings, fixtures, solder and flux installed in a system providing water for human consumption shall comply with lead free requirements of California Health and Safety Code Section 116875. Provide submittal information for products third-party certified by an approved laboratory as complying with California Health and Safety Code Section 116875.
- C. Maintenance data.

**1.03 QUALITY ASSURANCE**

- A. California Health and Safety Code Compliance: For products covered under the scope of HSC 116875 for potable water service. Products for potable water service shall be third-party certified by an approved laboratory as complying with California Health and Safety Code Section 116875.

**PART 2 - PRODUCTS**

**2.01 SERVICE BASINS**

- A. Service Basins: Terrazzo, floor mounted.
  - 1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
    - a. Fiat Products.
    - b. Florestone Products Co., Inc.
  - 2. Fixture:
    - a. Standard: IAPMO PS 99.
    - b. Shape: Radial front.
    - c. Height: 12 inches with dropped front.
    - d. Tiling Flange: On two sides.

- e. Rim Guard: On front top surfaces.
- f. Drain: Grid with NPS 3 outlet.
- 3. Mounting: On floor and flush to wall.
- 4. Faucet: F-1. Refer to article, Sink Faucets.

## 2.02 STAINLESS STEEL SINKS

- A. Kitchen Sinks: One bowl, counter mounted, stainless steel.
  - 1. Stainless-Steel Sinks:
    - a. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
      - 1) Elkay Manufacturing Co.
      - 2) Just Manufacturing.
  - 2. Fixture:
    - a. Standard: ASME A112.19.3/CSA B45.4 for stainless-steel sinks.
    - b. Metal Thickness: [0.038 inch] [0.050 inch] <Insert dimension>.
    - c. Bowl:
      - 1) Dimensions: Refer to schedules on Drawings.
    - d. Faucet: F-2. Refer to article, Sink Faucets.
  - 3. Supply Fittings: Comply with requirements in "Supply Fittings" Article.
  - 4. Waste Fittings: Comply with requirements in "Waste Fittings" Article, except include continuous waste for multibowl sinks.

## 2.03 SINK FAUCETS

- A. NSF Standard: Comply with NSF/ANSI 61 Annex G, "Drinking Water System Components - Health Effects," for faucet-spout materials that will be in contact with potable water.
- B. Sink Faucets : Manual type, two-lever-handle mixing valve.
  - 1. Commercial, Solid-Brass Faucets (Service Basins) F-1:
    - a. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
      - 1) Speakman Company.
      - 2) T & S Brass and Bronze Works, Inc.
    - b. Standard: ASME A112.18.1/CSA B125.1.
    - c. General: Include hot- and cold-water indicators; coordinate faucet inlets with supplies and fixture hole punchings; coordinate outlet with spout and sink receptor.
    - d. Body Type: Widespread.
    - e. Body Material: Commercial, solid brass.
    - f. Finish: Chrome plated.
    - g. Maximum Flow Rate: 2.2 gpm.
    - h. Handle(s): Lever.

- i. Mounting Type: Back/wall, exposed.
  - j. Spout Type: Rigid, solid brass with wall brace and pail hook.
  - k. Vacuum Breaker: Required for hose outlet.
  - l. Spout Outlet: Aerator.
2. Commercial, Solid-Brass Faucets (Stainless Steel Sinks) F-2.
    - a. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
      - 1) American Standard America.
3. Standard: ASME A112.18.1/CSA B125.1.
  4. General: Include hot- and cold-water indicators; coordinate faucet inlets with supplies and fixture holes; coordinate outlet with spout and fixture receptor.
  5. Finish: Polished chrome plate.
  6. Mixing Valve: Two-lever handle.
  7. Centers: 8 inches.
  8. Mounting: Deck, exposed.
  9. Handle(s): Wrist blade, 4 inches.
  10. Spout Type: Rigid/swing gooseneck.
  11. Spout Outlet: Aerator.
  12. Drain: Not a part of faucet.

#### **2.04 SUPPLY FITTINGS**

- A. NSF Standard: Comply with NSF/ANSI 61 Annex G, "Drinking Water System Components - Health Effects," for supply-fitting materials that will be in contact with potable water.
- B. Standard: ASME A112.18.1/CSA B125.1.
- C. Supply Piping: Chrome-plated brass pipe or chrome-plated copper tube matching water-supply piping size. Include chrome-plated brass or stainless-steel wall flange.
- D. Supply Stops: Chrome-plated brass, one-quarter-turn, ball-type or compression valve with female threaded inlet connection matching supply piping.
- E. Operation: Loose key.
- F. Risers:
  1. NPS 1/2
  2. Chrome-plated, rigid-copper pipe.

#### **2.05 WASTE FITTINGS**

- A. Standard: ASME A112.18.2/CSA B125.2.
- B. Drain: Grid type with NPS 1-1/2 offset and straight tailpiece.
- C. Trap:
  1. Size: NPS 1-1/2.

2. Material: Chrome-plated, two-piece, cast-brass trap and ground-joint swivel elbow with 0.032-inch-thick brass tube to wall; and chrome-plated brass or steel wall flange.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine roughing-in of water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before sink installation.
- B. Examine walls, floors, and counters for suitable conditions where sinks will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 INSTALLATION**

- A. Install sinks level and plumb according to roughing-in drawings.
- B. Install supports, affixed to building substrate, for wall-hung sinks.
- C. Install accessible wall-mounted sinks at adult mounting height according to CBC 11B.
- D. Set floor-mounted sinks in leveling bed of cement grout.
- E. Install water-supply piping with stop on each supply to each sink faucet.
  1. Exception: Use ball or gate valves if supply stops are not specified with sink. Comply with valve requirements specified in Section 220523 "General-Duty for Plumbing Piping."
  2. Install stops in locations where they can be easily reached for operation.
- F. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons if required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 220518 "Escutcheons for Plumbing Piping."
- G. Seal joints between sinks and counters, floors, and walls using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."
- H. Install protective shielding pipe covers and enclosures on exposed supplies and waste piping of accessible sinks. Comply with requirements in Section 220719 "Plumbing Piping Insulation."

### **3.03 CONNECTIONS**

- A. Connect sinks with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Comply with soil and waste piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."

### **3.04 ADJUSTING**

- A. Operate and adjust sinks and controls. Replace damaged and malfunctioning sinks, fittings, and controls.
- B. Adjust water pressure at faucets to produce proper flow.

### **3.05 CLEANING AND PROTECTION**

- A. After completing installation of sinks, inspect and repair damaged finishes.

- B. Clean sinks, faucets, and other fittings with manufacturers' recommended cleaning methods and materials.
- C. Provide protective covering for installed sinks and fittings.
- D. Do not allow use of sinks for temporary facilities unless approved in writing by Owner.

END OF SECTION



**SECTION 23 00 50**  
**COMMON WORK RESULTS FOR HVAC SYSTEMS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

A. Section Includes:

1. General requirements applicable to all Division 23 Sections.

**1.02 RELATED REQUIREMENTS**

A. This Section is a part of each Division 23 Section.

**1.03 ADDITIONAL REQUIREMENTS**

- A. Furnish and install incidental work not shown or specified necessary to provide a complete and workable system.
- B. Make all temporary connections required to maintain services, including adequate heat and cooling, during the course of the Contract without additional cost to Owner. Notify Owner seven days in advance before disrupting services.
- C. Provide for adjustments or modifications to fan and motor sheaves, belts, damper linkages, and other components as required to achieve specified air balance at no additional cost to Owner.

**1.04 REFERENCES AND STANDARDS**

- A. Where material or equipment is specified to conform to referenced standards, it shall be assumed that the most recent edition of the standard in effect at the time of bid shall be used.
  1. AABC - Associated Air Balance Council
  2. AFBMA - Anti Friction Bearing Manufacturer's Association
  3. AMCA - Air Moving and Control Association Inc.
    - a. Standard 210 - Laboratory Methods of Testing Fans
  4. ANSI - American National Standards Institute
  5. ARI - Air-Conditioning and Refrigeration Institute
  6. ASHRAE - American Society of Heating, Refrigerating and Air Conditioning Engineers
  7. ASME - American Society of Mechanical Engineers
  8. ASTM - American Society for Testing and Materials
  9. CCR - California Code of Regulations
    - a. Title 8 - Division of Industrial Safety, Subchapter 7; General Industry Safety Orders, Articles 31 through 36
  10. CSA – Canadian Standards Association International
  11. CSFM - California State Fire Marshal



12. NCPWB - National Certified Pipe Welding Bureau
13. NIST - National Institute of Standards and Technology
14. NEMA - National Electrical Manufacturers' Association
15. NFPA - National Fire Protection Association
16. OSHA - Occupational Safety and Health Act
17. SMACNA - Duct Manuals
18. UL - Underwriters' Laboratories, Inc.

B. Requirements of Regulatory Agencies:

1. The publications listed below form part of this specification; comply with provisions of these publications except as otherwise shown or specified.
2. Code editions shall be as noted on Drawings, as adopted by the California Division of the State Architect (DSA).
  - a. California Building Code.
  - b. California Electrical Code.
  - c. California Energy Code.
  - d. California Fire Code.
  - e. California Green Building Standards Code.
  - f. California Mechanical Code.
  - g. California Plumbing Code.
  - h. California Code of Regulations, Title 24.
  - i. California Health and Safety Code.
  - j. CAL-OSHA.
  - k. California State Fire Marshal, Title 19 CCR.
  - l. National Fire Protection Association.
  - m. Occupational Safety and Health Administration.
  - n. Other applicable state laws.
3. Nothing in Drawings or specifications shall be construed to permit work not conforming to these codes, or to requirements of authorities having jurisdiction. It is not the intent of Drawings or specifications to repeat requirements of codes except where necessary for clarity.

### 1.05 DRAWINGS

- A. Examine Contract Documents prior to bidding of work and report discrepancies in writing to Architect.
- B. Drawings showing location of equipment and materials are diagrammatic and job conditions will not always permit installation in location shown. The HVAC Drawings show general arrangement of equipment and materials, etc., and shall be followed as closely as existing conditions, actual building construction, and work of other trades permit.

1. Architectural and Structural Drawings shall be considered part of the Work. These Drawings furnish Contractor with information relating to design and construction of the Project. Architectural Drawings take precedence over HVAC Drawings.
  2. Because of the small scale of HVAC Drawings, not all offsets, fittings, and accessories required are shown. Investigate structural and finish conditions affecting the Work and arrange Work accordingly. Provide offsets, fittings, and accessories required to meet conditions. Inform Architect immediately when job conditions do not permit installation of equipment and materials in the locations shown. Obtain the Architects approval prior to relocation of equipment and materials.
  3. Relocate equipment and materials installed without prior approval of the Architect. Remove and relocate equipment and materials at Contactors' expense upon Architects' direction.
  4. Minor changes in locations of equipment, piping, ducts, etc., from locations shown shall be made when directed by the Architect at no additional cost to the Owner providing such change is ordered before such items of work, or work directly connected to same are installed and providing no additional material is required.
- C. Execute work mentioned in the Specifications and not shown on the Drawings, or vice versa, the same as if specifically mentioned or shown in both.

#### **1.06 FEES AND PERMITS**

- A. Obtain and pay for permits and service required in installation of the Work. Arrange for required inspections and secure approvals from authorities having jurisdiction. Comply with requirements of Division 01.
- B. Arrange for utility connections and pay charges incurred, including excess service charges.

#### **1.07 ADMINISTRATIVE REQUIREMENTS**

- A. Submittal Procedures:
  1. Submittals shall be submitted in accordance with the requirements of Division 01 Specifications.
  2. Closeout Submittals shall be submitted in accordance with the requirements of Division 01 Specifications.
- B. Coordination:
  1. General:
    - a. Coordinate HVAC Work with trades covered in other Specifications Sections to provide a complete, operable and sanitary installation of the highest quality workmanship.
  2. Have fire damper and fire smoke damper installation instructions available at Project site during construction for use by Project Inspector.
  3. Electrical Coordination:

- a. Refer to Section 26 05 30, "Conduit and Wire," for service voltage and power feed wiring for equipment specified under this section. Contractor has full responsibility for the following items of work:
  - 1) Review the Electrical Drawings and Division 26 Specifications to verify that electrical services provided are adequate and compatible with equipment requirements.
  - 2) If additional electrical services are required above that indicated on Electrical Drawings and in Division 26, such as more control interlock conductors, larger feeder, or separate 120 volt control power source, include cost to furnish and install additional electrical services as part of the bid.
  - 3) Prior to proceeding with installation of additional electrical work, submit detailed drawings indicating exact scope of additional electrical work.
4. Mechanical Coordination:
  - a. Arrange for pipe spaces, chases, slots and openings in building structure during progress of construction, to accommodate mechanical system installation.
  - b. Coordinate installation of supporting devices. Set sleeves in poured-in-place concrete and other structural components during construction.
  - c. Coordinate requirements for access panels and doors for mechanical items requiring access where concealed behind finished surfaces.
  - d. Coordinate with other trades equipment locations, pipe, duct and conduit runs, electrical outlets and fixtures, air inlets and outlets, and structural and architectural features. Provide information on location of piping and seismic bracing to other trades as required for a completely coordinated project.

#### **1.08 SUBMITTALS - GENERAL**

- A. Submittal packages may be submitted via email as PDF electronic files, or as printed packages. PDFs shall be legible at actual size (100 percent). Provide seven copies of printed submittal packages.
- B. Provide submittal of materials proposed for use as part of this Project. Product names in Specifications and on Drawings are used as standards of quality. Furnish standard items on specified equipment at no extra cost to the Contract regardless of disposition of submittal data. Other materials or methods shall not be used unless approved in writing by Architect. Architect's review will be required even though "or equal" or synonymous terms are used. Refer to Division 01 for complete instructions.
  1. Partial or incomplete submittals will not be considered.
  2. Quantities are Contractor's responsibility and will not be reviewed.
  3. Provide materials of the same brand or manufacturer for each class of equipment or material.
  4. Identify each item by manufacturer, brand, trade name, number, size, rating, or other data necessary to properly identify and review materials and equipment. Words "as specified" are not sufficient identification.

5. Identify each submittal item by reference to items' Specification Section number and paragraph, by Drawing and detail number, and by unit tag number.
6. Organize submittals in same sequence as in Specification Sections.
7. Show physical arrangement, construction details, finishes, materials used in fabrications, provisions for piping entrance, access requirements for installation and maintenance, physical size, mechanical characteristics, foundation and support details, and weight.
  - a. Submit Shop Drawings, performance curves, and other pertinent data, showing size and capacity of proposed materials.
  - b. Specifically indicate, by drawn detail or note, that equipment complies with each specifically stated requirement of Contract Documents.
  - c. Drawings shall be drawn to scale and dimensioned (except schematic diagrams). Drawings may be prepared by vendor but must be submitted as instruments of Contractor, thoroughly checked and signed by Contractor before submission to Architect for review.
  - d. Catalog cuts and published material may be included with supplemental scaled drawings.
- C. Review of submittals will be only for general conformance with design concept and general compliance with information given in Contract Documents. Review will not include quantities, dimensions, weights or gauges, fabrication processes, construction methods, coordination with work of other trades, or construction safety precautions, which are sole responsibility of Contractor. Review of a component of an assembly does not indicate acceptance of an assembly. Deviations from Contract Documents not clearly identified by Contractor are Contractor's responsibility and will not be reviewed by Architect.
- D. Within reasonable time after award of contract and in ample time to avoid delay of construction, submit to Architect shop drawings or submittals on all items of equipment and materials provided. Provide submittal as a complete package.
  1. Shop drawings and submittals shall include Specification Section, Paragraph number, and Drawing unit symbol or detail number for reference. Organize submittals into booklets for each Specification section and submit in loose-leaf binders with index. Deviations from the Contract Documents shall be prominently displayed in the front of the submittal package and referenced to the applicable Contract requirement.
- E. Furnish to the Project Inspector complete installation instructions on material and equipment before starting installation.

#### **1.09 ACTION SUBMITTALS**

- A. Product Data: Submit manufacturer's technical product data and installation instructions for plumbing systems materials and products.
- B. Shop Drawings.
- C. Provide product data for insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings, indicating compliance with requirement that these products contain less than 0.1 percent (by mass) polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations.
- D. Sustainable Design Submittals:

1. Product Data: For adhesives and sealants, documentation of compliance including printed statement of VOC content and chemical components.

#### **1.10 INFORMATIONAL SUBMITTALS**

- A. Provide coordinated layouts for HVAC systems, in accordance with Specification Section 23 31 13, "Metal Ducts."
- B. Provide evidence of equipment certification to California Energy Code Section 110.1 or 110.2, if not providing Electrically Commutated motors for HVAC fans sized below 1 hp and above 1/12 hp.

#### **1.11 CLOSEOUT SUBMITTALS**

A. Operation and Maintenance Data:

1. Refer to Section 01 78 50, Operating and Maintenance Data, for complete instructions. Requirements given below are in addition to or are intended to amplify Division 01 requirements. In case of conflict between requirements given in this Section and those of Division 01, Division 01 requirements shall apply.
2. Furnish three complete sets of Operation and Maintenance Manual bound in hardboard binder, and one compact disc containing complete Operation and Maintenance Manual in searchable PDF format. Provide Table of Contents. Provide index tabs for each piece of equipment in binder and disc. Begin compiling data upon approval of submittals.
  - a. Sets shall incorporate the following:
    - 1) Product Data.
    - 2) Shop Drawings.
    - 3) Record Drawings.
    - 4) Service telephone number, address and contact person for each category of equipment or system.
    - 5) Complete operating instructions for each item of heating, ventilating and air conditioning equipment.
    - 6) Copies of guarantees/warranties for each item of equipment or systems.
    - 7) Test data and system balancing reports.
    - 8) Typewritten maintenance instructions for each item of equipment listing lubricants to be used, frequency of lubrication, inspections required, adjustment, etc.
    - 9) Manufacturers' bulletins with parts numbers, instructions, etc., for each item of equipment.
    - 10) Temperature control diagrams and literature.
    - 11) Check test and start reports for each piece of mechanical equipment provided as part of the Work.
    - 12) Commissioning and Preliminary Operation Tests required as part of the Work.
3. Post service telephone numbers and addresses in an appropriate place designated by Architect.

B. Record Drawings:

1. Refer to Section 01 78 20, Project Record Documents, for requirements governing Work specified herein.
2. Upon completion of the Work, deliver to Architect the following:
  - a. Originals of drawings showing the Work exactly as installed.
  - b. One complete set of reproducible drawings showing the Work exactly as installed.
  - c. One compact disc with complete set of drawings in PDF format showing the Work exactly as installed.
  - d. Provide Contractor's signature, verifying accuracy of record drawings.
  - e. Obtain the signature of the Project Inspector of Record for Record Drawings.

### **1.12 SUBSTITUTIONS**

- A. Refer to Section 01 25 00, Substitution Procedures, for complete instructions. Requirements given below are in addition to or are intended to amplify Division 01 requirements. In case of conflict between requirements given in this Section and those of Division 01, Division 01 requirements shall apply.
- B. It is the responsibility of Contractor to assume costs incurred because of additional work and or changes required to incorporate proposed substitute into the Project. Refer to Division 01 for complete instructions.
- C. Substitutions will be interpreted to be manufacturers other than those specifically listed in the Contract Documents by brand name, model, or catalog number.
- D. Only one request for substitution will be considered for each item of equipment or material.
- E. Substitution requests shall include the following:
  1. Reason for substitution request.
  2. Complete submittal information as described herein; see "Submittals."
  3. Coordinated scale layout drawings depicting position of substituted equipment in relation to other work, with required clearances for operation, maintenance and replacement.
  4. List optional features required for substituted equipment to meet functional requirements of the system as indicated in Contract Documents.
  5. Explanation of impact on connected utilities.
  6. Explanation of impact on structural supports.
- F. Installation of reviewed substitution is Contractors' responsibility. Any mechanical, electrical, structural, or other changes required for installation of substituted equipment or material must be made by Contractor without additional cost to Owner. Review by Architect of substituted equipment or material, will not waive these requirements.
- G. Contractor may be required to compensate Architect for costs related to substituted equipment or material.

### **1.13 QUALITY ASSURANCE**

- A. Manufacturer's Qualifications: Firms regularly engaged in manufacture of HVAC systems products, of types, materials, and sizes required, whose products have been in satisfactory use in similar service for not less than 5 years.

- B. Contractor's Qualifications: Firm with at least 5 years of successful installation experience on projects with HVAC systems work similar to that required for this Project.
- C. Comply with applicable portions of California Mechanical Code pertaining to selection and installation of HVAC materials and products.
- D. All materials and products shall be new.

#### **1.14 DELIVERY, STORAGE, AND HANDLING**

- A. Protect equipment and materials delivered to Project site from weather, humidity and temperature variations, dirt, dust and other contaminants.

#### **1.15 FIELD CONDITIONS**

- A. Contractor shall visit Project site and examine existing conditions in order to become familiar with Project scope. Verify dimensions shown on Drawings at Project site. Bring discrepancies to the attention of Architect. Failure to examine Project site shall not constitute basis for claims for additional work because of lack of knowledge or location of hidden conditions that affect Project scope.
- B. Information on Drawings relative to existing conditions is approximate. Deviations from Drawings necessary during progress of construction to conform to actual conditions shall be approved by the Architect and shall be made without additional cost to the Owner. The Contractor shall be held responsible for damage caused to existing services. Promptly notify the Architect if services are found which are not shown on Drawings.

#### **1.16 WARRANTY**

- A. Refer to Division 01 for warranty requirements, including effective date of warranty. Refer to specific items of equipment specified herein for warranty duration if different from that specified in Division 01.
- B. Repair or replace defective work, material, or part that appears within the warranty period, including damage caused by leaks.
- C. On failure to comply with warranty requirements within a reasonable length of time after notification is given, Architect/Owner shall have repairs made at Contractor's expense.

### **PART 2 - PRODUCTS**

#### **2.01 GENERAL**

- A. Materials or equipment of the same type shall be of the same brand wherever possible. All materials shall be new and in first class condition.
- B. All sizes, capacities, and efficiency ratings shown are minimum, except that gas capacity is maximum available.
- C. Refer to Division 23 technical Sections for specific system piping materials.

#### **2.02 MATERIALS**

- A. No material installed as part of this Work shall contain asbestos.
- B. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).

- C. California Green Building Code Compliance:
  - 1. HVAC and refrigeration equipment shall not contain CFCs.
  - 2. HVAC and refrigeration equipment shall not contain Halons.

### **2.03 MOTOR STARTERS**

- A. Square D, Allen Bradley, or equal, in NEMA Type 1 enclosure, unless otherwise specified or required. Minimum starter size shall be Size 1. Provide NEMA 3R enclosure where exposed to outdoors.
- B. Provide magnetic motor starters for all equipment provided under the Mechanical Work. Starters shall be non-combination type. Provide part winding or reduced voltage start motors where shown or as hereinafter specified. Minimum size starter shall be Size 1.
  - 1. All starters shall have the following:
    - a. Cover mounted hand-off-automatic switch. Starters installed exposed in occupied spaces shall have key operated HOA switch.
    - b. Ambient compensated thermal overload.
    - c. Fused control transformer (for 120 or 24 volt service).
    - d. Pilot lights, integral with the starters. Starters located outdoors shall be in NEMA IIIR enclosures.
  - 2. Where three phase motors are provided for two-speed operation, provide two speed motor starters.
  - 3. Starters for single-phase motors shall have thermal overloads. NEMA I enclosure for starters located indoors, NEMA IIIR enclosure for starters located outdoors.
  - 4. Provide OSHA label indicating the device starts automatically.

### **2.04 VALVE BOXES**

- A. General:
  - 1. Where several valves or other equipment are grouped together, provide larger boxes of rectangular "vault" type adequately sized for condition and similar in construction to those specified above.
  - 2. Provide valve box extensions as required to set bottom of valve box tight up to top of piping in which valve is installed.
  - 3. Provide a tee handle wrench for each size, Alhambra Foundry Co. #A-3008, or equal.
- B. Valve Boxes in Traffic Areas: Provide Christy No. G5 traffic valve box, Brooks, or approved equal, 10-3/8 inches inside diameter with extensions to suit conditions, with cast iron locking cover. Provide Owner with set of special wrenches or tools as required for operation of valves.
- C. Valve Boxes in Non-Traffic Areas: Provide Christy No. F22, Brooks, or approved equal, 8 inches inside diameter by 30 inches long, with cast iron locking cover. Provide Owner with set of special wrenches or tools as required for operation of valves. Cut bottom of plastic body for operation of valves.



- D. Valve Box (Rectangular Vault Type): Precast concrete or cast iron with cast iron locking type covers lettered to suit service – Brooks No. 3-TL, Christy No. B3, Fraser No. 3, Alhambra A-3004 or A-3005, Alhambra E-2202, or E-2702, or approved equal, with extension to suit conditions.

## **2.05 ACCESS DOORS**

- A. Where floors, walls, or ceilings must be penetrated for access to mechanical equipment, provide access doors, 14 inch by 14 inch minimum size in usable opening. Where entrance of a serviceman may be required, provide 20 inch by 30 inch minimum usable opening. Locate access doors/panels for non-obstructed and easy reach.
  - 1. All access doors less than 7'-0" above floors and exposed to public access shall have keyed locks.
- B. Access doors shall match those supplied in Section 08 31 00, "Access Doors and Panels," except as noted in this Section.
- C. Provide stainless steel access doors for use in toilet rooms, shower rooms, kitchens and other damp areas. Provide steel access doors with prime coat of baked-on paint for all other areas.
- D. Where panels are located on ducts or plenums, provide neoprene gaskets to prevent air leakage, and use frames to set door out to flush with insulation.
- E. Provide insulated doors where located in internally insulated ducts or casings.
- F. Do not locate access doors in highly visible public areas such as lobbies, waiting areas, and primary entrance areas. Coordinate with the Architect when access is required in these areas.
- G. Where specific information or details relating to access panels different from the above is shown or given on the Drawings or other Divisions of work, then that information shall supersede this specification.
- H. Manufacturers: Subject to compliance with requirements, available manufacturers offering products which may be incorporated into the Work include Milcor, Karp, Nystrom, or Cesco, equal to the following:
  - 1. Milcor
    - a. Style K (plaster).
    - b. Style DW (gypsum board).
    - c. Style M (Masonry).
    - d. Style "Fire Rated" where required.

## **PART 3 - EXECUTION**

### **3.01 FRAMING, CUTTING AND PATCHING**

- A. Special framing, recesses, chases and backing for Work of this Section, unless otherwise specified, are covered under other Specification Sections.
- B. Contractor is responsible for placement of pipe sleeves, hangers, inserts, supports, and location of openings for the Work.

### **3.02 ELECTRICAL REQUIREMENTS**

- A. Provide adequate working space around electrical equipment in compliance with the California Electrical Code. Coordinate the Mechanical Work with the Electrical Work to comply.
- B. Furnish necessary control diagrams and instructions for the controls. Before permitting operation of any equipment which is furnished, installed, or modified under this Section, review all associated electrical work, including overload protection devices, and assume complete responsibility for the correctness of the electrical connections and protective devices. Motors and control equipment shall conform to the Standards of the National Electrical Manufacturers' Association. All equipment and connections exposed to the weather shall be NEMA IIIIR with factory-wired strip heaters in each starter enclosure and temperature control panel where required to inhibit condensation.
- C. All line voltage and low voltage wiring and conduit associated with the Temperature Control System are included in this Section. Wiring and conduit shall comply with Division 26.

### **3.03 PIPING SYSTEM REQUIREMENTS**

- A. Drawing plans, schematic and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on coordination drawings.

### **3.04 INSTALLATION OF PIPING AND DUCT SYSTEMS**

- A. General:
  - 1. All piping shall be concealed unless shown or otherwise directed. Allow sufficient space for ceiling panel removal.
  - 2. Installation of piping shall be made with appropriate fittings. Bending of piping will not be accepted.
  - 3. Install piping to permit application of insulation and to allow valve servicing.
  - 4. Where piping, conduit, or ductwork is left exposed within a room, the same shall be run true to plumb, horizontal, or intended planes. Where possible, uniform margins are to be maintained between parallel lines and/or adjacent wall, floor, or ceiling surfaces.
  - 5. Horizontal runs of pipes, conduits, or ductwork suspended from ceilings shall provide for a maximum headroom clearance. The clearance shall not be less than 6'-6" without written approval from the Architect.
  - 6. Close ends of pipe immediately after installation. Leave closure in place until removal is necessary for completion of installation.
  - 7. At the time of rough installation, or during storage on the construction site and until final startup of the heating and cooling equipment, all duct and other related air distribution component opening shall be covered with tape, plastic, sheet metal, or other methods acceptable to the enforcing agency.
  - 8. Each piping system shall be thoroughly flushed and proved clean before connection to equipment.
  - 9. Pipe the discharge of each relief valve, air vent, backflow preventer, and similar device to floor sink or drain.

10. Install exposed polished or enameled connections with special care showing no tool marks or threads at fittings.
11. Install horizontal valves with valve stem above horizontal.
12. Use reducing fittings; bushings shall not be allowed. Use eccentric reducing fittings wherever necessary to provide free drainage of lines and passage of air.
13. Verify final equipment locations for roughing-in.
14. Where piping is installed in walls within one inch of the face of stud, provide a 16 gauge sheet metal shield plate on the face of the stud. The shield plate shall extend a minimum of 1-1/2 inches beyond the outside diameter of the pipe.

### **3.05 ACCESS DOORS**

- A. Furnish and install access doors wherever required whether shown or not for easy maintenance of mechanical systems; for example, at concealed valves, strainers, traps, cleanouts, dampers, motors, controls, operating equipment, etc. Access doors shall provide for complete removal and replacement of equipment.

### **3.06 EXPANSION ANCHORS IN HARDENED CONCRETE**

- A. Refer to Structural Drawings.

### **3.07 OPERATION OF SYSTEMS**

- A. Do not operate any mechanical equipment for any purpose, temporary or permanent, until all of the following has been completed:
  1. Complete all requirements listed under "Check, Test and Start Requirements."
  2. Ductwork and piping has been properly cleaned. Piping systems shall be flushed and treated prior to operation.
  3. Filters, strainers etc. are in place.
  4. Bearings have been lubricated, and alignment of rotating equipment has been checked.
  5. Equipment has been run under observation, and is operating in a satisfactory manner.
- B. Provide test and balance agency with one set of Contract Drawings, Specifications, Addenda, Change orders issued, applicable shop drawings and submittals and temperature control drawings.
- C. Operate every fire damper, smoke damper, combination smoke and fire damper under normal operating conditions. Activate smoke detectors as required to operate the damper, stage fan, etc. Provide written confirmation that all systems operate in a satisfactory manner.

### **3.08 CHECK, TEST AND START REQUIREMENTS**

- A. An authorized representative of the equipment manufacturer shall perform check, test and start of each piece of mechanical equipment. The representative may be an employee of the equipment manufacturer, or a manufacturer-certified contractor. Submit written certification from the manufacturer stating that the representative is qualified to perform the check test and start of the equipment.

1. As part of the submittal process, provide a copy of each manufacturer's printed startup form to be used.
  2. Some items of specified equipment may require that check, test and start of equipment must be performed by the manufacturer, using manufacturer's employees. See specific equipment Articles in these Specifications for this requirement.
  3. Provide all personnel, test instruments, and equipment to properly perform the check, test and start work.
  4. When work has been completed, provide copies of reports for review, prior to final observation of work.
- B. Provide copies of the completed check, test and start report of each item of equipment, bound with the Operation and Maintenance Manual.
- C. Upon completion of the work, provide a schedule of planned maintenance for each piece of equipment. Indicate frequency of service, recommended spare parts (including filters and lubricants), and methods for adjustment and alignment of all equipment components. Provide a copy of the schedule with each Operation and Maintenance Manual. Provide a copy of certification from the Owner's representative indicating that they have been properly instructed in maintenance requirements for the equipment installed.

### **3.09 PRELIMINARY OPERATIONAL REQUIREMENTS AND TESTS**

- A. Prior to observation to determine final acceptance, put HVAC, plumbing, and fire protection systems into service and check that work required for that purpose has been done, including but not limited to the following condensed check list. Provide indexed report to tabulating the results of all work.
1. Refer to Division 22 technical Sections for specific testing requirements.
  2. All equipment has been started, checked, lubricated and adjusted in accordance with the manufacturer's recommendations, including modulating power exhausts if present.
  3. Correct rotation of motors and ratings of overload heaters are verified.
  4. Specified filters are installed and spare filters have been turned over to Owner.
  5. All manufacturers' certificates of start-up specified have been delivered to the Owner.
  6. All equipment has been cleaned, and damaged painted finishes touched up.
  7. Damaged fins on heat exchangers have been combed out.
  8. Missing or damaged parts have been replaced.
  9. Flushing and chemical treatment of piping systems has been completed and water treatment equipment, where specified, is in operation.
  10. Equipment labels, pipe marker labels, ceiling markers and valve tags are installed.
  11. Valve tag schedules, corrected control diagrams, sequence of operation lists and start-stop instructions have been posted.
  12. Preliminary test and balance work is complete, and reports have been forwarded for review.
  13. Automatic control set points are as designated and performance of controls checks out to agree with the sequence of operation.

14. Operation and Maintenance Manuals have been delivered and instructions to the operating personnel have been made.
- B. Prior to the observation to determine final acceptance, operate all mechanical systems as required to demonstrate that the installation and performance of these systems conform to the requirements of these specifications.
1. Operate and test all mechanical equipment and systems for a period of at least five consecutive 8 hour days to demonstrate the satisfactory overall operation of the project as a complete unit.
  2. Include operation of heating and air conditioning equipment and systems for a period of not less than two 8 hour days at not less than 90 percent of full specified heating and cooling capacities in tests.
  3. Commence tests after preliminary balancing and adjustments to equipment have been checked. Immediately before starting tests, install air filters and lubricate all running equipment. Notify the Architect at least seven calendar days in advance of starting the above tests.
  4. During the test period, make final adjustments and balancing of equipment, systems controls, and circuits so that all are placed in first class operating condition.
  5. Where Utility District rebates are applicable, demonstrate that the systems meet the rebate program requirements.
- C. Before handing over the system to Owner replace all filters with complete new set of filters.
- D. Review of Contractor's Tests:
1. All tests made by the Contractor or manufacturers' representatives are subject to observation and review by the Owner. Provide timely notice prior to start of each test, in order to allow for observation of testing. Upon the completion of all tests, provide a report to confirm that all testing has been successful.
- E. Test Logs:
1. Maintain test logs listing the tests on all mechanical systems showing dates, items tested, inspectors' names, remarks on success or failure of the tests.
- F. Preliminary Operation:
1. The Owner reserves the right to operate portions of the mechanical system on a preliminary basis without voiding the guarantee.
- G. Operational Tests:
1. Before operational tests are performed, demonstrate that all systems and components are complete and fully charged with operating fluid and lubricants.
  2. Systems shall be operable and capable of maintaining continuous uninterrupted operation during the operating and demonstration period. After all systems have been completely installed, connections made, and tests completed, operate the systems continuously for a period of five working days during the hours of a normal working day.

3. This period of continuous systems operation may be coordinated with the removal of Volatile Organic Compounds (VOCs) from the building prior to occupancy should the Owner decide to implement such a program.
  4. Control systems shall be completely operable with settings properly calibrated and adjusted.
  5. Rotating equipment shall be in dynamic balance and alignment.
  6. If the system fails to operate continuously during the test period, the deficiencies shall be corrected and the entire test repeated.
- H. Pre-Occupancy Building Purge:
1. Prior to occupancy, ventilate the building on 100 percent outside air, 100 percent exhaust for a continuous period determined by a qualified industrial hygienist (engaged by the Contractor) to reduce V.O.C's prior to occupancy.
  2. Submit report by the industrial hygienist verifying satisfactory completion of the pre-occupancy purge.

### **3.10 CERTIFICATES OF INSTALLATION**

- A. Contractor shall complete applicable "Certificates of Installation" forms contained in the California Building Energy Efficiency Standards and submit to the authorities having jurisdiction for approval and issuance of final occupancy permit, as described in the California Energy Code.

### **3.11 ACCEPTANCE REQUIREMENTS**

- A. Contractor shall complete the applicable Acceptance Requirements for Code Compliance contained in the California Building Energy Efficiency Standards. Refer to T-24 compliance forms on Drawings for systems having Acceptance testing requirements. Contractor shall perform Acceptance tests under the direction of the Commissioning Agent and complete the appropriate "Certificates of Acceptance." Submit certificates to the authorities having jurisdiction for approval and issuance of final occupancy permit. Contractor shall engage certified HERS Rater to verify duct leakage rate for duct systems indicated on T-24 compliance forms on Drawings as requiring duct leakage rate testing. For additional duct leak testing requirements, refer to Section 23 31 13, "Metal Ducts."

### **3.12 DEMONSTRATION AND TRAINING**

- A. An authorized representative of the equipment manufacturer shall train Owner-designated personnel in maintenance and adjustment of equipment. The representative may be an employee of the equipment manufacturer, or a manufacturer-certified contractor. Submit written certification from the manufacturer stating that the representative is qualified to perform the Owner training for the equipment installed.
  1. As part of the submittal process, provide a training agenda outlining major topics and time allowed for each topic.
  2. Some items of specified equipment require that training must be performed by the manufacturer, using manufacturer's employees. See specific equipment Articles in these Specifications for this requirement.

3. Contractor shall provide three copies of certification by Contractor that training has been completed, signed by Owner's representative, for inclusion in Operation and Maintenance Manual. Certificates shall include:
  - a. Listing of Owner-designated personnel completing training, by name and title.
  - b. Name and title of training instructor.
  - c. Date(s) of training.
  - d. List of topics covered in training sessions.
4. Refer to specific equipment Sections for minimum training period duration for each piece of equipment.

### **3.13 COMMISSIONING**

- A. This Project will be commissioned by a third-party Commissioning Agent. In addition to the requirements of this Section, comply with the requirements of Section 01 81 00, "Commissioning."

END OF SECTION

**SECTION 23 05 13**  
**COMMON MOTOR REQUIREMENTS FOR HVAC EQUIPMENT**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section includes general requirements for single-phase and polyphase, general-purpose, horizontal, small and medium, squirrel-cage induction motors for use on alternating-current power systems up to 600 V and installed at equipment manufacturer's factory or shipped separately by equipment manufacturer for field installation.

**1.02 SUBMITTALS**

- A. Provide evidence of equipment certification to California Energy Code Section 110.1 or 110.2, if not providing Electrically Commutated motors for HVAC fans sized below 1 hp and above 1/12 hp.

**1.03 COORDINATION**

- A. Coordinate features of motors, installed units, and accessory devices to be compatible with the following:
  - 1. Motor controllers.
  - 2. Torque, speed, and horsepower requirements of the load.
  - 3. Ratings and characteristics of supply circuit and required control sequence.
  - 4. Ambient and environmental conditions of installation location.

**PART 2 - PRODUCTS**

**2.01 GENERAL MOTOR REQUIREMENTS**

- A. Comply with NEMA MG 1 unless otherwise indicated.
- B. Comply with IEEE 841 for severe-duty motors.

**2.02 MOTOR CHARACTERISTICS**

- A. Duty: Continuous duty at ambient temperature of 40 deg C and at altitude of 3300 feet above sea level.
- B. Capacity and Torque Characteristics: Sufficient to start, accelerate, and operate connected loads at designated speeds, at installed altitude and environment, with indicated operating sequence, and without exceeding nameplate ratings or considering service factor.

**2.03 POLYPHASE MOTORS**

- A. Description: NEMA MG 1, Design B, medium induction motor.
- B. Efficiency: Premium efficient, as defined in NEMA MG 1.
- C. Service Factor: 1.15.
- D. Multispeed Motors: Variable torque.
  - 1. For motors with 2:1 speed ratio, consequent pole, single winding.



- 2. For motors with other than 2:1 speed ratio, separate winding for each speed.
- E. Multispeed Motors: Separate winding for each speed.
- F. Rotor: Random-wound, squirrel cage.
- G. Bearings: Regreasable, shielded, antifriction ball bearings suitable for radial and thrust loading.
- H. Temperature Rise: Match insulation rating.
- I. Insulation: Class F.
- J. Code Letter Designation:
  - 1. Motors 15 HP and Larger: NEMA starting Code F or Code G.
  - 2. Motors Smaller Than 15 HP: Manufacturer's standard starting characteristic.
- K. Enclosure Material: Cast iron for motor frame sizes 324T and larger; rolled steel for motor frame sizes smaller than 324T.

#### **2.04 ADDITIONAL REQUIREMENTS FOR POLYPHASE MOTORS**

- A. Motors Used with Reduced-Voltage and Multispeed Controllers: Match wiring connection requirements for controller with required motor leads. Provide terminals in motor terminal box, suited to control method.
- B. Motors Used with Variable-Frequency Controllers: Ratings, characteristics, and features coordinated with and approved by controller manufacturer.
  - 1. Windings: Copper magnet wire with moisture-resistant insulation varnish, designed and tested to resist transient spikes, high frequencies, and short time rise pulses produced by pulse-width-modulated inverters.
  - 2. Premium-Efficient Motors: Class B temperature rise; Class F insulation.
  - 3. Inverter-Duty Motors: Class F temperature rise; Class H insulation.
  - 4. Thermal Protection: Comply with NEMA MG 1 requirements for thermally protected motors.
- C. Severe-Duty Motors: Comply with IEEE 841, with 1.15 minimum service factor.

#### **2.05 SINGLE-PHASE MOTORS**

- A. Motors larger than 1/20 hp shall be one of the following, to suit starting torque and requirements of specific motor application:
  - 1. Permanent-split capacitor.
  - 2. Split phase.
  - 3. Capacitor start, inductor run.
  - 4. Capacitor start, capacitor run.
- B. Motors for HVAC exhaust, transfer, and supply fans larger than 1/12 hp and smaller than 1 hp shall be the following:
  - 1. Electrically Commutated motor (EC type): Motor shall be brushless DC type specifically designed for applications with heavy duty ball bearings and electronic commutation. The motor shall be speed controllable down to 20 percent of full speed and 85 percent efficient at all speeds. These motors shall also have the means to adjust motor speed for either balancing or remote control. Exceptions:

- a. Motors in fan-coils and terminal units that operate only when providing heating to the space served.
- b. Motors installed in space conditioning equipment certified under 2013 California Energy Code Section 110.1 or 110.2.
- C. Multispeed Motors: Variable-torque, permanent-split-capacitor type.
- D. Bearings: Prelubricated, antifriction ball bearings or sleeve bearings suitable for radial and thrust loading.
- E. Motors 1/20 HP and Smaller: Shaded-pole type.
- F. Thermal Protection: Internal protection to automatically open power supply circuit to motor when winding temperature exceeds a safe value calibrated to temperature rating of motor insulation. Thermal-protection device shall automatically reset when motor temperature returns to normal range.

**PART 3 - EXECUTION (NOT APPLICABLE)**

END OF SECTION



**SECTION 23 05 17**  
**SLEEVES AND SLEEVE SEALS FOR HVAC PIPING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Sleeves.
  - 2. Sleeve-seal systems.
  - 3. Grout.
- B. Related Requirements:
  - 1. Section 078413 "Penetration Firestopping" for penetration firestopping installed in fire-resistance-rated walls, horizontal assemblies, and smoke barriers, with and without penetrating items.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
- B. Sustainable Design Submittals:
  - 1. Product Data: For sealants, indicating VOC content.
  - 2. Laboratory Test Reports: For sealants, indicating compliance with requirements for low-emitting materials.

**PART 2 - PRODUCTS**

**2.01 SLEEVES**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Advance Products & Systems, Inc.
  - 2. CALPICO, Inc.
  - 3. GPT; an EnPro Industries company.
- B. Steel Pipe Sleeves: ASTM A 53/A 53M, Type E, Grade B, Schedule 40, zinc coated, with plain ends and integral welded waterstop collar.
- C. Galvanized-Steel Sheet Sleeves: 0.0239-inch minimum thickness; round tube closed with welded longitudinal joint.

**2.02 SLEEVE-SEAL SYSTEMS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Advance Products & Systems, Inc.
  - 2. Airex Manufacturing.
  - 3. CALPICO, Inc.

4. GPT; an EnPro Industries company.
  5. Metraflex Company (The).
  6. Proco Products, Inc.
- B. Description:
1. Modular sealing-element unit, designed for field assembly, for filling annular space between piping and sleeve.
  2. Designed to form a hydrostatic seal of 20-psig.
  3. Sealing Elements: EPDM-rubber interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size.
  4. Pressure Plates: Carbon steel.
  5. Connecting Bolts and Nuts: Carbon steel, with corrosion-resistant coating, ASTM B 633 of length required to secure pressure plates to sealing elements.

### 2.03 GROUT

- A. Description: Nonshrink, recommended for interior and exterior sealing openings in nonfire-rated walls or floors.
- B. Standard: ASTM C 1107/C 1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- C. Design Mix: 5000-psi, 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

## PART 3 - EXECUTION

### 3.01 SLEEVE INSTALLATION

- A. Install sleeves for piping passing through penetrations in floors, partitions, roofs, and walls.
- B. For sleeves that will have sleeve-seal system installed, select sleeves of size large enough to provide 1-inch annular clear space between piping and concrete slabs and walls.
  1. Sleeves are not required for core-drilled holes.
- C. Install sleeves in concrete floors, concrete roof slabs, and concrete walls as new slabs and walls are constructed.
  1. Permanent sleeves are not required for holes in slabs formed by molded-PE or -PP sleeves.
  2. Cut sleeves to length for mounting flush with both surfaces.
    - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches above finished floor level.
  3. Using grout, seal space outside of sleeves in slabs and walls without sleeve-seal system.
- D. Install sleeves for pipes passing through interior partitions.
  1. Cut sleeves to length for mounting flush with both surfaces.
  2. Install sleeves that are large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation.

3. Seal annular space between sleeve and piping or piping insulation; use sealants appropriate for size, depth, and location of joint. Comply with requirements for sealants specified in Section 079200, "Joint Sealants."
- E. Fire-Resistance-Rated Penetrations, Horizontal Assembly Penetrations, and Smoke-Barrier Penetrations: Maintain indicated fire or smoke rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with fire- and smoke-stop materials. Comply with requirements for firestopping and fill materials specified in Section 078413 "Penetration Firestopping."

### **3.02 SLEEVE-SEAL-SYSTEM INSTALLATION**

- A. Install sleeve-seal systems in sleeves in exterior concrete walls and slabs-on-grade at service piping entries into building.
- B. Select type, size, and number of sealing elements required for piping material and size and for sleeve ID or hole size. Position piping in center of sleeve. Center piping in penetration, assemble sleeve-seal-system components, and install in annular space between piping and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make a watertight seal.

### **3.03 SLEEVE AND SLEEVE-SEAL SCHEDULE**

- A. Use sleeves and sleeve seals for the following piping-penetration applications:
  1. Exterior Concrete Walls Above Grade:
    - a. Piping Smaller Than NPS 6: Steel pipe sleeves.
    - b. Piping NPS 6 and Larger: Steel pipe sleeves.
  2. Exterior Concrete Walls Below Grade:
    - a. Piping Smaller Than NPS 6: Steel pipe sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
    - b. Piping NPS 6 and Larger: Steel pipe sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
  3. Concrete Slabs-on-Grade:
    - a. Piping Smaller Than NPS 6: Steel pipe sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
    - b. Piping NPS 6 and Larger: Steel pipe sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
  4. Interior Partitions:
    - a. Piping Smaller Than NPS 6: Steel pipe sleeves.
    - b. Piping NPS 6 and Larger: Galvanized-steel sheet sleeves.

END OF SECTION

**SECTION 23 05 18**  
**ESCUTCHEONS FOR HVAC PIPING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Escutcheons.
  - 2. Floor plates.

**1.02 DEFINITIONS**

- A. Existing Piping to Remain: Existing piping that is not to be removed and that is not otherwise indicated to be removed, removed and salvaged, or removed and reinstalled.

**1.03 ACTION SUBMITTALS**

- A. Product Data: For each type of product.

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. BrassCraft Manufacturing Co.; a Masco company.
  - 2. Dearborn Brass.

**2.02 ESCUTCHEONS**

- A. One-Piece, Cast-Brass Type: With polished, chrome-plated finish and setscrew fastener.
- B. One-Piece, Deep-Pattern Type: Deep-drawn, box-shaped brass with polished, chrome-plated finish and spring-clip fasteners.
- C. One-Piece, Stamped-Steel Type: With polished, chrome-plated finish and spring-clip fasteners.

**2.03 FLOOR PLATES**

- A. Split Floor Plates: Steel with concealed hinge.

**PART 3 - EXECUTION**

**3.01 INSTALLATION**

- A. Install escutcheons for piping penetrations of walls, ceilings, and finished floors.
- B. Install escutcheons with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
  - 1. Escutcheons for New Piping:



- a. Piping with Fitting or Sleeve Protruding from Wall: One-piece, deep pattern.
  - b. Insulated Piping: One-piece cast brass with polished, chrome-plated finish.
  - c. Bare Piping in Unfinished Service Spaces: One-piece stamped steel with polished, chrome-plated finish.
  - d. Bare Piping in Equipment Rooms: One-piece stamped steel with polished, chrome-plated finish.
- C. Install floor plates for piping penetrations of equipment-room floors.
  - D. Install floor plates with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
    - 1. New Piping: Split floor plate.

### **3.02 FIELD QUALITY CONTROL**

- A. Using new materials, replace broken and damaged escutcheons and floor plates.

END OF SECTION

**SECTION 23 05 29**  
**HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Metal pipe hangers and supports.
  - 2. Metal framing systems.
  - 3. Fastener systems.
  - 4. Equipment supports.
- B. Related Sections:
  - 1. Section 05 50 00 "Metal Fabrications" for structural-steel shapes and plates for trapeze hangers for pipe and equipment supports.
  - 2. Section 23 05 16 "Expansion Fittings and Loops for HVAC Piping" for pipe guides and anchors.
  - 3. Section 23 05 48 "Vibration and Seismic Controls for HVAC" for vibration isolation devices.
  - 4. Section 23 31 13 "Metal Ducts" for duct hangers and supports.

**1.02 DEFINITIONS**

- A. MSS: Manufacturers Standardization Society of The Valve and Fittings Industry Inc.

**1.03 PERFORMANCE REQUIREMENTS**

- A. Delegated Design: Design trapeze pipe hangers and equipment supports, including comprehensive engineering analysis by a qualified professional engineer, using performance requirements and design criteria indicated.
- B. Structural Performance: Hangers and supports for HVAC piping and equipment shall withstand the effects of gravity loads and stresses within limits and under conditions indicated according to CBC and ASCE/SEI 7 as referenced by the CBC.
  - 1. Design supports for multiple pipes, including pipe stands, capable of supporting combined weight of supported systems, system contents, and test water.
  - 2. Design equipment supports capable of supporting combined operating weight of supported equipment and connected systems and components.
  - 3. Design seismic-restraint hangers and supports for piping and equipment and obtain approval from authorities having jurisdiction.
- C. All connections and attachments to the building structural systems will require review and approval for structural engineer of record.

**1.04 ACTION SUBMITTALS**

- A. Product Data: For each type of product indicated.

- B. Shop Drawings: Signed and sealed by a qualified professional engineer. Show fabrication and installation details and include calculations for the following; include Product Data for components:
  - 1. Metal framing systems.
  - 2. Equipment supports.

#### **1.05 INFORMATIONAL SUBMITTALS**

- A. Welding certificates.

#### **1.06 QUALITY ASSURANCE**

- A. Structural Steel Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code - Steel."
- B. Pipe Welding Qualifications: Qualify procedures and operators according to ASME Boiler and Pressure Vessel Code.

### **PART 2 - PRODUCTS**

#### **2.01 METAL PIPE HANGERS AND SUPPORTS**

- A. Carbon-Steel Pipe Hangers and Supports:
  - 1. Description: MSS SP-58, Types 1 through 58, factory-fabricated components.
  - 2. Galvanized Metallic Coatings: Pregalvanized or hot dipped.
  - 3. Nonmetallic Coatings: Plastic coating, jacket, or liner.
  - 4. Padded Hangers: Hanger with fiberglass or other pipe insulation pad or cushion to support bearing surface of piping.
  - 5. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
- B. Copper Pipe Hangers:
  - 1. Description: MSS SP-58, Types 1 through 58, copper-coated-steel, factory-fabricated components.
  - 2. Hanger Rods: Continuous-thread rod, nuts, and washer made of stainless steel.

#### **2.02 METAL FRAMING SYSTEMS**

- A. MFMA Manufacturer Metal Framing Systems:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. B-line, an Eaton business.
    - b. Flex-Strut Inc.
    - c. Thomas & Betts Corporation; A Member of the ABB Group.
    - d. Unistrut; Part of Atkore International.
    - e. Wesanco, Inc.
  - 2. Description: Shop- or field-fabricated pipe-support assembly for supporting multiple parallel pipes.

3. Standard: MFMA-4.
4. Channels: Continuous slotted steel channel with inturned lips.
5. Channel Nuts: Formed or stamped steel nuts or other devices designed to fit into channel slot and, when tightened, prevent slipping along channel.
6. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
7. Metallic Coating: Electroplated zinc or hot-dipped galvanized.

### **2.03 FASTENER SYSTEMS**

- A. Mechanical-Expansion Anchors: Insert-wedge-type, stainless-steel anchors, for use in hardened portland cement concrete; with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.

### **2.04 EQUIPMENT SUPPORTS**

- A. Description: Welded, shop- or field-fabricated equipment support made from structural carbon-steel shapes.

### **2.05 MISCELLANEOUS MATERIALS**

- A. Structural Steel: ASTM A 36/A 36M, carbon-steel plates, shapes, and bars; black and galvanized.
- B. Grout: ASTM C 1107, factory-mixed and -packaged, dry, hydraulic-cement, nonshrink and nonmetallic grout; suitable for interior and exterior applications.
  1. Properties: Nonstaining, noncorrosive, and nongaseous.
  2. Design Mix: 5000-psi, 28-day compressive strength.

## **PART 3 - EXECUTION**

### **3.01 HANGER AND SUPPORT INSTALLATION**

- A. Metal Pipe-Hanger Installation: Comply with MSS SP-58. Install hangers, supports, clamps, and attachments as required to properly support piping from the building structure.
- B. Metal Framing System Installation: Arrange for grouping of parallel runs of piping, and support together on field-assembled metal framing systems.
- C. Fastener System Installation:
  1. Install mechanical-expansion anchors in concrete after concrete is placed and completely cured. Install fasteners according to manufacturer's written instructions.
- D. Install hangers and supports complete with necessary attachments, inserts, bolts, rods, nuts, washers, and other accessories.
- E. Equipment Support Installation: Fabricate from welded-structural-steel shapes.
- F. Install hangers and supports to allow controlled thermal and seismic movement of piping systems, to permit freedom of movement between pipe anchors, and to facilitate action of expansion joints, expansion loops, expansion bends, and similar units.
- G. Install lateral bracing with pipe hangers and supports to prevent swaying.

- H. Install building attachments within concrete slabs or attach to structural steel. Install additional attachments at concentrated loads, including valves, flanges, and strainers, NPS 2-1/2 and larger and at changes in direction of piping. Install concrete inserts before concrete is placed; fasten inserts to forms and install reinforcing bars through openings at top of inserts.
- I. Load Distribution: Install hangers and supports so that piping live and dead loads and stresses from movement will not be transmitted to connected equipment.
- J. Pipe Slopes: Install hangers and supports to provide indicated pipe slopes and to not exceed maximum pipe deflections allowed by ASME B31.9 for building services piping.

### **3.02 EQUIPMENT SUPPORTS**

- A. Fabricate structural-steel stands to suspend equipment from structure overhead or to support equipment above floor.
- B. Grouting: Place grout under supports for equipment and make bearing surface smooth.
- C. Provide lateral bracing, to prevent swaying, for equipment supports.

### **3.03 METAL FABRICATIONS**

- A. Cut, drill, and fit miscellaneous metal fabrications for trapeze pipe hangers and equipment supports.
- B. Fit exposed connections together to form hairline joints. Field weld connections that cannot be shop welded because of shipping size limitations.
- C. Field Welding: Comply with AWS D1.1/D1.1M procedures for shielded, metal arc welding; appearance and quality of welds; and methods used in correcting welding work; and with the following:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. Finish welds at exposed connections so no roughness shows after finishing and so contours of welded surfaces match adjacent contours.

### **3.04 ADJUSTING**

- A. Hanger Adjustments: Adjust hangers to distribute loads equally on attachments and to achieve indicated slope of pipe.
- B. Trim excess length of continuous-thread hanger and support rods to 1-1/2 inches.

### **3.05 PAINTING**

- A. Touchup: Clean field welds and abraded areas of shop paint. Paint exposed areas immediately after erecting hangers and supports. Use same materials as used for shop painting. Comply with SSPC-PA 1 requirements for touching up field-painted surfaces.
  - 1. Apply paint by brush or spray to provide a minimum dry film thickness of 2.0 mils.
- B. Galvanized Surfaces: Clean welds, bolted connections, and abraded areas and apply galvanizing-repair paint to comply with ASTM A 780.

### 3.06 HANGER AND SUPPORT SCHEDULE

- A. Specific hanger and support requirements are in Sections specifying piping systems and equipment.
- B. Comply with MSS SP-58 for pipe-hanger selections and applications that are not specified in piping system Sections.
- C. Use hangers and supports with galvanized metallic coatings for piping and equipment that will not have field-applied finish.
- D. Use nonmetallic coatings on attachments for electrolytic protection where attachments are in direct contact with copper tubing.
- E. Use carbon-steel pipe hangers and supports metal trapeze pipe hangers and metal framing systems and attachments for general service applications.
- F. Use copper-plated pipe hangers and stainless-steel attachments for copper piping and tubing.
- G. Use padded hangers for piping that is subject to scratching.
- H. Horizontal-Piping Hangers and Supports: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Adjustable, Steel Clevis Hangers (MSS Type 1): For suspension of noninsulated or insulated, stationary pipes NPS 1/2 to NPS 30.
  - 2. Yoke-Type Pipe Clamps (MSS Type 2): For suspension of up to 1050 deg F, pipes NPS 4 to NPS 24, requiring up to 4 inches of insulation.
  - 3. Carbon- or Alloy-Steel, Double-Bolt Pipe Clamps (MSS Type 3): For suspension of pipes NPS 3/4 to NPS 36, requiring clamp flexibility and up to 4 inches of insulation.
  - 4. Steel Pipe Clamps (MSS Type 4): For suspension of cold and hot pipes NPS 1/2 to NPS 24 if little or no insulation is required.
  - 5. Pipe Hangers (MSS Type 5): For suspension of pipes NPS 1/2 to NPS 4, to allow off-center closure for hanger installation before pipe erection.
  - 6. Adjustable, Swivel Split- or Solid-Ring Hangers (MSS Type 6): For suspension of noninsulated, stationary pipes NPS 3/4 to NPS 8.
  - 7. Adjustable, Steel Band Hangers (MSS Type 7): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
  - 8. Adjustable Band Hangers (MSS Type 9): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
  - 9. Adjustable, Swivel-Ring Band Hangers (MSS Type 10): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
  - 10. Split Pipe Ring with or without Turnbuckle Hangers (MSS Type 11): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 8.
  - 11. Extension Hinged or Two-Bolt Split Pipe Clamps (MSS Type 12): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 3.
  - 12. U-Bolts (MSS Type 24): For support of heavy pipes NPS 1/2 to NPS 30.
  - 13. Clips (MSS Type 26): For support of insulated pipes not subject to expansion or contraction.

14. Pipe Saddle Supports (MSS Type 36): For support of pipes NPS 4 to NPS 36, with steel-pipe base stanchion support and cast-iron floor flange or carbon-steel plate.
  15. Pipe Stanchion Saddles (MSS Type 37): For support of pipes NPS 4 to NPS 36, with steel-pipe base stanchion support and cast-iron floor flange or carbon-steel plate, and with U-bolt to retain pipe.
  16. Adjustable Pipe Saddle Supports (MSS Type 38): For stanchion-type support for pipes NPS 2-1/2 to NPS 36 if vertical adjustment is required, with steel-pipe base stanchion support and cast-iron floor flange.
  17. Single-Pipe Rolls (MSS Type 41): For suspension of pipes NPS 1 to NPS 30, from two rods if longitudinal movement caused by expansion and contraction might occur.
  18. Adjustable Roller Hangers (MSS Type 43): For suspension of pipes NPS 2-1/2 to NPS 24, from single rod if horizontal movement caused by expansion and contraction might occur.
  19. Complete Pipe Rolls (MSS Type 44): For support of pipes NPS 2 to NPS 42 if longitudinal movement caused by expansion and contraction might occur but vertical adjustment is not necessary.
  20. Pipe Roll and Plate Units (MSS Type 45): For support of pipes NPS 2 to NPS 24 if small horizontal movement caused by expansion and contraction might occur and vertical adjustment is not necessary.
  21. Adjustable Pipe Roll and Base Units (MSS Type 46): For support of pipes NPS 2 to NPS 30 if vertical and lateral adjustment during installation might be required in addition to expansion and contraction.
- I. Vertical-Piping Clamps: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Extension Pipe or Riser Clamps (MSS Type 8): For support of pipe risers NPS 3/4 to NPS 24.
  2. Carbon- or Alloy-Steel Riser Clamps (MSS Type 42): For support of pipe risers NPS 3/4 to NPS 24 if longer ends are required for riser clamps.
- J. Hanger-Rod Attachments: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Steel Turnbuckles (MSS Type 13): For adjustment up to 6 inches for heavy loads.
  2. Steel Clevises (MSS Type 14): For 120 to 450 deg F piping installations.
  3. Swivel Turnbuckles (MSS Type 15): For use with MSS Type 11, split pipe rings.
  4. Malleable-Iron Sockets (MSS Type 16): For attaching hanger rods to various types of building attachments.
  5. Steel Weldless Eye Nuts (MSS Type 17): For 120 to 450 deg F piping installations.
- K. Building Attachments: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Steel or Malleable Concrete Inserts (MSS Type 18): For upper attachment to suspend pipe hangers from concrete ceiling.
  2. Top-Beam C-Clamps (MSS Type 19): For use under roof installations with bar-joist construction, to attach to top flange of structural shape.

3. Side-Beam or Channel Clamps (MSS Type 20): For attaching to bottom flange of beams, channels, or angles.
  4. Center-Beam Clamps (MSS Type 21): For attaching to center of bottom flange of beams.
  5. Welded Beam Attachments (MSS Type 22): For attaching to bottom of beams if loads are considerable and rod sizes are large.
  6. C-Clamps (MSS Type 23): For structural shapes.
  7. Top-Beam Clamps (MSS Type 25): For top of beams if hanger rod is required tangent to flange edge.
  8. Side-Beam Clamps (MSS Type 27): For bottom of steel I-beams.
  9. Steel-Beam Clamps with Eye Nuts (MSS Type 28): For attaching to bottom of steel I-beams for heavy loads.
  10. Linked-Steel Clamps with Eye Nuts (MSS Type 29): For attaching to bottom of steel I-beams for heavy loads, with link extensions.
  11. Malleable-Beam Clamps with Extension Pieces (MSS Type 30): For attaching to structural steel.
  12. Welded-Steel Brackets: For support of pipes from below or for suspending from above by using clip and rod. Use one of the following for indicated loads:
    - a. Light (MSS Type 31): 750 lb.
    - b. Medium (MSS Type 32): 1500 lb.
    - c. Heavy (MSS Type 33): 3000 lb.
  13. Side-Beam Brackets (MSS Type 34): For sides of steel or wooden beams.
  14. Plate Lugs (MSS Type 57): For attaching to steel beams if flexibility at beam is required.
  15. Horizontal Travelers (MSS Type 58): For supporting piping systems subject to linear horizontal movement where headroom is limited.
- L. Saddles and Shields: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Steel-Pipe-Covering Protection Saddles (MSS Type 39): To fill interior voids with insulation that matches adjoining insulation.
  2. Protection Shields (MSS Type 40): Of length recommended in writing by manufacturer to prevent crushing insulation.
  3. Thermal-Hanger Shield Inserts: For supporting insulated pipe.
- M. Spring Hangers and Supports: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Restraint-Control Devices (MSS Type 47): Where indicated to control piping movement.
  2. Spring Cushions (MSS Type 48): For light loads if vertical movement does not exceed 1-1/4 inches.
  3. Spring-Cushion Roll Hangers (MSS Type 49): For equipping Type 41, roll hanger with springs.
  4. Spring Sway Braces (MSS Type 50): To retard sway, shock, vibration, or thermal expansion in piping systems.



5. Variable-Spring Hangers (MSS Type 51): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from hanger.
6. Variable-Spring Base Supports (MSS Type 52): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from base support.
7. Variable-Spring Trapeze Hangers (MSS Type 53): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from trapeze support.
8. Constant Supports: For critical piping stress and if necessary to avoid transfer of stress from one support to another support, critical terminal, or connected equipment. Include auxiliary stops for erection, hydrostatic test, and load-adjustment capability. These supports include the following types:
  - a. Horizontal (MSS Type 54): Mounted horizontally.
  - b. Vertical (MSS Type 55): Mounted vertically.
- N. Comply with MFMA-103 for metal framing system selections and applications that are not specified in piping system Sections.
- O. Use mechanical-expansion anchors instead of building attachments where required in concrete construction.

END OF SECTION

**SECTION 230548**  
**VIBRATION AND SEISMIC CONTROLS FOR HVAC**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Open-spring isolators.
  - 2. Housed-spring isolators.
  - 3. Housed-restrained-spring isolators.
  - 4. Pipe-riser resilient supports.
  - 5. Resilient pipe guides.
  - 6. Spring hangers.
  - 7. Snubbers.
  - 8. Restraint channel bracings.
  - 9. Restraint cables.
  - 10. Seismic-restraint accessories.
  - 11. Mechanical anchor bolts.
  - 12. Vibration isolation equipment bases.
- B. Related Requirements:
  - 1. Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment" for devices for plumbing equipment and systems.

**1.02 DEFINITIONS**

- A. OSHPD: Office of Statewide Health Planning & Development (for the State of California).

**1.03 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
  - 1. Include rated load, rated deflection, and overload capacity for each vibration isolation device.
  - 2. Illustrate and indicate style, material, strength, fastening provision, and finish for each type and size of vibration isolation device and seismic-restraint component required.
    - a. Tabulate types and sizes of seismic restraints, complete with report numbers and rated strength in tension and shear as evaluated by OSHPD.
    - b. Annotate to indicate application of each product submitted and compliance with requirements.
  - 3. Interlocking Snubbers: Include ratings for horizontal, vertical, and combined loads.
- B. Shop Drawings:

1. Detail fabrication and assembly of equipment bases. Detail fabrication including anchorages and attachments to structure and to supported equipment. Include adjustable motor bases, rails, and frames for equipment mounting.
  2. Vibration Isolation Base Details: Detail fabrication including anchorages and attachments to structure and to supported equipment. Include adjustable motor bases, rails, and frames for equipment mounting.
- C. Delegated-Design Submittal: For each vibration isolation and seismic-restraint device.
1. Calculations performed for use in selection of seismic supports, anchorages, and restraints shall utilize criteria indicated in Structural Contract Documents.
  2. Supports, anchorage and restraints for piping, ductwork, and equipment shall be an OSHPD pre-approved system such as Tolco, ISAT, Mason, or equal. Pipes, ducts and equipment shall be seismically restrained in accordance with requirements of current edition of California Building Code. System shall have current OPM number and shall meet additional requirements of authority having jurisdiction. Provide supporting documentation required by the reviewing authority and the Architect and Engineer. Provide layout drawings showing piping, ductwork and restraint locations.
    - a. Bracing of Piping and Equipment: Specifically state how bracing attachment to structure is accomplished. Provide shop drawings indicating seismic restraints, including details of anchorage to building. In-line equipment must be braced independently of piping, and in conformance with applicable building codes. Provide calculations to show that pre-approval numbers have been correctly applied in accordance with general information notes of pre-approval documentation.
  3. In lieu of the above or for non-standard installations not covered in the above pre-approved systems, Contractor shall provide layout drawings showing piping, ductwork, and restraint locations, and detail supports, attachments and restraints, and furnish supporting calculations and legible details sealed by a California registered structural engineer, in accordance with 2016 California Building Code
  4. Additional Requirements: In addition to the above, conform to all state and local requirements.

#### **1.04 INFORMATIONAL SUBMITTALS**

- A. Coordination Drawings: Show coordination of vibration isolation device installation and seismic bracing for HVAC piping and equipment with other systems and equipment in the vicinity, including other supports and restraints, if any. Refer to Section 23 00 50, "Common Work Results for HVAC Systems for additional requirements.
- B. Qualification Data: For professional engineer and testing agency.
- C. Welding certificates.
- D. Field quality-control reports.

#### **1.05 QUALITY ASSURANCE**

- A. Testing Agency Qualifications: An independent agency, with the experience and capability to conduct the testing indicated, that is an NRTL as defined by OSHA in 29 CFR 1910.7 and that is acceptable to authorities having jurisdiction.

- B. Comply with seismic-restraint requirements in the CBC unless requirements in this Section are more stringent.
- C. Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code - Steel."
- D. Seismic-restraint devices shall have horizontal and vertical load testing and analysis and shall bear anchorage preapproval OPM number from OSHPD showing maximum seismic-restraint ratings. For additional requirements, refer to article, Action Submittals.

## **PART 2 - PRODUCTS**

### **2.01 PERFORMANCE REQUIREMENTS**

- A. See structural documents for wind and seismic restraint loads.
- B. Rated strengths, features, and applications shall be as defined in reports by OSHPD or provide calculations, signed and sealed by a qualified structural engineer registered in the State of California.

### **2.02 OPEN-SPRING ISOLATORS**

- A. Freestanding, Laterally Stable, Open-Spring Isolators: .
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Kinetics Noise Control, Inc.
    - b. Mason Industries, Inc.
    - c. Vibration Isolation.
    - d. Vibration Mountings & Controls, Inc.
  - 2. Outside Spring Diameter: Not less than 80 percent of the compressed height of the spring at rated load.
  - 3. Minimum Additional Travel: 50 percent of the required deflection at rated load.
  - 4. Lateral Stiffness: More than 80 percent of rated vertical stiffness.
  - 5. Overload Capacity: Support 200 percent of rated load, fully compressed, without deformation or failure.
  - 6. Baseplates: Factory-drilled steel plate for bolting to structure with an elastomeric isolator pad attached to the underside. Baseplates shall limit floor load to 500 psig.
  - 7. Top Plate and Adjustment Bolt: Threaded top plate with adjustment bolt and cap screw to fasten and level equipment.

### **2.03 HOUSED-SPRING ISOLATORS**

- A. Freestanding, Laterally Stable, Open-Spring Isolators in Two-Part Telescoping Housing: .
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Kinetics Noise Control, Inc.

- b. Mason Industries, Inc.
  - c. Vibration Isolation.
  - d. Vibration Mountings & Controls, Inc.
2. Outside Spring Diameter: Not less than 80 percent of the compressed height of the spring at rated load.
  3. Minimum Additional Travel: 50 percent of the required deflection at rated load.
  4. Lateral Stiffness: More than 80 percent of rated vertical stiffness.
  5. Overload Capacity: Support 200 percent of rated load, fully compressed, without deformation or failure.
  6. Two-Part Telescoping Housing: A steel top and bottom frame separated by an elastomeric material and enclosing the spring isolators.
    - a. Drilled base housing for bolting to structure with an elastomeric isolator pad attached to the underside. Bases shall limit floor load to 500 psig.
    - b. Top housing with attachment and leveling bolt.

#### **2.04 HOUSED-RESTRAINED-SPRING ISOLATORS**

- A. Freestanding, Steel, Open-Spring Isolators with Vertical-Limit Stop Restraint in Two-Part Telescoping Housing: .
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Ace Mountings Co., Inc.
    - b. California Dynamics Corporation.
    - c. Isolation Technology, Inc.
    - d. Kinetics Noise Control, Inc.
    - e. Mason Industries, Inc.
    - f. Vibration Eliminator Co., Inc.
    - g. Vibration Isolation.
    - h. Vibration Mountings & Controls, Inc.
  2. Two-Part Telescoping Housing: A steel top and bottom frame separated by an elastomeric material and enclosing the spring isolators. Housings are equipped with adjustable snubbers to limit vertical movement.
    - a. Drilled base housing for bolting to structure with an elastomeric isolator pad attached to the underside. Bases shall limit floor load to 500 psig.
    - b. Threaded top housing with adjustment bolt and cap screw to fasten and level equipment.
  3. Outside Spring Diameter: Not less than 80 percent of the compressed height of the spring at rated load.
  4. Minimum Additional Travel: 50 percent of the required deflection at rated load.
  5. Lateral Stiffness: More than 80 percent of rated vertical stiffness.

6. Overload Capacity: Support 200 percent of rated load, fully compressed, without deformation or failure.

## **2.05 PIPE-RISER RESILIENT SUPPORT**

- A. Description: All-directional, acoustical pipe anchor consisting of two steel tubes separated by a minimum 1/2-inch-thick neoprene.
  1. Vertical-Limit Stops: Steel and neoprene vertical-limit stops arranged to prevent vertical travel in both directions.
  2. Maximum Load Per Support: 500 psigon isolation material providing equal isolation in all directions.

## **2.06 RESILIENT PIPE GUIDES**

- A. Description: Telescopic arrangement of two steel tubes or post and sleeve arrangement separated by a minimum 1/2-inch-thick neoprene.
  1. Factory-Set Height Guide with Shear Pin: Shear pin shall be removable and reinsertable to allow for selection of pipe movement. Guides shall be capable of motion to meet location requirements.

## **2.07 SPRING HANGERS**

- A. Combination Coil-Spring and Elastomeric-Insert Hanger with Spring and Insert in Compression:
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Kinetics Noise Control, Inc.
    - b. Mason Industries, Inc.
    - c. Vibration Isolation.
    - d. Vibration Mountings & Controls, Inc.
  2. Frame: Steel, fabricated for connection to threaded hanger rods and to allow for a maximum of 30 degrees of angular hanger-rod misalignment without binding or reducing isolation efficiency.
  3. Outside Spring Diameter: Not less than 80 percent of the compressed height of the spring at rated load.
  4. Minimum Additional Travel: 50 percent of the required deflection at rated load.
  5. Lateral Stiffness: More than 80 percent of rated vertical stiffness.
  6. Overload Capacity: Support 200 percent of rated load, fully compressed, without deformation or failure.
  7. Elastomeric Element: Molded, oil-resistant rubber or neoprene. Steel-washer-reinforced cup to support spring and bushing projecting through bottom of frame.
  8. Adjustable Vertical Stop: Steel washer with neoprene washer "up-stop" on lower threaded rod.
  9. Self-centering hanger-rod cap to ensure concentricity between hanger rod and support spring coil.

## **2.08 SNUBBERS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Kinetics Noise Control, Inc.
  - 2. Mason Industries, Inc.
  - 3. Novia; A Division of C&P.
  - 4. Vibration Mountings & Controls, Inc.
- B. Description: Factory fabricated using welded structural-steel shapes and plates, anchor bolts, and replaceable resilient isolation washers and bushings.
  - 1. Anchor bolts for attaching to concrete shall be seismic-rated, drill-in, and stud-wedge or female-wedge type.
  - 2. Resilient Isolation Washers and Bushings: Oil- and water-resistant neoprene.
  - 3. Maximum 1/4-inch air gap, and minimum 1/4-inch-thick resilient cushion.

## **2.09 RESTRAINT CHANNEL BRACINGS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. B-line, an Eaton business.
  - 2. Hilti, Inc.
  - 3. Mason Industries, Inc.
  - 4. Unistrut; Part of Atkore International.
- B. Description: MFMA-4, shop- or field-fabricated bracing assembly made of slotted steel channels with accessories for attachment to braced component at one end and to building structure at the other end and other matching components and with corrosion-resistant coating; rated in tension, compression, and torsion forces.

## **2.10 RESTRAINT CABLES**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Kinetics Noise Control, Inc.
  - 2. Mason Industries, Inc.
  - 3. Vibration Mountings & Controls, Inc.
- B. Restraint Cables: ASTM A 603 galvanized-steel cables. End connections made of steel assemblies with thimbles, brackets, swivel, and bolts designed for restraining cable service; with a minimum of two clamping bolts for cable engagement.

## **2.11 SEISMIC-RESTRAINT ACCESSORIES**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. B-line, an Eaton business.
  - 2. Kinetics Noise Control, Inc.

3. Mason Industries, Inc.
  4. TOLCO.
- B. Hanger-Rod Stiffener: Steel tube or steel slotted-support-system sleeve with internally bolted connections or reinforcing steel angle clamped to hanger rod.
  - C. Hinged and Swivel Brace Attachments: Multifunctional steel connectors for attaching hangers to rigid channel bracings and restraint cables.
  - D. Bushings for Floor-Mounted Equipment Anchor Bolts: Neoprene bushings designed for rigid equipment mountings, and matched to type and size of anchor bolts and studs.
  - E. Bushing Assemblies for Wall-Mounted Equipment Anchorage: Assemblies of neoprene elements and steel sleeves designed for rigid equipment mountings, and matched to type and size of attachment devices used.
  - F. Resilient Isolation Washers and Bushings: One-piece, molded, oil- and water-resistant neoprene, with a flat washer face.

## **2.12 MECHANICAL ANCHOR BOLTS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. B-line, an Eaton business.
  2. Hilti, Inc.
  3. Kinetics Noise Control, Inc.
  4. Mason Industries, Inc.
- B. Mechanical Anchor Bolts: Drilled-in and stud-wedge or female-wedge type in zinc-coated steel for interior applications and stainless steel for exterior applications. Select anchor bolts with strength required for anchor and as tested according to ASTM E 488.

## **2.13 VIBRATION ISOLATION EQUIPMENT BASES**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. California Dynamics Corporation.
  2. Kinetics Noise Control, Inc.
  3. Mason Industries, Inc.
  4. Novia; A Division of C&P.
  5. Vibration Eliminator Co., Inc.
  6. Vibration Isolation.
  7. Vibration Mountings & Controls, Inc.
- B. Steel Rails: Factory-fabricated, welded, structural-steel rails.
  1. Design Requirements: Lowest possible mounting height with not less than 1-inch clearance above the floor. Include equipment anchor bolts and auxiliary motor slide rails.
    - a. Include supports for suction and discharge elbows for pumps.
  2. Structural Steel: Steel shapes, plates, and bars complying with ASTM A 36/A 36M. Rails shall have shape to accommodate supported equipment.



3. Support Brackets: Factory-welded steel brackets on frame for outrigger isolation mountings and to provide for anchor bolts and equipment support.
- C. Steel Bases: Factory-fabricated, welded, structural-steel bases and rails.
1. Design Requirements: Lowest possible mounting height with not less than 1-inch clearance above the floor. Include equipment anchor bolts and auxiliary motor slide bases or rails.
    - a. Include supports for suction and discharge elbows for pumps.
  2. Structural Steel: Steel shapes, plates, and bars complying with ASTM A 36/A 36M. Bases shall have shape to accommodate supported equipment.
  3. Support Brackets: Factory-welded steel brackets on frame for outrigger isolation mountings and to provide for anchor bolts and equipment support.
- D. Concrete Inertia Base: Factory-fabricated, welded, structural-steel bases and rails ready for placement of cast-in-place concrete.
1. Design Requirements: Lowest possible mounting height with not less than 1-inch clearance above the floor. Include equipment anchor bolts and auxiliary motor slide bases or rails.
    - a. Include supports for suction and discharge elbows for pumps.
  2. Structural Steel: Steel shapes, plates, and bars complying with ASTM A 36/A 36M. Bases shall have shape to accommodate supported equipment.
  3. Support Brackets: Factory-welded steel brackets on frame for outrigger isolation mountings and to provide for anchor bolts and equipment support.
  4. Fabrication: Fabricate steel templates to hold equipment anchor-bolt sleeves and anchors in place during placement of concrete. Obtain anchor-bolt templates from supported equipment manufacturer.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine areas and equipment to receive vibration isolation and seismic- and wind-control devices for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine roughing-in of reinforcement and cast-in-place anchors to verify actual locations before installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 APPLICATIONS**

- A. Multiple Pipe Supports: Secure pipes to trapeze member with clamps approved for application by OSHPD.
- B. Hanger-Rod Stiffeners: Install hanger-rod stiffeners where indicated or scheduled on Drawings to receive them and where required to prevent buckling of hanger rods due to seismic forces.
- C. Strength of Support and Seismic-Restraint Assemblies: Where not indicated, select sizes of components so strength is adequate to carry present and future static and seismic loads within specified loading limits.

### 3.03 VIBRATION CONTROL AND SEISMIC-RESTRAINT DEVICE INSTALLATION

- A. Coordinate the location of embedded connection hardware with supported equipment attachment and mounting points and with requirements for concrete reinforcement and formwork specified in Section 033000 "Cast-in-Place Concrete."
- B. Installation of vibration isolators must not cause any change of position of equipment, piping, or ductwork resulting in stresses or misalignment.
- C. Comply with requirements in Section 077200 "Roof Accessories" for installation of roof curbs, equipment supports, and roof penetrations.
- D. Equipment Restraints:
  - 1. Install seismic snubbers on HVAC equipment mounted on vibration isolators. Locate snubbers as close as possible to vibration isolators and bolt to equipment base and supporting structure.
  - 2. Install resilient bolt isolation washers on equipment anchor bolts where clearance between anchor and adjacent surface exceeds 0.125 inch.
  - 3. Install seismic-restraint devices using methods approved by OSHPD that provides required submittals for component.
- E. Piping Restraints:
  - 1. Comply with requirements in MSS SP-127.
  - 2. Space lateral supports a maximum of 40 feet o.c., and longitudinal supports a maximum of 80 feet o.c.
  - 3. Brace a change of direction longer than 12 feet.
- F. Install cables so they do not bend across edges of adjacent equipment or building structure.
- G. Install seismic-restraint devices using methods approved by OSHPD that provides required submittals for component.
- H. Install bushing assemblies for anchor bolts for floor-mounted equipment, arranged to provide resilient media between anchor bolt and mounting hole in concrete base.
- I. Install bushing assemblies for mounting bolts for wall-mounted equipment, arranged to provide resilient media where equipment or equipment-mounting channels are attached to wall.
- J. Attachment to Structure: If specific attachment is not indicated, anchor bracing to structure at flanges of beams, at upper truss chords of bar joists, or at concrete members.
- K. Drilled-in Anchors:
  - 1. Identify position of reinforcing steel and other embedded items prior to drilling holes for anchors. Do not damage existing reinforcing or embedded items during coring or drilling. Notify the structural engineer if reinforcing steel or other embedded items are encountered during drilling. Locate and avoid prestressed tendons, electrical and telecommunications conduit, and gas lines.
  - 2. Do not drill holes in concrete or masonry until concrete, mortar, or grout has achieved full design strength.
  - 3. Wedge Anchors: Protect threads from damage during anchor installation. Heavy-duty sleeve anchors shall be installed with sleeve fully engaged in the structural element to which anchor is to be fastened.

4. Set anchors to manufacturer's recommended torque, using a torque wrench.
5. Install zinc-coated steel anchors for interior and stainless-steel anchors for exterior applications.

### **3.04 ACCOMMODATION OF DIFFERENTIAL SEISMIC MOTION**

- A. Install flexible connections in piping where they cross seismic joints, where adjacent sections or branches are supported by different structural elements, and where the connections terminate with connection to equipment that is anchored to a different structural element from the one supporting the connections as they approach equipment. Comply with requirements in Section 232113 "Hydronic Piping" for piping flexible connections.

### **3.05 FIELD QUALITY CONTROL**

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Perform tests and inspections.
- C. Tests and Inspections:
  1. Provide evidence of recent calibration of test equipment by a testing agency acceptable to authorities having jurisdiction.
  2. Schedule test with Owner, through Architect, before connecting anchorage device to restrained component (unless postconnection testing has been approved), and with at least seven days' advance notice.
  3. Obtain Architect's approval before transmitting test loads to structure. Provide temporary load-spreading members.
  4. Test at least four of each type and size of installed anchors and fasteners selected by Architect.
  5. Test to 90 percent of rated proof load of device.
  6. Measure isolator restraint clearance.
  7. Measure isolator deflection.
  8. Verify snubber minimum clearances.
- D. Remove and replace malfunctioning units and retest as specified above.
- E. Prepare test and inspection reports.

### **3.06 ADJUSTING**

- A. Adjust isolators after piping system is at operating weight.
- B. Adjust limit stops on restrained-spring isolators to mount equipment at normal operating height. After equipment installation is complete, adjust limit stops so they are out of contact during normal operation.

### **3.07 VIBRATION ISOLATION EQUIPMENT BASES INSTALLATION**

- A. Coordinate the location of embedded connection hardware with supported equipment attachment and mounting points and with requirements for concrete reinforcement and formwork specified in Section 033000 "Cast-in-Place Concrete."

END OF SECTION



**SECTION 23 05 53**  
**IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Equipment labels.
  - 2. Warning signs and labels.
  - 3. Pipe labels.
  - 4. Duct labels.
  - 5. Stencils.
  - 6. Valve tags.
  - 7. Warning tags.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
- B. Samples: For color, letter style, and graphic representation required for each identification material and device.
- C. Equipment Label Schedule: Include a listing of all equipment to be labeled with the proposed content for each label.
- D. Valve numbering scheme.
- E. Valve Schedules: For each piping system to include in maintenance manuals.

**PART 2 - PRODUCTS**

**2.01 EQUIPMENT LABELS**

- A. Metal Labels for Equipment:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Brimar Industries, Inc.
    - b. Craftmark Pipe Markers.
    - c. Marking Services, Inc.
    - d. Seton Identification Products.
  - 2. Material and Thickness: Brass, 0.032-inch minimum thickness, and having predrilled or stamped holes for attachment hardware.
  - 3. Letter Color: White.
  - 4. Background Color: Black.

5. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
  6. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-quarters the size of principal lettering.
  7. Fasteners: Stainless-steel rivets or self-tapping screws.
  8. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- B. Plastic Labels for Equipment:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Brimar Industries, Inc.
    - b. Craftmark Pipe Markers.
    - c. Marking Services, Inc.
    - d. Seton Identification Products.
  2. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, and having predrilled holes for attachment hardware.
  3. Letter Color: White.
  4. Background Color: Black.
  5. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
  6. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
  7. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-quarters the size of principal lettering.
  8. Fasteners: Stainless-steel rivets or self-tapping screws.
  9. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- C. Label Content: Include equipment's Drawing designation or unique equipment number, Drawing numbers where equipment is indicated (plans, details, and schedules), and the Specification Section number and title where equipment is specified.
- D. Equipment Label Schedule: For each item of equipment to be labeled, on 8-1/2-by-11-inch bond paper. Tabulate equipment identification number, and identify Drawing numbers where equipment is indicated (plans, details, and schedules) and the Specification Section number and title where equipment is specified. Equipment schedule shall be included in operation and maintenance data.

## 2.02 WARNING SIGNS AND LABELS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
1. Brimar Industries, Inc.

2. Craftmark Pipe Markers.
  3. Marking Services Inc.
  4. National Marker Company.
  5. Seton Identification Products.
  6. Stranco, Inc.
- B. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, and having predrilled holes for attachment hardware.
  - C. Letter Color: Red.
  - D. Background Color: Yellow.
  - E. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
  - F. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
  - G. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-quarters the size of principal lettering.
  - H. Fasteners: Stainless-steel rivets or self-tapping screws.
  - I. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
  - J. Label Content: Include caution and warning information plus emergency notification instructions.

### **2.03 PIPE LABELS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. Brimar Industries, Inc.
  2. Craftmark Pipe Markers.
  3. Marking Services Inc.
  4. Seton Identification Products.
- B. General Requirements for Manufactured Pipe Labels: Preprinted, color-coded, with lettering indicating service, and showing flow direction according to ASME A13.1.
- C. Pretensioned Pipe Labels: Precoiled, semirigid plastic formed to cover full circumference of pipe and to attach to pipe without fasteners or adhesive.
- D. Self-Adhesive Pipe Labels: Printed plastic with contact-type, permanent-adhesive backing.
- E. Pipe Label Contents: Include identification of piping service using same designations or abbreviations as used on Drawings; also include pipe size and an arrow indicating flow direction.
  1. Flow-Direction Arrows: Integral with piping system service lettering to accommodate both directions or as separate unit on each pipe label to indicate flow direction.
  2. Lettering Size: At least 1/2 inch for viewing distances up to 72 inches and proportionately larger lettering for greater viewing distances.



## 2.04 DUCT LABELS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Brady Corporation.
  - 2. Brimar Industries, Inc.
  - 3. Carlton Industries, LP.
  - 4. Champion America.
  - 5. Craftmark Pipe Markers.
  - 6. emedco.
  - 7. Kolbi Pipe Marker Co.
  - 8. LEM Products Inc.
  - 9. Marking Sevices Inc.
  - 10. Seton Identification Products.
- B. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, and having predrilled holes for attachment hardware.
- C. Letter Color: Black.
- D. Background Color: White.
- E. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
- F. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
- G. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-quarters the size of principal lettering.
- H. Fasteners: Stainless-steel rivets or self-tapping screws.
- I. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- J. Duct Label Contents: Include identification of duct service using same designations or abbreviations as used on Drawings; also include duct size and an arrow indicating flow direction.
  - 1. Flow-Direction Arrows: Integral with duct system service lettering to accommodate both directions or as separate unit on each duct label to indicate flow direction.

## 2.05 STENCILS

- A. Stencils for Access Panels and Door Labels, Equipment Labels, and Similar Operational Instructions:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Brimar Industries, Inc.
    - b. Carlton Industries, LP.

- c. Champion America.
  - d. Craftmark Pipe Markers.
  - e. Kolbi Pipe Marker Co.
  - f. Marking Sevices Inc.
2. Lettering Size: At least 1/2 inch for viewing distances up to 72 inches and proportionately larger lettering for greater viewing distances.
  3. Stencil Material: Aluminum.
  4. Stencil Paint: Exterior, gloss, acrylic enamel in colors complying with recommendations in ASME A13.1 unless otherwise indicated. Paint may be in pressurized spray-can form.
  5. Identification Paint: Exterior, acrylic enamel in colors according to ASME A13.1 unless otherwise indicated. Paint may be in pressurized spray-can form.

## **2.06 VALVE TAGS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. Brimar Industries, Inc.
  2. Craftmark Pipe Markers.
  3. Marking Sevices Inc.
  4. Seton Identification Products.
- B. Description: Stamped or engraved with 1/4-inch letters for piping system abbreviation and 1/2-inch numbers.
  1. Tag Material: Brass, 0.032-inch minimum thickness, and having predrilled or stamped holes for attachment hardware.
  2. Fasteners: Brass wire-link chain or beaded chain.
- C. Valve Schedules: For each piping system, on 8-1/2-by-11-inch bond paper. Tabulate valve number, piping system, system abbreviation (as shown on valve tag), location of valve (room or space), normal-operating position (open, closed, or modulating), and variations for identification. Mark valves for emergency shutoff and similar special uses.
  1. Valve-tag schedule shall be included in operation and maintenance data.

## **2.07 WARNING TAGS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  1. Brimar Industries, Inc.
  2. Craftmark Pipe Markers.
  3. Marking Sevices Inc.
  4. Seton Identification Products.
- B. Description: Preprinted or partially preprinted accident-prevention tags of plasticized card stock with matte finish suitable for writing.
  1. Size: 3 by 5-1/4 inches minimum.
  2. Fasteners: Brass grommet and wire.

3. Nomenclature: Large-size primary caption such as "DANGER," "CAUTION," or "DO NOT OPERATE."
4. Color: Safety-yellow background with black lettering.

### **PART 3 - EXECUTION**

#### **3.01 PREPARATION**

- A. Clean piping and equipment surfaces of substances that could impair bond of identification devices, including dirt, oil, grease, release agents, and incompatible primers, paints, and encapsulants.

#### **3.02 GENERAL INSTALLATION REQUIREMENTS**

- A. Coordinate installation of identifying devices with completion of covering and painting of surfaces where devices are to be applied.
- B. Coordinate installation of identifying devices with locations of access panels and doors.
- C. Install identifying devices before installing acoustical ceilings and similar concealment.

#### **3.03 EQUIPMENT LABEL INSTALLATION**

- A. Install or permanently fasten labels on each major item of mechanical equipment.
- B. Locate equipment labels where accessible and visible.

#### **3.04 PIPE LABEL INSTALLATION**

- A. Piping Color Coding: Painting of piping is specified in Section 099123 "Interior Painting" and Section 099600 "High-Performance Coatings."
- B. Pipe Label Locations: Locate pipe labels where piping is exposed or above accessible ceilings in finished spaces; machine rooms; accessible maintenance spaces such as shafts, tunnels, and plenums; and exterior exposed locations as follows:
  1. Near each valve and control device.
  2. Near each branch connection, excluding short takeoffs for fixtures and terminal units. Where flow pattern is not obvious, mark each pipe at branch.
  3. Near penetrations and on both sides of through walls, floors, ceilings, and inaccessible enclosures.
  4. At access doors, manholes, and similar access points that permit view of concealed piping.
  5. Near major equipment items and other points of origination and termination.
  6. Spaced at maximum intervals of 50 feet along each run. Reduce intervals to 25 feet in areas of congested piping and equipment.
  7. On piping above removable acoustical ceilings. Omit intermediately spaced labels.
- C. Directional Flow Arrows: Arrows shall be used to indicate direction of flow in pipes, including pipes where flow is allowed in both directions.
- D. Pipe Label Color Schedule:
  1. Chilled-Water Piping: White letters on a safety-green background.

2. Heating Water Piping: White letters on a safety-green background.
3. Refrigerant Piping: Black letters on a safety-orange background.

### **3.05 DUCT LABEL INSTALLATION**

- A. Install plastic-laminated duct labels with permanent adhesive on air ducts in the following color codes:
  1. Blue: For cold-air supply ducts.
  2. Yellow: For hot-air supply ducts.
  3. Green: For exhaust-, outside-, relief-, return-, and mixed-air ducts.
- B. Locate labels near points where ducts enter into and exit from concealed spaces and at maximum intervals of 50 feet in each space where ducts are exposed or concealed by removable ceiling system.

### **3.06 VALVE-TAG INSTALLATION**

- A. Install tags on valves and control devices in piping systems, except check valves, valves within factory-fabricated equipment units, shutoff valves, faucets, convenience and lawn-watering hose connections, and HVAC terminal devices and similar roughing-in connections of end-use fixtures and units. List tagged valves in a valve schedule.
- B. Valve-Tag Application Schedule: Tag valves according to size, shape, and color scheme and with captions similar to those indicated in the following subparagraphs:
  1. Valve-Tag Size and Shape:
    - a. Chilled Water: 1-1/2 inches, round.
    - b. Refrigerant: 1-1/2 inches, round.
    - c. Hot Water: 1-1/2 inches, round.
    - d. Gas: 1-1/2 inches, round.
  2. Valve-Tag Colors:
    - a. Toxic and Corrosive Fluids: Black letters on a safety-orange background.
    - b. Flammable Fluids: Black letters on a safety-yellow background.
    - c. Combustible Fluids: White letters on a safety-brown background.
    - d. Potable and Other Water: White letters on a safety-green background.
    - e. Defined by User: White letters on a safety-purple background, black letters on a safety-white background, white letters on a safety-gray background, and white letters on a safety-black background

### **3.07 WARNING-TAG INSTALLATION**

- A. Write required message on, and attach warning tags to, equipment and other items where required.

END OF SECTION



**SECTION 23 05 93**  
**TESTING, ADJUSTING, AND BALANCING FOR HVAC**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Balancing Air Systems:
    - a. Variable-air-volume systems.

**1.02 REFERENCES**

- A. Associated Air Balance Council (AABC)
  - 1. National Standards for Total System Balance latest edition.

**1.03 DEFINITIONS**

- A. The intent of this Section is to use the standards pertaining to the TAB specialist engaged to perform the Work of this Contract, with additional requirements specified in this Section. Contract requirements take precedence over corresponding AABC or NEBB standards requirements. Differences in terminology between the Specifications and the specified TAB organization standards do not relieve the TAB entity engaged to perform the Work of this Contract of responsibility from completing the Work as described in the Specifications.
- B. Similar Terms: The following table is provided for clarification only:

| <b><u>Similar Terms</u></b> |   |
|-----------------------------|---|
| <b>Contract Term</b>        | <b>AABC Term</b>  |
| TAB Specialist              | TAB Agency  |
| TAB Standard                | National Standards for Testing and Balancing Heating, Ventilating, and Air Conditioning Systems |
| TAB Field Supervisor        | Test and Balance Engineer   |

- C. AABC: Associated Air Balance Council.
- D. TAB: Testing, adjusting, and balancing.
- E. TAB Organization: Body governing practices of TAB Specialists.
- F. TAB Specialist: An entity engaged to perform TAB Work.

**1.04 INFORMATIONAL SUBMITTALS**

- A. Qualification Data: Within 30 days of Contractor's Notice to Proceed, submit documentation that the TAB specialist and this Project's TAB team members meet the qualifications specified in "Quality Assurance" Article.

1. Provide list of similar projects completed by proposed TAB field supervisor.
2. Provide copy of completed TAB report, approved by mechanical engineer of record for a completed project with similar system types and of similar complexity.
- B. Contract Documents Examination Report: Within 30 days of Contractor's Notice to Proceed, submit the Contract Documents review report as specified in Part 3.
  1. Submit examinations report with qualifications data.
- C. Strategies and Procedures Plan: Within 60 days of Contractor's Notice to Proceed, submit TAB strategies and step-by-step procedures as specified in "Preparation" Article.
- D. Interim Reports. Submit interim reports as specified in Part 3. Include list of system conditions requiring correction and problems not identified in Contract Documents examination report.
- E. Certified TAB reports.
  1. Provide three printed copies of final TAB report. Provide one electronic file copy in PDF format.
- F. Sample report forms.
- G. Instrument calibration reports, to include the following:
  1. Instrument type and make.
  2. Serial number.
  3. Application.
  4. Dates of use.
  5. Dates of calibration.
    - a. Instruments to be used for testing and balancing shall have been calibrated within a period of one year, or less if so recommended by instrument manufacturer and be checked for accuracy prior to start of work.

#### **1.05 QUALITY ASSURANCE**

- A. Independent TAB Specialist Qualifications: Engage a TAB entity certified by AABC or NEBB.
  1. The certification shall be maintained for the entire duration of TAB work for this Project. If TAB specialist loses certification during this period, the Contractor shall immediately notify the Architect and submit another TAB specialist for approval. All work specified in this Section and in other related Sections performed by the TAB specialist shall be invalidated if the TAB specialist loses certification, and shall be performed by an approved successor.
- B. To secure approval for the proposed TAB specialist, submit information certifying that the TAB specialist is either a first-tier subcontractor engaged and paid by the Contractor, or is engaged and paid directly by the Owner. TAB specialist shall not be affiliated with any other entity participating in Work of this Contract, including design, furnishing equipment, or construction. In addition, submit evidence of the following:
  1. TAB Field Supervisor: Full-time employee of the TAB specialist and certified by AABC.
    - a. TAB field supervisor shall have minimum 10 years supervisory experience in TAB work.

2. TAB Technician: Full-time employee of the TAB specialist and who is certified by AABC as a TAB technician.
  - a. TAB technician shall have minimum 4 years TAB field experience.
- C. TAB Specialist engaged to perform TAB work in this Project shall be a business limited to and specializing in TAB work, or in TAB work and Commissioning.
- D. TAB specialist engaged to perform TAB work shall not also perform commissioning activities on this Project.
- E. Certified TAB field supervisor or certified TAB technician shall be present at the Project site at all times when TAB work is performed.
  1. TAB specialist shall maintain at the Project site a minimum ratio of one certified field supervisor or technician for each non-certified employee at times when TAB work is being performed.
- F. Contractor shall notify Architect in writing within three days of receiving direction resulting in reduction of test and balance scope or other deviations from Contract Documents. Deviations from the TAB plan shall be approved in writing by the mechanical engineer of record for the Project.
- G. TAB Standard:
  1. Perform TAB work in accordance with the requirements of the standard under which the TAB agencies' qualifications are approved unless Specifications contain different or more stringent requirements:
    - a. AABC National Standards for Total System Balance.
  2. All recommendations and suggested practices contained in the TAB standard are mandatory. Use provisions of the TAB standard, including checklists and report forms, to the extent to which they are applicable to this Project.
  3. Testing, adjusting, balancing procedures, and reporting required for this Project, and not covered by the TAB standard applicable to the TAB specialist engaged to perform the Work of this Contract, shall be submitted for approval by the design engineer.
- H. TAB Conference: Meet with Architect and mechanical engineer on approval of the TAB strategies and procedures plan to develop a mutual understanding of the project requirements. Require the participation of the TAB field supervisor. Provide seven days' advance notice of scheduled meeting time and location. TAB conference shall take place at location selected by Architect.
  1. Agenda Items:
    - a. The Contract Documents examination report.
    - b. The TAB plan.
    - c. Coordination and cooperation of trades and subcontractors.
    - d. Coordination of documentation and communication flow, including protocol for resolution tracking and documentation.
  2. The requirement for TAB conference may be waived at the discretion of the mechanical engineer of record for the Project.
- I. Certify TAB field data reports and perform the following:



1. Review field data reports to validate accuracy of data and to prepare certified TAB reports.
  2. Certify that the TAB team complied with the approved TAB plan and the procedures specified and referenced in this Specification.
- J. TAB Report Forms: Use standard TAB specialist's forms approved by Architect.
- K. Instrumentation Type, Quantity, Accuracy, and Calibration: As described in ASHRAE 111, Section 5, "Instrumentation."
- L. ASHRAE Compliance: Applicable requirements in ASHRAE 62.1, Section 7.2.2 - "Air Balancing."
- M. ASHRAE/IESNA Compliance: Applicable requirements in ASHRAE/IESNA 90.1, Section 6.7.2.3 - "System Balancing."

### **1.06 WARRANTY**

- A. Provide workmanship and performance warranty applicable to TAB specialist engaged to perform Work of this Contract:
1. AABC Performance Guarantee.
- B. Refer to Division 01 Specifications for additional requirements.

### **1.1 COORDINATION**

- C. Notice: Provide seven days' advance notice for each test. Include scheduled test dates and times.
- D. Perform TAB after leakage and pressure tests on air and water distribution systems have been satisfactorily completed.
- E. Coordinate TAB work with work of other trades.

## **PART 2 - PRODUCTS (NOT APPLICABLE)**

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Contract Documents Examination Report:
1. TAB specialist shall review Contract Documents, including plans and specifications. Provide report listing conditions that would prevent the system(s) from operating in accordance with the sequence of operations specified, or would prevent accurate testing and balancing:
    - a. Identify each condition requiring correction using equipment designation shown on Drawings. Provide room number, nearest building grid line intersection, or other information necessary to identify location of condition requiring correction.
    - b. Proposed corrective action necessary for proper system operation.
- B. Examine systems for installed balancing devices, such as test ports, gage cocks, thermometer wells, flow-control devices, balancing valves and fittings, and manual volume dampers. Verify that locations of these balancing devices are accessible.
- C. Examine the approved submittals for HVAC systems and equipment.

- D. Examine design data including HVAC system descriptions, statements of design assumptions for environmental conditions and systems' output, and statements of philosophies and assumptions about HVAC system and equipment controls.
- E. Examine equipment performance data including fan and pump curves.
  - 1. Relate performance data to Project conditions and requirements, including system effects that can create undesired or unpredicted conditions that cause reduced capacities in all or part of a system.
- F. Examine system and equipment installations and verify that field quality-control testing, cleaning, and adjusting specified in individual Sections have been performed.
- G. Examine test reports specified in individual system and equipment Sections.
- H. Examine HVAC equipment and filters and verify that bearings are greased, belts are aligned and tight, and equipment with functioning controls is ready for operation.
- I. Examine terminal units, such as variable-air-volume boxes, and verify that they are accessible and their controls are connected and functioning.
- J. Examine strainers. Verify that startup screens are replaced by permanent screens with indicated perforations.
- K. Examine three-way valves for proper installation for their intended function of diverting or mixing fluid flows.
- L. Examine heat-transfer coils for correct piping connections and for clean and straight fins.
- M. Examine operating safety interlocks and controls on HVAC equipment.
- N. Report conditions requiring correction discovered before and during performance of TAB procedures.
- O. Observe and record system reactions to changes in conditions. Record default set points if different from indicated values.

### **3.02 PREPARATION**

- A. Prepare a TAB plan that includes strategies and step-by-step procedures. TAB plan shall be specific to Project and include the following:
  - 1. General description of each air system and sequence(s) of operation.
  - 2. Complete list of measurements to be performed.
  - 3. Complete list of measurement procedures. Specify types of instruments to be utilized and method of instrument application.
  - 4. Qualifications of personnel assigned to Project.
  - 5. Single-line CAD drawings reflecting all test locations (terminal units, grilles, diffusers, traverse locations, etc).
  - 6. Table indicating pressure relationships (positive, negative, or neutral) between building spaces.
  - 7. Air terminal correction factors for the following:
    - a. Air terminal configuration.
    - b. Flow direction (supply or return/exhaust).
    - c. Effective area of each size and type of air terminal.

- d. Air density.
- B. Complete system-readiness checks and prepare reports. Verify the following:
  - 1. Permanent electrical-power wiring is complete.
  - 2. Hydronic systems are filled, clean, and free of air.
  - 3. Automatic temperature-control systems are operational.
  - 4. Equipment and duct access doors are securely closed.
  - 5. Balance, smoke, and fire dampers are open.
  - 6. Isolating and balancing valves are open and control valves are operational.
  - 7. Ceilings are installed in critical areas where air-pattern adjustments are required and access to balancing devices is provided.
  - 8. Windows and doors can be closed so indicated conditions for system operations can be met.

### **3.03 GENERAL PROCEDURES FOR TESTING AND BALANCING**

- A. Perform testing and balancing procedures on each system according to the procedures contained in AABC's "National Standards for Total System Balance" and in this Section.
  - 1. Comply with requirements in ASHRAE 62.1, Section 7.2.2 - "Air Balancing."
- B. Cut insulation, ducts, pipes, and equipment cabinets for installation of test probes to the minimum extent necessary for TAB procedures.
  - 1. After testing and balancing, patch probe holes in ducts with same material and thickness as used to construct ducts.
  - 2. Install and join new insulation that matches removed materials. Restore insulation, coverings, vapor barrier, and finish according to Section 230713 "Duct Insulation," Section 230716 "HVAC Equipment Insulation," and Section 230719 "HVAC Piping Insulation."
- C. Mark equipment and balancing devices, including damper-control positions, valve position indicators, fan-speed-control levers, and similar controls and devices, with paint or other suitable, permanent identification material to show final settings.
- D. Take and report testing and balancing measurements in inch-pound (IP) units.

### **3.04 GENERAL PROCEDURES FOR BALANCING AIR SYSTEMS**

- A. Prepare test reports for both fans and outlets. Obtain manufacturer's outlet factors and recommended testing procedures. Crosscheck the summation of required outlet volumes with required fan volumes.
- B. Test each system to verify building or space operating pressure, including all stages of economizer cycle. Maximum building pressure shall not exceed 0.03 inches of pressure.
- C. Except as specifically indicated in this Specification, Pitot tube traverses shall be made of each duct to measure airflow. Pitot tubes, associated instruments, traverses, and techniques shall conform to ASHRAE Handbook, HVAC Applications, and ASHRAE Handbook, HVAC Systems and Equipment.
  - 1. Use state-of-the-art instrumentation approved by TAB specialists governing agency.

2. Where ducts' design velocity and air quantity are both less than 1000 fpm/CFM, air quantity may be determined by measurements at terminals served.
- D. Test holes shall be placed in straight duct, as far as possible downstream from elbow, bends, take-offs, and other turbulence-generating devices.
- E. For variable-air-volume systems, develop a plan to simulate diversity.
- F. Determine the best locations in main and branch ducts for accurate duct-airflow measurements.
- G. Check airflow patterns from the outdoor-air louvers and dampers and the return- and exhaust-air dampers through the supply-fan discharge and mixing dampers.
- H. Locate start-stop and disconnect switches, electrical interlocks, and motor starters.
- I. Verify that motor starters are equipped with properly sized thermal protection.
- J. Check dampers for proper position to achieve desired airflow path.
- K. Check for airflow blockages.
- L. Check condensate drains for proper connections and functioning.
- M. Check for proper sealing of air-handling-unit components.
- N. Verify that air duct system is sealed as specified in Section 233113 "Metal Ducts."
- O. Provide for adjustments or modifications to fan and motor sheaves, belts, damper linkages, and other components as required to achieve specified air balance at no additional cost to Owner.
- P. Automatically operated dampers shall be adjusted to operate as indicated in Contract Documents. Controls shall be checked for proper calibration.

### **3.05 PROCEDURES FOR VARIABLE-AIR-VOLUME SYSTEMS**

- A. Comply with applicable requirements for constant-volume air systems in addition to those listed below.
- B. Compensating for Diversity: When the total airflow of all terminal units is more than the indicated airflow of the fan, place a selected number of terminal units at a minimum set-point airflow with the remainder at maximum-airflow condition until the total airflow of the terminal units equals the indicated airflow of the fan. Select the reduced-airflow terminal units so they are distributed evenly among the branch ducts.
- C. Pressure-Independent, Variable-Air-Volume Systems: After the fan systems have been adjusted, adjust the variable-air-volume systems as follows:
  1. Set outdoor-air dampers at minimum, and set return- and exhaust-air dampers at a position that simulates full-cooling load.
  2. Select the terminal unit that is most critical to the supply-fan airflow and static pressure. Measure static pressure. Adjust system static pressure so the entering static pressure for the critical terminal unit is not less than the sum of the terminal-unit manufacturer's recommended minimum inlet static pressure plus the static pressure needed to overcome terminal-unit discharge system losses.
  3. Measure total system airflow. Adjust to within indicated airflow.
  4. Set terminal units at maximum airflow and adjust controller or regulator to deliver the designed maximum airflow. Use terminal-unit manufacturer's written instructions to

make this adjustment. When total airflow is correct, balance the air outlets downstream from terminal units the same as described for constant-volume air systems.

5. Set terminal units at minimum airflow and adjust controller or regulator to deliver the designed minimum airflow. Check air outlets for a proportional reduction in airflow the same as described for constant-volume air systems.
  - a. If air outlets are out of balance at minimum airflow, report the condition but leave outlets balanced for maximum airflow.
6. Remeasure the return airflow to the fan while operating at maximum return airflow and minimum outdoor airflow.
  - a. Adjust the fan and balance the return-air ducts and inlets the same as described for constant-volume air systems.
7. Measure static pressure at the most critical terminal unit and adjust the static-pressure controller at the main supply-air sensing station to ensure that adequate static pressure is maintained at the most critical unit.
8. Record final fan-performance data including optimum operating static control set point.

### **3.06 PROCEDURES FOR VARIABLE-FLOW HYDRONIC SYSTEMS**

- A. Balance systems with automatic two- and three-way control valves by setting systems at maximum flow through heat-exchange terminals and proceed as specified above for hydronic systems.

### **1.2 PROCEDURES FOR MOTORS**

- A. Motors, 1/2 HP and Larger: Test at final balanced conditions and record the following data:
  1. Manufacturer's name, model number, and serial number.
  2. Motor horsepower rating.
  3. Motor rpm.
  4. Efficiency rating.
  5. Nameplate and measured voltage, each phase.
  6. Nameplate and measured amperage, each phase.
  7. Starter manufacturer's name, model number, size, type, and thermal-protection-element rating.
    - a. Starter strip heater size, type, and rating.
- B. Motors Driven by Variable-Frequency Controllers: Test for proper operation at speeds varying from minimum to maximum. Test the manual bypass of the controller to prove proper operation. Record observations including name of controller manufacturer, model number, serial number, and nameplate data.

### **1.3 GENERAL PROCEDURES FOR PLUMBING SYSTEMS**

- A. Measure water flow at pumps. Use the following procedures except for positive-displacement pumps:
  1. Verify impeller size by operating the pump with the discharge valve closed. Read pressure differential across the pump. Convert pressure to head and correct for

differences in gage heights. Note the point on manufacturer's pump curve at zero flow and verify that the pump has the intended impeller size.

- a. If impeller sizes must be adjusted to achieve pump performance, obtain approval from Architect Owner Construction Manager Commissioning Authority and comply with requirements in Section 221123 "Domestic Water Pumps."
2. Check system resistance. With all valves open, read pressure differential across the pump and mark pump manufacturer's head-capacity curve. Adjust pump discharge valve until indicated water flow is achieved.
  - a. Monitor motor performance during procedures and do not operate motors in overload conditions.
3. Verify pump-motor brake horsepower. Calculate the intended brake horsepower for the system based on pump manufacturer's performance data. Compare calculated brake horsepower with nameplate data on the pump motor. Report conditions where actual amperage exceeds motor nameplate amperage.
4. Report flow rates that are not within range given in article, Tolerances.
- B. Set calibrated balancing valves, if installed, at calculated presettings.
- C. Measure flow at all stations and adjust, where necessary, to obtain first balance.
  1. System components that have Cv rating or an accurately cataloged flow-pressure-drop relationship may be used as a flow-indicating device.
- D. Measure flow at main balancing station and set main balancing device to achieve flow that is 5 percent greater than indicated flow.
- E. Adjust balancing stations to within specified tolerances of indicated flow rate as follows:
  1. Determine the balancing station with the highest percentage over indicated flow.
  2. Adjust each station in turn, beginning with the station with the highest percentage over indicated flow and proceeding to the station with the lowest percentage over indicated flow.
  3. Record settings and mark balancing devices.
- F. Measure pump flow rate and make final measurements of pump amperage, voltage, rpm, pump heads, and systems' pressures and temperatures including outdoor-air temperature.
- G. Measure the differential-pressure-control-valve settings existing at the conclusion of balancing.
- H. Check settings and operation of each safety valve. Record settings.

#### **1.4 TOLERANCES**

- A. Set HVAC system's air flow rates and water flow rates within the following tolerances:
  1. Supply, Return, and Exhaust Fans and Equipment with Fans: Plus 10 percent and minus 0 percent.
  2. Air Outlets and Inlets: Plus 5 percent and minus 5 percent.
  3. Multiple outlets within single room: Plus 5 percent and minus 0 percent for total airflow within room. Tolerance for individual outlets within a single room having multiple outlets shall be as for "Air Outlets and Inlets".

- a. Room shall be balanced to create pressure relationship (positive, negative, or neutral) with adjacent spaces as indicated on Drawings. Maintain airflow differentials between supply, return, and exhaust indicated on Drawings.
- B. Set plumbing systems water flow rates within plus or minus 10 percent.

## **1.5 REPORTING**

- A. Initial Construction-Phase Report: Based on examination of the Contract Documents as specified in "Examination" Article, prepare a report on the adequacy of design for systems' balancing devices. Recommend changes and additions to systems' balancing devices to facilitate proper performance measuring and balancing. Recommend changes and additions to HVAC systems and general construction to allow access for performance measuring and balancing devices.
- B. Interim Reports: Prepare periodic lists of conditions requiring correction and problems found in systems being tested and balanced. Prepare a separate report for each system and each building floor for systems serving multiple floors.

## **1.6 FINAL REPORT**

- A. General: Prepare a certified written report; tabulate and divide the report into separate sections for tested systems and balanced systems.
  - 1. Include a certification sheet at the front of the report's binder, signed and sealed by the certified testing and balancing field supervisor. Report shall be co-signed by the Contractor, attesting that he has reviewed the report, and the report has been found to be complete and accurate.
  - 2. The certification sheet shall be followed by sheet(s) listing items for which balancing objectives could not be achieved. Provide explanation for failure to achieve balancing objectives for each item listed.
  - 3. Include a list of instruments used for procedures, along with proof of calibration.
- B. Final Report Contents: In addition to certified field-report data, include the following:
  - 1. Pump curves.
  - 2. Fan curves.
  - 3. Manufacturers' test data.
  - 4. Field test reports prepared by system and equipment installers.
  - 5. Other information relative to equipment performance; do not include Shop Drawings and product data.
- C. General Report Data: In addition to form titles and entries, include the following data:
  - 1. Title page.
  - 2. Name and address of the TAB specialist.
  - 3. Project name.
  - 4. Project location.
  - 5. Project Performance Guaranty
  - 6. Architect's name and address.
  - 7. Engineer's name and address.

8. Contractor's name and address.
  9. Report date.
  10. Signature of TAB supervisor who certifies the report.
  11. Table of Contents with the total number of pages defined for each section of the report. Number each page in the report.
  12. Summary of contents including the following:
    - a. Indicated versus final performance.
    - b. Notable characteristics of systems.
    - c. Description of system operation sequence if it varies from the Contract Documents.
  13. Nomenclature sheets for each item of equipment.
  14. Data for terminal units, including manufacturer's name, type, size, and fittings.
  15. Test conditions for fans and pump performance forms including the following:
    - a. Settings for outdoor-, return-, and exhaust-air dampers.
    - b. Conditions of filters.
    - c. Cooling coil, wet- and dry-bulb conditions.
    - d. Face and bypass damper settings at coils.
    - e. Fan drive settings including settings and percentage of maximum pitch diameter.
    - f. Inlet vane settings for variable-air-volume systems.
    - g. Settings for supply-air, static-pressure controller.
    - h. Other system operating conditions that affect performance.
- D. System Diagrams: Include schematic layouts of air and hydronic distribution systems. Present each system with single-line diagram and include the following:
1. Quantities of outdoor, supply, return, and exhaust airflows.
  2. Water and steam flow rates.
  3. Duct, outlet, and inlet sizes.
  4. Pipe and valve sizes and locations.
  5. Terminal units.
  6. Balancing stations.
  7. Position of balancing devices.
- E. Air distribution outlets and inlets shall be shown on keyed plans with designation for each outlet and inlet matching designation used in Contract Documents and TAB test reports. Room numbers shall be included in keyed plans and test reports. Where multiple outlets and inlets are installed within a single room, a designation shall be assigned and listed for each outlet and inlet in addition to room number.
- F. Test Reports – General:
1. All test reports containing air or liquid flow data shall record flow values prior to system adjustment in addition to required data listed for each test report.
- G. Air-Handling-Unit Test Reports: For air-handling units with coils, include the following:
1. Unit Data:



- a. Unit identification.
  - b. Location.
  - c. Make and type.
  - d. Model number and unit size.
  - e. Manufacturer's serial number.
  - f. Unit arrangement and class.
  - g. Discharge arrangement.
  - h. Sheave make, size in inches, and bore.
  - i. Center-to-center dimensions of sheave, and amount of adjustments in inches.
  - j. Number, make, and size of belts.
  - k. Number, type, and size of filters.
2. Motor Data:
- a. Motor make, and frame type and size.
  - b. Horsepower and rpm.
  - c. Volts, phase, and hertz.
  - d. Full-load amperage and service factor.
  - e. Sheave make, size in inches, and bore.
  - f. Center-to-center dimensions of sheave, and amount of adjustments in inches.
  - g. VFD model and number.
3. Test Data (Indicated and Actual Values):
- a. Total air flow rate in cfm.
  - b. Total system static pressure in inches wg.
  - c. Fan rpm.
  - d. Discharge static pressure in inches wg.
  - e. Filter static-pressure differential in inches wg.
  - f. Preheat-coil static-pressure differential in inches wg.
  - g. Cooling-coil static-pressure differential in inches wg.
  - h. Heating-coil static-pressure differential in inches wg.
  - i. Outdoor airflow in cfm.
  - j. Return airflow in cfm.
  - k. Relief airflow in cfm.
  - l. Outdoor-air damper position, normal and economizer, power exhaust, or power exhaust economizer modes, as applicable to installed equipment.
  - m. Return-air damper position.
  - n. Relief-air damper position, normal and economizer, power exhaust, or power exhaust economizer modes, as applicable to installed equipment.
  - o. Vortex damper position.

- H. Apparatus-Coil Test Reports:
1. Coil Data:
    - a. System identification.
    - b. Location.
    - c. Coil type.
    - d. Number of rows.
    - e. Fin spacing in fins per inch o.c.
    - f. Make and model number.
    - g. Face area in sq. ft.
    - h. Tube size in NPS.
    - i. Tube and fin materials.
    - j. Circuiting arrangement.
  2. Test Data (Indicated and Actual Values):
    - a. Air flow rate in cfm.
    - b. Average face velocity in fpm.
    - c. Air pressure drop in inches wg.
    - d. Outdoor-air, wet- and dry-bulb temperatures in deg F.
    - e. Return-air, wet- and dry-bulb temperatures in deg F.
    - f. Entering-air, wet- and dry-bulb temperatures in deg F.
    - g. Leaving-air, wet- and dry-bulb temperatures in deg F.
    - h. Water flow rate in gpm.
    - i. Water pressure differential in feet of head or psig.
    - j. Entering-water temperature in deg F.
    - k. Leaving-water temperature in deg F.
    - l. Refrigerant expansion valve and refrigerant types.
    - m. Inlet steam pressure in psig.
- I. Fan Test Reports: For supply, return, and exhaust fans, include the following:
1. Fan Data:
    - a. System identification.
    - b. Location.
    - c. Make and type.
    - d. Model number and size.
    - e. Manufacturer's serial number.
    - f. Arrangement and class.
    - g. Sheave make, size in inches, and bore.
    - h. Center-to-center dimensions of sheave, and amount of adjustments in inches.
  2. Motor Data:

- a. Motor make, and frame type and size.
  - b. Horsepower and rpm.
  - c. Volts, phase, and hertz.
  - d. Full-load amperage and service factor.
  - e. Sheave make, size in inches, and bore.
  - f. Center-to-center dimensions of sheave, and amount of adjustments in inches.
  - g. Number, make, and size of belts.
3. Test Data (Indicated and Actual Values):
- a. Total airflow rate in cfm.
  - b. Total system static pressure in inches wg.
  - c. Fan rpm.
  - d. Discharge static pressure in inches wg.
  - e. Suction static pressure in inches wg.
- J. Round, Flat-Oval, and Rectangular Duct Traverse Reports: Include a diagram with a grid representing the duct cross-section and record the following:
1. Report Data:
- a. System and air-handling-unit number.
  - b. Location and zone.
  - c. Traverse air temperature in deg F.
  - d. Duct static pressure in inches wg.
  - e. Duct size in inches.
  - f. Duct area in sq. ft..
  - g. Indicated air flow rate in cfm.
  - h. Indicated velocity in fpm.
  - i. Actual air flow rate in cfm.
  - j. Actual average velocity in fpm.
  - k. Barometric pressure in psig.
- K. Air-Terminal-Device Reports:
1. Unit Data:
- a. System and air-handling unit identification.
  - b. Location and zone.
  - c. Apparatus used for test.
  - d. Area served.
  - e. Make.
  - f. Number from system diagram.
  - g. Type and model number.
  - h. Size.

- i. Effective area in sq. ft.
  - 2. Test Data (Indicated and Actual Values):
    - a. Air flow rate in cfm.
    - b. Air velocity in fpm.
    - c. Preliminary air flow rate as needed in cfm.
    - d. Preliminary velocity as needed in fpm.
    - e. Final air flow rate in cfm.
    - f. Final velocity in fpm.
    - g. Space temperature in deg F.
- L. Pump Test Reports: Calculate impeller size by plotting the shutoff head on pump curves and include the following:
  - 1. Unit Data:
    - a. Unit identification.
    - b. Location.
    - c. Service.
    - d. Make and size.
    - e. Model number and serial number.
    - f. Water flow rate in gpm.
    - g. Water pressure differential in feet of head or psig.
    - h. Required net positive suction head in feet of head or psig.
    - i. Pump rpm.
    - j. Impeller diameter in inches.
    - k. Motor make and frame size.
    - l. Motor horsepower and rpm.
    - m. Voltage at each connection.
    - n. Amperage for each phase.
    - o. Full-load amperage and service factor.
    - p. Seal type.
  - 2. Test Data (Indicated and Actual Values):
    - a. Static head in feet of head or psig.
    - b. Pump shutoff pressure in feet of head or psig.
    - c. Actual impeller size in inches.
    - d. Full-open flow rate in gpm.
    - e. Full-open pressure in feet of head or psig.
    - f. Final discharge pressure in feet of head or psig.
    - g. Final suction pressure in feet of head or psig.
    - h. Final total pressure in feet of head or psig.

- i. Final water flow rate in gpm.
- j. Voltage at each connection.
- k. Amperage for each phase.

M. Instrument Calibration Reports:

- 1. Report Data:
  - a. Instrument type and make.
  - b. Serial number.
  - c. Application.
  - d. Dates of use.
  - e. Dates of calibration.

## 1.7 INSPECTIONS

A. Initial Inspection:

- 1. After testing and balancing are complete, operate each system and randomly check measurements to verify that the system is operating according to the final test and balance readings documented in the final report.
- 2. Check the following for each system:
  - a. Measure airflow of at least 10 percent of air outlets.
  - b. Measure water flow of at least 5 percent of terminals.
  - c. Measure room temperature at each thermostat/temperature sensor. Compare the reading to the set point.
  - d. Verify that balancing devices are marked with final balance position.
  - e. Note deviations from the Contract Documents in the final report.

B. Final Inspection:

- 1. After initial inspection is complete and documentation by random checks verifies that testing and balancing are complete and accurately documented in the final report, request that a final inspection be made by Architect.
- 2. The TAB specialist's test and balance engineer shall conduct the inspection in the presence of Architect.
- 3. Architect shall randomly select measurements, documented in the final report, to be rechecked. Rechecking shall be limited to either 10 percent of the total measurements recorded or the extent of measurements that can be accomplished in a normal 8-hour business day.
- 4. If rechecks yield measurements that differ from the measurements documented in the final report by more than 10 percent, the measurements shall be noted as "FAILED."
- 5. If the number of "FAILED" measurements is greater than 10 percent of the total measurements checked during the final inspection, the testing and balancing shall be considered incomplete and shall be rejected.

- C. TAB Work will be considered defective if it does not pass final inspections. If TAB Work fails, proceed as follows:

1. Recheck all measurements and make adjustments. Revise the final report and balancing device settings to include all changes; resubmit the final report and request a second final inspection.
  2. If the second final inspection also fails, Owner may contact the TAB specialists' governing organization for remedial action by the governing organization under the workmanship and performance warranty. See article, Warranty.
  3. If remedial action is not provided by the TAB specialists' governing organization in a timely manner, Owner may contract the services of another TAB specialist to complete the TAB Work according to the Contract Documents and deduct the cost of the services from the original TAB specialists' final payment.
- D. Prepare test and inspection reports.

### **1.8 ADDITIONAL TESTS**

- A. Seasonal Periods: If initial TAB procedures were not performed during near-peak summer and winter conditions, perform additional TAB during near-peak summer and winter conditions.

END OF SECTION



## **SECTION 23 07 13 DUCT INSULATION**

### **PART 1 - GENERAL**

#### **1.01 SUMMARY**

- A. Section includes insulating the following duct services:
  - 1. Indoor, concealed supply.
- B. Related Sections:
  - 1. Section 23 07 19 "HVAC Piping Insulation."
  - 2. Section 233113 "Metal Ducts" for duct liners.

#### **1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product indicated. Include thermal conductivity, water-vapor permeance thickness, and jackets (both factory- and field-applied if any).
- B. Product Data for California Green Building Standards Code Compliance: For adhesives and sealants, including primers, documentation of compliance including printed statement of VOC content and chemical components.
- C. Product data for insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings, indicating compliance with requirement that these products contain less than 0.1 percent (by mass) polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations.
- D. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Detail application of protective shields, saddles, and inserts at hangers for each type of insulation and hanger.
  - 2. Detail insulation application at elbows, fittings, dampers, specialties and flanges for each type of insulation.
  - 3. Detail application of field-applied jackets.
  - 4. Detail application at linkages of control devices.

#### **1.03 INFORMATIONAL SUBMITTALS**

- A. Qualification Data: For qualified Installer.
- B. Material Test Reports: From a qualified testing agency acceptable to authorities having jurisdiction indicating, interpreting, and certifying test results for compliance of insulation materials, sealers, attachments, cements, and jackets, with requirements indicated. Include dates of tests and test methods employed.
- C. Field quality-control reports.

#### **1.04 QUALITY ASSURANCE**

- A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or another craft training program certified by the Department of Labor, Bureau of Apprenticeship and Training.



- B. Surface-Burning Characteristics: For insulation and related materials, as determined by testing identical products according to ASTM E 84, by a testing agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing agency.
  - 1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.
  - 2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.

#### **1.05 DELIVERY, STORAGE, AND HANDLING**

- A. Packaging: Insulation material containers shall be marked by manufacturer with appropriate ASTM standard designation, type and grade, and maximum use temperature.

#### **1.06 COORDINATION**

- A. Coordinate sizes and locations of supports, hangers, and insulation shields specified in Section 230529 "Hangers and Supports for HVAC Piping and Equipment."
- B. Coordinate clearance requirements with duct Installer for duct insulation application. Before preparing ductwork Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes and for space required for maintenance.

#### **1.07 SCHEDULING**

- A. Schedule insulation application after pressure testing systems. Insulation application may begin on segments that have satisfactory test results.
- B. Complete installation and concealment of plastic materials as rapidly as possible in each area of construction.

### **PART 2 - PRODUCTS**

#### **2.01 INSULATION MATERIALS**

- A. Comply with requirements in "Duct Insulation Schedule, General," "Indoor Duct and Plenum Insulation Schedule," and "Aboveground, Outdoor Duct and Plenum Insulation Schedule" articles for where insulating materials shall be applied.
- B. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).
- C. Products shall not contain asbestos, lead, mercury, or mercury compounds.
- D. Products that come in contact with stainless steel shall have a leachable chloride content of less than 50 ppm when tested according to ASTM C 871.
- E. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C 795.
- F. Mineral-Fiber Blanket Insulation: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 553, Type II and ASTM C 1290, Type III with factory-applied FSK jacket. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. CertainTeed Corporation.
  - b. Johns Manville; a Berkshire Hathaway company.
  - c. Knauf Insulation.
  - d. Manson Insulation Inc.
  - e. Owens Corning.
  
- G. Mineral-Fiber Board Insulation: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 612, Type IA or Type IB. For duct and plenum applications, provide insulation with factory-applied FSK. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. CertainTeed Corporation.
    - b. Johns Manville; a Berkshire Hathaway company.
    - c. Knauf Insulation.
    - d. Manson Insulation Inc.
    - e. Owens Corning.

## 2.02 ADHESIVES

- A. Materials shall be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated unless otherwise indicated.
- B. Mineral-Fiber Adhesive: Comply with MIL-A-3316C, Class 2, Grade A.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. Mon-Eco Industries, Inc.
  2. Fiberglass adhesive shall have a VOC content of 80 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  3. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- C. FSK Jacket Adhesive: Comply with MIL-A-3316C, Class 2, Grade A for bonding insulation jacket lap seams and joints.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.

- b. Eagle Bridges - Marathon Industries.
  - c. Foster Brand; H. B. Fuller Construction Products.
  - d. Mon-Eco Industries, Inc.
2. Adhesive shall have a VOC content of 80 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  3. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.

### **2.03 MASTICS**

- A. Materials shall be compatible with insulation materials, jackets, and substrates; comply with MIL-PRF-19565C, Type II.
  1. VOC Content: 300 g/L or less.
  2. Low-Emitting Materials: Mastic coatings shall comply with the testing and product requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- B. Vapor-Barrier Mastic: Water based; suitable for indoor use on below ambient services.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Foster Brand; H. B. Fuller Construction Products.
    - c. Knauf Insulation.
    - d. Vimasco Corporation.
  2. Water-Vapor Permeance: ASTM E 96/E 96M, Procedure B, 0.013 perm at 43-mil dry film thickness.
  3. Service Temperature Range: Minus 20 to plus 180 deg F.
  4. Solids Content: ASTM D 1644, 58 percent by volume and 70 percent by weight.
  5. Color: White.

### **2.04 LAGGING ADHESIVES**

- A. Description: Comply with MIL-A-3316C, Class I, Grade A and shall be compatible with insulation materials, jackets, and substrates.
  1. Adhesives shall have a VOC content of 50 g/L or less.
  2. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
  3. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Foster Brand; H. B. Fuller Construction Products.
    - c. Vimasco Corporation.

4. Fire-resistant, water-based lagging adhesive and coating for use indoors to adhere fire-resistant lagging cloths over duct insulation.
5. Service Temperature Range: 0 to plus 180 deg F.
6. Color: White.

## **2.05 SEALANTS**

### **A. FSK and Metal Jacket Flashing Sealants:**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Childers Brand; H. B. Fuller Construction Products.
  - b. Eagle Bridges - Marathon Industries.
  - c. Foster Brand; H. B. Fuller Construction Products.
  - d. Mon-Eco Industries, Inc.
2. Materials shall be compatible with insulation materials, jackets, and substrates.
3. Fire- and water-resistant, flexible, elastomeric sealant.
4. Service Temperature Range: Minus 40 to plus 250 deg F.
5. Color: Aluminum.
6. Sealant shall have a VOC content of 420 g/L or less.
7. Sealant shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.

## **2.06 FACTORY-APPLIED JACKETS**

- ### **A. Insulation system schedules indicate factory-applied jackets on various applications. When factory-applied jackets are indicated, comply with the following:**
1. FSK Jacket: Aluminum-foil, fiberglass-reinforced scrim with kraft-paper backing; complying with ASTM C 1136, Type II.

## **2.07 FIELD-APPLIED FABRIC-REINFORCING MESH**

- ### **A. Woven Glass-Fiber Fabric: Approximately 6 oz./sq. yd. with a thread count of 5 strands by 5 strands/sq. in. for covering ducts.**
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
- ### **B. Woven Polyester Fabric: Approximately 1 oz./sq. yd. with a thread count of 10 strands by 10 strands/sq. in., in a Leno weave, for ducts.**
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Foster Brand; H. B. Fuller Construction Products.
    - b. Vimasco Corporation.

## 2.08 FIELD-APPLIED CLOTHS

- A. Woven Glass-Fiber Fabric: Comply with MIL-C-20079H, Type I, plain weave, and presized a minimum of 8 oz./sq. yd.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Alpha Associates, Inc.

## 1.1 TAPES

- A. FSK Tape: Foil-face, vapor-retarder tape matching factory-applied jacket with acrylic adhesive; complying with ASTM C 1136.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Avery Dennison Corporation, Specialty Tapes Division.
    - b. Compac Corporation.
    - c. Ideal Tape Co., Inc.; an American Biltrite company.
    - d. Knauf Insulation.
    - e. Venture Tape.
  - 2. Width: 3 inches.
  - 3. Thickness: 6.5 mils.
  - 4. Adhesion: 90 ounces force/inch in width.
  - 5. Elongation: 2 percent.
  - 6. Tensile Strength: 40 lbf/inch in width.
  - 7. FSK Tape Disks and Squares: Precut disks or squares of FSK tape.
- B. Aluminum-Foil Tape: Vapor-retarder tape with acrylic adhesive.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Avery Dennison Corporation, Specialty Tapes Division.
    - b. Compac Corporation.
    - c. Ideal Tape Co., Inc.; an American Biltrite company.
    - d. Knauf Insulation.
    - e. Venture Tape.
  - 2. Width: 2 inches.
  - 3. Thickness: 3.7 mils.
  - 4. Adhesion: 100 ounces force/inch in width.
  - 5. Elongation: 5 percent.
  - 6. Tensile Strength: 34 lbf/inch in width.

## 1.2 SECUREMENTS

### A. Bands:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. ITW Insulation Systems; Illinois Tool Works, Inc.
  - b. RPR Products, Inc.
2. Stainless Steel: ASTM A 167 or ASTM A 240/A 240M, Type 316; 0.015 inch thick, 3/4 inch wide with wing seal.
3. Springs: Twin spring set constructed of stainless steel with ends flat and slotted to accept metal bands. Spring size determined by manufacturer for application.

### B. Insulation Pins and Hangers:

1. Capacitor-Discharge-Weld Pins: Copper- or zinc-coated steel pin, fully annealed for capacitor-discharge welding, 0.135-inch-diameter shank, length to suit depth of insulation indicated.
  - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - 1) AGM Industries, Inc.
    - 2) Gemco.
    - 3) Hardcast, Inc.
    - 4) Midwest Fasteners, Inc.
    - 5) Nelson Stud Welding.
2. Cupped-Head, Capacitor-Discharge-Weld Pins: Copper- or zinc-coated steel pin, fully annealed for capacitor-discharge welding, 0.135-inch-diameter shank, length to suit depth of insulation indicated with integral 1-1/2-inch galvanized carbon-steel washer.
  - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - 1) AGM Industries, Inc.
    - 2) CL WARD & Family Inc.
    - 3) Gemco.
    - 4) Hardcast, Inc.
    - 5) Midwest Fasteners, Inc.
    - 6) Nelson Stud Welding.
3. Insulation-Retaining Washers: Self-locking washers formed from 0.016-inch-thick, stainless-steel sheet, with beveled edge sized as required to hold insulation securely in place but not less than 1-1/2 inches in diameter.
  - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:

- 1) AGM Industries, Inc.
  - 2) Gemco.
  - 3) Hardcast, Inc.
  - 4) Midwest Fasteners, Inc.
  - 5) Nelson Stud Welding.
- b. Protect ends with capped self-locking washers incorporating a spring steel insert to ensure permanent retention of cap in exposed locations.
- C. Staples: Outward-clinching insulation staples, nominal 3/4-inch-wide, stainless steel or Monel.
- D. Wire: 0.062-inch soft-annealed, stainless steel.
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. C & F Wire.

### 1.3 CORNER ANGLES

- A. Aluminum Corner Angles: 0.040 inch thick, minimum 1 by 1 inch, aluminum according to ASTM B 209, Alloy 3003, 3005, 3105, or 5005; Temper H-14.

## PART 2 - EXECUTION

### 2.01 EXAMINATION

- A. Examine substrates and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of insulation application.
1. Verify that systems to be insulated have been tested and are free of defects.
  2. Verify that surfaces to be insulated are clean and dry.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 2.02 PREPARATION

- A. Surface Preparation: Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.

### 2.03 GENERAL INSTALLATION REQUIREMENTS

- A. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of ducts and fittings.
- B. Install insulation materials, vapor barriers or retarders, jackets, and thicknesses required for each item of duct system as specified in insulation system schedules.
- C. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, soften, or otherwise attack insulation or jacket in either wet or dry state.
- D. Install insulation with longitudinal seams at top and bottom of horizontal runs.
- E. Install multiple layers of insulation with longitudinal and end seams staggered.
- F. Keep insulation materials dry during application and finishing.

- G. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- H. Install insulation with least number of joints practical.
- I. Where vapor barrier is indicated, seal joints, seams, and penetrations in insulation at hangers, supports, anchors, and other projections with vapor-barrier mastic.
  - 1. Install insulation continuously through hangers and around anchor attachments.
  - 2. For insulation application where vapor barriers are indicated, extend insulation on anchor legs from point of attachment to supported item to point of attachment to structure. Taper and seal ends at attachment to structure with vapor-barrier mastic.
  - 3. Install insert materials and install insulation to tightly join the insert. Seal insulation to insulation inserts with adhesive or sealing compound recommended by insulation material manufacturer.
- J. Apply adhesives, mastics, and sealants at manufacturer's recommended coverage rate and wet and dry film thicknesses.
- K. Install insulation with factory-applied jackets as follows:
  - 1. Draw jacket tight and smooth.
  - 2. Cover circumferential joints with 3-inch-wide strips, of same material as insulation jacket. Secure strips with adhesive and outward clinching staples along both edges of strip, spaced 4 inches o.c.
  - 3. Overlap jacket longitudinal seams at least 1-1/2 inches. Clean and dry surface to receive self-sealing lap. Staple laps with outward clinching staples along edge at 2 inches o.c.
    - a. For below ambient services, apply vapor-barrier mastic over staples.
  - 4. Cover joints and seams with tape, according to insulation material manufacturer's written instructions, to maintain vapor seal.
  - 5. Where vapor barriers are indicated, apply vapor-barrier mastic on seams and joints and at ends adjacent to duct flanges and fittings.
- L. Cut insulation in a manner to avoid compressing insulation more than 75 percent of its nominal thickness.
- M. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- N. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches beyond damaged areas. Adhere, staple, and seal patches similar to butt joints.

## **2.04 PENETRATIONS**

- A. Insulation Installation at Roof Penetrations: Install insulation continuously through roof penetrations.
  - 1. Seal penetrations with flashing sealant.
  - 2. For applications requiring only indoor insulation, terminate insulation above roof surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.



- B. Insulation Installation at Interior Wall and Partition Penetrations (That Are Not Fire Rated): Install insulation continuously through walls and partitions.
- C. Insulation Installation at Fire-Rated Wall and Partition Penetrations: Terminate insulation at fire damper sleeves for fire-rated wall and partition penetrations. Externally insulate damper sleeves to match adjacent insulation and overlap duct insulation at least 2 inches.
  - 1. Comply with requirements in Section 078400 "Firestopping" and fire-resistive joint sealers.
- D. Insulation Installation at Floor Penetrations:
  - 1. Duct: For penetrations through fire-rated assemblies, terminate insulation at fire damper sleeves and externally insulate damper sleeve beyond floor to match adjacent duct insulation. Overlap damper sleeve and duct insulation at least 2 inches.
  - 2. Seal penetrations through fire-rated assemblies. Comply with requirements in Section 078400 "Firestopping."

## **2.05 INSTALLATION OF MINERAL-FIBER INSULATION**

- A. Blanket Insulation Installation on Ducts and Plenums: Secure with adhesive and insulation pins.
  - 1. Apply adhesives according to manufacturer's recommended coverage rates per unit area, for 100 percent coverage of duct and plenum surfaces.
  - 2. Apply adhesive to entire circumference of ducts and to all surfaces of fittings and transitions.
  - 3. Install either capacitor-discharge-weld pins and speed washers or cupped-head, capacitor-discharge-weld pins on sides and bottom of horizontal ducts and sides of vertical ducts as follows:
    - a. On duct sides with dimensions 18 inches and smaller, place pins along longitudinal centerline of duct. Space 3 inches maximum from insulation end joints, and 16 inches o.c.
    - b. On duct sides with dimensions larger than 18 inches, place pins 16 inches o.c. each way, and 3 inches maximum from insulation joints. Install additional pins to hold insulation tightly against surface at cross bracing.
    - c. Pins may be omitted from top surface of horizontal, rectangular ducts and plenums.
    - d. Do not overcompress insulation during installation.
    - e. Impale insulation over pins and attach speed washers.
    - f. Cut excess portion of pins extending beyond speed washers or bend parallel with insulation surface. Cover exposed pins and washers with tape matching insulation facing.
  - 4. For ducts and plenums with surface temperatures below ambient, install a continuous unbroken vapor barrier. Create a facing lap for longitudinal seams and end joints with insulation by removing 2 inches from one edge and one end of insulation segment. Secure laps to adjacent insulation section with 1/2-inch outward-clinching staples, 1 inch o.c. Install vapor barrier consisting of factory- or field-applied jacket, adhesive, vapor-barrier mastic, and sealant at joints, seams, and protrusions.
    - a. Repair punctures, tears, and penetrations with tape or mastic to maintain vapor-barrier seal.

- b. Install vapor stops for ductwork and plenums operating below 50 deg F at 18-foot intervals. Vapor stops shall consist of vapor-barrier mastic applied in a Z-shaped pattern over insulation face, along butt end of insulation, and over the surface. Cover insulation face and surface to be insulated a width equal to two times the insulation thickness, but not less than 3 inches.
- 5. Overlap unfaced blankets a minimum of 2 inches on longitudinal seams and end joints. At end joints, secure with steel bands spaced a maximum of 18 inches o.c.
- 6. Install insulation on rectangular duct elbows and transitions with a full insulation section for each surface. Install insulation on round and flat-oval duct elbows with individually mitered gores cut to fit the elbow.
- 7. Insulate duct stiffeners, hangers, and flanges that protrude beyond insulation surface with 6-inch-wide strips of same material used to insulate duct. Secure on alternating sides of stiffener, hanger, and flange with pins spaced 6 inches o.c.

## **2.6 FIELD QUALITY CONTROL**

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Tests and Inspections:
  - 1. Inspect ductwork, randomly selected by Architect, by removing field-applied jacket and insulation in layers in reverse order of their installation. Extent of inspection shall be limited to one location(s) for each duct system defined in the "Duct Insulation Schedule, General" Article.
- C. All insulation applications will be considered defective Work if sample inspection reveals noncompliance with requirements.

## **2.7 DUCT INSULATION SCHEDULE, GENERAL**

- A. Plenums and Ducts Requiring Insulation:
  - 1. Indoor, concealed supply air.
- B. Items Not Insulated:
  - 1. Metal ducts with duct liner of sufficient thickness to comply with energy code and ASHRAE/IESNA 90.1.
  - 2. Factory-insulated flexible ducts.
  - 3. Factory-insulated plenums and casings.
  - 4. Flexible connectors.
  - 5. Vibration-control devices.
  - 6. Factory-insulated access panels and doors.

## **2.8 INDOOR DUCT AND PLENUM INSULATION SCHEDULE**

- A. Concealed, round and flat-oval, supply-air duct insulation shall be one of the following:
  - 1. Mineral-Fiber Blanket: 1-1/2 inches thick, R-4.2.
- B. Concealed, rectangular, supply-air duct insulation shall be one of the following:

1. Mineral-Fiber Blanket: 1-1/2 inches thick, R-4.2.
  2. Mineral-Fiber Board: 1-1/2 inches thick, R-4.2
- C. Concealed, supply-air and return-air plenum insulation shall be one of the following:
1. Mineral-Fiber Blanket: 1-1/2 inches thick, R-4.2.
  2. Mineral-Fiber Board: 1-1/2 inches thick, R-4.2.

END OF SECTION

**SECTION 23 07 19**  
**HVAC PIPING INSULATION**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

**1.02 SUMMARY**

- A. Section includes insulating the following HVAC piping systems:
  - 1. Condensate drain piping, indoors and outdoors.
  - 2. Refrigerant suction, liquid and hot-gas piping, indoors and outdoors.
- B. Related Sections:
  - 1. Section 230713 "Duct Insulation."

**1.03 ACTION SUBMITTALS**

- A. Product Data: For each type of product indicated. Include thermal conductivity, water-vapor permeance thickness, and jackets (both factory and field applied if any).
- B. Product Data for California Green Building Standards Code Compliance: For adhesives and sealants, including primers, documentation of compliance including printed statement of VOC content and chemical components.
- C. Product data for insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings, indicating compliance with requirement that these products contain less than 0.1 percent (by mass) polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations.
- D. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Detail application of protective shields, saddles, and inserts at hangers for each type of insulation and hanger.
  - 2. Detail insulation application at pipe expansion joints for each type of insulation.
  - 3. Detail insulation application at elbows, fittings, flanges, valves, and specialties for each type of insulation.
  - 4. Detail removable insulation at piping specialties.
  - 5. Detail application of field-applied jackets.
  - 6. Detail application at linkages of control devices.

**1.04 INFORMATIONAL SUBMITTALS**

- A. Qualification Data: For qualified Installer.
- B. Material Test Reports: From a qualified testing agency acceptable to authorities having jurisdiction indicating, interpreting, and certifying test results for compliance of insulation materials, sealers, attachments, cements, and jackets, with requirements indicated. Include dates of tests and test methods employed.

- C. Field quality-control reports.

### **1.05 QUALITY ASSURANCE**

- A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or another craft training program certified by the Department of Labor, Bureau of Apprenticeship and Training.
- B. Surface-Burning Characteristics: For insulation and related materials, as determined by testing identical products according to ASTM E 84, by a testing and inspecting agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing agency.
  - 1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.
  - 2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.

### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Packaging: Insulation material containers shall be marked by manufacturer with appropriate ASTM standard designation, type and grade, and maximum use temperature.

### **1.07 COORDINATION**

- A. Coordinate sizes and locations of supports, hangers, and insulation shields specified in Section 230529 "Hangers and Supports for HVAC Piping and Equipment."
- B. Coordinate clearance requirements with piping Installer for piping insulation application. Before preparing piping Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes and for space required for maintenance.

### **1.08 SCHEDULING**

- A. Schedule insulation application after pressure testing systems. Insulation application may begin on segments that have satisfactory test results.
- B. Complete installation and concealment of plastic materials as rapidly as possible in each area of construction.

## **PART 2 - PRODUCTS**

### **2.01 INSULATION MATERIALS**

- A. Comply with requirements in "Piping Insulation Schedule, General," "Indoor Piping Insulation Schedule," "Outdoor, Aboveground Piping Insulation Schedule," and "Outdoor, Underground Piping Insulation Schedule" articles for where insulating materials shall be applied.
- B. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).
- C. Products shall not contain asbestos, lead, mercury, or mercury compounds.

- D. Products that come in contact with stainless steel shall have a leachable chloride content of less than 50 ppm when tested according to ASTM C 871.
- E. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C 795.
- F. Foam insulation materials shall not use CFC or HCFC blowing agents in the manufacturing process.
- G. Flexible Elastomeric Insulation: Closed-cell, sponge- or expanded-rubber materials. Comply with ASTM C 534, Type I for tubular materials.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Aeroflex USA, Inc.
    - b. Armacell LLC.
    - c. K-Flex USA.
- H. Mineral-Fiber, Preformed Pipe Insulation:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Johns Manville; a Berkshire Hathaway company.
    - b. Knauf Insulation.
    - c. Manson Insulation Inc.
    - d. Owens Corning.
  - 2. Type I, 850 deg F Materials: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 547, Type I, Grade A, with factory-applied ASJ. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.

## 2.02 INSULATING CEMENTS

- A. Mineral-Fiber Insulating Cement: Comply with ASTM C 195.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Ramco Insulation, Inc.
- B. Expanded or Exfoliated Vermiculite Insulating Cement: Comply with ASTM C 196.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Ramco Insulation, Inc.
- C. Mineral-Fiber, Hydraulic-Setting Insulating and Finishing Cement: Comply with ASTM C 449.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Ramco Insulation, Inc.

## 2.03 ADHESIVES

- A. Materials shall be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated unless otherwise indicated.
- B. Flexible Elastomeric Adhesive: Comply with MIL-A-24179A, Type II, Class I.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Aeroflex USA, Inc.
    - b. Armacell LLC.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. K-Flex USA.
  - 2. For indoor applications, adhesive shall have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 3. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- C. Mineral-Fiber Adhesive: Comply with MIL-A-3316C, Class 2, Grade A.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. Mon-Eco Industries, Inc.
  - 2. Fiberglass adhesive shall have a VOC content of 80 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 3. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- D. ASJ Adhesive: Comply with MIL-A-3316C, Class 2, Grade A for bonding insulation jacket lap seams and joints.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. Mon-Eco Industries, Inc.
  - 2. Adhesive shall have a VOC content of 80 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 3. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.

## 2.04 MASTICS

- A. Materials shall be compatible with insulation materials, jackets, and substrates; comply with MIL-PRF-19565C, Type II.
  - 1. VOC Content: 300 g/L or less.
- B. Vapor-Barrier Mastic: Water based; suitable for indoor use on below-ambient services.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Foster Brand; H. B. Fuller Construction Products.
    - b. Vimasco Corporation.
  - 2. Water-Vapor Permeance: ASTM E 96/E 96M, Procedure B, 0.013 perm at 43-mil dry film thickness.
  - 3. Service Temperature Range: Minus 20 to plus 180 deg F.
  - 4. Solids Content: ASTM D 1644, 58 percent by volume and 70 percent by weight.
  - 5. Color: White.
- C. Vapor-Barrier Mastic: Solvent based; suitable for outdoor use on below-ambient services.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
  - 2. Water-Vapor Permeance: ASTM F 1249, 0.05 perm at 30-mil dry film thickness.
  - 3. Service Temperature Range: Minus 50 to plus 220 deg F.
  - 4. Solids Content: ASTM D 1644, 33 percent by volume and 46 percent by weight.
  - 5. Color: White.
- D. Breather Mastic: Water based; suitable for indoor and outdoor use on above-ambient services.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. Mon-Eco Industries, Inc.
    - e. Vimasco Corporation.
  - 2. Water-Vapor Permeance: ASTM F 1249, 1.8 perms at 0.0625-inch dry film thickness.
  - 3. Service Temperature Range: Minus 20 to plus 180 deg F.
  - 4. Solids Content: 60 percent by volume and 66 percent by weight.
  - 5. Color: White.



## 2.05 LAGGING ADHESIVES

- A. Description: Comply with MIL-A-3316C, Class I, Grade A and shall be compatible with insulation materials, jackets, and substrates.
  - 1. Adhesives shall have a VOC content of 50 g/L or less.
  - 2. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
  - 3. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Foster Brand; H. B. Fuller Construction Products.
    - c. Vimasco Corporation.
  - 4. Fire-resistant, water-based lagging adhesive and coating for use indoors to adhere fire-resistant lagging cloths over pipe insulation.
  - 5. Service Temperature Range: 0 to plus 180 deg F.
  - 6. Color: White.

## 2.06 SEALANTS

- A. Metal Jacket Flashing Sealants:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. Eagle Bridges - Marathon Industries.
    - c. Foster Brand; H. B. Fuller Construction Products.
    - d. Mon-Eco Industries, Inc.
  - 2. Materials shall be compatible with insulation materials, jackets, and substrates.
  - 3. Fire- and water-resistant, flexible, elastomeric sealant.
  - 4. Service Temperature Range: Minus 40 to plus 250 deg F.
  - 5. Color: Aluminum.
  - 6. Sealant shall have a VOC content of 420 g/L or less.
  - 7. Sealant shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- B. ASJ Flashing Sealants:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
  - 2. Materials shall be compatible with insulation materials, jackets, and substrates.
  - 3. Fire- and water-resistant, flexible, elastomeric sealant.
  - 4. Service Temperature Range: Minus 40 to plus 250 deg F.

5. Color: White.
6. Sealant shall have a VOC content of 420 g/L or less.
7. Sealant shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.

#### **2.07 FACTORY-APPLIED JACKETS**

- A. Insulation system schedules indicate factory-applied jackets on various applications. When factory-applied jackets are indicated, comply with the following:
  1. ASJ: White, kraft-paper, fiberglass-reinforced scrim with aluminum-foil backing; complying with ASTM C 1136, Type I.

#### **2.08 FIELD-APPLIED FABRIC-REINFORCING MESH**

- A. Woven Glass-Fiber Fabric: Approximately 2 oz./sq. yd. with a thread count of 10 strands by 10 strands/sq. in. for covering pipe and pipe fittings.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
- B. Woven Polyester Fabric: Approximately 1 oz./sq. yd. with a thread count of 10 strands by 10 strands/sq. in., in a Leno weave, for pipe.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Foster Brand; H. B. Fuller Construction Products.
    - b. Vimasco Corporation.

#### **2.09 FIELD-APPLIED CLOTHS**

- A. Woven Glass-Fiber Fabric: Comply with MIL-C-20079H, Type I, plain weave, and presized a minimum of 8 oz./sq. yd..
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Alpha Associates, Inc.

#### **2.10 FIELD-APPLIED JACKETS**

- A. Field-applied jackets shall comply with ASTM C 921, Type I, unless otherwise indicated.
- B. PVC Jacket: High-impact-resistant, UV-resistant PVC complying with ASTM D 1784, Class 16354-C; thickness as scheduled; roll stock ready for shop or field cutting and forming. Thickness is indicated in field-applied jacket schedules.
  1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Johns Manville; a Berkshire Hathaway company.
    - b. P.I.C. Plastics, Inc.
    - c. Proto Corporation.

- d. Speedline Corporation.
  - 2. Adhesive: As recommended by jacket material manufacturer.
  - 3. Color: White.
  - 4. Factory-fabricated fitting covers to match jacket if available; otherwise, field fabricate.
    - a. Shapes: 45- and 90-degree, short- and long-radius elbows, tees, valves, flanges, unions, reducers, end caps, soil-pipe hubs, traps, mechanical joints, and P-trap and supply covers for lavatories.
- C. Metal Jacket:
- 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Childers Brand; H. B. Fuller Construction Products.
    - b. ITW Insulation Systems; Illinois Tool Works, Inc.
    - c. RPR Products, Inc.
  - 2. Aluminum Jacket: Comply with ASTM B 209, Alloy 3003, 3005, 3105, or 5005, Temper H-14.
    - a. Sheet and roll stock ready for shop or field sizing or Factory cut and rolled to size.
    - b. Finish and thickness are indicated in field-applied jacket schedules.
    - c. Moisture Barrier for Indoor Applications: 2.5-mil- thick polysurlyn.
    - d. Moisture Barrier for Outdoor Applications: 2.5-mil- thick polysurlyn.
    - e. Factory-Fabricated Fitting Covers:
      - 1) Same material, finish, and thickness as jacket.
      - 2) Preformed 2-piece or gore, 45- and 90-degree, short- and long-radius elbows.
      - 3) Tee covers.
      - 4) Flange and union covers.
      - 5) End caps.
      - 6) Beveled collars.
      - 7) Valve covers.
      - 8) Field fabricate fitting covers only if factory-fabricated fitting covers are not available.

## 2.11 TAPES

- A. ASJ Tape: White vapor-retarder tape matching factory-applied jacket with acrylic adhesive, complying with ASTM C 1136.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Avery Dennison Corporation, Specialty Tapes Division.
    - b. Compac Corporation.

- c. Ideal Tape Co., Inc.; an American Biltrite company.
    - d. Knauf Insulation.
    - e. Venture Tape.
  - 2. Width: 3 inches.
  - 3. Thickness: 11.5 mils.
  - 4. Adhesion: 90 ounces force/inch in width.
  - 5. Elongation: 2 percent.
  - 6. Tensile Strength: 40 lbf/inch in width.
  - 7. ASJ Tape Disks and Squares: Precut disks or squares of ASJ tape.
- B. Aluminum-Foil Tape: Vapor-retarder tape with acrylic adhesive.
- 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Avery Dennison Corporation, Specialty Tapes Division.
    - b. Compac Corporation.
    - c. Ideal Tape Co., Inc.; an American Biltrite company.
    - d. Knauf Insulation.
    - e. Venture Tape.
  - 2. Width: 2 inches.
  - 3. Thickness: 3.7 mils.
  - 4. Adhesion: 100 ounces force/inch in width.
  - 5. Elongation: 5 percent.
  - 6. Tensile Strength: 34 lbf/inch in width.

## 2.12 SECUREMENTS

- A. Bands:
- 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. ITW Insulation Systems; Illinois Tool Works, Inc.
    - b. RPR Products, Inc.
  - 2. Aluminum: ASTM B 209, Alloy 3003, 3005, 3105, or 5005; Temper H-14, 0.020 inch thick, 3/4 inch wide with wing seal or closed seal.
  - 3. Springs: Twin spring set constructed of stainless steel with ends flat and slotted to accept metal bands. Spring size determined by manufacturer for application.
- B. Staples: Outward-clinching insulation staples, nominal 3/4-inch- wide, stainless steel or Monel.
- C. Wire: 0.062-inch soft-annealed, stainless steel.
- 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:

- a. C & F Wire.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine substrates and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of insulation application.
  - 1. Verify that systems to be insulated have been tested and are free of defects.
  - 2. Verify that surfaces to be insulated are clean and dry.
  - 3. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 PREPARATION**

- A. Surface Preparation: Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.
- B. Mix insulating cements with clean potable water; if insulating cements are to be in contact with stainless-steel surfaces, use demineralized water.

### **3.03 GENERAL INSTALLATION REQUIREMENTS**

- A. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of piping including fittings, valves, and specialties.
- B. Install insulation materials, forms, vapor barriers or retarders, jackets, and thicknesses required for each item of pipe system as specified in insulation system schedules.
- C. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, soften, or otherwise attack insulation or jacket in either wet or dry state.
- D. Install insulation with longitudinal seams at top and bottom of horizontal runs.
- E. Install multiple layers of insulation with longitudinal and end seams staggered.
- F. Do not weld brackets, clips, or other attachment devices to piping, fittings, and specialties.
- G. Keep insulation materials dry during application and finishing.
- H. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- I. Install insulation with least number of joints practical.
- J. Where vapor barrier is indicated, seal joints, seams, and penetrations in insulation at hangers, supports, anchors, and other projections with vapor-barrier mastic.
  - 1. Install insulation continuously through hangers and around anchor attachments.
  - 2. For insulation application where vapor barriers are indicated, extend insulation on anchor legs from point of attachment to supported item to point of attachment to structure. Taper and seal ends at attachment to structure with vapor-barrier mastic.
  - 3. Install insert materials and install insulation to tightly join the insert. Seal insulation to insulation inserts with adhesive or sealing compound recommended by insulation material manufacturer.

4. Cover inserts with jacket material matching adjacent pipe insulation. Install shields over jacket, arranged to protect jacket from tear or puncture by hanger, support, and shield.
- K. Apply adhesives, mastics, and sealants at manufacturer's recommended coverage rate and wet and dry film thicknesses.
- L. Install insulation with factory-applied jackets as follows:
1. Draw jacket tight and smooth.
  2. Cover circumferential joints with 3-inch- wide strips, of same material as insulation jacket. Secure strips with adhesive and outward clinching staples along both edges of strip, spaced 4 inches o.c.
  3. Overlap jacket longitudinal seams at least 1-1/2 inches. Install insulation with longitudinal seams at bottom of pipe. Clean and dry surface to receive self-sealing lap. Staple laps with outward clinching staples along edge at 2 inches o.c.
    - a. For below-ambient services, apply vapor-barrier mastic over staples.
  4. Cover joints and seams with tape, according to insulation material manufacturer's written instructions, to maintain vapor seal.
  5. Where vapor barriers are indicated, apply vapor-barrier mastic on seams and joints and at ends adjacent to pipe flanges and fittings.
- M. Cut insulation in a manner to avoid compressing insulation more than 75 percent of its nominal thickness.
- N. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- O. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches beyond damaged areas. Adhere, staple, and seal patches similar to butt joints.
- P. For above-ambient services, do not install insulation to the following:
1. Vibration-control devices.
  2. Testing agency labels and stamps.
  3. Nameplates and data plates.
  4. Manholes.
  5. Handholes.
  6. Cleanouts.

### **3.04 PENETRATIONS**

- A. Insulation Installation at Roof Penetrations: Install insulation continuously through roof penetrations.
1. Seal penetrations with flashing sealant.
  2. For applications requiring only indoor insulation, terminate insulation above roof surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.

3. Extend jacket of outdoor insulation outside roof flashing at least 2 inches below top of roof flashing.
  4. Seal jacket to roof flashing with flashing sealant.
- B. Insulation Installation at Aboveground Exterior Wall Penetrations: Install insulation continuously through wall penetrations.
1. Seal penetrations with flashing sealant.
  2. For applications requiring only indoor insulation, terminate insulation inside wall surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
  3. Extend jacket of outdoor insulation outside wall flashing and overlap wall flashing at least 2 inches.
  4. Seal jacket to wall flashing with flashing sealant.
- C. Insulation Installation at Interior Wall and Partition Penetrations (That Are Not Fire Rated): Install insulation continuously through walls and partitions.
- D. Insulation Installation at Fire-Rated Wall and Partition Penetrations: Install insulation continuously through penetrations of fire-rated walls and partitions.
1. Comply with requirements in Section 078400 "Firestopping" for firestopping and fire-resistive joint sealers.
- E. Insulation Installation at Floor Penetrations:
1. Pipe: Install insulation continuously through floor penetrations.
  2. Seal penetrations through fire-rated assemblies. Comply with requirements in Section 078400 "Firestopping."

### **3.05 GENERAL PIPE INSULATION INSTALLATION**

- A. Requirements in this article generally apply to all insulation materials except where more specific requirements are specified in various pipe insulation material installation articles.
- B. Insulation Installation on Fittings, Valves, Strainers, Flanges, and Unions:
1. Install insulation over fittings, valves, strainers, flanges, unions, and other specialties with continuous thermal and vapor-retarder integrity unless otherwise indicated.
  2. Insulate pipe elbows using preformed fitting insulation or mitered fittings made from same material and density as adjacent pipe insulation. Each piece shall be butted tightly against adjoining piece and bonded with adhesive. Fill joints, seams, voids, and irregular surfaces with insulating cement finished to a smooth, hard, and uniform contour that is uniform with adjoining pipe insulation.
  3. Insulate tee fittings with preformed fitting insulation or sectional pipe insulation of same material and thickness as used for adjacent pipe. Cut sectional pipe insulation to fit. Butt each section closely to the next and hold in place with tie wire. Bond pieces with adhesive.
  4. Insulate valves using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. For valves, insulate up to and including the bonnets, valve

- stuffing-box studs, bolts, and nuts. Fill joints, seams, and irregular surfaces with insulating cement.
5. Insulate strainers using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. Fill joints, seams, and irregular surfaces with insulating cement. Insulate strainers so strainer basket flange or plug can be easily removed and replaced without damaging the insulation and jacket. Provide a removable reusable insulation cover. For below-ambient services, provide a design that maintains vapor barrier.
  6. Insulate flanges and unions using a section of oversized preformed pipe insulation. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker.
  7. Cover segmented insulated surfaces with a layer of finishing cement and coat with a mastic. Install vapor-barrier mastic for below-ambient services and a breather mastic for above-ambient services. Reinforce the mastic with fabric-reinforcing mesh. Trowel the mastic to a smooth and well-shaped contour.
  8. For services not specified to receive a field-applied jacket except for flexible elastomeric and polyolefin, install fitted PVC cover over elbows, tees, strainers, valves, flanges, and unions. Terminate ends with PVC end caps. Tape PVC covers to adjoining insulation facing using PVC tape.
  9. Stencil or label the outside insulation jacket of each union with the word "union." Match size and color of pipe labels.
- C. Insulate instrument connections for thermometers, pressure gages, pressure temperature taps, test connections, flow meters, sensors, switches, and transmitters on insulated pipes. Shape insulation at these connections by tapering it to and around the connection with insulating cement and finish with finishing cement, mastic, and flashing sealant.
- D. Install removable insulation covers at locations indicated. Installation shall conform to the following:
1. Make removable flange and union insulation from sectional pipe insulation of same thickness as that on adjoining pipe. Install same insulation jacket as adjoining pipe insulation.
  2. When flange and union covers are made from sectional pipe insulation, extend insulation from flanges or union long at least two times the insulation thickness over adjacent pipe insulation on each side of flange or union. Secure flange cover in place with stainless-steel or aluminum bands. Select band material compatible with insulation and jacket.
  3. Construct removable valve insulation covers in same manner as for flanges, except divide the two-part section on the vertical center line of valve body.
  4. When covers are made from block insulation, make two halves, each consisting of mitered blocks wired to stainless-steel fabric. Secure this wire frame, with its attached insulation, to flanges with tie wire. Extend insulation at least 2 inches over adjacent pipe insulation on each side of valve. Fill space between flange or union cover and pipe insulation with insulating cement. Finish cover assembly with insulating cement applied in two coats. After first coat is dry, apply and trowel second coat to a smooth finish.



5. Unless a PVC jacket is indicated in field-applied jacket schedules, finish exposed surfaces with a metal jacket.

### **3.06 INSTALLATION OF FLEXIBLE ELASTOMERIC INSULATION**

- A. Seal longitudinal seams and end joints with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- B. Insulation Installation on Pipe Flanges:
  1. Install pipe insulation to outer diameter of pipe flange.
  2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
  3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of sheet insulation of same thickness as pipe insulation.
  4. Secure insulation to flanges and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- C. Insulation Installation on Pipe Fittings and Elbows:
  1. Install mitered sections of pipe insulation.
  2. Secure insulation materials and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- D. Insulation Installation on Valves and Pipe Specialties:
  1. Install preformed valve covers manufactured of same material as pipe insulation when available.
  2. When preformed valve covers are not available, install cut sections of pipe and sheet insulation to valve body. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  3. Install insulation to flanges as specified for flange insulation application.
  4. Secure insulation to valves and specialties and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

### **3.07 INSTALLATION OF MINERAL-FIBER INSULATION**

- A. Insulation Installation on Straight Pipes and Tubes:
  1. Secure each layer of preformed pipe insulation to pipe with wire or bands and tighten bands without deforming insulation materials.
  2. Where vapor barriers are indicated, seal longitudinal seams, end joints, and protrusions with vapor-barrier mastic and joint sealant.
  3. For insulation with factory-applied jackets on above-ambient surfaces, secure laps with outward-clinched staples at 6 inches o.c.
  4. For insulation with factory-applied jackets on below-ambient surfaces, do not staple longitudinal tabs. Instead, secure tabs with additional adhesive as recommended by insulation material manufacturer and seal with vapor-barrier mastic and flashing sealant.
- B. Insulation Installation on Pipe Flanges:

1. Install preformed pipe insulation to outer diameter of pipe flange.
  2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
  3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with mineral-fiber blanket insulation.
  4. Install jacket material with manufacturer's recommended adhesive, overlap seams at least 1 inch, and seal joints with flashing sealant.
- C. Insulation Installation on Pipe Fittings and Elbows:
1. Install preformed sections of same material as straight segments of pipe insulation when available.
  2. When preformed insulation elbows and fittings are not available, install mitered sections of pipe insulation, to a thickness equal to adjoining pipe insulation. Secure insulation materials with wire or bands.
- D. Insulation Installation on Valves and Pipe Specialties:
1. Install preformed sections of same material as straight segments of pipe insulation when available.
  2. When preformed sections are not available, install mitered sections of pipe insulation to valve body.
  3. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  4. Install insulation to flanges as specified for flange insulation application.

### **3.08 FIELD-APPLIED JACKET INSTALLATION**

- A. Where metal jackets are indicated, install with 2-inch overlap at longitudinal seams and end joints. Overlap longitudinal seams arranged to shed water. Seal end joints with weatherproof sealant recommended by insulation manufacturer. Secure jacket with stainless-steel bands 12 inches o.c. and at end joints.

### **3.09 FINISHES**

- A. Flexible Elastomeric Thermal Insulation: After adhesive has fully cured, apply two coats of insulation manufacturer's recommended protective coating.
- B. Do not field paint aluminum jackets.

### **3.10 FIELD QUALITY CONTROL**

- A. Testing Agency: Owner will engage a qualified testing agency to perform tests and inspections.
- B. Perform tests and inspections.
- C. Tests and Inspections:
1. Inspect pipe, fittings, strainers, and valves, randomly selected by Architect, by removing field-applied jacket and insulation in layers in reverse order of their installation. Extent of inspection shall be limited to three locations of straight pipe, three locations of threaded fittings, three locations of welded fittings, two locations of threaded strainers, two locations of welded strainers, three locations of threaded valves, and three locations of

flanged valves for each pipe service defined in the "Piping Insulation Schedule, General" Article.

- D. All insulation applications will be considered defective Work if sample inspection reveals noncompliance with requirements.

### **3.11 PIPING INSULATION SCHEDULE, GENERAL**

- A. Acceptable preformed pipe and tubular insulation materials and thicknesses are identified for each piping system and pipe size range. If more than one material is listed for a piping system, selection from materials listed is Contractor's option.

### **3.12 INDOOR PIPING INSULATION SCHEDULE**

- A. Condensate and Equipment Drain Water below 60 Deg F:
  - 1. All Pipe Sizes: Insulation shall be the following:
    - a. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1 inch thick.
- B. Refrigerant Suction, Liquid, and Hot-Gas Piping:
  - 1. NPS 3/4 and Smaller: Insulation shall be the following:
    - a. Flexible Elastomeric: 1 inch thick.
  - 2. NPS 1 and Larger: Insulation shall be the following:
    - a. Flexible Elastomeric: 1-1/2 inches thick.
- C. Refrigerant Suction, Liquid, and Hot-Gas Flexible Tubing:
  - 1. NPS 3/4 and Smaller: Insulation shall be the following:
    - a. Flexible Elastomeric: 1 inch thick.
  - 2. NPS 1 and Larger: Insulation shall be the following:
    - a. Flexible Elastomeric: 1-1/2 inches thick.

### **3.13 OUTDOOR, ABOVEGROUND PIPING INSULATION SCHEDULE**

- A. Refrigerant Suction, Liquid, and Hot-Gas Piping:
  - 1. All Pipe Sizes: Insulation shall be the following:
    - a. Flexible Elastomeric: 2 inches thick.
- B. Refrigerant Suction, Liquid, and Hot-Gas Flexible Tubing:
  - 1. All Pipe Sizes: Insulation shall be the following:
    - a. Flexible Elastomeric: 2 inches thick.

### **3.14 INDOOR, FIELD-APPLIED JACKET SCHEDULE**

- A. Install jacket over insulation material. For insulation with factory-applied jacket, install the field-applied jacket over the factory-applied jacket.
- B. If more than one material is listed, selection from materials listed is Contractor's option.
- C. Piping, Concealed:
  - 1. None.

- D. Piping, Exposed:
  - 1. PVC: 30 mils thick

### **3.15 OUTDOOR, FIELD-APPLIED JACKET SCHEDULE**

- A. Install jacket over insulation material. For insulation with factory-applied jacket, install the field-applied jacket over the factory-applied jacket.
- B. If more than one material is listed, selection from materials listed is Contractor's option.
- C. Piping, Exposed:
  - 1. Aluminum, Smooth with Z-Shaped Locking Seam: 0.040 inch thick.

### **3.16 PIPE PROTECTION**

- A. Field-installed insulation jacket may be omitted for manufactured, pre-charged and pre-insulated refrigerant line-set piping run in rigid or flexible conduit.
- B. Field-installed insulation jacket may be omitted for field-assembled refrigerant piping run in rigid or flexible conduit.
- C. Refer to Article, Piping Installation, in Section 232300 "Refrigerant Piping," for refrigerant pipe protection requirements.

END OF SECTION



**SECTION 23 09 23**  
**DIRECT DIGITAL CONTROL SYSTEM FOR HVAC**

**PART 1 - GENERAL**

**1.01 WORK INCLUDED**

- A. Furnish a campus standard Alerton Compass System, The operator's workstation, all building controllers, application controllers, and all input/output devices shall communicate using the protocols and network standards as defined by ANSI/ ASHRAE Standard 135-2008, BACnet. All workstations and controllers, including unitary controllers, shall be native BACnet MSTP or BACnet IP devices. No gateways shall be used for communication to controllers installed under this section. Gateways may be used for communication to existing systems or to systems installed under other sections.
- B. Provide all necessary BACnet-compliant hardware and software to meet the system's functional specifications. Provide Protocol Implementation Conformance Statement (PICS) for Windows-based control software and every controller in system, including unitary controllers.
- C. Prepare individual hardware layouts, interconnection drawings, and software configuration from project design data.
- D. Implement the detailed design for all analog and binary objects, system databases, graphic displays, logs, and management reports based on control descriptions, logic drawings, configuration data, and bid documents.
- E. Design, provide, and install all equipment cabinets, panels, data communication network cables needed, and all associated hardware.
- F. Provide and install all interconnecting cables between supplied cabinets, application controllers, and input/output devices.
- G. Provide and install all interconnecting cables between all operator's terminals and peripheral devices (such as printers, etc.) supplied under this section.
- H. Provide complete manufacturer's specifications for all items that are supplied. Include vendor name of every item supplied.
- I. Provide supervisory specialists and technicians at the job site to assist in all phases of system installation, startup, and commissioning.
- J. Provide a comprehensive operator and technician training program as described herein.
- K. Provide as-built documentation, operator's terminal software, diagrams, and all other associated project operational documentation (such as technical manuals) on approved media, the sum total of which accurately represents the final system.
- L. Provide new sensors, dampers, valves, and install only new electronic actuators. No used components shall be used as any part or piece of installed system.
- M. Include as an added bid item the cost of the service contract for the remote monitoring of all BMS controlled systems in the building.
- N. Include as an added bid item the cost of the scheduling modifications and refinement with the tenant.

**1.02 SYSTEM DESCRIPTION**

- A. A distributed logic control system complete with all software and hardware functions shall be provided and installed. System shall be completely based on ANSI/ASH RAE Standard 135-2008, BACnet and achieved listing under the BACnet Testing Laboratories BACnet - Advanced Workstation Software (B-AWS). This system is to control all mechanical equipment, including all unitary equipment such as VAV boxes, AC units, etc., and all air handlers, boilers, lighting control panels, UPS, generators, building elevators, and any other listed equipment using native BACnet-compliant components. Non-BACnet-compliant or proprietary equipment or systems (including gateways) shall not be acceptable and are specifically prohibited.
- B. Provide integration to the lighting system through BACnet IP protocol so the lighting can be scheduled through the DOC system and include graphics that show whether lights are on or off on the floor plans. The DOC system shall be able to interface with the lighting control panel to facilitate scheduling, automatic daylight saving time adjustments, etc.
- C. Operator's workstation software shall use Microsoft Windows 8 or Windows 10 as the computer operating system. The Direct Digital Control system (DOC) application program shall be written to communicate specifically utilizing BACnet protocols. Software functions delivered on this project shall include password protection, scheduling (including optimum start), alarming, logging of historical data, full graphics including animation, after-hours billing program, demand limiting, and a full suite of field engineering tools including graphical programming and applications. Systems using operating systems other than that described above are strictly prohibited. All software required to program application specific controllers and all field level devices and controllers will be left with the owner. All software passwords required to program and make future changes to the system will also become the property of the owner. All software required to make any program changes anywhere in the system, along with scheduling and trending applications, will be left with the owner. All software passwords required to program and make future changes to schedules, trends and related program changes will also become the property of the owner. All software required for all field engineering tools including graphical programming and applications will be left with the owner. All software passwords required to program and make future changes to field engineering tools, including graphical programming and applications will be left with the owner.
- D. Building controllers shall include complete energy management software, including scheduling building control strategies with optimum start and logging routines. All energy management software and firmware shall be resident in field hardware and shall not be dependent on the operator's terminal. Operator's terminal software is to be used for access to field-based energy management functions only. Provide zone-by-zone direct digital logic control of space temperature, scheduling, runtime accumulation, equipment alarm reporting, and override timers for after-hours usage.
- E. Room sensors shall be provided with digital readout that allows the user to view room temperature and humidity, adjust the room setpoint within preset limits and set desired override time. User shall also be able to start and stop unit from the digital sensor. Include all necessary wiring and firmware such that room sensor includes field service mode. Field service mode shall allow a technician to balance VAV zones and access any parameter in zone controller directly from the room sensor. Field service mode shall have the ability to be locked out.
- F. All application controllers for every terminal unit (VAV, FCU, etc.) air handler, all central plant equipment, and any other piece of controlled equipment shall be fully programmable. Application controllers shall be mounted next to controlled equipment and communicate with building controller through BACnet MSTP.

### **1.03 APPROVED MANUFACTURERS**

- A. Approved Control Manufacturers
  - 1. Alerton Compass (integrated into existing Alerton Compass network)
  - 2. Other systems will not be accepted.

### **1.04 QUALITY ASSURANCE**

- A. The Building Automation System (BAS) system shall be designed, installed, commissioned, and serviced by manufacturer authorized and trained personnel. System provider shall have an in-place support facility within 2 hours' response time of the site with technical staff, spare parts inventory, and necessary test and diagnostic equipment.
- B. The contractor shall provide full-time, on-site, experienced project manager for this work, responsible for direct supervision of the design, installation, start-up and commissioning of the BAS system.
- C. The Bidder shall be regularly engaged in the design, installation and maintenance of BAS systems and shall have demonstrated technical expertise and experience in the design, installation and maintenance of BAS systems similar in size and complexity to this project.
- D. Materials and equipment shall be manufacturer's latest standard design that complies with the specification requirements.
- E. All BAS peer-to-peer network controllers, central system controllers and local user displays shall be UL Listed under Standard UL 916, category PAZX.
- F. All electronic equipment shall conform to the requirements of FCC Regulation, Part 15, Governing Radio Frequency Electromagnetic Interference and be so labeled.
- G. Control system shall be engineered, programmed and supported completely by representative's local office

### **1.05 REFERENCE STANDARDS**

- A. The latest edition of the following standards and codes in effect and amended as of supplier's proposal date, and any applicable subsections thereof, shall govern design and selection of equipment and material supplied:
  - 1. American Society of Heating, Refrigerating and Air Conditioning Engineers (ASHRAE).
  - 2. ANSI/ASHRAE Standard 135-2008, BACnet.
  - 3. Uniform Building Code (UBC), including local amendments.
  - 4. UL 916 Underwriters Laboratories Standard for Energy Management Equipment. Canada and the US.
  - 5. National Electrical Code (NEC).
  - 6. FCC Part 15, Subpart J, Class A
  - 7. EMC Directive 89/336/EEC (European CE Mark).
  - 8. UL-864 UUKL listing for Smoke Controls for any equipment used in smoke control sequences.
- B. City, county, state, and federal regulations and codes in effect as of contract date.



- C. Except as otherwise indicated, the system supplier shall secure and pay for all permits, inspections, and certifications required for his work, and arrange for necessary approvals by the governing authorities.

#### **1.06 SUBMITTALS**

- A. Drawings
  - 1. The system supplier shall submit engineered drawings, control sequence, and bill of materials for approval.
  - 2. Drawings shall be submitted in the following standard sizes: 11" x 17" (ANSI B).
  - 3. Eight complete sets (copies) of submittal drawings shall be provided.
  - 4. Drawings shall be available on CD-ROM.
- B. System Documentation: Include the following in submittal package:
  - 1. System configuration diagrams in simplified block format.
  - 2. All input/output object listings and an alarm point summary listing.
  - 3. Electrical drawings that show all system internal and external connection points, terminal block layouts, and terminal identification.
  - 4. Complete bill of materials, valve schedule and damper schedule.
  - 5. Manufacturer's instructions and drawings for installation, maintenance, and operation of all purchased items.
  - 6. Overall system operation and maintenance instructions- including preventive maintenance and troubleshooting instructions.
  - 7. For all system elements-operator's workstation(s), building controller(s), application controllers, routers, and repeaters- provide BACnet Protocol Implementation Conformance Statements (PICS) as per ANSI/ ASH RAE Standard 135-2001.
  - 8. Provide complete description and documentation of any proprietary (non-BACnet) services and/or objects used in the system.
  - 9. A list of all functions available and a sample of function block programming that shall be part of delivered system.
- C. Project Management
  - 1. The vendor shall provide a detailed project design and installation schedule with time markings and details for hardware items and software development phases. Schedule shall show all the target dates for transmission of project information and documents, and shall indicate timing and dates for system installation, debugging, and commissioning.

#### **1.07 WARRANTY**

- A. Warranty shall cover all costs for parts, labor, associated travel, and expenses for a period of one year from completion of system acceptance.
- B. Hardware and software personnel supporting this warranty agreement shall provide on-site or off-site service in a timely manner after failure notification to the vendor. The maximum acceptable response time to provide this service at the site shall be 24 hours, Monday through Friday and 48 hours on Saturday and Sunday.
- C. This warranty shall apply equally to both hardware and software.

## PART 2 - PRODUCTS

### 2.01 OPERATOR'S WORKSTATION

- A. General structure of workstation interaction shall be a standard client/server relationship. Server shall be used to archive data and store system database. Clients shall access server for all archived data. Each client shall include flexibility to access graphics from server or local drive. Server shall support a minimum of 50 simultaneous clients.
- B. BACnet Conformance
  - 1. Operator Work Station shall be approved by the BTL as meeting the BACnet Advanced Work Station requirements.
  - 2. Refer to Section 22.2, BACnet Functional Groups, in the BACnet standard, for a complete list of the services that must be directly supported to provide each of the functional groups listed above. All proprietary services, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.
  - 3. Standard BACnet object types accessed by the workstation shall include as a minimum: Analog *Value*, Analog Input, Analog Output, Binary Value, Binary Input, Binary Output, Calendar, Device, Event Enrollment, File, Notification Class, Program, and Schedule object types. All proprietary object types, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.
  - 4. The operator's workstation shall comply with Annex J of the BACnet specification for IP connections. Must support remote connection to server using a thick client application. This device shall use Ethernet to connect to the IP internetwork, while using the same Ethernet LAN for non-IP communications to other BACnet devices on the LAN. Must support interoperability on wide area networks (WANs) and campus area networks (CANs). Workstation shall support Foreign Device Registration to allow temporary workstation connection to IP network.
- C. Displays
  - 1. Operator's workstation shall display all data associated with project as called out on drawings and/or object type list supplied. Graphic files shall be created using digital, full color photographs of system installation, AutoCAD or Visio drawing files of field installation drawings and wiring diagrams from as-built drawings. Operator's workstation shall display all data using three-dimensional graphic representations of all mechanical equipment. System shall be capable of displaying graphic file, text, and dynamic object data together on each display and shall include animation. Information shall be labeled with descriptors and shall be shown with the appropriate engineering units. All information on any display shall be dynamically updated without any action by the user. Workstation shall allow user to change all field-resident EMCS functions associated with the project, such as setpoints, weekly schedules, exception schedules, etc., from any screen, no matter if that screen shows all text or a complete graphic display. This shall be done without any reference to object addresses or other numeric/mnemonic indications.

2. All displays and programming shall be generated and customized by the local EMCS supplier and installer. Systems requiring factory development of graphics or programming of DOC logic are specifically prohibited.
3. Binary objects shall be displayed as ACTIVE/I NACTIVE/NULL or with customized text such as Hand-Off-Auto. Text shall be justified left, right or center as selected by the user. Also, allow binary objects to be displayed as individual change-of-state graphic objects on the display screen such that they overlay the system graphic. Each binary object displayed in this manner shall be assigned up to three graphic files for display when the point is ON, OFF or in alarm. For binary outputs, toggle the object's commanded status when the graphic item is selected with the system mouse. Similarly, allow the workstation operator to toggle the binary object's status by selecting with the mouse, for example, a graphic of a switch or light, which then displays a different graphic (such as an "ON" switch or lighted lamp. Additionally, allow binary objects to be displayed as an animated graphic. Animated graphic objects shall be displayed as a sequence of multiple graphics to simulate motion. For example, when a pump is in the OFF condition, display a stationary graphic of the pump. When the operator selects the pump graphic with the mouse, the represented object's status is toggled and the graphic of the pump's impeller rotates in a time- based animation. The operator shall be able to click an animated graphical object or switch it from the OFF position to ON, or ON to OFF. Allow operator to change graphic file assignment and also create new and original graphics online. System shall be supplied with a library of standard graphics, which may be used unaltered or modified by the operator. Systems that do not allow customization or creation of new graphic objects by the operator (or with third-party software) shall not be allowed.
4. Analog objects shall be displayed with operator modifiable units. Analog input objects may also be displayed as individual graphic items on the display screen as an overlay to the system graphic. Each analog input object may be assigned a minimum of five graphic files, each with high/low limits for automatic selection and display of these graphics. As an example, a graphic representation of a thermometer would rise and fall in response to either the room temperature or its deviation from the controlling setpoint. Analog output objects, when selected with the mouse, shall be displayed as a prompted dialog (text only) box. Selection for display type shall be individual for each object. Analog object values may be changed by selecting either the "increase" or "decrease" arrow in the analog object spinner box without using the keypad. Pressing the button on the right side of the analog object spinner box allows direct entry of an analog value and accesses various menus where the analog value may be used, such as trend logs.
5. Analog objects may also be assigned to a system graphic, where the color of the defined object changes based on the analog object's value. For example, graphical thermostat device served by a single control zone would change color with respect to the temperature of the zone or its deviation from setpoint. All editing and area assignment shall be created or modified online using simple icon tools.
6. A customized menu label (push-button) shall be used for display selection. Menu items on a display shall allow penetration to lower level displays or additional menus. Dynamic point information and menu label pushbuttons may be mixed on the same display to allow sub-displays to exist for each item. Each display may be protected from viewing unless operator has appropriate security level. A security level may be assigned to each display

and system object. The menu label shall not appear on the graphic if the operator does not have the appropriate security level.

7. The BAS displays shall have the ability to link to content outside of the BAS system. Such content shall include but is not limited to: Launching external files in their native applications (for example, a Microsoft Word document) and launching a Web browser resolving to a specified Web address.
8. The BAS system shall have the ability to run multiple, concurrent displays windows showing continuously updated data.
9. Graphic items with custom geometry that offer both color gradient shading and variable opacity in scale to system variables and range setpoints (OmniGraphics). Ability to automatically resize to display (OmniZoom).

#### D. Password Protection

1. Provide security system that prevents unauthorized use unless operator is logged on. Access shall be limited to operator's assigned functions when user is logged on. This includes displays as outlined above.
2. Each operator's terminal shall provide security for a minimum of 200 users. Each user shall have an individual User ID, User Name, and Password. Entries are alphanumeric characters only and are case sensitive (except for User ID). User ID shall be 0-8 characters, User Name shall be 0-29 characters, and Password shall be 4-8 characters long. Each system user shall be allowed individual assignment of only those control functions, menu items, and user specific system start display, as well restricted access to discrete BACnet devices to which that user requires access. All passwords, user names, and access assignments shall be adjustable online at the operator's terminal. Users should have the capability to be assigned to specific user type "groups" that can share the same access levels to speed setup. Users who are members of multiple "groups" shall have the ability to activate/deactivate membership to those groups while using the BAS (without logout). Users shall also have a set security level, which defines access to displays and individual objects the user may control. System shall include 10 separate and distinct security levels for assignment to users.
3. System shall include an Auto Logout Feature that shall automatically logout user when there has been no keyboard or mouse activity for a set period of time. Time period shall be adjustable by system administrator. Auto Logout may be enabled and disabled by system administrator. Operator terminal shall display message on screen that user is logged out after Auto Logout occurs.
4. The system shall permit the assignment of an effective date range, as well as an effective time of day, that the User IDs are permitted to authenticate.

#### E. Operator Activity Log

1. Operator Activity Log that tracks all operator changes and activities shall be included with system. System shall track what is changed in the system, who performed this change, date and time of system activity, and value of the change before and after operator activity. Operator shall be able to display all activity, sort the changes by user and also by operation. Operator shall be able to print the Operator Activity log display.
2. Log shall be gathered and archived to hard drive on operator's workstation as needed. Operator shall be able to export data for display and sorting in a spreadsheet.

3. Any displayed data that is changeable by the operator may be selected using the right mouse button and the operator activity log shall then be selectable on the screen. Selection of the operator activity log using this method shall show all operator changes of just that displayed data.

F. Scheduling

1. Operator's workstation shall show all information in easy-to-read daily format including calendar of this month and next. All schedules shall show actual ON/OFF times for day based on scheduling priority. Priority for scheduling shall be events, holidays and daily, with events being the highest.
2. Holiday and special event schedules shall display data in calendar format. Operator shall be able to schedule holidays and special events directly from these calendars.
3. Operator shall be able to change all information for a given weekly or exception schedule if logged on with the appropriate security access.
4. System shall include a Schedule Wizard for set up of schedules. Wizard shall walk user through all steps necessary for schedule generation. Wizard shall have its own pull-down selection for startup or may be started by right-clicking on value displayed on graphic and then selecting Schedule.
5. Scheduling shall include optimum start based on outside air temperature, current heating/cooling setpoints, indoor temperature and history of previous starts. Each and every individual zone shall have optimum start time independently calculated based on all parameters listed. User shall input schedules to set time that occupied setpoint is to be attained. Optimum start feature shall calculate the startup time needed to match zone temperature to setpoint. User shall be able to set a limit for the maximum startup time allowed.
6. Any displayed data that is changeable by the operator may be selected using the right mouse button and the schedule shall then be selectable on the screen. Selection of the schedule using this method shall allow the viewing of the assigned schedule or launch the Schedule Wizard to allow the point to be scheduled.

G. Alarm Indication and Handling.

1. Operator's workstation shall provide audible, visual, printed, and email means of alarm indication. The alarm dialog box shall always become the top dialog box regardless of the application(s) currently running. Printout of alarms shall be sent to the assigned terminal and port. Alarm notification can be filtered based on the User ID's authorization level.
2. System shall provide log of alarm messages. Alarm log shall be archived to the hard disk of the system operator's terminal. Each entry shall include a description of the event-initiating object generating the alarm. Description shall be an alarm message of at least 256 characters in length. Entry shall include time and date of alarm occurrence, time and date of object state return to normal, time and date of alarm acknowledgment, and identification of operator acknowledging alarm.
3. Alarm messages shall be in user-definable text (English or other specified language) and shall be delivered either to the operator's terminal, client or through remote communication using email (Authenticated SMTP supported).

4. System shall include an Alarm Wizard for set up of alarms. Wizard shall walk user through all steps necessary for alarm generation. Wizard shall have its own pull-down selection for startup or may be started by right-clicking on value displayed on graphic and then selecting alarm setup.
5. Any displayed data that is changeable by the operator may be selected using the right mouse button and the alarm shall then be selectable on the screen. Selection of the alarm using this method shall allow the viewing of the alarm history or launch the Alarm Wizard to allow the creation of a new alarm.

#### H. Trendlog Information

1. System server shall periodically gather historically recorded data stored in the building controllers and store the information in the system database. Stored records shall be appended with new sample data, allowing records to be accumulated. Systems that write over stored records shall not be allowed unless limited file size is specified. System database shall be capable of storing up to 50 million records before needing to archive data. Samples may be viewed at the operator's workstation. Operator shall be able to view all trended records, both stored and archived. All trendlog records shall be displayed in standard engineering units.
2. Software that is capable of graphing the trend logged object data shall be included. Software shall be capable of creating two-axis (X, Y) graphs that display up to 10 object types at the same time in different colors. Graphs shall show object values relative to time. Each trendlog shall support a custom scale setting for the graph view that is to be stored continuously. System shall be capable of trending on an interval determined by a polling rate, or change-of-value.
3. Operator shall be able to change Trendlog setup information. This includes the information to be logged as well as the interval at which it is to be logged. All input, output, and value object types in the system may be logged. All operations shall be password protected. Setup and viewing may be accessed directly from any and all graphics on which object is displayed.
4. System shall include a Trend Wizard for setup of logs. Wizard shall walk user through all necessary steps. Wizard shall have its own pull-down selection for startup, or may be started by right-clicking on value displayed on graphic, and then selecting Trendlogs from the displayed menu.
5. System shall be capable of using Microsoft SQL as the system database.
6. Any displayed data that is changeable by the operator may be selected using the right mouse button and the trendlog shall then be selectable on the screen. Selection of the trendlog using this method shall allow the viewing of the trendlog view or launch the Trendlog wizard to allow the creation of a new trend.

#### I. Energy Log Information

1. System server shall be capable of periodically gathering energy log data stored in the field equipment and archive the information. Archive files shall be appended with new data, allowing data to be accumulated. Systems that write over archived data shall not be allowed unless limited file size is specified. Display all energy log information in standard engineering units.

2. All data shall be stored in database file format for direct use by third-party programs. Operation of system shall stay completely online during all graphing operations.
3. Operator shall be able to change the energy log setup information as well. This includes the meters to be logged, meter pulse value, and the type of energy units to be logged. All meters monitored by the system may be logged. System shall support using flow and temperature sensors for BTU monitoring.
4. System shall display archived data in tabular format form for both consumption and peak values. Data shall be shown in hourly, daily, weekly, monthly and yearly formats. In each format, the user shall be able to select a specific period of data to view.

J. Demand Limiting

1. System shall include demand limiting program that includes two types of load shedding. One type of load shedding shall shed/restore equipment in binary fashion based on energy usage when compared to shed and restore settings. The other type of shedding shall adjust operator selected control setpoints in an analog fashion based on energy usage when compared to shed and restore settings. Shedding may be implemented independently on each and every zone or piece of equipment connected to system.
2. Binary shedding shall include minimum of five (5) priority levels of equipment shedding. All loads in a given priority level shall be shed before any loads in a higher priority level are shed. Load shedding within a given priority level shall include two methods. In one, the loads shall be shed/restored in a "first off-first on" mode, and in the other the loads are just shed/restored in a "first off-last on" (linear) fashion.
3. Analog shed program shall generate a ramp that is independently used by each individual zone or individual control algorithm to raise the appropriate cooling setting and lower appropriate heating setting to reduce energy usage.
4. Status of each and every load shed program shall be capable of being displayed on every operator terminal connected to system. Status of each load assigned to an individual shed program shall be displayed along with English description of each load.

K. Tenant Activity

1. System shall include program that monitors after-hours overrides by tenants, logs that data, and generates a bill based on usage and rate charged for each tenant space. Tenant Activity program shall be able to assign multiple zones, from a list of every zone connected to system, to a particular tenant. Every zone is monitored for after-hour override usage and that data logged in server. Operator may then generate a bill based on the usage for each tenant and the rate charged for any overtime use.
2. Configuration shall include entry of the following information for use in logging and billing:
  - a. Tenant's contact name and address
  - b. One or multiple tenant zones that make up a total tenant space, including a separate billing rate for each separate zone
  - c. Minimum and maximum values an event duration and event limit
  - d. Property management information
  - e. Overall billing rate
  - f. Seasonal adjustments or surcharge to billing rate

- g. Billing notification type such including, but not limited to printer, file and email
      - h. Billing form template
  - 3. Logging shall include recording the following information for each and every tenant event:
    - a. Zone description
    - b. Time the event begins
    - c. Total override time
    - d. Limits shall be applied to override time
  - 4. A tenant bill shall be generated for a specific period using all the entered configuration data and the logged data. User with appropriate security level shall be able to view and override billing information. User shall be able to select a billing period to view and be able to delete events from billing and edit a selected tenant activity event's override time.
- L. Reports
  - 1. System server shall be capable of periodically producing reports of trendlogs, alarm history, tenant activities, device summary, energy logs, and override points. The frequency, content, and delivery are to be user adjustable.
  - 2. All reports shall be capable of being delivered in multiple formats including text- and comma-separated value (CSV) files. The files can be printed, emailed, or saved to a folder, either on the server hard drive or on any network drive location.
- M. Configuration/Setup
  - 1. Provide means for operator to display and change system configuration. This shall include, but not be limited to, system time, day of the week, date of daylight savings set forward/set back, printer termination, port addresses, modem port and speed, etc. Items shall be modified using understandable terminology with simple mouse/cursor key movements.
- N. Field Engineering Tools
  - 1. Operator's workstation software shall include field engineering tools for programming all controllers supplied. All controllers shall be programmed using graphical tools that allow the user to connect function blocks on screen that provide sequencing of all control logic. Function blocks shall be represented by graphical displays that are easily identified and distinct from other types of blocks. Graphical programming that uses simple rectangles and squares is not acceptable.
  - 2. User shall be able to select a graphical function block from menu and place on screen. Provide zoom in and zoom out capabilities. Function blocks shall be downloaded to controller without any reentry of data.
  - 3. Programming tools shall include a real-time operation mode. Function blocks shall display real-time data and be animated to show status of data inputs and outputs when in real-time operation. Animation shall show change of status on logic devices and countdown of timer devices in graphical format
  - 4. Field engineering tools shall also include a database manager of applications that include logic files for controllers and associated graphics. Operator shall be able to



select unit type, input/output configuration and other items that define unit to be controlled. Supply minimum of 250 applications as part of workstation software.

5. Field engineering tool shall include Device Manager for detection of devices connected anywhere on the BACnet network by scanning of the entire network. This function shall display device instance, network identification, model number, and description of connected devices. It shall record and display software file loaded into each controller. A copy of each file shall be stored on the computer's hard drive. If needed, this file shall be downloaded to the appropriate controller using the mouse.
6. System shall automatically notify the user when a device that is not in the database is added to the network.
7. System shall include backup/restore function that will back up entire system to selected medium and then restore system from that media. The system shall be capable of creating a backup for the purpose of instantiating a new client PC.
8. The system shall provide a means to scan, detect, interrogate, and edit third-party BACnet devices and BACnet objects within those devices.

O. Workstation Hardware

1. Provide operator's workstation(s) at location(s) noted on the plans.
2. Workstation/server computer minimum requirements
  - a. PC Processor of 2.5 GHz quad-core or better
  - b. 8 GB RAM or better
  - c. 1TB hard disk or better
  - d. High-performance graphics adapter
  - e. Ethernet 10/100 network interface card
  - f. Keyboard, monitor, mouse, USB port and CD-ROM
  - g. Microsoft Windows 8 or Windows 10
  - h. Monitor size shall be 22" minimum
  - i. Color printer (inkjet, color dye or laser)

P. Software

1. At the conclusion of project, contractor shall leave with owner a CD ROM that includes the complete software operation system and project graphics, setpoints, system parameters, etc. This backup shall allow the owner how to completely restore the system in the case of a computer malfunction.

## 2.02 GRAPHICAL USER INTERFACE

A. Display of Data

1. Graphics displays shall include animation of all Fans shall turn, pilot lights shall blink, coils shall change colors, and so on.
2. Real-time data shall be shown. This data must be directly gathered using the BACnet network and automatically updated without any user action.

3. It shall be possible for user to change data if the user is logged on with the appropriate password. Clicking on a button or typing in a new value shall change digital data. Using pull-down menus or typing in a new value shall change analog data.
  4. Data displays shall be navigated using pushbuttons on the displays that are simply clicked on with the mouse to select a new display.
- B. Time Schedule Adjustment
1. Logged in access shall allow user to view and edit all schedules in the system. This includes standard, holiday and event schedules as described in BAS specification. Display of schedules shall show interaction of all schedules on a single display so user sees an overview of how all work together. User shall be able to edit schedules from this display.
  2. Display of all three schedules must show all ON times for standard, holiday and event schedules in different colors on a given day. In addition, OFF times for each must also be shown in additional colors. User shall be able to select from standard calendar what days are to be scheduled and same display shall show all points and zones affected. User shall be able to set time for one day and select all days of the week that shall be affected as a recurrence of that same schedule for that given day.
  3. Schedule list shall show all schedules currently defined. This list shall include all standard, holiday and event schedules. In addition, user shall be able to select a list that shows all scheduled points and zones.
- C. Logging of Information
1. User shall use standard browser technology to view all trendlogs in system. User shall be able to view logged data in tabular form or graphical format. User shall be able to adjust time interval of logged data viewed and shall be able to adjust Y axis of data viewed in graphical format. Data shall be in CSV format.
- D. Alarm Handling
1. The front end shall display alarms as they occur. User shall be able to acknowledge alarms using browser technology. In addition, user shall be able to view history of alarm occurrence over a user-selected time frame. In addition, those alarms may be filtered for viewing per user-selected options. A single selection shall display all alarms that have not been acknowledged.
- E. BACnet Communication
1. The Alerton system shall directly communicate to all devices on the BAS network using BACnet protocol. No intermediate devices shall be necessary for BACnet communication.

## **2.03 BUILDING CONTROLLER**

### **A. General Requirements**

1. BACnet Conformance
  - a. Building Controller shall be approved by the BTL as meeting the BACnet Building Controller requirements.
  - b. Please refer to section 22.2, BACnet Functional Groups, in the BACnet standard, for a complete list of the services that must be directly supported to provide each of the

functional groups listed above. All proprietary services, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.

2. Building controller shall be of modular construction such that various modules may be selected to fit the specific requirements of a given project. At a minimum, modules shall consist of a power supply module, a BACnet Ethernet-MS/TP (master slave token passing) module, a BACnet MS/TP-only module, and a modem module for telephone communication. Those projects that require special interfaces may use Modbus modules as needed. However, all Ethernet communications and all controllers-including central plant controllers, advanced application controllers and unitary controllers-supplied by BAS manufacturer shall utilize the BACnet protocol standard.
3. Modules shall be selected to fit the particular project application. Up to seven modules shall be powered by a single power supply module. All modules shall be panel-mounted on DIN rail for ease of addition and shall be interconnected using a simple plug-in cable. A module in the middle shall be replaceable without removing any other modules.
4. All modules shall be capable of providing global control strategies for the system based on information from any objects in the system, regardless if the object is directly monitored by the building controller module or by another controller. The software program implementing these strategies shall be completely flexible and user-definable. All software tools necessary for programming shall be provided as part of project software. Any systems utilizing factory pre-programmed global strategies that cannot be modified by field personnel on-site, using a WAN or downloaded through remote communications are not acceptable. Changing global strategies using firmware changes is also unacceptable.
5. Programming shall be object-oriented using control function blocks, and support DDC functions, 1000 Analog Values and 1000 Binary Values. All flowcharts shall be generated and automatically downloaded to controller. Programming tool shall be supplied and be resident on workstation. The same tool shall be used for all controllers.
6. Provide means to graphically view inputs and outputs to each program block in real-time as program is executing. This function may be performed using the operator's workstation or field computer.
7. Controller shall have sufficient memory to ensure high performance and data reliability. Battery shall provide power for orderly shutdown of controller and storage of data in nonvolatile flash memory. Battery backup shall maintain real-time clock functions for a minimum of 20 days.
8. Global control algorithms and automated control functions shall execute using 32-bit processor.
9. Schedules
  - a. Each building controller module shall support a minimum of 80 BACnet Schedule Objects and 80 BACnet Calendar Objects.
  - b. Building controller modules shall provide normal seven-day scheduling, holiday scheduling and event scheduling.
10. Logging Capabilities

- a. Each building controller shall log as minimum 320 values. Any object in the system (real or calculated) may be logged. Sample time interval shall be adjustable at the operator's workstation.
  - b. Logs may be viewed both on-site or off-site using WAN or remote communication.
  - c. Building controller shall periodically upload trended data to networked operator's workstation for long-term archiving if desired.
  - d. Archived data stored in database format shall be available for use in third-party spreadsheet or database programs.
11. Alarm Generation
- a. Alarms may be generated within the system for any object change of value or state (either real or calculated). This includes things such as analog object value changes, binary object state changes, and various controller communication failures.
  - b. Each alarm may be dialed out as noted elsewhere.
  - c. Alarm log shall be provided for alarm viewing. Log may be viewed on-site at the operator's terminal or off-site using remote communications.
  - d. Controller must be able to handle up to 320 alarm setups stored as BACnet event enrollment objects, with system destination and actions individually configurable.
12. Demand Limiting
- a. Demand limiting of energy shall be a built-in, user-configurable function. Each controller module shall support shedding of up to 200 loads using a minimum of two types of shed programs.
  - b. Load shedding programs in building controller modules shall operate as defined in section 2.1.J of this specification.
13. Tenant Activity Logging
- a. Tenant Activity logging shall be supported by building controller module. Each independent module shall support a minimum of 80 zones.
  - b. Tenant Activity logging shall function as defined in section 2.1.K of this specification.
- B. Ethernet - MS/TP Module
1. Ethernet - MS/TP Module shall support every function as listed under paragraph A, General Requirements, of this section and the following.
  2. All communication with operator's workstation and all application controllers shall be through BACnet. Building controller Ethernet - MS/TP module shall incorporate as a minimum, the functions of a 2-way BACnet router. Controller shall route BACnet messages between the high-speed LAN (Ethernet 10/100 MHz) and MS/TP LAN. Ethernet - MS/TP module shall also route messages from all other building controller modules onto the BACnet Ethernet network.
    - a. MS/TP LAN must be software-configurable from 9.6 to 76.8Kbps.
    - b. The RJ-45 Ethernet connection must accept either 10Base-T or 100Base-TX BACnet over twisted pair cable (UTP).
  3. BACnet Conformance
    - a. Ethernet - MS/TP module shall, as a minimum, support MS/TP and Ethernet BACnet LAN types. It shall communicate directly using these BACnet LANs as a native BACnet

device and shall support simultaneous routing functions between all supported LAN types. Global controller shall be approved by the BACnet Testing Laboratory (BTL) as meeting the BACnet Building Controller requirements.

- b. All proprietary object types, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.
- c. The building controller shall comply with Annex J of the BACnet specification for IP connections. This device shall use Ethernet to connect to the IP internetwork, while using the same Ethernet LAN for non-I P communications to other BACnet devices on the LAN. Must support interoperability on WANs and CANs and function as a BACnet Broadcast Management Device (BBMD).

#### C. MS/TP Module

1. MS/TP Module shall support every function as listed under paragraph A, General Requirements, of this section and the following:
  - a. Building controller MS/TP module communications shall be through BACnet MS/TP LAN to all advanced application and application-specific controllers. MS/TP module shall also route messages to Ethernet - MS/TP module for communication over WAN.
  - b. MS/TP LAN must be software configurable from 9.6 to 76.8Kbps
  - c. Configuration shall be through RS-232 connection.
2. BACnet Conformance
  - a. MS/TP module shall be approved by the BTL (BACnet Testing Laboratory) as meeting the BACnet Building Controller requirements. MS/TP module shall as a minimum support MS/TP BACnet LAN type. It shall communicate directly using this BACnet LAN as a native BACnet device and shall support simultaneous routing functions between all supported LAN types.
  - b. Standard BACnet object types supported shall include, as a minimum, Analog Value, Binary Value, Calendar, Device, File, Group, Notification Class, Program, and Schedule object types. All proprietary object types, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.

#### D. Power Supply Module

1. Power supply module shall power up to seven building controller modules. Input for power shall accept between 17-30VAC, 47-65Hz.
2. Power supply module shall include rechargeable battery for orderly shutdown of controller modules including storage of all data in flash memory and for continuous operation of real-time clocks for minimum of 20 days.

### 2.04 AIR HANDLER APPLICATION CONTROLLERS

- A. Provide one or more native BACnet application controllers for each air handler and provide native BACnet application controllers as needed for central plant control that adequately cover all objects listed in object list. All controllers shall interface to building controller through either MS/TP LAN using BACnet protocol, or Ethernet LAN using BACnet over Ethernet or BACnet TCP/IP. No gateways shall be used. Controllers

shall include input, output and self-contained logic program as needed for complete control of units. Controllers shall be fully programmable using graphical programming blocks. Programming tool shall be resident on operator workstation and be the same tool as used for the building controller. No auxiliary or non-BACnet controllers shall be used.

A. BACnet Conformance

1. Application controllers shall be approved by the BTL as meeting the BACnet Advanced Application Controller requirements.
2. Please refer to section 22.2, BACnet Functional Groups, in the BACnet standard, for a complete list of the services that must be directly supported to provide each of the functional groups listed above. All proprietary services, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.
3. Standard BACnet object types supported shall include, as a minimum, Analog Input, Analog Output, Analog Value, Binary Input, Binary Output, Binary Value, Multi-state Values, Device, File, and Program object types. All proprietary object types, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.

B. Application controllers shall include universal inputs with 12-bit resolution that accept 3K and 10K thermistors, 0-10VDC, Platinum 1000 ohm RTD, 0-SVDC, 4-20mA and dry contact signals. Any input on a controller may be either analog or digital with a minimum of three inputs that accept pulses. Controller shall also include support and modifiable programming for interface to intelligent room sensor with digital display. Controller shall include binary and analog outputs on board. Analog outputs with 12-bit resolution shall support either 0-10VDC or 0-20mA. Binary outputs shall have LED indication of status. Software shall include scaling features for analog outputs.

1. Application controller shall include 20VDC voltage supply for use as power supply to external sensors.
2. All outputs must have onboard Hand-Off-Auto (HOA) switches and a status indicator light. HOA switch position shall be monitored. Each analog output shall include a potentiometer for manually adjusting the output when the HOA switch is in the Hand position.
3. The position of each and every HOA switch shall be available system wide as a BACnet object property.

C. All program sequences shall be stored on board application controller in EEPROM. No batteries shall be needed to retain logic program. All program sequences shall be executed by controller up to 20 times per second (minimum of 10 times per second) and capable of multiple PID loops for control of multiple devices. All calculations shall be completed using floating-point math and system shall support display of all information in floating-point nomenclature at operator's terminal.

1. The following control blocks shall be supported:
  - a. Natural Log
  - b. Exponential
  - c. Log base 10

- d. X to the power of Y
  - e. Nth square root of X
  - f. f. 5th Order Polynomial Equations
  - g. Astronomical Clock (sunrise/sunset calculation)
  - h. Time based schedules
- D. Programming of application controller shall be completely modifiable in the field over installed BACnet LANs or remotely using modem interface. Operator shall program logic sequences by graphically moving function blocks on screen and tying blocks together on screen. Application controller shall be programmed using programming tools as described in operator's terminal section.
- E. Application controller shall include support for intelligent room sensor (see Section 2.10.B.) Display on intelligent room sensor shall be programmable at application controller and include an operating mode and a field service mode. All button functions and display data shall be programmable to show specific controller data in each mode, based on which button is pressed on the sensor. See sequence of operation for specific display requirements at intelligent room sensor.
- F. Schedules
1. The controller shall support a minimum of 3 BACnet Schedule Objects and have a real time clock on board with battery backup to maintain time through a power loss.
- G. Logging Capabilities
1. Controller shall support a minimum of 50 trendlogs. Any object in the controller (real or calculated) may be logged. Sample time interval shall be adjustable at the operator's workstation.
  2. Controller shall periodically upload trended data to system server for long-term archiving if desired. Archived data stored in (MS Jet Database or SQL) database form and shall be available for use in third-party spreadsheet or database programs.
- H. Alarm Generation
1. Alarms may be generated within the controller for any object change of value or state (either real or calculated). This includes things such as analog object value changes, and binary object state changes.
  2. Alarm log shall be provided for alarm viewing. Log may be viewed on-site at the operator's terminal or off-site using remote communications.
  3. Controller must be able to handle up to 25 alarm setups stored as BACnet event enrollment objects, with system destination and actions individually configurable.
- I. The controller processor shall be a 32-bit processor.
- J. The packaging of the controller shall provide operable doors to cover the terminals once installation is complete. The housing of the controller shall provide for DIN rail mounting and also fully enclose circuit board.

## **2.05 TERMINAL UNIT APPLICATION CONTROLLERS (FAN-COILS)**

- A. Provide one native BACnet application controller for each piece of unitary mechanical equipment that adequately covers all objects listed in object list for unit. All controllers shall interface to building controller through MS/TP LAN using BACnet protocol. No gateways shall

be used. Controllers shall include input, output and self-contained logic program as needed for complete control of unit.

**B. BACnet Conformance**

1. Application controllers shall, as a minimum, support MS/TP BACnet LAN types. They shall communicate directly using this BACnet LAN at 9.6, 19.2, 38.4 and 76.8 Kbps, as a native BACnet device. Application controllers shall be approved by the BTL as meeting the BACnet Application Specific Controller requirements and support all BACnet services necessary to provide the following BACnet functional groups:
    - a. Files Functional Group
    - b. Reinitialize Functional Group
    - c. Device Communications Functional Group
  2. Please refer to Section 22.2, BACnet Functional Groups in the BACnet standard, for a complete list of the services that must be directly supported to provide each of the functional groups listed above. All proprietary services, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.
  3. Standard BACnet object types supported shall include, as a minimum, Analog Input, Analog Output, Analog Value, Binary Input, Binary Output, Binary Value, Device, File, and Program Object Types. All proprietary object types, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.
- C.** Application controllers shall include universal inputs with 10-bit resolution that can accept 3K and IOK thermistors, 0-5VDC, 4-20mA, dry contact signals and a minimum of 3 pulse inputs. Any input on controller may be either analog or digital. Controller shall also include support and modifiable programming for interface to intelligent room sensor. Controller shall include binary outputs on board with analog outputs as needed.
- D.** All program sequences shall be stored on board controller in EEPROM. No batteries shall be needed to retain logic program. All program sequences shall be executed by controller 10 times per second and shall be capable of multiple PID loops for control of multiple devices. Programming of application controller shall be completely modifiable in the field over installed BACnet LANs or remotely through modem interface. Operator shall program logic sequences by graphically moving function blocks on screen and tying blocks together on screen. Application controller shall be programmed using same programming tools as building controller and as described in operator workstation section. All programming tools shall be provided and installed as part of system.
- E.** Application controller shall include support for intelligent room sensor (see Section 2.10.B.) Display on room sensor shall be programmable at controller and include an operating mode and a field service mode. All button functions and display data shall be programmable to show specific controller data in each mode based on which button is pressed on the sensor. See sequence of operation for specific display requirements at intelligent room sensor.

**2.06 VAV BOX CONTROLLERS- SINGLE DUCT WITH HOT WATER REHEAT**

- A.** Provide one native BACnet application controller for each VAV box that adequately covers all objects listed in object list for unit. All controllers shall interface to building controller through MS/TP LAN using BACnet protocol. No gateways shall be used. Controllers shall include on board



CFM flow sensor, inputs, outputs and programmable, self-contained logic program as needed for control of units.

B. BACnet Conformance

1. Application controllers shall, at a minimum, support MS/TP BACnet LAN types. They shall communicate directly through this BACnet LAN at 9.6, 19.2, 38.4 and 76.8 Kbps, as a native BACnet device. Application controllers shall be approved by the BTL as meeting the BACnet Application Specific Controller requirements.
2. Please refer to Section 22.2, BACnet Functional Groups, in the BACnet standard, for a complete list of the services that must be directly supported to provide each of the functional groups listed above. All proprietary services, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.
3. Standard BACnet object types supported shall include, as a minimum, Analog Input, Analog Output, Analog Value, Binary Input, Binary Output, Binary Value, Device, File, and Program Object Types. All proprietary object types, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.

C. Application controllers shall include universal inputs with 10-bit resolution that can accept 3K and IOK thermistors, 0-5 VDC, and dry contact signals. Inputs on controller may be either analog or digital. Controller shall also include support and modifiable programming for interface to intelligent room sensor with digital display. Controller shall also include binary outputs on board. For applications using variable speed parallel fans, provide a single analog output selectable for 0-10 V or 0-20 mA control signals. Application controller shall include microprocessor driven flow sensor for use in pressure independent control logic. All boxes shall be controlled using pressure- independent control algorithms and all flow readings shall be in CFM (LPS if metric).

D. All program sequences shall be stored on board application controller in EEPROM. No batteries shall be needed to retain logic program. All program sequences shall be executed by controller 10 times per second and shall be capable of multiple PIO loops for control of multiple devices. Programming of application controller shall be completely modifiable in the field over installed BACnet LANs or remotely using modem interface. Operator shall program logic sequences by graphically moving function blocks on screen and tying blocks together on screen. Application controller shall be programmed using the same programming tool as Building Controller and as described in operator's workstation section. All programming tools shall be provided as part of system.

E. Application controller shall include support for intelligent room sensor (see Section 2.10.B.) Display on room sensor shall be programmable at application controller and include an operating mode and a field service mode. All button functions and display data shall be programmable to show specific controller data in each mode based on which button is pressed on the sensor. See sequence of operations for specific display requirements for intelligent room sensor.

F. On board flow sensor shall be microprocessor-driven and pre-calibrated at the factory. Pre-calibration shall be at 16 flow points as a minimum. All factory calibration data shall be stored in non-volatile memory. Calibration data shall be field adjustable to compensate for variations in VAV box type and installation. All calibration parameters shall be adjustable through

intelligent room sensor. Operator's workstation, portable computers, and special hand-held field tools shall not be needed for field calibration.

- G. Provide duct temperature sensor at discharge of each VAV box that is connected to controller for reporting back to operator's workstation.

## **2.07 AUXILIARY CONTROL DEVICES**

### **A. Temperature Sensors**

- B. All temperature sensors to be solid-state electronic, interchangeable with housing appropriate for application. Wall sensors to be installed as indicated on drawings. Mount 48 inches above finished floor. Duct sensors to be installed such that the sensing element is in the main air stream. Immersion sensors to be installed in wells provided by control contractor, but installed by mechanical contractor. Immersion wells shall be filled with thermal compound before installation of immersion sensors. Outside air sensors shall be installed away from exhaust or relief vents, not in an outside air intake, and in a location that is in the shade most of the day.

### **C. Intelligent Room Sensor with LCD Readout**

1. All room sensors shall be a combination temperature and humidity sensor and integrated Co2 where shown on the floor plans. The sensor shall contain a backlit LCD digital display and user function keys along with temperature sensor. Controller shall function as room control unit, and shall allow occupant to raise and lower setpoint, and activate terminal unit for override use-all within limits as programmed by building operator. Sensor shall also allow service technician access to hidden functions as described in sequence of operation.
2. Override time may be set and viewed in half-hour increments. Override time countdown shall be automatic, but may be reset to zero by occupant from the sensor. Time remaining shall be displayed. Display shall show the word "OFF" in unoccupied mode unless a function button is pressed.
3. See sequence of operation for specific operation of LCD displays and function keys in field service mode and in normal occupant mode. Provide intelligent room sensors as specified in point list.
4. Field service mode shall be customizable to fit different applications. If intelligent room sensor is connected to VAV controller, VAV box shall be balanced and all air flow parameters shall be viewed and set from the intelligent room sensor with no computer or other field service tool needed.

### **D. Wall Sensor**

1. Standard wall sensor shall use solid-state sensor identical to intelligent room sensor and shall be packaged in aesthetically pleasing enclosure. Sensor shall provide override function, warmer/cooler lever for set point adjustment and port for plug-in of Field Service Tool for field adjustments. Override time shall be stored in controller and be adjustable on a zone-by-zone basis. Adjustment range for warmer/cooler lever shall also be stored in EEPROM on controller. All programmable variables shall be available to field service tool through wall sensor port.

### **E. Wireless Wall Sensor**

1. Wireless wall sensor shall use solid-state sensor and shall be packaged in aesthetically pleasing enclosure. Sensor shall provide override function, warmer/cooler dial for set

point adjustment. Override time shall be stored in controller and be adjustable on a zone-by-zone basis. Adjustment range for warmer/cooler lever shall also be stored in EEPROM on controller. All programmable variables shall be available to field service tool through wall sensor port. There shall be a mechanical means to lock the wall sensor to the base to prevent theft and vandalism.

2. Wireless wall sensor shall have a battery life of 5 year with alkaline batteries and 7.5 years with lithium batteries. A low battery indication shall be signaled to the controller prior to the battery being exhausted. The wireless sensor shall run on industry standard AA style batteries.
3. The wireless range in open air shall meet or exceed 300 ft. The strength of the wireless signal must be indicated at the wireless sensor to aid in placement and trouble shooting. The receiver shall have a wireless-communications-received light that indicates the proper communication is occurring.
4. The wireless wall sensor and receiver must be paired in an addressable mean to facilitate easy replacement and reassignment.

F. Airflow Control:

1. Where indicated, provide airflow measuring stations and control. Refer to Section 237213, "Custom Air Handling Units," and control diagrams on Drawings.
2. A factory-furnished and calibrated controller shall be programmed, in nonvolatile EPROM, with application-specific airflow set point and range.
3. The controller and actuator shall communicate to control the desired airflow.
4. The controller shall receive a zero- to 10-V de input signal and report a zero- to 20- mA output signal that is proportional to the airflow.
5. Airflow measurement and control range shall be suitable for operation between 150 to 2000 fpm (0.8 to 10 m/s).
6. Ambient Operating Temperature Range: Minus 40 to plus 140 deg F (Minus 40 to plus 60 deg C).
7. Ambient Operating Humidity Range: 5 to 95 percent relative humidity, non- condensing.
8. Provide unit with control transformer rated for not less than 85 VA. Provide transformer with primary and secondary protection and primary disconnecting means. Coordinate requirements with field power connection.
9. Provide screw terminals for interface to field wiring.
10. Factory mount electronics within a NEMA 250, Type 1painted steel enclosure.

## 2.08 THERMAL ENERGY METERS

- A. Performance Requirements: Manufacturer shall certify that each energy meter indicated complies with specified performance requirements and characteristics.
1. Product certificates are required.
  2. Insertion-Type Thermal Energy Meters:
    - a. Manufacturer: Subject to compliance with requirements, provide products by the following:

- 1) ONICON Incorporated Turbine Flow Meter Model F-1210 and BTU Meter Model System-10-BAC.
- b. Description:
- 1) Factory-packaged meter consisting of supply and return temperature sensors, flow sensor, digital display, keypad user interface, installation hardware, color-coded interconnecting cabling, and installation instructions.
  - 2) Each thermal energy meter shall be individually calibrated and provided with calibration certification traceable to NIST.
- c. Alphanumeric display of the following on face of enclosure:
- 1) Total energy consumption.
  - 2) Energy rate.
  - 3) Flow rate.
  - 4) Supply temperature.
  - 5) Return temperature.
  - 6) Visual indication of power status (on/off) on face of enclosure.
- d. Electronics Enclosure:
- 1) Remote from temperature and flow sensors.
  - 2) NEMA 250, Type 12 or Type 13 for indoor applications and NEMA 250, Type 4 or Type 4X for outdoor applications.
  - 3) Labeled terminal strip for field wiring connections.
- e. Programming:
- 1) Factory programmed for specific application and field programmable through keypad on face of enclosure.
  - 2) Programmed parameters and total energy consumption shall be stored in non-volatile EEPROM memory.
- f. Output Signals:
- 1) Total Energy Consumption: Isolated solid-state dry contact with 100 mA, 50-V rating and contact duration of 0.5, 1, 2, or 6 seconds.
  - 2) Energy Rate, Flow Rate, Supply Temperature, Return Temperature: 4 to 20 mA or zero- to 10-V de for each.
- g. Temperature Sensors:
- 1) Temperature range matched to application.
  - 2) Temperature accuracy within 0.15 deg F (0.08 deg C) over the calibrated range.
  - 3) Stainless-steel or brass thermowell with NPS 1/2 (DN 15) N PT connection for each sensor.
- h. Current Sensors:

- 1) Veris Model H-908 or equal.
- i. Differential Pressure Transmitters & Switches:
  - 1) Duct Static Pressure shall be Dwyer Model MS2-D102 or equal.
  - 2) Space Static Pressure shall be Dwyer Model MS2-WIII or equal.
  - 3) Hydronic Differential Pressure shall be Dwyer Model 629-05-CH-P2-E5- 51-3V or equal.
  - 4) Filter Switches shall be Dwyer Model ADPS-04-1-N or equal.

## 2.09 ELECTRONIC ACTUATORS AND VALVES

- A. Quality Assurance for Actuators and Valves
  1. UL Listed Standard 873 and C.S.A. Class 4813 02 certified.
  2. NEMA 2 rated enclosures for inside mounting, provide with weather shield for outside mounting.
  3. Five-year manufacturer's warranty. Two-year unconditional and three-year product defect from date of installation.
- B. Execution Details for Actuators and Valves
  1. Furnish a Freeze-stat and install "Hard Wire" interlock to disconnect the mechanical spring return actuator power circuit for fail-safe operation. Use of the control signal to drive the actuators closed is not acceptable.
  2. Each DOC analog output point shall have an actuator feedback signal, independent of control signal, wired and terminated in the control panel for true position information and troubleshooting. Or the actuator feedback signal may be wired to the DOC as an analog input for true actuator position status.
  3. VAV box damper actuation shall be floating type or analog (2-IOVDC, 4-20mA).
  4. Booster-heat valve actuation shall be floating type or analog (2-IOvdc, 4-20ma).
  5. Primary valve control shall be analog (2-IOVDC, 4-20mA).
- C. Actuators for damper and control valves 0.5-6 inches shall be electric unless otherwise specified, provide actuators as follows:
  1. UL Listed Standard 873 and Canadian Standards Association Class 481302 shall certify actuators.
  2. NEMA 2 rated actuator enclosures for inside mounting. Use additional weather shield to protect actuator when mounted outside.
  3. Five-year manufacturer's warranty. Two-year unconditional and Three year product defect from date of installation.
  4. Mechanical spring shall be provided when specified. Capacitors or other non-mechanical forms of fail-safe are not acceptable.
  5. Position indicator device shall be installed and made visible to the exposed side of the actuator. For damper short shaft mounting, a separate indicator shall be provided to the exposed side of the actuator.
  6. Overload Protection: Actuators shall provide protection against actuator burnout by using an internal current limiting circuit or digital motor rotation sensing circuit. Circuit shall

insure that actuators cannot burn out due to stalled damper or mechanical and electrical paralleling. End switches to deactivate the actuator at the end of rotation are acceptable only for butterfly valve actuators.

7. A Pushbutton gearbox release shall be provided for all non-spring actuators.
8. Modulating actuators shall be 24VAC and consume IOVA power or less.
9. Conduit connectors are required when specified and when code requires it.

D. Damper Actuators:

1. Outside air and exhaust air damper actuators shall be mechanical spring return. Capacitors or other non-mechanical forms of fail-safe are not acceptable. The actuator mounting arrangement and spring return feature shall permit normally open or normally closed positions of the damper as required.
2. Economizer actuators shall utilize analog control 2-IOVDC, floating control is not acceptable.
3. Electric damper actuators (including VAV box actuators) shall be direct shaft-mounted and use a V-bolt and toothed V-clamp causing a cold weld effect for positive gripping. Single bolt or set-screw type fasteners are not acceptable.
4. One electronic actuator shall be direct shaft-mounted per damper section. No connecting rods or jackshafts shall be needed. Small outside air and return air economizer dampers may be mechanically linked together if one actuator has sufficient torque to drive both and damper drive shafts are both horizontal installed.
5. Multi-section dampers with electric actuators shall be arranged so that each damper section operates individually. One electronic actuator shall be direct shaft-mounted per damper section. (See below execution section for more installation details.)

E. Valve Actuators 0.5-6 inches

1. Mechanical spring shall be provided on all actuators for pre-heat coil and actuators for AHU heating or cooling coil when units are mounted outside. See plans for fail- safe flow function: Normal Open or Normal Closed. Capacitors or other non-mechanical forms of fail-safe are not acceptable.
2. All zone service actuators shall be non-spring return unless otherwise specified.
3. The valve actuator shall be capable of providing the minimum torque required for proper valve close-off for the required application.
4. All control valves actuators shall have an attached 3-foot cable for easy installation to a junction box.
5. Override handle and gearbox release shall be provided for all non-spring return valve actuators.

F. Control Valves 0.5-6 inches

1. The BAS contractor shall furnish all specified motorized control valves and actuators. BAS contractor shall furnish all control wiring to actuators. The contractor shall install all valves. Equal percentage control characteristic shall be provided for all water coil control valves. Linear valve characteristic is acceptable for 3-way valves that are 2.5 inches and above.
2. Characterized control valves shall be used for hydronic heating or cooling applications and small to medium AHU water-coil applications to 200 GPM. Cooling tower coil control

valves shall be for water-coil applications up to 550 GPM Actuators are non-spring return for terminal unit coil control unless otherwise noted. If the coil is exposed to the outside air stream, see plans for spring return requirement.

- a. Leakage is aero percent, close-off is 200psi, maximum differential is 30psi; rangeability is 500:1.
  - b. Valves 0.5-2 inches shall be nickel-plated forged brass body, NPT screw type connections.
  - c. Valves 0.5-1.25 inches shall be rated for ANSI Class 600 working pressure. Valves over 1.5 inches shall be rated for ANSI Class 400 working pressure. Two- position control valves shall be line size.
  - d. The operating temperature range shall be 0-250 degrees F.
  - e. Stainless steel ball and stem shall be furnished on all modulating valves.
  - f. Seats shall be fiberglass reinforced Teflon.
  - g. Two-way and three-way valves shall have an equal percentage control port. Full stem rotation is required for maximum flow to insure stable BTU control of the coil.
  - h. Three-way valve shall be applicable for both mixing and diverting.
  - i. The characterizing disc is made of TEFZEL and shall be keyed and held secure by a retaining ring.
  - j. The valves shall have a blow-out proof stem design.
  - k. The stem packing shall consist of 2 lubricated O-rings designed for on-off or modulating service and require no maintenance.
  - l. The valves shall have an ISO type, 4-bolt flange for mounting actuator in any orientation parallel or perpendicular to the pipe.
  - m. A non-metallic thermal isolation adapter shall separate valve flange from actuator.
  - n. One fastening screw shall secure the direct coupling of the thermal isolation adapter between the actuator and the valve. This will prevent all lateral or rotational forces from affecting the stem and its packing O-rings.
3. Globe valves 0.5-2 inches shall be single port, top or bottom guided plug control or water flow applications.
- a. Valves shall be bronze body, NPT screw type, and shall be rated for ANSI Class 250 working pressure.
  - b. Valves 0.5 inches (DN15) through 2 inches (DN50) with spring return actuators shall close off against 50 psi pressure differential with Class III leakage (0.1%).
  - c. The operating temperature range shall be 20-280 degrees F.
  - d. Spring loaded TFE packing shall protect against leakage at the stem.
  - e. Two-way valves shall have an equal percentage control port.
  - f. Three-way valves shall have a linear control and bypass port.
  - g. Mixing and diverting valves must be installed specific to the valve design.
4. Globe Valve 2.5-6 inches
- a. Valves 2.5 inches (DN65) through 6 inches (DN150) shall be iron body, 125 lb. flanged with Class III (0.1%) close-off leakage at 50 psi differential.

- b. Valves with spring return actuators shall close off against 50 psi pressure differential with Class III leakage (0.1%).
- c. Flow type for two-way valves shall be equal percentage. Flow type for three-way valves shall be linear.
- d. Mixing and diverting valves must be installed specific to the valve design.

G. Butterfly valves

- 1. Butterfly valves shall be sized for modulating service at 60-70 degree stem rotation. Isolation valves shall be line-size. Design velocity shall be less than 12 feet per second when used with standard EPDM seats.
  - a. Body is cast iron.
  - b. Disc is aluminum bronze standard.
  - c. Seat is EPDM standard.
  - d. Body Pressure is 200 psi, -30-275 degrees F.
  - e. Flange is ANSI 125/250.
  - f. Media Temperature Range is -22-240 degree F.
  - g. Maximum Differential Pressure is 200 psi for 2- to 6- inch size.

H. Butterfly Valve Industrial Actuators

- 1. Actuators shall be approved under Canadian Standards Association or other Nationally Recognized Testing Laboratory to UL standards. CSA Class 4813 02 or equal. Enclosure shall be NEMA 4 (weatherproof) enclosure and will have an industrial quality coating.
  - a. Actuator shall have a motor rated for continuous duty. The motor shall be fractional horsepower; permanent split capacitor type designed to operate on a 120VAC, 1 $\phi$ H, 60Hz supply. Two adjustable cam-actuated end travel limit switches shall be provided to control direction of travel. A self-resetting thermal switch shall be imbedded in the motor for overload protection.
  - b. Reduction gearing shall be designed to withstand the actual motor stall torque. Gears shall be hardened alloy steel, permanently lubricated. A self-locking gear assembly or a brake shall be supplied.
  - c. Actuator shall have a 6 ft wiring harness provided for ease in field wiring (above 1500 in-lbs). Two adjustable SPDT cam-actuated auxiliary switches, rated at 250VAC shall be provided for indication of open and closed position. Actuator shall have heater and thermostat to minimize condensation within the actuator housing.
  - d. Actuator shall be equipped with a hand wheel for manual override to permit operation of the valve in the event of electrical power failure or system malfunction. Hand wheel must be permanently attached to the actuator and when in manual operation electrical power to the actuator will be permanently interrupted. The hand wheel will not rotate while the actuator is electrically driven.
  - e. The actuator shall be analog, floating, or two position as called out in the control sequence of operation. All Analog valves shall be positive positioning, and respond to a 2-IOVDC, 4-20mA, or adjustable signal as required. Analog actuators shall have a digital control card allowing any voltage input for control and any DC voltage feedback signal for position indication.



2. Performance Verification Test
  - a. Control loops shall cause productive actuation with each movement of the actuator and actuators shall modulate at a rate that is stable and responsive. Actuator movement shall not occur before the effects of previous movement have affected the sensor.
  - b. Actuator shall have capability of signaling a trouble alarm when the actuator Stop-Go Ratio exceeds 30%.
3. Actuator mounting for damper and valve arrangements shall comply with the following:
  - a. Damper actuators: Shall not be installed in the air stream
  - b. A weather shield shall be used if actuators are located outside. For damper actuators, use clear plastic enclosure.
  - c. Damper or valve actuator ambient temperature shall not exceed 122 degrees F through any combination of medium temperature or surrounding air. Appropriate air gaps, thermal isolation washers or spacers, standoff legs, or insulation shall be provided as necessary.
  - d. Actuator cords or conduit shall incorporate a drip leg if condensation is possible. Water shall not be allowed to contact actuator or internal parts. Location of conduits in temperatures dropping below dew point shall be avoided to prevent water from condensing in conduit and running into actuator.
4. Damper mounting arrangements shall comply with the following:
  - a. The contractor shall furnish and install damper channel supports and sheet metal collars.
  - b. No jack shafting of damper sections shall be allowed.
  - c. Multi-section dampers shall be arranged so that each damper section operates individually. One electronic actuator shall be direct shaft mounted per section.
5. Valve Sizing for Water Coil
  - a. Modulating control valve body size may be reduced, at most, two pipe sizes from the line size or not less than half the pipe size. The BAS contractor shall size all water coil control valves for the application as follows:
    - 1) Booster-heat valves shall be sized not to exceed 4-9psi differential pressure. Size valve for 50% valve authority. Valve design pressure drop is equal to the sum of coil drop plus the balance valve drop.
    - 2) Primary valves shall be sized not to exceed 5-15psi differential pressure. Size valve for 50% valve authority. Valve design pressure drop is equal to the sum of coil drop plus the balance valve drop.
    - 3) Butterfly valves shall be sized for modulating service at 60-70 degree rotation. Design velocity shall be 12 feet per second or less when used with standard EPDM seats.
  - b. Valve mounting arrangements shall comply to the following:
    - 1) Unions shall be provided on all ports of two-way and three-way valves.

- 2) Install three-way equal percentage characterized control valves in a mixing configuration with the "A" port piped to the coil.
- 3) Install 2.5 inches and above, three-way globe valves, as manufactured for mixing or diverting service to the coil.

## **2.10 CONTROL PANELS**

- A. All controllers, power supplies and relays shall be mounted in enclosures.
- B. Enclosures may be NEMA 1 when located in a clean, dry, indoor environment. Indoor enclosures shall be NEMA 12 when installed in other than a clean environment.
- C. Enclosures shall have hinged, locking doors.
- D. Provide laminated plastic nameplates for all enclosures in any mechanical room or electrical room. Include location and unit served on nameplate. Laminated plastic shall be 0.125 inches thick and appropriately sized to make label easy to read.
- E. Control panels must be assembled by a UL authorized fabricator in accordance with UL508A standards and labeled with separate UL label numbers.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Prior to starting work, carefully inspect installed work of other trades and verify that such work is complete to the point where work of this Section may properly commence.
- B. Notify the owner's representative in writing of conditions detrimental to the proper and timely completion of the work
- C. Do not begin work until all unsatisfactory conditions are resolved.

### **3.02 INSTALLATION (GENERAL)**

- A. Install in accordance with manufacturer's instructions.
- A. Provide all miscellaneous devices, hardware, software, interconnections, installation, and programming required to ensure a complete operating system in accordance with the sequences of operation and point schedules.

### **3.03 LOCATION AND INSTALLATION OF COMPONENTS**

- A. Locate and install components for easy accessibility; in general, mount 48 inches above floor with minimum 3 feet of clear access space in front of units. Obtain approval on locations from owner's representative prior to installation.
- B. All instruments, switches, transmitters, etc., shall be suitably wired and mounted to protect them from vibration, moisture, and high or low temperatures.
- C. Identify all equipment and panels. Provide permanently mounted tags for all panels.
- D. Provide stainless steel or brass thermowells suitable for respective application and for installation under other sections, and sized to suit pipe diameter without restricting flow.

### **3.04 INTERLOCKING AND CONTROL WIRING**

- A. Provide all interlock and control wiring. All wiring shall be installed neatly and professionally, in accordance with Specification Division 16 and all national, state and local electrical codes.

- B. Provide wiring as required by functions as specified and as recommended by equipment manufacturers, to serve specified control functions. Provide shielded low capacitance wire for all communications trunks.
- C. Control wiring shall not be installed in power circuit raceways. Magnetic starters and disconnect switches shall not be used as junction boxes. Provide auxiliary junction boxes as required. Coordinate location and arrangement of all control equipment with the owner's representative prior to rough-in.
- D. Provide auxiliary pilot duty relays on motor starters as required for control function.
- E. Provide power for all control components from nearest electrical control panel or as indicated on the electrical drawings; coordinate with electrical contractor.
- F. All control wiring in the mechanical, electrical, telephone and boiler rooms to be installed in raceways. All other wiring to be installed neatly and inconspicuously per local code requirements. If local code allows, control wiring above accessible ceiling spaces may be run with plenum-rated cable (without conduit).

### **3.05 DDC OBJECT TYPE SUMMARY**

- A. Provide all database generation.
- B. Displays
  - 1. System displays shall show all analog and binary object types within the system. They shall be logically laid out for easy use by the owner. Provide outside air temperature indication on all system displays associated with economizer cycles.
- C. Run Time Totalization
  - 1. At a minimum, run time totalization shall be incorporated for each monitored supply fan, return fan, exhaust fan, hot water and chilled water pumps. Warning limits for each point shall be entered for alarm and or maintenance purposes.
- D. Trendlog
  - 1. All binary and analog object types (including zones) shall have the capability to be automatically trended.
- E. Alarm
  - 1. All analog inputs (High/Low Limits) and selected binary input alarm points shall be prioritized and routed (locally or remotely) with alarm message per owner's requirements.
- F. Database Save
  - 1. Provide backup database for all standalone application controllers on disk.

### **3.06 FIELD SERVICES**

- A. Prepare and start logic control system under provisions of this section.
- B. Start up and commission systems. Allow sufficient time for startup and commissioning prior to placing control systems in permanent operation.
- C. Provide the capability for off-site monitoring at control contractor's local or main office. At a minimum, off-site facility shall be capable of system diagnostics and software download. Owner shall provide phone line for this service for one year or as specified.

- D. Provide owner's representative with spare parts list. Identify equipment critical to maintaining the integrity of the operating system.

### **3.07 AS-BUILT DOCUMENTATION REQUIRED**

- A. Complete set of accurate control drawings and programming.

### **3.08 TRAINING**

- A. Provide application engineer to instruct owner in operation of systems and equipment.
- B. Provide system operator's training to include (but not be limited to) such items as the following: modification of data displays, alarm and status descriptors, requesting data, execution of commands and request of logs. Provide this training to a minimum of three persons.
- C. Provide on-site training above as required, up to 16 hours as part of this contract.
- D. Provide tuition for at least two individuals to attend for a two-day factory training class.
- E. If applicable, costs for travel, lodging and meals will be the responsibility of the owner.

### **3.09 DEMONSTRATION**

- A. Demonstrate complete operating system to owner's representative.
- B. Provide certificate stating that control system has been tested and adjusted for proper operation.

END OF SECTION



**SECTION 22 11 23**  
**FACILITY NATURAL-GAS PIPING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Pipes, tubes, and fittings.
  - 2. Piping specialties.
  - 3. Piping and tubing joining materials.
  - 4. Manual gas shutoff valves.
  - 5. Pressure regulators.
  - 6. Dielectric fittings.

**1.02 DEFINITIONS**

- A. Finished Spaces: Spaces other than mechanical and electrical equipment rooms, furred spaces, pipe and duct shafts, unheated spaces immediately below roof, spaces above ceilings, unexcavated spaces, crawlspaces, and tunnels.
- B. Exposed, Interior Installations: Exposed to view indoors. Examples include finished occupied spaces and mechanical equipment rooms.
- C. Exposed, Exterior Installations: Exposed to view outdoors or subject to outdoor ambient temperatures and weather conditions. Examples include rooftop locations.

**1.03 ACTION SUBMITTALS**

- A. Product Data: For each type of the following:
  - 1. Piping specialties.
  - 2. Valves. Include pressure rating, capacity, settings, and electrical connection data of selected models.
  - 3. Pressure regulators. Indicate pressure ratings and capacities.
  - 4. Dielectric fittings.
- B. Shop Drawings: For facility natural-gas piping layout. Include plans, piping layout and elevations, sections, and details for fabrication of pipe anchors, hangers, supports for multiple pipes, alignment guides, expansion joints and loops, and attachments of the same to building structure. Detail location of anchors, alignment guides, and expansion joints and loops.
  - 1. Shop Drawing Scale: 1/4 inch per foot.
  - 2. Detail mounting, supports, and valve arrangements for service meter assembly and pressure regulator assembly.

**1.04 INFORMATIONAL SUBMITTALS**

- A. Coordination Drawings: Plans and details, drawn to scale, on which natural-gas piping is shown and coordinated with other installations, using input from installers of the items involved.

Refer to Section 23 00 50, "Common Work Results for HVAC Systems for additional requirements.

- B. Site Survey: Plans, drawn to scale, on which natural-gas piping is shown and coordinated with other services and utilities.
- C. Qualification Data: For qualified professional engineer.
- D. Welding certificates.
- E. Gas Pipe Installer Qualifications: Provide evidence of current qualifications for individuals performing work requiring qualifications.
- F. Field quality-control reports.

#### **1.05 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For pressure regulators to include in emergency, operation, and maintenance manuals.

#### **1.06 QUALITY ASSURANCE**

- A. Steel Support Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code - Steel."
- B. Pipe Welding Qualifications: Qualify procedures and operators according to ASME Boiler and Pressure Vessel Code.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.

#### **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Handling Flammable Liquids: Remove and dispose of liquids from existing natural-gas piping according to requirements of authorities having jurisdiction.
- B. Deliver pipes and tubes with factory-applied end caps. Maintain end caps through shipping, storage, and handling to prevent pipe end damage and to prevent entrance of dirt, debris, and moisture.
- C. Store and handle pipes and tubes having factory-applied protective coatings to avoid damaging coating, and protect from direct sunlight.
- D. Protect stored PE pipes and valves from direct sunlight.

#### **1.08 PROJECT CONDITIONS**

- A. Perform site survey, research public utility records, and verify existing utility locations. Contact utility-locating service for area where Project is located.
- B. Interruption of Existing Natural-Gas Service: Do not interrupt natural-gas service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide purging and startup of natural-gas supply according to requirements indicated:
  - 1. Notify Owner and Construction Manager no fewer than seven days in advance of proposed interruption of natural-gas service.
  - 2. Do not proceed with interruption of natural-gas service without Owner's and Construction Manager written permission.

## **1.09 COORDINATION**

- A. Coordinate sizes and locations of concrete bases with actual equipment provided.
- B. Coordinate requirements for access panels and doors for valves installed concealed behind finished surfaces.

## **PART 2 - PRODUCTS**

### **2.01 PERFORMANCE REQUIREMENTS**

- A. Minimum Operating-Pressure Ratings:
  - 1. Piping and Valves: 100 psig minimum unless otherwise indicated.
- B. Natural-Gas System Pressure within Buildings: 0.5 psig or less.

### **2.02 PIPES, TUBES, AND FITTINGS**

- A. Steel Pipe: ASTM A 53/A 53M, black steel, Schedule 40, Type E or S, Grade B.
  - 1. Malleable-Iron Threaded Fittings: ASME B16.3, Class 150, standard pattern.
  - 2. Wrought-Steel Welding Fittings: ASTM A 234/A 234M for butt welding and socket welding.
  - 3. Unions: ASME B16.39, Class 150, malleable iron with brass-to-iron seat, ground joint, and threaded ends.
  - 4. Forged-Steel Flanges and Flanged Fittings: ASME B16.5, minimum Class 150, including bolts, nuts, and gaskets of the following material group, end connections, and facings:
    - a. Material Group: 1.1.
    - b. End Connections: Threaded or butt welding to match pipe.
    - c. Lapped Face: Not permitted underground.
    - d. Gasket Materials: ASME B16.20, metallic, flat, asbestos free, aluminum o-rings, and spiral-wound metal gaskets.
    - e. Bolts and Nuts: ASME B18.2.1, carbon steel aboveground and stainless steel underground.

### **2.03 PIPING SPECIALTIES**

- A. Appliance Flexible Connectors:
  - 1. Indoor, Fixed-Appliance Flexible Connectors: Comply with ANSI Z21.24.
  - 2. Indoor, Movable-Appliance Flexible Connectors: Comply with ANSI Z21.69.
  - 3. Operating-Pressure Rating: 0.5 psig.
  - 4. End Fittings: Zinc-coated steel.
  - 5. Threaded Ends: Comply with ASME B1.20.1.
  - 6. Maximum Length: 72 inches
- B. Quick-Disconnect Devices: Comply with ANSI Z21.41.
  - 1. Copper-alloy convenience outlet and matching plug connector.
  - 2. Nitrile seals.



3. Hand operated with automatic shutoff when disconnected.
  4. For indoor or outdoor applications.
  5. Adjustable, retractable restraining cable.
- C. Y-Pattern Strainers:
1. Body: ASTM A 126, Class B, cast iron with bolted cover and bottom drain connection.
  2. End Connections: Threaded ends for NPS 2 and smaller; flanged ends for NPS 2-1/2 and larger.
  3. Strainer Screen: 40-mesh startup strainer, and perforated stainless-steel basket with 50 percent free area.
  4. CWP Rating: 125 psig.
- D. Basket Strainers:
1. Body: ASTM A 126, Class B, high-tensile cast iron with bolted cover and bottom drain connection.
  2. End Connections: Threaded ends for NPS 2 and smaller; flanged ends for NPS 2-1/2 and larger.
  3. Strainer Screen: 40-mesh startup strainer, and perforated stainless-steel basket with 50 percent free area.
  4. CWP Rating: 125 psig.
- E. T-Pattern Strainers:
1. Body: Ductile or malleable iron with removable access coupling and end cap for strainer maintenance.
  2. End Connections: Grooved ends.
  3. Strainer Screen: 40-mesh startup strainer, and perforated stainless-steel basket with 57 percent free area.
  4. CWP Rating: 750 psig.
- F. Weatherproof Vent Cap: Cast- or malleable-iron increaser fitting with corrosion-resistant wire screen, with free area at least equal to cross-sectional area of connecting pipe and threaded-end connection.

## **2.04 JOINING MATERIALS**

- A. Joint Compound and Tape: Suitable for natural gas.
- B. Welding Filler Metals: Comply with AWS D10.12/D10.12M for welding materials appropriate for wall thickness and chemical analysis of steel pipe being welded.

## **2.05 MANUAL GAS SHUTOFF VALVES**

- A. See "Underground Manual Gas Shutoff Valve Schedule" and "Aboveground Manual Gas Shutoff Valve Schedule" Articles for where each valve type is applied in various services.
- B. General Requirements for Metallic Valves, NPS 2 and Smaller: Comply with ASME B16.33.
  1. CWP Rating: 125 psig.
  2. Threaded Ends: Comply with ASME B1.20.1.
  3. Dryseal Threads on Flare Ends: Comply with ASME B1.20.3.

4. Tamperproof Feature: Locking feature for valves indicated in "Underground Manual Gas Shutoff Valve Schedule" and "Aboveground Manual Gas Shutoff Valve Schedule" Articles.
  5. Listing: Listed and labeled by an NRTL acceptable to authorities having jurisdiction for valves 1 inch and smaller.
  6. Service Mark: Valves 1-1/4 inches to NPS 2 shall have initials "WOG" permanently marked on valve body.
- C. General Requirements for Metallic Valves, NPS 2-1/2 and Larger: Comply with ASME B16.38.
1. CWP Rating: 125 psig.
  2. Flanged Ends: Comply with ASME B16.5 for steel flanges.
  3. Tamperproof Feature: Locking feature for valves indicated in "Underground Manual Gas Shutoff Valve Schedule" and "Aboveground Manual Gas Shutoff Valve Schedule" Articles.
  4. Service Mark: Initials "WOG" shall be permanently marked on valve body.
- D. Two-Piece, Full-Port, Bronze Ball Valves with Bronze Trim: MSS SP-110.
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. A.Y. McDonald Mfg. Co.
    - b. Apollo Flow Controls; Conbraco Industries, Inc.
    - c. BrassCraft Manufacturing Co.; a Masco company.
    - d. Lyall, R. W. & Company, Inc.
    - e. Perfection Corporation.
  2. Body: Bronze, complying with ASTM B 584.
  3. Ball: Chrome-plated bronze.
  4. Stem: Bronze; blowout proof.
  5. Seats: Reinforced TFE; blowout proof.
  6. Packing: Threaded-body packnut design with adjustable-stem packing.
  7. Ends: Threaded, flared, or socket as indicated in "Underground Manual Gas Shutoff Valve Schedule" and "Aboveground Manual Gas Shutoff Valve Schedule" Articles.
  8. CWP Rating: 600 psig.
  9. Listing: Valves NPS 1 and smaller shall be listed and labeled by an NRTL acceptable to authorities having jurisdiction.
  10. Service: Suitable for natural-gas service with "WOG" indicated on valve body.
- E. Bronze Plug Valves: MSS SP-78.
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. A.Y. McDonald Mfg. Co.
    - b. Lee Brass Company.
  2. Body: Bronze, complying with ASTM B 584.

3. Plug: Bronze.
4. Ends: Threaded, socket, or flanged as indicated in "Underground Manual Gas Shutoff Valve Schedule" and "Aboveground Manual Gas Shutoff Valve Schedule" Articles.
5. Operator: Square head or lug type with tamperproof feature where indicated.
6. Pressure Class: 125 psig.
7. Listing: Valves NPS 1 and smaller shall be listed and labeled by an NRTL acceptable to authorities having jurisdiction.
8. Service: Suitable for natural-gas service with "WOG" indicated on valve body.

## **2.06 PRESSURE REGULATORS**

### **A. General Requirements:**

1. Single stage and suitable for natural gas.
2. Steel jacket and corrosion-resistant components.
3. Elevation compensator.
4. End Connections: Threaded for regulators NPS 2 and smaller; flanged for regulators NPS 2-1/2 and larger.

### **B. Line Pressure Regulators: Comply with ANSI Z21.80.**

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:
  - a. Actaris.
  - b. American Meter Company.
  - c. Invensys.
  - d. Itron Gas.
2. Body and Diaphragm Case: Cast iron or die-cast aluminum.
3. Springs: Zinc-plated steel; interchangeable.
4. Diaphragm Plate: Zinc-plated steel.
5. Seat Disc: Nitrile rubber resistant to gas impurities, abrasion, and deformation at the valve port.
6. Orifice: Aluminum; interchangeable.
7. Seal Plug: Ultraviolet-stabilized, mineral-filled nylon.
8. Single-port, self-contained regulator with orifice no larger than required at maximum pressure inlet, and no pressure sensing piping external to the regulator.
9. Pressure regulator shall maintain discharge pressure setting downstream, and not exceed 150 percent of design discharge pressure at shutoff.
10. Overpressure Protection Device: Factory mounted on pressure regulator.
11. Atmospheric Vent: Factory- or field-installed, stainless-steel screen in opening if not connected to vent piping.
12. Maximum Inlet Pressure: 2 psig.

## 2.07 DIELECTRIC FITTINGS

- A. General Requirements: Assembly of copper alloy and ferrous materials with separating nonconductive insulating material. Include end connections compatible with pipes to be joined.
- B. Dielectric Unions:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. A.Y. McDonald Mfg. Co.
    - b. Capitol Manufacturing Company.
    - c. Central Plastics Company.
    - d. HART Industrial Unions, LLC.
    - e. Jomar Valve.
    - f. Matco-Norca.
    - g. Watts; a Watts Water Technologies company.
    - h. Wilkins.
    - i. Zurn Industries, LLC.
  - 2. Description:
    - a. Standard: ASSE 1079.
    - b. Pressure Rating: 125 psig minimum at 180 deg F.
    - c. End Connections: Solder-joint copper alloy and threaded ferrous.
- C. Dielectric Flanges:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Capitol Manufacturing Company.
    - b. Central Plastics Company.
    - c. Matco-Norca.
    - d. Watts; a Watts Water Technologies company.
    - e. Wilkins.
  - 2. Description:
    - a. Standard: ASSE 1079.
    - b. Factory-fabricated, bolted, companion-flange assembly.
    - c. Pressure Rating: 125 psig minimum at 180 deg F.
    - d. End Connections: Solder-joint copper alloy and threaded ferrous; threaded solder-joint copper alloy and threaded ferrous.
- D. Dielectric-Flange Insulating Kits:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - a. Advance Products & Systems, Inc.
  - b. Calpico, Inc.
  - c. Central Plastics Company.
  - d. Pipeline Seal and Insulator, Inc.
2. Description:
  - a. Nonconducting materials for field assembly of companion flanges.
  - b. Pressure Rating: 150 psig.
  - c. Gasket: Neoprene or phenolic.
  - d. Bolt Sleeves: Phenolic or polyethylene.
  - e. Washers: Phenolic with steel backing washers.

### **PART 3 - EXECUTION**

#### **3.01 EXAMINATION**

- A. Examine roughing-in for natural-gas piping system to verify actual locations of piping connections before equipment installation.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

#### **3.02 PREPARATION**

- A. Close equipment shutoff valves before turning off natural gas to premises or piping section.
- B. Inspect natural-gas piping according to NFPA 54 to determine that natural-gas utilization devices are turned off in piping section affected.
- C. Comply with NFPA 54 requirements for prevention of accidental ignition.

#### **3.03 OUTDOOR PIPING INSTALLATION**

- A. Comply with NFPA 54 for installation and purging of natural-gas piping.
- B. Install fittings for changes in direction and branch connections.

#### **3.04 INDOOR PIPING INSTALLATION**

- A. Comply with NFPA 54 for installation and purging of natural-gas piping.
- B. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements are used to size pipe and calculate friction loss, expansion, and other design considerations. Install piping as indicated unless deviations to layout are approved on Coordination Drawings.
- C. Arrange for pipe spaces, chases, slots, sleeves, and openings in building structure during progress of construction, to allow for mechanical installations.
- D. Install piping in concealed locations unless otherwise indicated and except in equipment rooms and service areas.

- E. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- F. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- G. Locate valves for easy access.
- H. Install natural-gas piping at uniform grade of 2 percent down toward drip and sediment traps.
- I. Install piping free of sags and bends.
- J. Install fittings for changes in direction and branch connections.
- K. Verify final equipment locations for roughing-in.
- L. Comply with requirements in Sections specifying gas-fired appliances and equipment for roughing-in requirements.
- M. Drips and Sediment Traps: Install drips at points where condensate may collect, including service-meter outlets. Locate where accessible to permit cleaning and emptying. Do not install where condensate is subject to freezing.
  - 1. Construct drips and sediment traps using tee fitting with bottom outlet plugged or capped. Use nipple a minimum length of 3 pipe diameters, but not less than 3 inches long and same size as connected pipe. Install with space below bottom of drip to remove plug or cap.
- N. Extend relief vent connections for line regulators, and overpressure protection devices to outdoors and terminate with weatherproof vent cap.
- O. Conceal pipe installations in walls, pipe spaces, utility spaces, above ceilings, below grade or floors, and in floor channels unless indicated to be exposed to view.
- P. Concealed Location Installations: Except as specified below, install concealed natural-gas piping and piping installed under the building in containment conduit constructed of steel pipe with welded joints as described in Part 2. Install a vent pipe from containment conduit to outdoors and terminate with weatherproof vent cap.
  - 1. Above Accessible Ceilings: Natural-gas piping, fittings, valves, and regulators may be installed in accessible spaces without containment conduit.
  - 2. In Walls or Partitions: Protect tubing installed inside partitions or hollow walls from physical damage using steel striker barriers at rigid supports.
    - a. Exception: Tubing passing through partitions or walls does not require striker barriers.
  - 3. Prohibited Locations:
    - a. Do not install natural-gas piping in or through circulating air ducts, clothes or trash chutes, chimneys or gas vents (flues), ventilating ducts, or dumbwaiter or elevator shafts.
    - b. Do not install natural-gas piping in solid walls or partitions.
- Q. Use eccentric reducer fittings to make reductions in pipe sizes. Install fittings with level side down.
- R. Connect branch piping from top or side of horizontal piping.

- S. Install unions in pipes NPS 2 and smaller, adjacent to each valve, at final connection to each piece of equipment. Unions are not required at flanged connections.
- T. Do not use natural-gas piping as grounding electrode.
- U. Install strainer on inlet of each line-pressure regulator.
- V. Install sleeves for piping penetrations of walls, ceilings, and floors. Comply with requirements for sleeves specified in Section 23 05 17 "Sleeves and Sleeve Seals for HVAC Piping."
- W. Install sleeve seals for piping penetrations of concrete walls and slabs. Comply with requirements for sleeve seals specified in Section 23 05 17 "Sleeves and Sleeve Seals for HVAC Piping."
- X. Install escutcheons for piping penetrations of walls, ceilings, and floors. Comply with requirements for escutcheons specified in Section 23 05 18 "Escutcheons for HVAC Piping."

### **3.05 VALVE INSTALLATION**

- A. Install manual gas shutoff valve for each gas appliance ahead of corrugated stainless-steel tubing, aluminum, or copper connector.
- B. Install regulators and overpressure protection devices with maintenance access space adequate for servicing and testing.

### **3.06 PIPING JOINT CONSTRUCTION**

- A. Ream ends of pipes and tubes and remove burrs.
- B. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
- C. Threaded Joints:
  - 1. Thread pipe with tapered pipe threads complying with ASME B1.20.1.
  - 2. Cut threads full and clean using sharp dies.
  - 3. Ream threaded pipe ends to remove burrs and restore full inside diameter of pipe.
  - 4. Apply appropriate tape or thread compound to external pipe threads unless dryseal threading is specified.
  - 5. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.
- D. Welded Joints:
  - 1. Construct joints according to AWS D10.12/D10.12M, using qualified processes and welding operators.
  - 2. Bevel plain ends of steel pipe.
  - 3. Patch factory-applied protective coating as recommended by manufacturer at field welds and where damage to coating occurs during construction.
- E. Flanged Joints: Install gasket material, size, type, and thickness appropriate for natural-gas service. Install gasket concentrically positioned.

### **3.07 CONNECTIONS**

- A. Install natural-gas piping electrically continuous, and bonded to gas appliance equipment grounding conductor of the circuit powering the appliance according to NFPA 70.

- B. Install piping adjacent to appliances to allow service and maintenance of appliances.
- C. Connect piping to appliances using manual gas shutoff valves and unions. Install valve within 72 inches of each gas-fired appliance and equipment. Install union between valve and appliances or equipment.
- D. Sediment Traps: Install tee fitting with capped nipple in bottom to form drip, as close as practical to inlet of each appliance.

### **3.08 PAINTING**

- A. Paint exposed, exterior metal piping, valves, earthquake valves, and piping specialties, except components, with factory-applied paint or protective coating.
  - 1. Alkyd System: MPI EXT 5.1D.
    - a. Prime Coat: Alkyd anticorrosive metal primer.
    - b. For a Premium Grade system, "MPI Manual" requires intermediate coat; delete intermediate coat for a Custom Grade system.
    - c. Intermediate Coat: Exterior alkyd enamel matching topcoat.
    - d. Topcoat: Exterior alkyd enamel (flat).
    - e. Color: Gray.
- B. Paint exposed, interior metal piping, valves, service regulators, and piping specialties, except components, with factory-applied paint or protective coating.
  - 1. Latex Over Alkyd Primer System: MPI INT 5.1Q.
    - a. Prime Coat: Alkyd anticorrosive metal primer.
    - b. Intermediate Coat: Interior latex matching topcoat.
    - c. Topcoat: Interior latex (flat).
    - d. Color: Gray.
  - 2. Alkyd System: MPI INT 5.1E.
    - a. Prime Coat: Alkyd anticorrosive metal primer.
    - b. Intermediate Coat: Interior alkyd matching topcoat.
    - c. Topcoat: Interior alkyd (flat).
    - d. Color: Gray.
- C. Damage and Touchup: Repair marred and damaged factory-applied finishes with materials and by procedures to match original factory finish.

### **3.09 LABELING AND IDENTIFYING**

- A. Comply with requirements in Section 23 05 53 "Identification for HVAC Piping and Equipment" for piping and valve identification.

### **3.10 FIELD QUALITY CONTROL**

- A. Perform tests and inspections.
- B. Tests and Inspections:
  - 1. Test, inspect, and purge natural gas according to NFPA 54 and authorities having jurisdiction.



- C. Natural-gas piping will be considered defective if it does not pass tests and inspections.
- D. Prepare test and inspection reports.

### **3.11 OUTDOOR PIPING SCHEDULE**

- A. Aboveground natural-gas piping shall be the following:
  - 1. NPS 2 and Smaller: Steel pipe with malleable-iron fittings and threaded joints.
  - 2. NPS 2-1/2 and Larger: Steel pipe with wrought-steel fittings and welded joints.

### **3.12 INDOOR PIPING SCHEDULE FOR SYSTEM PRESSURES LESS THAN 0.5 PSIG**

- A. Aboveground, branch piping shall be the following:
  - 1. NPS 2 and Smaller: Steel pipe with malleable-iron fittings and threaded joints.
  - 2. NPS 2-1/2 and Larger: Steel pipe with wrought-steel fittings and welded joints.
- B. Aboveground, distribution piping shall be the following:
  - 1. NPS 2 and Smaller: Steel pipe with malleable-iron fittings and threaded joints.
  - 2. NPS 2-1/2 and Larger: Steel pipe with wrought-steel fittings and welded joints.

### **3.13 ABOVEGROUND MANUAL GAS SHUTOFF VALVE SCHEDULE**

- A. Distribution piping valves for pipe sizes NPS 2 and smaller shall be the following:
  - 1. Bronze plug valve.
  - 2. Two-piece, full-port, bronze ball valves with bronze trim.
- B. Valves in branch piping for single appliance shall be one of the following:
  - 1. Bronze plug valve.
  - 2. Two-piece, full-port, bronze ball valves with bronze trim.

END OF SECTION

**SECTION 23 23 00**  
**REFRIGERANT PIPING**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
1. Refrigerant pipes and fittings.
  2. Refrigerant piping valves and specialties.

**1.02 PERFORMANCE REQUIREMENTS**

- A. Line Test Pressure for Refrigerant R-410A:
1. Suction Lines for Heat-Pump Applications: 535 psig.
  2. Hot-Gas and Liquid Lines: 535 psig.

**1.03 ACTION SUBMITTALS**

- A. Shop Drawings:
1. Show layout of refrigerant piping and specialties, including pipe, tube, and fitting sizes, flow capacities, valve arrangements and locations, slopes of horizontal runs, oil traps, double risers, wall and floor penetrations, and equipment connection details. Show interface and spatial relationships between piping and equipment.
  2. Show piping size and piping layout, including oil traps, double risers, specialties, and pipe and tube sizes to accommodate, as a minimum, equipment provided, elevation difference between compressor and evaporator, and length of piping to ensure proper operation and compliance with warranties of connected equipment.
  3. Show interface and spatial relationships between piping and equipment.
  4. Shop Drawing Scale: 1/4 inch equals 1 foot.

**1.04 INFORMATIONAL SUBMITTALS**

- A. Welding certificates.
- B. Field quality-control test reports.

**1.05 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For refrigerant valves and piping specialties to include in maintenance manuals.

**1.06 QUALITY ASSURANCE**

- A. Welding: Qualify procedures and personnel according to ASME Boiler and Pressure Vessel Code: Section IX, "Welding and Brazing Qualifications."
- B. Comply with ASHRAE 15, "Safety Code for Refrigeration Systems."
- C. Comply with ASME B31.5, "Refrigeration Piping and Heat Transfer Components."

## 1.07 PRODUCT STORAGE AND HANDLING

- A. Store piping with end caps in place to ensure that piping interior and exterior are clean when installed.

## 1.08 COORDINATION

- A. Coordinate size and location of roof curbs, equipment supports, and roof penetrations. These items are specified in Section 077200 "Roof Accessories."

## PART 2 - PRODUCTS

### 2.01 COPPER TUBE AND FITTINGS

- A. Copper Tube: ASTM B 280, Type ACR. Refer to piping application schedules in PART 3 of this Section.
  - 1. Manufactured, pre-charged and pre-insulated refrigerant line-set refrigerant piping may be utilized at Contractor's discretion.
  - 2. VRF Systems: Refrigerant piping between outdoor condensing unit and first distribution header shall be hard-drawn copper as specified in this Section. When system manufacturer's installation instructions allow use of refrigerant line-set piping between distribution headers and tees and air terminal devices, follow instructions for allowable pipe size range and support to avoid forming traps in the piping.
- A. Variable Refrigerant Flow Heat Pump Systems Fittings:
  - 1. For systems manufacturers requiring engineered, pre-assembled headers and branch fittings, Contractor shall obtain such fittings from system manufacturer. Fittings shall be suitable for system type and configuration.
  - 2. VRF Systems: Use of manufactured, pre-charged and pre-insulated refrigerant line-set refrigerant piping between outdoor condensing units and indoor distribution headers and tees is not allowed. When system manufacturer's installation instructions allow use of refrigerant line-set piping between distribution headers and tees, and air terminal devices, follow instructions for allowable pipe size range and support to avoid forming traps in the piping.
- B. Wrought-Copper Fittings: ASME B16.22.
- C. Wrought-Copper Unions: ASME B16.22.
- D. Brazing Filler Metals: AWS A5.8.
- E. Flexible Connectors:
  - 1. Body: Tin-bronze bellows with woven, flexible, tinned-bronze-wire-reinforced protective jacket.
  - 2. End Connections: Socket ends.
  - 3. Offset Performance: Capable of minimum 3/4-inch misalignment in minimum 7-inch-long assembly.
  - 4. Pressure Rating: Factory test at minimum 500 psig.
  - 5. Maximum Operating Temperature: 250 deg F.

## **2.02 REFRIGERANTS**

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Atofina Chemicals, Inc.
  - 2. DuPont Company; Fluorochemicals Div.
  - 3. Honeywell, Inc.; Genetron Refrigerants.
  - 4. INEOS Fluor Americas LLC.
- C. ASHRAE 34, R-410A: Pentafluoroethane/Difluoromethane.

## **PART 3 - EXECUTION**

### **3.01 PIPING APPLICATIONS FOR REFRIGERANT R-410A**

- A. Suction, Hot Gas and Liquid Lines, all Sizes, for Heat Pump Applications: Copper, Type ACRL, drawn-temper tubing and wrought-copper fittings with brazed joints.
- B. Safety-Relief-Valve Discharge Piping:
  - 1. Safety relief valve piping shall be as specified for refrigerant piping.

### **3.02 PIPING INSTALLATION**

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems; indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on Shop Drawings.
- B. Install refrigerant piping according to ASHRAE 15.
- C. Install piping in concealed locations unless otherwise indicated and except in equipment rooms and service areas.
- D. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- E. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- F. Install piping adjacent to machines to allow service and maintenance.
- G. Install piping free of sags and bends.
- H. Install fittings for changes in direction and branch connections.
- I. Select system components with pressure rating equal to or greater than system operating pressure.
- J. Refer to Section 230923 "Direct Digital Control System for HVAC" for solenoid valve controllers and control wiring.
- K. Refer Drawings for sequence of operation.

- L. Install piping as short and direct as possible, with a minimum number of joints, elbows, and fittings.
- M. Arrange piping to allow inspection and service of refrigeration equipment. Install valves and specialties in accessible locations to allow for service and inspection. Install access doors or panels as specified in Section 083100 "Access Doors and Panels" if valves or equipment requiring maintenance is concealed behind finished surfaces.
- N. Install refrigerant piping in protective conduit where installed belowground.
- O. Install refrigerant piping in rigid or flexible conduit in locations where exposed to mechanical injury.
- P. Install manufactured, pre-charged and pre-insulated refrigerant line-set refrigerant piping in rigid or flexible conduit.
- Q. Slope refrigerant piping as follows:
  - 1. Install horizontal hot-gas discharge piping with a uniform slope downward away from compressor.
  - 2. Install horizontal suction lines with a uniform slope downward to compressor.
  - 3. Install traps and double risers to entrain oil in vertical runs.
  - 4. Liquid lines may be installed level.
- R. When brazing or soldering, remove solenoid-valve coils and sight glasses; also remove valve stems, seats, and packing, and accessible internal parts of refrigerant specialties. Do not apply heat near expansion-valve bulb.
- S. Install piping with adequate clearance between pipe and adjacent walls and hangers or between pipes for insulation installation.
- T. Identify refrigerant piping and valves according to Section 230553 "Identification for HVAC Piping and Equipment."
- U. Install sleeves for piping penetrations of walls, ceilings, and floors. Comply with requirements for sleeves specified in Section 230517 "Sleeves and Sleeve Seals for HVAC Piping."
- V. Install sleeve seals for piping penetrations of concrete walls and slabs. Comply with requirements for sleeve seals specified in Section 230517 "Sleeves and Sleeve Seals for HVAC Piping."
- W. Install escutcheons for piping penetrations of walls, ceilings, and floors. Comply with requirements for escutcheons specified in Section 230518 "Escutcheons for HVAC Piping."

### **3.03 PIPE JOINT CONSTRUCTION**

- A. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- B. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
- C. Fill pipe and fittings with an inert gas (nitrogen or carbon dioxide), during brazing or welding, to prevent scale formation.
- D. Brazed Joints: Construct joints according to AWS's "Brazing Handbook," Chapter "Pipe and Tube."

1. Use Type BcuP, copper-phosphorus alloy for joining copper socket fittings with copper pipe.
2. Use Type BAg, cadmium-free silver alloy for joining copper with bronze or steel.

### **3.04 HANGERS AND SUPPORTS**

- A. Hanger, support, and anchor products are specified in Section 230529 "Hangers and Supports for HVAC Piping and Equipment."
- B. Install the following pipe attachments:
  1. Adjustable steel clevis hangers for individual horizontal runs less than 20 feet long.
  2. Roller hangers and spring hangers for individual horizontal runs 20 feet or longer.
  3. Pipe Roller: MSS SP-58, Type 44 for multiple horizontal piping 20 feet or longer, supported on a trapeze.
  4. Spring hangers to support vertical runs.
  5. Copper-clad hangers and supports for hangers and supports in direct contact with copper pipe.
- C. Install hangers for copper tubing with the following maximum spacing and minimum rod sizes:
  1. NPS 1/2: Maximum span, 60 inches; minimum rod size, 3/8 inch.
  2. NPS 5/8: Maximum span, 60 inches; minimum rod size, 3/8 inch.
  3. NPS 1: Maximum span, 72 inches; minimum rod size, 3/8 inch.
  4. NPS 1-1/4: Maximum span, 96 inches; minimum rod size, 3/8 inch.
  5. NPS 1-1/2: Maximum span, 96 inches; minimum rod size, 3/8 inch.
  6. NPS 2: Maximum span, 96 inches; minimum rod size, 3/8 inch.
  7. NPS 2-1/2: Maximum span, 108 inches; minimum rod size, 3/8 inch.
  8. NPS 3: Maximum span, 10 feet; minimum rod size, 3/8 inch.
  9. NPS 4: Maximum span, 12 feet; minimum rod size, 1/2 inch.
- D. Support multifloor vertical runs at least at each floor.

### **3.05 FIELD QUALITY CONTROL**

- A. Perform tests and inspections and prepare test reports.
- B. Tests and Inspections:
  1. Comply with ASME B31.5, Chapter VI.
  2. Test refrigerant piping, specialties, and receivers. Isolate compressor, condenser, evaporator, and safety devices from test pressure if they are not rated above the test pressure.
  3. Test high- and low-pressure side piping of each system separately at not less than the pressures indicated in Part 1 "Performance Requirements" Article.
    - a. Fill system with nitrogen to the required test pressure.

- b. System shall maintain test pressure at the manifold gage throughout duration of test.
- c. Test joints and fittings with electronic leak detector or by brushing a small amount of soap and glycerin solution over joints.
- d. Remake leaking joints using new materials, and retest until satisfactory results are achieved.

### **3.06 SYSTEM CHARGING**

- A. Charge system using the following procedures:
  - 1. Install core in filter dryers after leak test but before evacuation.
  - 2. Evacuate entire refrigerant system with a vacuum pump to 500 micrometers. If vacuum holds for 12 hours, system is ready for charging.
  - 3. Break vacuum with refrigerant gas, allowing pressure to build up to 2 psig.
  - 4. Charge system with a new filter-dryer core in charging line.

END OF SECTION

**SECTION 23 31 13**  
**METAL DUCTS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Single-wall rectangular ducts and fittings.
  - 2. Single-wall round ducts and fittings.
  - 3. Sheet metal materials.
  - 4. Duct liner.
  - 5. Sealants and gaskets.
  - 6. Hangers and supports.
  - 7. Seismic-restraint devices.
- B. Related Sections:
  - 1. Section 23 05 93 "Testing, Adjusting, and Balancing for HVAC" for testing, adjusting, and balancing requirements for metal ducts.
  - 2. Section 23 33 00 "Air Duct Accessories" for dampers, sound-control devices, duct-mounting access doors and panels, turning vanes, and flexible ducts.

**1.02 PERFORMANCE REQUIREMENTS**

- A. Delegated Duct Design: Duct construction, including sheet metal thicknesses, seam and joint construction, reinforcements, and hangers and supports, shall comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" and performance requirements and design criteria indicated in "Duct Schedule" Article.
- B. Structural Performance: Duct hangers and supports and seismic restraints shall withstand the effects of gravity and seismic loads and stresses within limits and under conditions described in CBC and ASCE/SEI 7, as referenced by the CBC.
  - 1. Seismic Hazard Level A: Seismic force to weight ratio, 0.48.
  - 2. Seismic Hazard Level B: Seismic force to weight ratio, 0.30.
  - 3. Seismic Hazard Level C: Seismic force to weight ratio, 0.15.
- C. Airstream Surfaces: Surfaces in contact with the airstream shall comply with requirements in ASHRAE 62.1.

**1.03 ACTION SUBMITTALS**

- A. Product Data: For each type of the following products:
  - 1. Liners and adhesives.
  - 2. Sealants and gaskets.
  - 3. Seismic-restraint devices.
- B. Sustainable Design Submittals:



1. Product Data: Documentation indicating that duct systems comply with ASHRAE 62.1, Section 5 - "Systems and Equipment."
  2. Product Data: For adhesives, indicating VOC content.
  3. Product Data: For sealants, indicating VOC content.
- C. Shop Drawings:
1. Fabrication, assembly, and installation, including plans, elevations, sections, components, and attachments to other work.
  2. Factory- and shop-fabricated ducts and fittings.
  3. Duct layout indicating sizes, configuration, liner material, and static-pressure classes.
  4. Elevation of top of ducts.
  5. Dimensions of main duct runs from building grid lines.
  6. Fittings.
  7. Reinforcement and spacing.
  8. Seam and joint construction.
  9. Penetrations through fire-rated and other partitions.
  10. Equipment installation based on equipment being used on Project.
  11. Locations for duct accessories, including dampers, turning vanes, and access doors and panels.
  12. Hangers and supports, including methods for duct and building attachment, seismic restraints, and vibration isolation.
- D. Delegated-Design Submittal:
1. Sheet metal thicknesses.
  2. Joint and seam construction and sealing.
  3. Reinforcement details and spacing.
  4. Materials, fabrication, assembly, and spacing of hangers and supports.
  5. Design Calculations: Calculations, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation for selecting hangers and supports and seismic restraints.

#### **1.04 INFORMATIONAL SUBMITTALS**

- A. Coordination Drawings: Plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
1. Duct installation in congested spaces, indicating coordination with general construction, building components, and other building services. Indicate proposed changes to duct layout.
  2. Suspended ceiling components.
  3. Structural members to which duct will be attached.
  4. Size and location of initial access modules for acoustical tile.
  5. Penetrations of smoke barriers and fire-rated construction.
  6. Items penetrating finished ceiling including the following:

- a. Lighting Fixtures.
  - b. Air outlets and inlets.
  - c. Speakers.
  - d. Sprinklers.
  - e. Access panels.
  - f. Perimeter moldings.
7. Refer to Section 23 00 50, "Common Work Results for HVAC Systems for additional requirements.
- A. Welding certificates.
  - B. Field quality-control reports.
  - C. Coordinated layout.

#### **1.05 COORDINATED LAYOUT:**

- A. Coordinated layouts are required to amplify, expand and coordinate the information contained in the Contract Documents.
- B. Provide minimum 1/4 inch equals one foot scaled coordinated layout drawings showing plan and pertinent section or elevation views of piping, ductwork, equipment, accessories, and electrical systems. Drawings shall be reproducible and work of each trade represented shall be fully coordinated with structure, other disciplines, and finished surfaces. Drawings shall be presented on a single size sheet. Coordinated layout drawings shall have title block, key plan, north arrow and sufficient grid lines to provide cross-reference to design Drawings.
  - 1. Provide a stamp or title block on each drawing with locations for signatures from all contractors involved, including but not limited to the General, HVAC, Plumbing, Fire Protection, and Electrical contractors. Include statement for signature that the contractor has reviewed the coordinated layout drawings in detail and has coordinated the work of his trade.
  - 2. Show on drawings the intended elevation of all ductwork in accordance with the following example:
    - a. B.O.D. = 9'-0"
    - b. OFFSET UP 6"
    - c. B.O.D. = 9'-6"
  - 3. Highlight, encircle or otherwise indicate deviations from the Contract Documents on the coordinated layouts. Architect will not be responsible for identifying deviations from the original Contract Documents.
- C. Since scale of contract drawings is small and all offsets and fittings are not shown, Contractor shall make allowances in bid for additional coordination time, detailing, fittings, offsets, hangers and the like to achieve a fully coordinated installation. If changes in duct size are required, equivalent area shall be maintained and the aspect ratio shall not be in excess of 2 to 1 unless approved by the engineer. Drawings shall be submitted for review prior to fabrication and installation. Drawings may be submitted in packages representing at least one quarter of the building ductwork.

- D. Check routing on all ductwork before fabricating. Report any discrepancies to Architect. No extra cost will be allowed for failure to conform to above.

## **1.06 QUALITY ASSURANCE**

- A. Welding Qualifications: Qualify procedures and personnel according to the following:
  - 1. AWS D1.1/D1.1M, "Structural Welding Code - Steel," for hangers and supports.
  - 2. AWS D1.2/D1.2M, "Structural Welding Code - Aluminum," for aluminum supports.
  - 3. AWS D9.1M/D9.1, "Sheet Metal Welding Code," for duct joint and seam welding.
- B. ASHRAE Compliance: Applicable requirements in ASHRAE 62.1, Section 5 - "Systems and Equipment" and Section 7 - "Construction and System Start-up."
- C. ASHRAE/IES Compliance: Applicable requirements in ASHRAE/IESNA 90.1, Section 6.4.4 - "HVAC System Construction and Insulation."

## **PART 2 - PRODUCTS**

### **2.01 MATERIALS**

- A. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).

### **2.02 SINGLE-WALL RECTANGULAR DUCTS AND FITTINGS**

- A. General Fabrication Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" based on indicated static-pressure class unless otherwise indicated.
- B. Transverse Joints: Select joint types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 2-1, "Rectangular Duct/Transverse Joints," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
- C. Longitudinal Seams: Select seam types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 2-2, "Rectangular Duct/Longitudinal Seams," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
- D. Elbows, Transitions, Offsets, Branch Connections, and Other Duct Construction: Select types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Chapter 4, "Fittings and Other Construction," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible." Square elbows with and without turning vanes will not be allowed. In their place 1-1/2 radius, 1 radius and SMACNA RE-3 elbow will be used in place of square elbows.

## 2.03 SINGLE-WALL ROUND DUCTS AND FITTINGS

- A. General Fabrication Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Chapter 3, "Round, Oval, and Flexible Duct," based on indicated static-pressure class unless otherwise indicated.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Ductmate Industries, Inc.
    - b. Elgen Manufacturing.
    - c. Linx Industries (formerly Lindab).
    - d. McGill AirFlow LLC.
    - e. MKT Metal Manufacturing.
    - f. SEMCO Incorporated.
    - g. Sheet Metal Connectors, Inc.
    - h. Spiral Manufacturing Co., Inc.
    - i. Stamped Fittings Inc.
- B. Transverse Joints: Select joint types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-1, "Round Duct Transverse Joints," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
  - 1. Transverse Joints in Ducts Larger Than 60 Inches in Diameter: Flanged.
- C. Longitudinal Seams: Select seam types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-2, "Round Duct Longitudinal Seams," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
  - 1. Fabricate round ducts larger than 90 inches in diameter with butt-welded longitudinal seams.
  - 2. Fabricate flat-oval ducts larger than 72 inches in width (major dimension) with butt-welded longitudinal seams.
- D. Tees and Laterals: Select types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-5, "90 Degree Tees and Laterals," and Figure 3-6, "Conical Tees," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."

## 2.04 SHEET METAL MATERIALS

- A. General Material Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for acceptable materials, material thicknesses, and duct construction methods unless otherwise indicated. Sheet metal materials shall be free of pitting, seam marks, roller marks, stains, discolorations, and other imperfections.

- B. Galvanized Sheet Steel: Comply with ASTM A 653/A 653M.
  - 1. Galvanized Coating Designation: G90.
  - 2. Finishes for Surfaces Exposed to View: Mill phosphatized.
- C. Reinforcement Shapes and Plates: ASTM A 36/A 36M, steel plates, shapes, and bars; black and galvanized.
- D. Tie Rods: Galvanized steel, 1/4-inch minimum diameter for lengths 36 inches or less; 3/8-inch minimum diameter for lengths longer than 36 inches.

## 2.05 DUCT LINER

- A. Fibrous-Glass Duct Liner: Comply with ASTM C 1071, NFPA 90A, or NFPA 90B; and with NAIMA AH124, "Fibrous Glass Duct Liner Standard."
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. CertainTeed Corporation.
    - b. Johns Manville; a Berkshire Hathaway company.
    - c. Knauf Insulation.
    - d. Owens Corning.
      - 1) Type I, Flexible: 0.27 Btu x in./h x sq. ft. x deg F at 75 deg F mean temperature.
      - 2) Type II, Rigid: 0.23 Btu x in./h x sq. ft. x deg F at 75 deg F mean temperature.
  - 2. Provide internal duct lining where indicated on the Drawings, with a minimum of 10'-0" length in each direction from the fan, fan casing, or unit casing. Provide additional lining length where shown. Line all transfer ducts.
    - a. Where ductwork is exposed to weather or outside the building insulation envelope, provide 2 inch thick, 1-1/2 pound density internal lining with matte facing, with an R-Value of 8.0 minimum.
    - b. Where ductwork is within the building insulation envelope, lining shall be 1" thick, 1-1/2 pound density, with R-value of 4.2 minimum.
  - 3. Antimicrobial Erosion-Resistant Coating: Apply to the surface of the liner that will form the interior surface of the duct to act as a moisture repellent and erosion-resistant coating. Antimicrobial compound shall be tested for efficacy by an NRTL and registered by the EPA for use in HVAC systems.
  - 4. Water-Based Liner Adhesive: Comply with NFPA 90A or NFPA 90B and with ASTM C 916.
    - a. Adhesive: As recommended by duct liner manufacturer and with a VOC content of 80 g/L or less.
    - b. Adhesive shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- B. Insulation Pins and Washers:
  - 1. Cupped-Head, Capacitor-Discharge-Weld Pins: Copper- or zinc-coated steel pin, fully annealed for capacitor-discharge welding, 0.135-inch- diameter shank, length to suit depth of insulation indicated with integral 1-1/2-inch galvanized carbon-steel washer.

2. Insulation-Retaining Washers: Self-locking washers formed from 0.016-inch-thick stainless steel; with beveled edge sized as required to hold insulation securely in place but not less than 1-1/2 inches in diameter.
- C. Shop Application of Duct Liner: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 7-11, "Flexible Duct Liner Installation."
1. Adhere a single layer of indicated thickness of duct liner with at least 90 percent adhesive coverage at liner contact surface area. Attaining indicated thickness with multiple layers of duct liner is prohibited.
  2. Apply adhesive to transverse edges of liner facing upstream that do not receive metal nosing.
  3. Butt transverse joints without gaps, and coat joint with adhesive.
  4. Fold and compress liner in corners of rectangular ducts or cut and fit to ensure butted-edge overlapping.
  5. Do not apply liner in rectangular ducts with longitudinal joints, except at corners of ducts, unless duct size and dimensions of standard liner make longitudinal joints necessary.
  6. Apply adhesive coating on longitudinal seams in ducts with air velocity of 2500 fpm.
  7. Secure liner with mechanical fasteners 4 inches from corners and at intervals not exceeding 12 inches transversely; at 3 inches from transverse joints and at intervals not exceeding 18 inches longitudinally.
  8. Secure transversely oriented liner edges facing the airstream with metal nosings that have either channel or "Z" profiles or are integrally formed from duct wall. Fabricate edge facings at the following locations:
    - a. Fan discharges.
    - b. Intervals of lined duct preceding unlined duct.
    - c. Upstream edges of transverse joints in ducts where air velocities are higher than 2500 fpm or where indicated.

## 2.06 SEALANT AND GASKETS

- A. General Sealant and Gasket Requirements: Surface-burning characteristics for sealants and gaskets shall be a maximum flame-spread index of 25 and a maximum smoke-developed index of 50 when tested according to UL 723; certified by an NRTL.
- B. Water-Based Joint and Seam Sealant:
1. Application Method: Brush on.
  2. Solids Content: Minimum 65 percent.
  3. Shore A Hardness: Minimum 20.
  4. Water resistant.
  5. Mold and mildew resistant.
  6. VOC: Maximum 75 g/L (less water).
  7. Maximum Static-Pressure Class: 10-inch wg, positive and negative.
  8. Service: Indoor or outdoor.

9. Substrate: Compatible with galvanized sheet steel (both PVC coated and bare), stainless steel, or aluminum sheets.
- C. Flanged Joint Sealant: Comply with ASTM C 920.
1. General: Single-component, acid-curing, silicone, elastomeric.
  2. Type: S.
  3. Grade: NS.
  4. Class: 25.
  5. Use: O.
  6. Sealant shall have a VOC content of 420 g/L or less.
  7. Sealant shall comply with testing and product requirements of South Coast Air Quality Management District, Rule 1168.
- D. Flange Gaskets: Butyl rubber, neoprene, or EPDM polymer with polyisobutylene plasticizer.
- E. Round Duct Joint O-Ring Seals:
1. Seal shall provide maximum leakage class of 3 cfm/100 sq. ft. at 1-inch wg and shall be rated for 10-inch wg static-pressure class, positive or negative.
  2. EPDM O-ring to seal in concave bead in coupling or fitting spigot.
  3. Double-lipped, EPDM O-ring seal, mechanically fastened to factory-fabricated couplings and fitting spigots.

## **2.07 HANGERS AND SUPPORTS**

- A. Hanger Rods for Noncorrosive Environments: Cadmium-plated steel rods and nuts.
- B. Strap and Rod Sizes: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Table 5-1, "Rectangular Duct Hangers Minimum Size," and Table 5-2, "Minimum Hanger Sizes for Round Duct."
- C. Steel Cables for Galvanized-Steel Ducts: Galvanized steel complying with ASTM A 603.
- D. Steel Cable End Connections: Cadmium-plated steel assemblies with brackets, swivel, and bolts designed for duct hanger service; with an automatic-locking and clamping device.
- E. Duct Attachments: Sheet metal screws, blind rivets, or self-tapping metal screws; compatible with duct materials.
- F. Trapeze and Riser Supports:
  1. Supports for Galvanized-Steel Ducts: Galvanized-steel shapes and plates.

## **2.08 SEISMIC-RESTRAINT DEVICES**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  1. B-line, an Eaton business.
  2. Ductmate Industries, Inc.
  3. Elgen Manufacturing.
  4. Hilti, Inc.
  5. Kinetics Noise Control, Inc.

6. Mason Industries, Inc.
  7. TOLCO.
  8. Unistrut; Part of Atkore International.
  9. Vibration & Seismic Technologies, LLC.
- B. General Requirements for Restraint Components: Rated strengths, features, and applications shall be as defined in reports by an evaluation service member of the the Office of Statewide Health Planning and Development for the State of California.
1. Structural Safety Factor: Allowable strength in tension, shear, and pullout force of components shall be at least four times the maximum seismic forces to which they will be subjected.
- C. Channel Support System: Shop- or field-fabricated support assembly made of slotted steel channels rated in tension, compression, and torsion forces and with accessories for attachment to braced component at one end and to building structure at the other end. Include matching components and corrosion-resistant coating.
- D. Restraint Cables: ASTM A 603, galvanized cables with end connections made of cadmium-plated steel assemblies with brackets, swivel, and bolts designed for restraining cable service; and with an automatic-locking and clamping device or double-cable clips.
- E. Hanger Rod Stiffener: Steel tube or steel slotted-support-system sleeve with internally bolted connections or Reinforcing steel angle clamped to hanger rod.
- F. Mechanical Anchor Bolts: Drilled-in and stud-wedge or female-wedge type. Select anchor bolts with strength required for anchor and as tested according to ASTM E 488.

### **PART 3 - EXECUTION**

#### **3.01 DUCT INSTALLATION**

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of duct system. Indicated duct locations, configurations, and arrangements were used to size ducts and calculate friction loss for air-handling equipment sizing and for other design considerations. Install duct systems as indicated unless deviations to layout are approved on Shop Drawings and Coordination Drawings.
- B. Install ducts according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" unless otherwise indicated.
- C. Install ducts in maximum practical lengths.
- D. Install ducts with fewest possible joints.
- E. Install factory- or shop-fabricated fittings for changes in direction, size, and shape and for branch connections.
- F. Unless otherwise indicated, install ducts vertically and horizontally, and parallel and perpendicular to building lines.
- G. Install ducts close to walls, overhead construction, columns, and other structural and permanent enclosure elements of building.
- H. Install ducts with a clearance of 1 inch, plus allowance for insulation thickness.



- I. Route ducts to avoid passing through transformer vaults and electrical equipment rooms and enclosures.
- J. Where ducts pass through non-fire-rated interior partitions and exterior walls and are exposed to view, cover the opening between the partition and duct or duct insulation with sheet metal flanges of same metal thickness as the duct. Overlap openings on four sides by at least 1-1/2 inches.
- K. Where ducts pass through fire-rated interior partitions and exterior walls, install fire dampers. Comply with requirements in Section 233300 "Air Duct Accessories" for fire and smoke dampers.
- L. Protect duct interiors from moisture, construction debris and dust, and other foreign materials. Comply with SMACNA's "IAQ Guidelines for Occupied Buildings Under Construction," Appendix G, "Duct Cleanliness for New Construction Guidelines."

### **3.02 INSTALLATION OF EXPOSED DUCTWORK**

- A. Protect ducts exposed in finished spaces from being dented, scratched, or damaged.
- B. Trim duct sealants flush with metal. Create a smooth and uniform exposed bead. Do not use two-part tape sealing system.
- C. Grind welds to provide smooth surface free of burrs, sharp edges, and weld splatter. When welding stainless steel with a No. 3 or 4 finish, grind the welds flush, polish the exposed welds, and treat the welds to remove discoloration caused by welding.
- D. Maintain consistency, symmetry, and uniformity in the arrangement and fabrication of fittings, hangers and supports, duct accessories, and air outlets.
- E. Repair or replace damaged sections and finished work that does not comply with these requirements.

### **3.03 HANGER AND SUPPORT INSTALLATION**

- A. Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Chapter 5, "Hangers and Supports."
- B. Building Attachments: Concrete inserts, powder-actuated fasteners, or structural-steel fasteners appropriate for construction materials to which hangers are being attached.
  - 1. Where practical, install concrete inserts before placing concrete.
  - 2. Install powder-actuated concrete fasteners after concrete is placed and completely cured.
  - 3. Use powder-actuated concrete fasteners for standard-weight aggregate concretes or for slabs more than 4 inches thick.
  - 4. Do not use powder-actuated concrete fasteners for lightweight-aggregate concretes or for slabs less than 4 inches thick.
  - 5. Do not use powder-actuated concrete fasteners for seismic restraints.
- C. Hanger Spacing: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Table 5-1, "Rectangular Duct Hangers Minimum Size," and Table 5-2, "Minimum Hanger Sizes for Round Duct," for maximum hanger spacing; install hangers and supports within 24 inches of each elbow and within 48 inches of each branch intersection.
- D. Hangers Exposed to View: Threaded rod and angle or channel supports.

- E. Support vertical ducts with steel angles or channel secured to the sides of the duct with welds, bolts, sheet metal screws, or blind rivets; support at each floor and at maximum intervals of 16 feet.
- F. Install upper attachments to structures. Select and size upper attachments with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.

### **3.04 SEISMIC-RESTRAINT-DEVICE INSTALLATION**

- A. Install ducts with hangers and braces designed to support the duct and to restrain against seismic forces required by applicable building codes. Comply with CBC, and ASCE/SEI 7, as referenced by the CBC.
  - 1. Space lateral supports a maximum of 40 feet o.c., and longitudinal supports a maximum of 80 feet o.c.
  - 2. Brace a change of direction longer than 12 feet.
- B. Select seismic-restraint devices with capacities adequate to carry present and future static and seismic loads.
- C. Install cables so they do not bend across edges of adjacent equipment or building structure.
- D. Install cable restraints on ducts that are suspended with vibration isolators.
- E. Install seismic-restraint devices using methods approved by an evaluation service member of the Office of Statewide Health Planning and Development for the State of California.
- F. Attachment to Structure: If specific attachment is not indicated, anchor bracing and restraints to structure, to flanges of beams, to upper truss chords of bar joists, or to concrete members.
- G. Drilling for and Setting Anchors:
  - 1. Identify position of reinforcing steel and other embedded items prior to drilling holes for anchors. Do not damage existing reinforcement or embedded items during drilling. Notify the Architect if reinforcing steel or other embedded items are encountered during drilling. Locate and avoid prestressed tendons, electrical and telecommunications conduit, and gas lines.
  - 2. Do not drill holes in concrete or masonry until concrete, mortar, or grout has achieved full design strength.
  - 3. Wedge Anchors: Protect threads from damage during anchor installation. Heavy-duty sleeve anchors shall be installed with sleeve fully engaged in the structural element to which anchor is to be fastened.
  - 4. Set anchors to manufacturer's recommended torque, using a torque wrench.
  - 5. Install zinc-coated steel anchors for interior applications and stainless-steel anchors for applications exposed to weather.

### **3.05 CONNECTIONS**

- A. Make connections to equipment with flexible connectors complying with Section 233300 "Air Duct Accessories."
- B. Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for branch, outlet and inlet, and terminal unit connections.

### 3.06 PAINTING

- A. Paint interior of metal ducts that are visible through registers and grilles and that do not have duct liner. Apply one coat of flat, black, latex paint over a compatible galvanized-steel primer. Paint materials and application requirements are specified in Section 099123 "Interior Painting."

### 3.07 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
- B. Ductwork Sealing and Leak Testing:
  - 1. All ductwork shall receive a Class A seal.
  - 2. Seal airtight all joints and seams, including standing seams and manufactured joints and seams, of all supply, return and exhaust ducts except those exposed in conditioned space.
  - 3. All duct systems (supply, return, outside air intake, and exhaust), except those identified on compliance forms on Drawings as requiring Acceptance Testing per the requirements of the California Energy Code, shall be tested in accordance with the requirements of SMACNA's "HVAC Air Duct Leakage Test Manual." Test pressure shall be equal to the pressure class of the duct. For additional duct leak testing requirements, refer to Section 230050, "Common Work Results for HVAC Systems," Article, "Acceptance Requirements."
- C. Duct System Cleanliness Tests:
  - 1. Visually inspect duct system to ensure that no visible contaminants are present.
  - 2. Test sections of metal duct system, chosen randomly by Owner, for cleanliness according to "Vacuum Test" in NADCA ACR, "Assessment, Cleaning and Restoration of HVAC Systems."
    - a. Acceptable Cleanliness Level: Net weight of debris collected on the filter media shall not exceed 0.75 mg/100 sq. cm.
- D. Duct system will be considered defective if it does not pass tests and inspections.
- E. Prepare test and inspection reports.

### 3.08 DUCT CLEANING

- A. Clean new duct system(s) before testing, adjusting, and balancing.
- B. Use service openings for entry and inspection.
  - 1. Create new openings and install access panels appropriate for duct static-pressure class if required for cleaning access. Provide insulated panels for insulated or lined duct. Patch insulation and liner as recommended by duct liner manufacturer.
  - 2. Disconnect and reconnect flexible ducts as needed for cleaning and inspection.
  - 3. Remove and reinstall ceiling to gain access during the cleaning process.
- C. Particulate Collection and Odor Control:
  - 1. When venting vacuuming system inside the building, use HEPA filtration with 99.97 percent collection efficiency for 0.3-micron-size (or larger) particles.

2. When venting vacuuming system to outdoors, use filter to collect debris removed from HVAC system, and locate exhaust downwind and away from air intakes and other points of entry into building.
- D. Clean the following components by removing surface contaminants and deposits:
1. Air outlets and inlets (registers, grilles, and diffusers).
  2. Supply, return, and exhaust fans including fan housings, plenums (except ceiling supply and return plenums), scrolls, blades or vanes, shafts, baffles, dampers, and drive assemblies.
  3. Air-handling unit internal surfaces and components including mixing box, coil section, air wash systems, spray eliminators, condensate drain pans, humidifiers and dehumidifiers, filters and filter sections, and condensate collectors and drains.
  4. Coils and related components.
  5. Return-air ducts, dampers, actuators, and turning vanes except in ceiling plenums and mechanical equipment rooms.
  6. Supply-air ducts, dampers, actuators, and turning vanes.
  7. Dedicated exhaust and ventilation components and makeup air systems.
- E. Mechanical Cleaning Methodology:
1. Clean metal duct systems using mechanical cleaning methods that extract contaminants from within duct systems and remove contaminants from building.
  2. Use vacuum-collection devices that are operated continuously during cleaning. Connect vacuum device to downstream end of duct sections so areas being cleaned are under negative pressure.
  3. Use mechanical agitation to dislodge debris adhered to interior duct surfaces without damaging integrity of metal ducts, duct liner, or duct accessories.
  4. Clean fibrous-glass duct liner with HEPA vacuuming equipment; do not permit duct liner to get wet. Replace fibrous-glass duct liner that is damaged, deteriorated, or delaminated or that has friable material, mold, or fungus growth.
  5. Clean coils and coil drain pans according to NADCA 1992. Keep drain pan operational. Rinse coils with clean water to remove latent residues and cleaning materials; comb and straighten fins.
  6. Provide drainage and cleanup for wash-down procedures.
  7. Antimicrobial Agents and Coatings: Apply EPA-registered antimicrobial agents if fungus is present. Apply antimicrobial agents according to manufacturer's written instructions after removal of surface deposits and debris.

### **3.09 START UP**

- A. Air Balance: Comply with requirements in Section 230593 "Testing, Adjusting, and Balancing for HVAC."

### **3.10 DUCT SCHEDULE**

- A. Fabricate ducts with galvanized sheet steel except as otherwise indicated:
- B. Supply Ducts:

1. Ducts Connected to Fan Coil Units, Furnaces, Heat Pumps, and Terminal Units:
    - a. Pressure Class: Positive 2-inch wg .
    - b. SMACNA Leakage Class for Rectangular: 16 .
    - c. SMACNA Leakage Class for Round and Flat Oval: 8 .
  2. Ducts Connected to Constant-Volume Air-Handling Units :
    - a. Pressure Class: Positive 2-inch wg .
    - b. SMACNA Leakage Class for Rectangular: 16 .
    - c. SMACNA Leakage Class for Round and Flat Oval: 8 .
  3. Ducts Connected to Variable-Air-Volume Air-Handling Units:
    - a. Pressure Class: Positive 4-inch wg.
    - b. SMACNA Leakage Class for Rectangular: 4.
    - c. SMACNA Leakage Class for Round and Flat Oval: 2.
  4. Ducts Connected to Equipment Not Listed Above:
    - a. Pressure Class: Positive 2-inch wg 3-inch wg 4-inch wg.
    - b. SMACNA Leakage Class for Rectangular: 16.
    - c. SMACNA Leakage Class for Round and Flat Oval: 8.
- C. Return Ducts:
1. Ducts Connected to Fan Coil Units, Furnaces, Heat Pumps, and Terminal Units:
    - a. Pressure Class: Positive or negative 2-inch wg.
    - b. SMACNA Leakage Class for Rectangular: 16.
    - c. SMACNA Leakage Class for Round and Flat Oval: 8.
  2. Ducts Connected to Air-Handling Units:
    - a. Pressure Class: Positive or negative 2-inch wg.
    - b. SMACNA Leakage Class for Rectangular: 16.
    - c. SMACNA Leakage Class for Round and Flat Oval: 8.
  3. Ducts Connected to Equipment Not Listed Above:
    - a. Pressure Class: Positive or negative 2-inch wg4-inch wg.
    - b. SMACNA Leakage Class for Rectangular: 16.
    - c. SMACNA Leakage Class for Round and Flat Oval: 8.
- D. Exhaust Ducts:
1. Ducts Connected to Fans Exhausting (ASHRAE 62.1, Class 1 and 2) Air:
    - a. Pressure Class: Negative 2-inch wg.
    - b. SMACNA Leakage Class for Rectangular: 16.
    - c. SMACNA Leakage Class for Round and Flat Oval: 8
  2. Ducts Connected to Air-Handling Units:
    - a. Pressure Class: Positive or negative 2-inch wg.
    - b. SMACNA Leakage Class for Rectangular: 16.

- c. SMACNA Leakage Class for Round and Flat Oval: 8.
  - 3. Ducts Connected to Equipment Not Listed Above:
    - a. Pressure Class: Positive or negative 2-inch wg.
    - b. SMACNA Leakage Class for Rectangular: 16.
    - c. SMACNA Leakage Class for Round and Flat Oval: 8.
- E. Outdoor-Air (Not Filtered, Heated, or Cooled) Ducts:
  - 1. Ducts Connected to Fan Coil Units, Furnaces, Heat Pumps, and Terminal Units:
    - a. Pressure Class: Positive or negative 2-inch wg.
    - b. SMACNA Leakage Class for Rectangular: 16.
    - c. SMACNA Leakage Class for Round and Flat Oval: 8.
  - 2. Ducts Connected to Air-Handling Units:
    - a. Pressure Class: Positive or negative 2-inch wg.
    - b. SMACNA Leakage Class for Rectangular: 16
    - c. SMACNA Leakage Class for Round and Flat Oval: 2 8.
  - 3. Ducts Connected to Equipment Not Listed Above:
    - a. Pressure Class: Positive or negative 2-inch wg
    - b. SMACNA Leakage Class for Rectangular: 16
    - c. SMACNA Leakage Class for Round and Flat Oval: 8.
- F. Intermediate Reinforcement:
  - 1. Galvanized-Steel Ducts: Galvanized steel.
- G. Liner:
  - 1. Refer to article, Duct Liner.
- H. Elbow Configuration:
  - 1. Round Duct: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-4, "Round Duct Elbows."
    - a. Minimum Radius-to-Diameter Ratio and Elbow Segments: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Table 3-1, "Mitered Elbows." Elbows with less than 90-degree change of direction have proportionately fewer segments.
      - 1) Velocity 1000 fpm or Lower: 0.5 radius-to-diameter ratio and three segments for 90-degree elbow.
      - 2) Velocity 1000 to 1500 fpm: 1.0 radius-to-diameter ratio and four segments for 90-degree elbow.
      - 3) Velocity 1500 fpm or Higher: 1.5 radius-to-diameter ratio and five segments for 90-degree elbow.
      - 4) Radius-to Diameter Ratio: 1.5.
    - b. Round Elbows, 12 Inches and Smaller in Diameter: Stamped or pleated.
    - c. Round Elbows, 14 Inches and Larger in Diameter: Welded.
- I. Branch Configuration:

1. Rectangular Duct: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 4-6, "Branch Connection."
  - a. Rectangular Main to Rectangular Branch: 45-degree entry.
  - b. Rectangular Main to Round Branch: Spin in.
2. Round and Flat Oval: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-5, "90 Degree Tees and Laterals," and Figure 3-6, "Conical Tees." Saddle taps are permitted in existing duct.
  - a. Velocity 1000 fpm or Lower: 90-degree tap.
  - b. Velocity 1000 to 1500 fpm: Conical tap.
  - c. Velocity 1500 fpm or Higher: 45-degree lateral.

END OF SECTION

**SECTION 23 33 00**  
**AIR DUCT ACCESSORIES**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Backdraft and pressure relief dampers.
  - 2. Manual volume dampers.
  - 3. Turning vanes.
  - 4. Duct-mounted access doors.
  - 5. Duct access panel assemblies.
  - 6. Flexible connectors.
  - 7. Duct accessory hardware.
- B. Related Requirements:
  - 1. Section 233346 "Flexible Ducts" for insulated flexible ducts.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
  - 1. For duct silencers, include pressure drop and dynamic insertion loss data. Include breakout noise calculations for high transmission loss casings.
- B. Shop Drawings: For duct accessories. Include plans, elevations, sections, details and attachments to other work.
  - 1. Detail duct accessories fabrication and installation in ducts and other construction. Include dimensions, weights, loads, and required clearances; and method of field assembly into duct systems and other construction. Include the following:
    - a. Special fittings.
    - b. Manual volume damper installations.
    - c. Control-damper installations.
    - d. Fire-damper, smoke-damper, combination fire- and smoke-damper, ceiling, and corridor damper installations, including sleeves; and duct-mounted access doors and remote damper operators.
    - e. Wiring Diagrams: For power, signal, and control wiring.

**1.03 INFORMATIONAL SUBMITTALS**

- A. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which ceiling-mounted access panels and access doors required for access to duct accessories are shown and coordinated with each other, using input from Installers of the items involved. Refer to Section 23 00 50, "Common Work Results for HVAC Systems for additional requirements.
- B. Source quality-control reports.



#### **1.04 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For air duct accessories to include in operation and maintenance manuals.

### **PART 2 - PRODUCTS**

#### **2.01 ASSEMBLY DESCRIPTION**

- A. Comply with NFPA 90A, "Installation of Air Conditioning and Ventilating Systems," and with NFPA 90B, "Installation of Warm Air Heating and Air Conditioning Systems."
- B. Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for acceptable materials, material thicknesses, and duct construction methods unless otherwise indicated. Sheet metal materials shall be free of pitting, seam marks, roller marks, stains, discolorations, and other imperfections.

#### **2.02 MATERIALS**

- A. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).
- B. Galvanized Sheet Steel: Comply with ASTM A 653/A 653M.
  - 1. Galvanized Coating Designation: G60.
  - 2. Exposed-Surface Finish: Mill phosphatized.
- C. Aluminum Sheets: Comply with ASTM B 209, Alloy 3003, Temper H14; with mill finish for concealed ducts and standard, 1-side bright finish for exposed ducts.
- D. Extruded Aluminum: Comply with ASTM B 221, Alloy 6063, Temper T6.
- E. Reinforcement Shapes and Plates: Galvanized-steel reinforcement where installed on galvanized sheet metal ducts.
- F. Tie Rods: Galvanized steel, 1/4-inch minimum diameter for lengths 36 inches or less; 3/8-inch minimum diameter for lengths longer than 36 inches.

#### **2.03 MANUAL VOLUME DAMPERS**

- A. Standard, Steel, Manual Volume Dampers:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. Aire Technologies.
    - b. American Warming and Ventilating; a Mestek Architectural Group company.
    - c. Flexmaster U.S.A., Inc.
    - d. Flex-Tek Group.
    - e. McGill AirFlow LLC.
    - f. Nailor Industries Inc.
    - g. Pottorff.
    - h. Ruskin Company.

- i. Trox USA Inc.
  - j. Vent Products Co., Inc.
- 2. Standard leakage rating, with linkage outside airstream.
- 3. Suitable for horizontal or vertical applications.
- 4. Frames:
  - a. Frame: Hat-shaped, 0.094-inch-thick, galvanized sheet steel.
  - b. Mitered and welded corners.
  - c. Flanges for attaching to walls and flangeless frames for installing in ducts.
- 5. Blades:
  - a. Multiple or single blade.
  - b. Parallel- or opposed-blade design.
  - c. Stiffen damper blades for stability.
  - d. Stainless-steel, 0.064 inch thick.
- 6. Blade Axles: Stainless steel.
- 7. Bearings:
  - a. Stainless-steel sleeve.
  - b. Dampers in ducts with pressure classes of 3-inch wg or less shall have axles full length of damper blades and bearings at both ends of operating shaft.
- 8. Tie Bars and Brackets: Galvanized steel.
- B. Low-Leakage, Steel, Manual Volume Dampers:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
    - a. American Warming and Ventilating; a Mestek Architectural Group company.
    - b. Flex-Tek Group.
    - c. McGill AirFlow LLC.
    - d. Nailor Industries Inc.
    - e. Pottorff.
    - f. Ruskin Company.
    - g. Trox USA Inc.
    - h. Vent Products Co., Inc.
  - 2. Comply with AMCA 500-D testing for damper rating.
  - 3. Low-leakage rating, with linkage outside airstream, and bearing AMCA's Certified Ratings Seal for both air performance and air leakage.
  - 4. Suitable for horizontal or vertical applications.
  - 5. Frames:
    - a. Hat shaped.
    - b. 0.05-inch-thick stainless steel.

- c. Mitered and welded corners.
  - d. Flanges for attaching to walls and flangeless frames for installing in ducts.
- 6. Blades:
  - a. Multiple or single blade.
  - b. Parallel- or opposed-blade design.
  - c. Stiffen damper blades for stability.
  - d. Stainless, roll-formed steel, 0.064 inch thick.
- 7. Blade Axles: Stainless steel.
- 8. Bearings:
  - a. Stainless-steel sleeve.
  - b. Dampers in ducts with pressure classes of 3-inch wg or less shall have axles full length of damper blades and bearings at both ends of operating shaft.
- 9. Blade Seals: Neoprene.
- 10. Jamb Seals: Cambered stainless steel.
- 11. Tie Bars and Brackets: Aluminum.
- 12. Accessories:
  - a. Include locking device to hold single-blade dampers in a fixed position without vibration.
- C. Jackshaft:
  - 1. Size: 0.5-inch diameter.
  - 2. Material: Galvanized-steel pipe rotating within pipe-bearing assembly mounted on supports at each mullion and at each end of multiple-damper assemblies.
  - 3. Length and Number of Mountings: As required to connect linkage of each damper in multiple-damper assembly.
- D. Damper Hardware:
  - 1. Zinc-plated, die-cast core with dial and handle made of 3/32-inch-thick zinc-plated steel, and a 3/4-inch hexagon locking nut.
  - 2. Include center hole to suit damper operating-rod size.
  - 3. Include elevated platform for insulated duct mounting.

## 2.04 TURNING VANES

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Aero-Dyne Sound Control Co.
  - 2. CL WARD & Family Inc.
  - 3. Ductmate Industries, Inc.
  - 4. Duro Dyne Inc.
  - 5. Elgen Manufacturing.
  - 6. Hardcast, Inc.

7. METALAIRE, Inc.
  8. SEMCO LLC.
  9. Ward Industries; a brand of Hart & Cooley, Inc.
- B. Manufactured Turning Vanes for Metal Ducts: Curved blades of galvanized sheet steel; support with bars perpendicular to blades set; set into vane runners suitable for duct mounting.
1. Acoustic Turning Vanes: Fabricate airfoil-shaped aluminum extrusions with perforated faces and fibrous-glass fill.
- C. General Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible"; Figures 4-3, "Vanes and Vane Runners," and 4-4, "Vane Support in Elbows."
- D. Vane Construction: Single wall for ducts up to 48 inches wide and double wall for larger dimensions.

## 2.05 DUCT-MOUNTED ACCESS DOORS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
1. Ductmate Industries, Inc.
  2. Flexmaster U.S.A., Inc.
  3. McGill AirFlow LLC.
  4. Nailor Industries Inc.
  5. Pottorff.
  6. Ventfabrics, Inc.
- B. Duct-Mounted Access Doors: Fabricate access panels according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible"; Figures 7-2, "Duct Access Doors and Panels," and 7-3, "Access Doors - Round Duct."
1. Door:
    - a. Double wall, rectangular.
    - b. Galvanized sheet metal with insulation fill and thickness as indicated for duct pressure class.
    - c. Vision panel.
    - d. Hinges and Latches: 1-by-1-inch butt or piano hinge and cam latches.
    - e. Fabricate doors airtight and suitable for duct pressure class.
  2. Frame: Galvanized sheet steel, with bend-over tabs and foam gaskets.
  3. Number of Hinges and Locks:
    - a. Access Doors Less Than 12 Inches Square: No hinges and two sash locks.
    - b. Access Doors up to 18 Inches] Square: Continuous and two sash locks.
    - c. Access Doors up to 24 by 48 Inches: Continuous and two compression latches with outside and inside handles.
    - d. Access Doors Larger Than 24 by 48 Inches: Continuous and two compression latches with outside and inside handles.

## **2.06 DUCT ACCESS PANEL ASSEMBLIES**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. 3M.
  - 2. Ductmate Industries, Inc.
  - 3. Flame Gard, Inc.
- B. Labeled according to UL 1978 by an NRTL.
- C. Panel and Frame: Minimum thickness 0.0428-inch stainless steel.
- D. Fasteners: Stainless steel. Panel fasteners shall not penetrate duct wall.
- E. Gasket: Comply with NFPA 96; grease-tight, high-temperature ceramic fiber, rated for minimum 2000 deg F.
- F. Minimum Pressure Rating: 10-inch wg, positive or negative.

## **2.07 FLEXIBLE CONNECTORS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Hardcast, Inc.
  - 2. Ventfabrics, Inc.
  - 3. Ward Industries; a brand of Hart & Cooley, Inc.
- B. Materials: Flame-retardant or noncombustible fabrics.
- C. Coatings and Adhesives: Comply with UL 181, Class 1.
- D. Metal-Edged Connectors: Factory fabricated with a fabric strip [3-1/2 inches] [5-3/4 inches] wide attached to two strips of 2-3/4-inch-wide, 0.028-inch-thick, galvanized sheet steel or 0.032-inch-thick aluminum sheets. Provide metal compatible with connected ducts.
- E. Indoor System, Flexible Connector Fabric: Glass fabric double coated with neoprene.
  - 1. Minimum Weight: 26 oz./sq. yd.
  - 2. Tensile Strength: 480 lbf/inch in the warp and 360 lbf/inch in the filling.
  - 3. Service Temperature: Minus 40 to plus 200 deg F.
- F. Outdoor System, Flexible Connector Fabric: Glass fabric double coated with weatherproof, synthetic rubber resistant to UV rays and ozone.
  - 1. Minimum Weight: 24 oz./sq. yd.
  - 2. Tensile Strength: 530 lbf/inch in the warp and 440 lbf/inch in the filling.
  - 3. Service Temperature: Minus 50 to plus 250 deg F.

## **2.08 DUCT ACCESSORY HARDWARE**

- A. Instrument Test Holes: Cast iron or cast aluminum to suit duct material, including screw cap and gasket. Size to allow insertion of pitot tube and other testing instruments and of length to suit duct-insulation thickness.
- B. Adhesives: High strength, quick setting, neoprene based, waterproof, and resistant to gasoline and grease.

## **PART 3 - EXECUTION**

### **3.01 INSTALLATION**

- A. Install duct accessories according to applicable details in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for metal ducts.
- B. Install duct accessories of materials suited to duct materials; use galvanized-steel accessories in galvanized-steel ducts.
- C. Install volume dampers at points on supply, return, and exhaust systems where branches extend from larger ducts. Where dampers are installed in ducts having duct liner, install dampers with hat channels of same depth as liner, and terminate liner with nosing at hat channel.
  - 1. Install steel volume dampers in steel ducts.
  - 2. Set dampers to fully open position before testing, adjusting, and balancing.
- D. Install test holes at fan inlets and outlets and elsewhere as indicated.
- E. Install duct access doors on sides of ducts to allow for inspecting, adjusting, and maintaining accessories and equipment at the following locations:
  - 1. On both sides of duct coils.
  - 2. At outdoor-air intakes and mixed-air plenums.
  - 3. At drain pans and seals.
  - 4. Downstream from manual volume dampers, control dampers, backdraft dampers, and equipment.
  - 5. Adjacent to and close enough to fire or smoke dampers, to reset or reinstall fusible links. Access doors for access to fire or smoke dampers having fusible links shall be pressure relief access doors and shall be outward operation for access doors installed upstream from dampers and inward operation for access doors installed downstream from dampers.
  - 6. At each change in direction and at maximum 50-foot spacing.
  - 7. Upstream and downstream from turning vanes.
  - 8. Upstream or downstream from duct silencers.
  - 9. Control devices requiring inspection.
  - 10. Elsewhere as indicated.
- F. Install access doors with swing against duct static pressure.
- G. Access Door Sizes:
  - 1. One-Hand or Inspection Access: 8 by 5 inches.
  - 2. Two-Hand Access: 12 by 6 inches.
  - 3. Head and Hand Access: 18 by 10 inches.
  - 4. Head and Shoulders Access: 21 by 14 inches.
  - 5. Body Access: 25 by 14 inches.
  - 6. Body plus Ladder Access: 25 by 17 inches.

- H. Label access doors according to Section 230553 "Identification for HVAC Piping and Equipment" to indicate the purpose of access door.
- I. Install flexible connectors to connect ducts to equipment.
- J. Connect terminal units to supply ducts directly or with maximum 12-inch lengths of flexible duct. Do not use flexible ducts to change directions.
- K. Connect diffusers ducts directly or with maximum 60-inch lengths of flexible duct clamped or strapped in place.
- L. Connect flexible ducts to metal ducts with draw bands.
- M. Install duct test holes where required for testing and balancing purposes.

### **3.02 FIELD QUALITY CONTROL**

- A. Tests and Inspections:
  - 1. Operate dampers to verify full range of movement.
  - 2. Inspect locations of access doors and verify that purpose of access door can be performed.
  - 3. Inspect turning vanes for proper and secure installation.

END OF SECTION

## **SECTION 23 33 46**

### **FLEXIBLE DUCTS**

#### **PART 1 - GENERAL**

##### **1.01 SUMMARY**

- A. Section Includes:
  - 1. Insulated flexible ducts.

##### **1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
- B. Sustainable Design Submittals:
  - 1. Product data showing compliance with ASHRAE 62.1.
  - 2. Product Data: For adhesives and sealants, indicating VOC content.
- C. Shop Drawings: For flexible ducts.
  - 1. Include plans showing locations and mounting and attachment details.

##### **1.03 INFORMATIONAL SUBMITTALS**

- A. Coordination Drawings: Plans, drawn to scale, on which ceiling-mounted access panels and access doors required for access to duct accessories are shown and coordinated with each other, using input from installers of the items involved. Refer to Section 23 00 50, "Common Work Results for HVAC Systems for additional requirements.

#### **PART 2 - PRODUCTS**

##### **2.01 ASSEMBLY DESCRIPTION**

- A. Comply with NFPA 90A, "Installation of Air Conditioning and Ventilating Systems," and with NFPA 90B, "Installation of Warm Air Heating and Air Conditioning Systems."
- B. Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for acceptable materials, material thicknesses, and duct construction methods unless otherwise indicated. Sheet metal materials shall be free of pitting, seam marks, roller marks, stains, discolorations, and other imperfections.
- C. Comply with the Air Diffusion Council's "ADC Flexible Air Duct Test Code FD 72-R1."
- D. Comply with ASTM E 96/E 96M, "Test Methods for Water Vapor Transmission of Materials."

##### **2.02 MATERIALS**

- A. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).

##### **2.03 INSULATED FLEXIBLE DUCTS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:



1. Flexmaster U.S.A., Inc.
  2. JP Lamborn Co.
  3. McGill AirFlow LLC.
  4. Thermaflex; a Flex-Tek Group company.
  5. Ward Industries; a brand of Hart & Cooley, Inc.
- B. Insulated, Flexible Duct: UL 181, Class 1, two-ply vinyl film supported by helically wound, spring-steel wire; fibrous-glass insulation; polyethylene or aluminized vapor-barrier film.
1. Pressure Rating: 10-inch wg positive and 1.0-inch wg negative.
  2. Maximum Air Velocity: 4000 fpm.
  3. Temperature Range: Minus 10 to plus 160 deg F.
  4. Insulation R-Value: R4.2.

#### **2.04 FLEXIBLE DUCT CONNECTORS**

- A. Clamps: Stainless-steel band with cadmium-plated hex screw to tighten band with a worm-gear action in sizes 3 through 18 inches, to suit duct size.
- B. Non-Clamp Connectors: Adhesive plus sheet metal screws.

### **PART 3 - EXECUTION**

#### **3.01 INSTALLATION**

- A. Install flexible ducts according to applicable details in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for metal ducts and in NAIMA AH116, "Fibrous Glass Duct Construction Standards," for fibrous-glass ducts.
- B. Install in indoor applications only. Flexible ductwork should not be exposed to UV lighting.
- C. Connect terminal units to supply ducts directly or with maximum 12-inch of flexible duct. Do not use flexible ducts to change directions.
- D. Connect diffusers or light troffer boots to ducts directly or with maximum 60-inch lengths of flexible duct clamped or strapped in place.
- E. Connect flexible ducts to metal ducts with draw bands.
- F. Install duct test holes where required for testing and balancing purposes.
- G. Installation:
  1. Install ducts fully extended.
  2. Do not bend ducts across sharp corners.
  3. Bends of flexible ducting shall not exceed a minimum of one duct diameter.
  4. Avoid contact with metal fixtures, water lines, pipes, or conduits.
  5. Install flexible ducts in a direct line, without sags, twists, or turns.
- H. Supporting Flexible Ducts:
  1. Suspend flexible ducts with bands 1-1/2 inches wide or wider and spaced a maximum of 48 inches apart. Maximum centerline sag between supports shall not exceed 1/2 inch per 12 inches.

2. Install extra supports at bends placed approximately one duct diameter from center line of the bend.
3. Ducts may rest on ceiling joists or truss supports. Spacing between supports shall not exceed the maximum spacing per manufacturer's written installation instructions.
4. Vertically installed ducts shall be stabilized by support straps at a maximum of 72 inches o.c.

END OF SECTION



**SECTION 233423**  
**HVAC POWER VENTILATORS**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

**1.02 SUMMARY**

- A. Section Includes:
  - 1. Centrifugal roof ventilators.

**1.03 PERFORMANCE REQUIREMENTS**

- A. Project Altitude: Base fan-performance ratings on actual Project site elevations.
- B. Operating Limits: Classify according to AMCA 99.

**1.04 ACTION SUBMITTALS**

- A. Product Data: For each type of product indicated. Include rated capacities, operating characteristics, and furnished specialties and accessories. Also include the following:
  - 1. Certified fan performance curves with system operating conditions indicated.
  - 2. Certified fan sound-power ratings.
  - 3. Motor ratings and electrical characteristics, plus motor and electrical accessories.
  - 4. Material thickness and finishes, including color charts.
  - 5. Dampers, including housings, linkages, and operators.
  - 6. Roof curbs.
- B. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
  - 2. Wiring Diagrams: For power, signal, and control wiring.

**1.05 INFORMATIONAL SUBMITTALS**

- A. Coordination Drawings: Reflected ceiling plans and other details, drawn to scale, on which the following items are shown and coordinated with each other, using input from Installers of the items involved:
  - 1. Roof framing and support members relative to duct penetrations.
  - 2. Ceiling suspension assembly members.
  - 3. Size and location of initial access modules for acoustical tile.
  - 4. Ceiling-mounted items including light fixtures, diffusers, grilles, speakers, sprinklers, access panels, and special moldings.

5. Refer to Section 23 00 50, "Common Work Results for HVAC Systems for additional requirements.
- B. Field quality-control reports.
- C. Roof Curb Data: For roof mounted equipment where combined weight of equipment unit and roof curb or rail exceeds 400 pounds, submit calculations from manufacturer for roof curbs proving compliance with the seismic requirements of the 2016 CBC, and ASCE 7-10. Manufacturer shall certify that roof curbs are suitable for use indicated on Drawings and in Specifications for the seismic design category indicated in structural Contract Documents. Calculations shall be stamped and signed by a State of California registered structural engineer.
- D. Provide evidence of equipment certification to California Energy Code Section 110.1 or 110.2, if not providing Electrically Commutated motors for HVAC fans sized below 1 hp and above 1/12 hp.

#### **1.06 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For power ventilators to include in emergency, operation, and maintenance manuals.

#### **1.07 QUALITY ASSURANCE**

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. AMCA Compliance: Fans shall have AMCA-Certified performance ratings and shall bear the AMCA-Certified Ratings Seal.
- C. UL Standards: Power ventilators shall comply with UL 705. Power ventilators for use for restaurant kitchen exhaust shall also comply with UL 762.

#### **1.08 COORDINATION**

- A. Coordinate size and location of structural-steel support members.
- B. Coordinate sizes and locations of concrete bases with actual equipment provided.
- C. Coordinate sizes and locations of roof curbs, equipment supports, and roof penetrations with actual equipment provided.

### **PART 2 - PRODUCTS**

#### **2.01 MATERIALS**

- A. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).

#### **2.02 CENTRIFUGAL ROOF VENTILATORS**

- A. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
  1. American Coolair Corporation.
  2. Loren Cook Company.

- B. Housing: Removable, spun-aluminum, dome top and outlet baffle; square, one-piece, aluminum base with venturi inlet cone.
  - 1. Upblast Units: Provide spun-aluminum discharge baffle to direct discharge air upward, with rain and snow drains.
  - 2. Hinged Subbase: Galvanized-steel hinged arrangement permitting service and maintenance.
- C. Fan Wheels: Aluminum hub and wheel with backward-inclined blades.
- D. Belt Drives:
  - 1. Resiliently mounted to housing.
  - 2. Fan Shaft: Turned, ground, and polished steel; keyed to wheel hub.
  - 3. Shaft Bearings: Permanently lubricated, permanently sealed, self-aligning ball bearings.
  - 4. Pulleys: Cast-iron, adjustable-pitch motor pulley.
  - 5. Fan and motor isolated from exhaust airstream.
- E. Accessories:
  - 1. Variable-Speed Controller: Solid-state control to reduce speed from 100 to less than 50 percent.
  - 2. Disconnect Switch: Nonfusible type, with thermal-overload protection mounted inside fan housing, factory wired through an internal aluminum conduit.
  - 3. Bird Screens: Removable, 1/2-inch mesh, aluminum or brass wire.
  - 4. Motorized Dampers: Parallel-blade dampers mounted in curb base with electric actuator; wired to close when fan stops.
- F. Roof Curbs: Galvanized steel; mitered and welded corners; 1-1/2-inch- thick, rigid, fiberglass insulation adhered to inside walls; and 1-1/2-inch wood nailer. Size as required to suit roof opening and fan base.
  - 1. Configuration: Built-in raised cant and mounting flange.
  - 2. Overall Height: 12 inches.
  - 3. Sound Curb: Curb with sound-absorbing insulation.
  - 4. Pitch Mounting: Manufacture curb for roof slope.
  - 5. Metal Liner: Galvanized steel.
  - 6. Mounting Pedestal: Galvanized steel with removable access panel.
  - 7. Vented Curb: Unlined with louvered vents in vertical sides.
- G. Controls: Refer to control diagrams on Drawings and to Section 230923, "Direct Digital Control System for HVAC."

### **2.03 MOTORS**

- A. Electrically commutated motor.
- B. Comply with NEMA designation, temperature rating, service factor, enclosure type, and efficiency requirements for motors specified in Section 230513 "Common Motor Requirements for HVAC Equipment."

1. Motor Sizes: Minimum size as indicated. If not indicated, large enough so driven load will not require motor to operate in service factor range above 1.0.
- C. Enclosure Type: Totally enclosed, fan cooled.
- D. For single-phase fan motors sized larger than 1/12 hp and smaller than 1 hp, refer to article, Single-Phase Motors, in Section 23 05 13, Common Motor Requirements for HVAC Equipment.

#### **2.04 SOURCE QUALITY CONTROL**

- A. Certify sound-power level ratings according to AMCA 301, "Methods for Calculating Fan Sound Ratings from Laboratory Test Data." Factory test fans according to AMCA 300, "Reverberant Room Method for Sound Testing of Fans." Label fans with the AMCA-Certified Ratings Seal.
- B. Certify fan performance ratings, including flow rate, pressure, power, air density, speed of rotation, and efficiency by factory tests according to AMCA 210, "Laboratory Methods of Testing Fans for Aerodynamic Performance Rating." Label fans with the AMCA-Certified Ratings Seal.

### **PART 3 - EXECUTION**

#### **3.01 INSTALLATION**

- A. Install power ventilators level and plumb.
- B. Secure roof-mounted fans to roof curbs with stainless steel hardware. See Section 077200 "Roof Accessories" for installation of roof curbs.
- C. Install units with clearances for service and maintenance.
- D. Label units according to requirements specified in Section 230553 "Identification for HVAC Piping and Equipment."

#### **3.02 CONNECTIONS**

- A. Drawings indicate general arrangement of ducts and duct accessories. Make final duct connections with flexible connectors. Flexible connectors are specified in Section 233300 "Air Duct Accessories."
- B. Install ducts adjacent to power ventilators to allow service and maintenance.
- C. Ground equipment according to Section 260530 "Conduit and Wire."
- D. Connect wiring according to Section 260530 "Conduit and Wire."

#### **3.03 FIELD QUALITY CONTROL**

1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect components, assemblies, and equipment installations, including connections, and to assist in testing.
- B. Tests and Inspections:
  1. Verify that shipping, blocking, and bracing are removed.
  2. Verify that unit is secure on mountings and supporting devices and that connections to ducts and electrical components are complete. Verify that proper thermal-overload protection is installed in motors, starters, and disconnect switches.
  3. Verify that cleaning and adjusting are complete.

4. Disconnect fan drive from motor, verify proper motor rotation direction, and verify fan wheel free rotation and smooth bearing operation. Reconnect fan drive system.
  5. Adjust damper linkages for proper damper operation.
  6. Verify lubrication for bearings and other moving parts.
  7. Verify that manual and automatic volume control and fire and smoke dampers in connected ductwork systems are in fully open position.
  8. Disable automatic temperature-control operators, energize motor and adjust fan to indicated rpm, and measure and record motor voltage and amperage.
  9. Shut unit down and reconnect automatic temperature-control operators.
  10. Remove and replace malfunctioning units and retest as specified above.
- C. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- D. Prepare test and inspection reports.

#### **3.04 ADJUSTING**

- A. Adjust damper linkages for proper damper operation.
- B. Comply with requirements in Section 230593 "Testing, Adjusting, and Balancing for HVAC" for testing, adjusting, and balancing procedures.
- C. Replace fan and motor pulleys as required to achieve design airflow.
- D. Lubricate bearings.

END OF SECTION





**SECTION 23 37 13**  
**DIFFUSERS, REGISTERS, AND GRILLES**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Submittal and installation requirements for diffusers, registers, and grilles.
- B. Related Requirements:
  - 1. Section 233300 "Air Duct Accessories" for fire and smoke dampers and volume-control dampers not integral to diffusers, registers, and grilles.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product indicated, include the following:
  - 1. Data Sheet: Indicate materials of construction, finish, and mounting details; and performance data including throw and drop, static-pressure drop, and noise ratings.
  - 2. Diffuser, Register, and Grille Schedule: Indicate drawing designation, room location, quantity, model number, size, and accessories furnished.

**1.03 INFORMATIONAL SUBMITTALS**

- A. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from Installers of the items involved:
  - 1. Ceiling suspension assembly members.
  - 2. Method of attaching hangers to building structure.
  - 3. Size and location of initial access modules for acoustical tile.
  - 4. Ceiling-mounted items including lighting fixtures, diffusers, grilles, speakers, sprinklers, access panels, and special moldings.
  - 5. Duct access panels.
  - 6. Refer to Section 23 00 50, "Common Work Results for HVAC Systems for additional requirements.
- B. Source quality-control reports.

**PART 2 - PRODUCTS**

**2.01 DIFFUSERS, REGISTERS, AND GRILLES**

- A. Diffusers, registers, and grilles manufacturers and models are specified on Drawings.

**2.02 SOURCE QUALITY CONTROL**

- A. Verification of Performance: Rate diffusers, registers, and grilles according to ASHRAE 70, "Method of Testing for Rating the Performance of Air Outlets and Inlets."

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine areas where diffusers, registers, and grilles are to be installed for compliance with requirements for installation tolerances and other conditions affecting performance of equipment.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 INSTALLATION**

- A. Install diffusers, registers, and grilles level and plumb.
- B. Ceiling-Mounted Outlets and Inlets: Drawings indicate general arrangement of ducts, fittings, and accessories. Air outlet and inlet locations have been indicated to achieve design requirements for air volume, noise criteria, airflow pattern, throw, and pressure drop. Make final locations where indicated, as much as practical. For units installed in lay-in ceiling panels, locate units in the center of panel. Where architectural features or other items conflict with installation, notify Architect for a determination of final location.
- C. Install diffusers, registers, and grilles with airtight connections to ducts and to allow service and maintenance of dampers, air extractors, and fire dampers.
- D. Unless otherwise indicated on Drawings, provide rectangular galvanized steel plenum on top of each diffuser and ceiling return for connection to ductwork. Line plenum with internal insulation as indicated for lined ductwork. Size plenum to allow full opening into air terminal. Plenum sheet metal gauge shall be equal to gauge for rectangular equivalent of the branch duct serving the air inlet or outlet.

### **3.03 ADJUSTING**

- A. After installation, adjust diffusers, registers, and grilles to air patterns indicated, or as directed, before starting air balancing.

END OF SECTION



**SECTION 23 41 00**  
**PARTICULATE AIR FILTRATION**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Pleated panel filters.
  - 2. Filter gages.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product indicated. Include dimensions; operating characteristics; required clearances and access; rated flow capacity, including initial and final pressure drop at rated airflow; efficiency and test method; fire classification; furnished specialties; and accessories for each model indicated.
- B. Shop Drawings: For air filters. Include plans, elevations, sections, details, and attachments to other work.
  - 1. Show filter rack assembly, dimensions, materials, and methods of assembly of components.
  - 2. Include setting drawings, templates, and requirements for installing anchor bolts and anchorages.
  - 3. Wiring Diagrams: For power, signal, and control wiring.

**1.03 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For each type of filter and rack to include in emergency, operation, and maintenance manuals.

**1.04 MAINTENANCE MATERIAL SUBMITTALS**

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Provide one complete set(s) of filters for each filter bank. If system includes prefilters, provide only prefilters.

**1.05 QUALITY ASSURANCE**

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. ASHRAE Compliance:
  - 1. Comply with applicable requirements in ASHRAE 62.1, Section 4 - "Outdoor Air Quality"; Section 5 - "Systems and Equipment"; and Section 7 - "Construction and Startup."
  - 2. Comply with ASHRAE 52.1 for arrestance and ASHRAE 52.2 for MERV for methods of testing and rating air-filter units.
- C. Comply with NFPA 90A and NFPA 90B.

## **PART 2 - PRODUCTS**

### **2.01 PLEATED PANEL FILTERS**

- A. Description: Factory-fabricated, self-supported, extended-surface, pleated, panel-type, disposable air filters with holding frames.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:
    - a. AAF International.
    - b. Camfil Farr.
    - c. Flanders Corporation.
- B. Filter Unit Class: UL 900, Class 2.
- C. Media: Interlaced glass or synthetic fibers or Cotton and synthetic fibers coated with nonflammable adhesive.
  - 1. Adhesive shall have a VOC content of 80 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 2. Media shall be coated with an antimicrobial agent.
  - 3. Separators shall be bonded to the media to maintain pleat configuration.
  - 4. Welded wire grid shall be on downstream side to maintain pleat.
  - 5. Media shall be bonded to frame to prevent air bypass.
  - 6. Support members on upstream and downstream sides to maintain pleat spacing.
- D. Filter-Media Frame: Cardboard frame with perforated metal retainer with metal grid on outlet side and steel rod grid on inlet side, hinged, with pull and retaining handles sealed or bonded to the media.
- E. Mounting Frames: Welded galvanized steel, with gaskets and fasteners; suitable for bolting together into built-up filter banks.
  - 1. Minimum MERV Rating: As specified or schedule for specific equipment, and tested according to ASHRAE 52.2.

### **2.02 FILTER GAGES**

- A. Diaphragm-type gage with dial and pointer in metal case, vent valves, black figures on white background, and front recalibration adjustment.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:
    - a. Airguard.
    - b. Dwyer Instruments, Inc.
  - 2. Diameter: 2 inches.
  - 3. Scale Range for Filter Media Having a Recommended Final Resistance of 0.5-Inch wg or Less: 0- to 0.5-inch wg.

4. Scale Range for Filter Media Having a Recommended Final Resistance of 0.5- to 1.0-Inch wg or Less: 0- to 1.0-inch wg.
  5. Scale Range for Filter Media Having a Recommended Final Resistance of 1.0- to 2.0-Inch wg or Less: 0- to 2.0-inch wg.
  6. Scale Range for Filter Media Having a Recommended Final Resistance of 2.0- to 3.0-Inch wg or Less: 0- to 3.0-inch wg.
- B. Accessories: Static-pressure tips, tubing, gage connections, and mounting bracket.

## **PART 3 - EXECUTION**

### **3.01 INSTALLATION**

- A. Position each filter unit with clearance for normal service and maintenance. Anchor filter holding frames to substrate.
- B. Install filters in position to prevent passage of unfiltered air.
- C. Install filter gage for each filter bank.
- D. Do not operate fan system until filters (temporary or permanent) are in place. Replace temporary filters used during construction and testing with new, clean filters.
- E. Install filter-gage, static-pressure taps upstream and downstream from filters. Install filter gages on filter banks with separate static-pressure taps upstream and downstream from filters. Mount filter gages on outside of filter housing or filter plenum in an accessible position. Adjust and level inclined gages.
- F. Coordinate filter installations with duct and air-handling-unit installations.

### **3.02 TEMPORARY (CONSTRUCTION PERIOD) FILTERS:**

- A. Install new temporary filters in all units that have filter systems installed. Temporary filters shall match the permanent filters that are specified for the units. Replace filters as needed, in accordance with manufacturer's directions, in order to provide protection for the unit prior to occupancy by the Owner. Provide new filters prior to air system balancing.
- B. If air handling units are operated during construction of the project, install temporary filters directly over each return air inlet. Filters shall match the permanent filters that are specified for the units. Select size of filter to completely cover the frame of the return air inlet, and tape filters firmly in place to eliminate any construction debris from entering the duct system or unit. Remove the temporary filters upon completion of the work, and repair all damaged paintwork.

### **3.03 FIELD QUALITY CONTROL**

- A. Tests and Inspections:
  1. Test for leakage of unfiltered air while system is operating.
- B. Air filter will be considered defective if it does not pass tests and inspections.
- C. Prepare test and inspection reports.

### **3.04 CLEANING**

- A. After completing system installation and testing, adjusting, and balancing of air-handling and air-distribution systems, clean filter housings and install new filter media.

END OF SECTION



**SECTION 23 51 23**  
**GAS VENTS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section Includes:
  - 1. Listed double-wall vents.

**1.02 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for product.
- B. Shop Drawings: For vents.
  - 1. Include plans, elevations, sections, and attachment details.
  - 2. Include details of equipment assemblies. Indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
  - 3. Detail fabrication and assembly of hangers and seismic restraints.

**1.03 INFORMATIONAL SUBMITTALS**

- A. Sample Warranty: For special warranty.

**PART 2 - PRODUCTS**

**2.01 LISTED TYPE B VENTS**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
  - 1. Heat-Fab, Inc.
  - 2. Metal-Fab, Inc.
  - 3. Selkirk Corporation.
- B. Description: Double-wall metal vents tested according to UL 441 and rated for 480 deg F continuously for Type B; with neutral or negative flue pressure complying with NFPA 211.
- C. Construction: Inner shell and outer jacket separated by at least a 1/4-inch airspace.
- D. Inner Shell: ASTM A 666, Type 430 stainless steel.
- E. Outer Jacket: Galvanized steel.
- F. Accessories: Tees, elbows, increasers, draft-hood connectors, terminations, adjustable roof flashings, storm collars, support assemblies, thimbles, firestop spacers, and fasteners; fabricated from similar materials and designs as vent-pipe straight sections; all listed for same assembly.
  - 1. Termination: Stack cap designed to exclude minimum 90 percent of rainfall.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine areas and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 APPLICATION**

- A. Listed Type B: Vents for certified gas appliances.

### **3.03 INSTALLATION OF LISTED VENTS**

- A. Comply with requirements of boiler and vent system manufacturers.
- B. Comply with minimum clearances from combustibles and minimum termination heights according to product listing or NFPA 211, whichever is most stringent.
- C. Seal between sections of positive-pressure vents according to manufacturer's written installation instructions, using sealants recommended by manufacturer.
- D. Support vents at intervals recommended by manufacturer to support weight of vents and all accessories, without exceeding appliance loading.
- E. Lap joints in direction of flow. Slope vent towards appliance.
- F. Install condensate trap kit and drain to receptacle.

### **3.04 CLEANING**

- A. After completing system installation, including outlet fittings and devices, inspect exposed finish. Remove burrs, dirt, and construction debris, and repair damaged finishes.

END OF SECTION

**SECTION 23 74 16**  
**PACKAGED, ROOFTOP AIR-CONDITIONING UNITS**

**PART 1 - GENERAL**

**1.01 SUMMARY**

- A. Section includes packaged, rooftop air-conditioning units (RTUs).

**1.02 DEFINITIONS**

- A. DDC: Direct digital controls.
- B. ECM: Electronically commutated motor.
- C. MERV: Minimum efficiency reporting value.
- D. Outdoor-Air Refrigerant Coil: Refrigerant coil in the outdoor-air stream to reject heat during cooling operations and to absorb heat during heating operations. "Outdoor air" is defined as the air outside the building or taken from outdoors and not previously circulated through the system.
- E. RTU: Rooftop unit. As used in this Section, this abbreviation means packaged, small-capacity, rooftop air-conditioning units. This abbreviation is used regardless of whether the unit is mounted on the roof or on a concrete base on ground.
- F. Supply-Air Fan: The fan providing supply air to conditioned space. "Supply air" is defined as the air entering a space from air-conditioning, heating, or ventilating apparatus.
- G. Supply-Air Refrigerant Coil: Refrigerant coil in the supply-air stream to absorb heat (provide cooling) during cooling operations and to reject heat (provide heating) during heating operations. "Supply air" is defined as the air entering a space from air-conditioning, heating, or ventilating apparatus.

**1.03 ACTION SUBMITTALS**

- A. Product Data: For each RTU.
  - 1. Include manufacturer's technical data.
  - 2. Include rated capacities, dimensions, required clearances, characteristics, and furnished specialties and accessories.
- B. Shop Drawings:
  - 1. Include details of equipment assemblies. Indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
  - 2. Include diagrams for power, signal, and control wiring.

**1.04 INFORMATIONAL SUBMITTALS**

- A. Coordinated Layout: Plans and other details, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
  - 1. Structural members to which RTUs will be attached.
  - 2. Roof openings.

3. Roof curbs and flashing.
  4. Refer to Section 23 00 50, "Common Work Results for HVAC Systems for additional requirements.
- B. Roof Curb Data: For roof mounted equipment where combined weight of equipment unit and roof curb or rail exceeds 400 pounds, submit calculations from manufacturer for roof curbs proving compliance with the seismic requirements of the 2016 CBC, and ASCE 7-10. Manufacturer shall certify that roof curbs are suitable for use indicated on Drawings and in Specifications for the seismic design category indicated in structural Contract Documents. Calculations shall be stamped and signed by a State of California registered structural engineer.
  - C. Provide evidence of equipment certification to California Energy Code Section 110.1 or 110.2, if not providing Electrically Commutated motors for HVAC fans sized below 1 hp and above 1/12 hp. Refer to specific equipment articles requiring electrically commutated motors.
  - D. Field quality-control reports.
  - E. Sample Warranty: For special warranty.

#### **1.05 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For RTUs to include in emergency, operation, and maintenance manuals.

#### **1.06 MAINTENANCE MATERIAL SUBMITTALS**

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Fan Belts: One set(s) for each belt-driven fan.
  2. Filters: One set(s) of filters for each unit.

#### **1.07 WARRANTY**

- A. Special Warranty: Manufacturer agrees to repair or replace components of RTUs that fail in materials or workmanship within specified warranty period.
  1. Warranty Period for Compressors: Manufacturer's standard, but not less than five <Insert number> years from date of Substantial Completion.
  2. Warranty Period for Gas Furnace Heat Exchangers: Refer to article, System Description.
  3. Warranty Period for Solid-State Ignition Modules: Manufacturer's standard, but not less than three years from date of Substantial Completion.
  4. Warranty Period for Control Boards: Manufacturer's standard, but not less than three years from date of Substantial Completion.

### **PART 2 - PRODUCTS**

#### **2.01 MATERIALS**

- A. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).

## 2.02 MANUFACTURERS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
  - 1. Trane.
  - 2. Johnson Controls, Inc.

## 2.03 SYSTEM DESCRIPTION

- A. Provide factory assembled single packaged outdoor rooftop mounted, electrically controlled gas heating and electric cooling unit, rated in accordance with ARI Standards 210/240 or 340/360, and ETL or UL listed and labeled, classified in accordance with UL 1995. Provide refrigerant charge R-410A, all internal wiring, piping, controls, and special features required prior to field startup. Design unit to conform to the following:
  - 1. California NOx emission requirements.
  - 2. ASHRAE 15.
  - 3. ASHRAE 90.1.
  - 4. Insulation, adhesive, and all materials exposed to air stream shall meet NFPA 90A requirements for flame spread and smoke generation.
  - 5. Unit casing shall be capable of withstanding 500-hour salt spray exposure per ASTM B117 (scribed specimen).
- B. Unit shall be rated in accordance with ARI sound standards 270 or 370.
- C. Unit shall be ETL or UL tested and certified in accordance with ANSI Z21.47 Standards as a total package.
- D. Roof curb shall be designed to conform to NRCA Standards.
- E. Unit shall be designed and manufactured in accordance with ISO 9001.
- F. For unit sizes applicable to Energy Star program, units shall be Energy Star qualified.
- G. Cabinet:
  - 1. Provide galvanized steel unit cabinet, bonderized and coated with a baked enamel finish.
  - 2. All airstream interior surfaces shall be insulated with a minimum 1/2 inch thick, 1.5 lb density cleanable insulation. Insulation shall be encapsulated with panel design or have sealed edges.
  - 3. Cabinet panels shall be hinged with integrated non-corrosive hinges. Provide hinged access panels for the filter, compressors, evaporator fan, and control box/ heat section areas. Each panel shall have multiple latches and handles. Each external hinged access panel shall be double-wall construction and permanently attached to the rooftop unit.
  - 4. Return air filters shall be accessible through a dedicated hinged access panel.
  - 5. Fork lift slots and rigging holes shall be provided in unit base rails. Base rails shall be minimum 16 gauge.

6. Unit shall have an integral sloped condensate drain pan, providing minimum 3/4 in.-14 NPT connections for horizontal drain configuration. Provide unit with alternate vertical thru-the-bottom drain connection when furnished as standard for units sizes scheduled on Drawings. See Drawings for drain configuration. Pan shall be removable for cleaning and maintenance. All drain pans shall conform to ASHRAE 62.1 self-draining provisions.
7. Unit shall have standard side and alternate field or factory installed thru-the-bottom power and control wiring connection capability. Thru-the-bottom electrical connections shall use manufacturer's approved water-tight connection method.
8. Unit shall be field convertible to, or factory furnished with, horizontal air discharge, as applicable for unit sizes as scheduled on Drawings.

H. Fans:

1. Centrifugal supply air blower (evaporator fan) shall have sealed, permanently lubricated ball bearings, or rigid pillow block bearings, as supplied as standard equipment for unit sizes scheduled on Drawings. Units supplied with pillow block bearings shall be furnished with accessible lubricant fittings. Provide belt-driven double inlet fan wheel, centrifugal type with forward curved blades and adjustable sheaves. Multiple speed direct drive motors may be utilized when supplied as standard equipment for efficiency and electrical requirements as scheduled on the Drawings. Fan wheel shall be steel, with corrosion resistant finish, dynamically balanced.
2. Condenser fans shall be of the direct-driven propeller type, with corrosion-resistant aluminum blades. Fans shall be dynamically balanced and discharge air upwards. Induced-draft blower shall be of the direct-driven, single inlet, forward-curved, centrifugal type, made from aluminized steel with a corrosion-resistant finish and shall be dynamically balanced.
3. Induced draft fan shall be of the direct driven, single inlet, forward-curved centrifugal type. Fan wheel shall be steel, with corrosion resistant finish, dynamically balanced.

I. Motors:

1. Compressor motors shall be cooled by refrigerant gas passing through motor windings and shall have line break thermal and current overload protection.
2. Evaporator fan motor shall have permanently lubricated, sealed bearings and inherent automatic-reset thermal overload protection or manual reset calibrated circuit breakers.
3. Totally enclosed condenser-fan motor shall have permanently lubricated, sealed bearings, and inherent automatic-reset thermal overload protection.
4. Induced-draft motor shall have permanently lubricated sealed bearings and inherent automatic-reset thermal overload protection.
5. For single-phase fan motors sized larger than 1/12 hp and smaller than 1 hp, refer to Section 23 05 13, "Common Motor Requirements for HVAC Equipment."

J. Compressor:

1. Fully hermetic, scroll type with internal high-pressure and temperature protection.
2. Factory installed rubber shock mounted and internally spring mounted for vibration isolation.

3. Compressor Anti-Recycle Timer: Compressor shall be prevented from restarting for a minimum of five minutes after shutdown, with manufacturers installed compressor cycle delay.

K. Coils:

1. Standard evaporator and condenser coils shall have aluminum plate fins mechanically bonded to seamless internally finned copper tubes with all joints brazed.
2. Units shall have face-split type evaporator coils.
3. For units with single compressor, condenser coils shall be single slab, single pass design. For dual compressor units, condenser coils shall be single slab, 2 pass design.
4. Evaporator coils shall be leak tested at minimum 150 psig, and pressure tested at minimum 450 psig.
5. Condenser coils shall be leak tested at minimum 150 psig, and pressure tested at minimum 650 psig.

L. Heating Section:

1. Induced-draft combustion type with direct-spark ignition system and redundant main gas valve with 2-stage capability on all 3-phase units.
2. Heat Exchanger:
  - a. Units 5 tons and below shall utilize the following: Optional low-NOx heat exchanger shall be of the tubular section type, with 20-gage, type 409 stainless steel primary tubes and vestibule plates. Other components shall be constructed of aluminized steel. Heat exchanger shall have a fifteen year warranty.
  - b. The standard aluminized heat exchanger shall be of the tubular-section type constructed of minimum 20-gage aluminized steel. Standard heat exchanger shall have a ten year warranty.
  - c. The optional stainless steel heat exchanger shall be of the tubular-section type, constructed of minimum 20-gage, type 409 stainless steel, including stainless steel tubes, vestibule plate, and collector box. Stainless steel heat exchanger shall have a fifteen year warranty.
3. Burners shall be of the in-shot type constructed of aluminum-coated steel.
4. All gas piping shall enter the unit at a single location. Gas entry shall be through side or bottom of unit. See Drawings for gas entry location. When bottom gas entry is utilized, unit shall be furnished with field installed conversion kit, arranged so that gas shut-off valve is accessible from the roof.
5. All factory-installed orifices are for operation up to 2,000 feet of altitude. For altitudes between 2,000 feet and 7,000 feet, a factory certified kit shall be furnished for field installation.
6. Units shall be suitable for use with natural gas or propane. Provide field-installed propane conversion kit as required, see schedule on Drawings.
7. The integrated gas controller board shall include gas heat operation fault notification using an LED (light-emitting diode).

8. Unit shall be equipped with anti-cycle protection with one short cycle on unit flame rollout switch or 4 continuous short cycles on the high-temperature limit switch. Fault indication shall be made using an LED.
9. The integrated gas controller board shall contain algorithms that modify evaporator-fan operation to prevent future cycling on high-temperature limit switch.
10. The LED shall be visible without removal of control box access panel.
11. Gas burner tray shall be removable for maintenance.
12. Heating section shall be insulated with foil-faced fiberglass insulation.

M. Refrigerant Components:

1. Each refrigerant circuit shall include:
  - a. Balanced port thermostatic expansion valve (TXV) with removable power element.
  - b. Solid core refrigerant filter driers with pressure ports.
  - c. Refrigerant pressure gage ports and connections on suction, discharge, and liquid lines.

N. Filter Section:

1. Standard filter section shall accommodate 2 inch deep filters. Filters shall conform to the "Air Filters" Article in this Specification Section.
2. Filter section shall use standard size filters.

O. Controls:

1. Unit shall be complete with self-contained low voltage fuse protected control circuit. Refer to Section 25 50 00, if included, and equipment schedule, sequence of operation and control diagram on Drawings for additional requirements.
2. When third party direct digital controls with an Energy Management System will be utilized, provide electro-mechanical controls with 24V thermostat interface.
3. When stand-alone thermostat operation is utilized, provide electro-mechanical controls with 24V thermostat interface or provide microprocessor controls.
4. When stand-alone thermostat operation is utilized for single-zone VAV units, provide microprocessor controls. Units shall have factory mounted supply fan variable frequency drives.
5. When third party direct digital controls with an Energy Management System will be utilized for single zone VAV units, provide microprocessor controls with BACnet or LON interface. Units shall have factory mounted supply fan variable frequency drives.
6. Electro-mechanical controls shall include the following, as a minimum:
  - a. Service run test capability.
  - b. Provide compressor minimum run time (3 minutes) and minimum off time (5 minutes).
  - c. Economizer control.
  - d. Unit shall have 35° F low ambient cooling operation.



- e. Time delay relay.
7. Microprocessor controls shall include the following, as a minimum:
- a. User diagnostic interface.
  - b. Unit control with standard suction pressure transducers and condensing temperature thermistors.
  - c. Shall provide a 5° F temperature difference between cooling and heating set points to meet ASHRAE 90.1 energy standard.
  - d. Service run test capability.
  - e. Shall accept input from a CO2 sensor (indoor).
  - f. Configurable alarm light shall be provided which activates when certain types of alarms occur.
  - g. Provide compressor minimum run time (3 minutes) and minimum off time (5 minutes).
  - h. Service diagnostic mode.
  - i. Economizer control.
  - j. Unit shall have 0° F low ambient cooling operation.
  - k. Time delay relay.

P. Safeties:

1. Unit shall incorporate a solid-state compressor lockout that provides optional reset capability at the space thermostat, should any of the following safety devices trip and shut off compressor:
  - a. Compressor lockout protection provided for either internal or external overload.
  - b. Low-pressure protection.
  - c. Freeze protection (evaporator coil).
  - d. High-pressure protection (high pressure switch or internal).
  - e. Compressor reverse rotation protection.
  - f. Loss of charge protection.
  - g. Start assist on single-phase units.
2. Supply-air sensor shall be located in the unit and detect both heating and cooling operation.
3. Induced draft heating section shall be provided with the following minimum protections:
  - a. High-temperature limit switch.
  - b. Induced-draft motor speed sensor.
  - c. Flame rollout switch.
  - d. Flame proving controls.
  - e. Redundant gas valve.
4. Phase Protection: Provide unit-mounted "SymCom," or equal, Motor Saver three phase voltage monitor, model 201A or equal, adjustable voltage range for each unit, install per manufacturer's recommendations, mount in NEMA 3R enclosure if exposed to the weather.
  - a. Units shall provide the following features:

- 1) Low voltage fault trip and reset.
- 2) Voltage unbalance/phasing fault trip and reset.
- 3) High voltage fault trip and reset.
- 4) Transient Protection (Internal).
- 5) Automatic restart.

b. Provide each unit with 600V socket, "SymCom" model OT08, or equal.

Q. Operating Characteristics:

1. Unit shall be capable of starting and running at 125° F ambient outdoor temperature per maximum load criteria of ARI Standards 210 or 360.
2. Unit will operate in cooling down to an outdoor ambient temperature of 35° F.
3. Unit shall be provided with fan time delay to prevent cold air delivery in heating mode.

R. Electrical Requirements:

1. All unit power wiring shall enter unit cabinet at a single location. Both unit side and bottom power entry provisions shall be provided. Refer to Drawings schedule for thru-the-bottom power wiring requirement.

S. Provide the following additional features and equipment:

1. Roof Curb: Formed galvanized steel with wood nailer strip capable of supporting entire unit weight. Provide 3 inch wide bottom flange.
2. Provide heavy-duty 18 gauge expanded metal coil guard grille to protect all surfaces of the condensing coil. Coil guard by Micrometl, Canfab, or equal.
3. Modulating Power Exhaust Economizer: Micrometl, Canfab, or equal. Integrated type capable of simultaneous economizer and compressor operation.
  - a. Provide self-contained outdoor rooftop system, mounted directly to the return air compartment of the HVAC packaged equipment. Provide differential dry bulb economizer control system and a factory programmed, fully programmable variable frequency drive package controlled by a differential pressure transmitter, mounted directly to the return air compartment of the HVAC packaged equipment. Design the system to continuously maintain space pressure, and provide capability of introducing up to 100 percent outdoor air.
    - 1) Economizer control system shall be certified as meeting the requirements for Fault Detection and Diagnostics (FDD) in the California Building Energy and Efficiency Standards.
  - b. Provide outside differential pressure tubing termination with hex style pneumatic filter-muffler, minimum filtration 40 microns, 53 SCFM maximum at 100 psi, as manufactured by McMaster-Carr, or equal.
  - c. Provide hinged cabinet access doors and include latches to provide a tool-less entry for servicing.
  - d. Provide door lock on the power exhaust cabinet to meet ETL safety requirements.

- e. Outdoor air intake dampers shall be low leak not to exceed 3 percent at 1 inch wg pressure differential and include stainless steel side seal and neoprene edge seal. Arrange dampers to close upon loss of power.
  - f. Provide belt driven exhaust blowers, double inlet, forward-curved centrifugal type. Provide gravity backdraft damper at fan outlet.
  - g. Provide fully programmable factory programmed variable frequency drive (VFD) package for each fan, driven by 4 to 20 mA signal from a differential pressure transmitter. Pressure transmitters shall measure 0 - 0.1 in wg. Install room sensor tubing with sensor tube termination installed within the room.
    - 1) Where direct digital controls are utilized, provide Belimo, or equal, damper actuator, complete with spring return and all controls required to make the system fully operational.
    - 2) Where stand-alone controls are utilized, provide Belimo, or equal, damper actuator, complete with spring return and all controls, including logic module, required to make the system fully operational.
4. Duct-Mounted Modulating Power Exhaust: Micrometl, Canfab, or equal.
- a. Provide self-contained outdoor rooftop system, mounted directly to the horizontal return air duct of the HVAC packaged equipment. Provide a factory programmed, fully programmable variable frequency drive package controlled by a differential pressure transmitter. Design the system to continuously maintain space pressure.
  - b. Provide outside differential pressure tubing termination with hex style pneumatic filter-muffler, minimum filtration 40 microns, 53 SCFM maximum at 100 psi, as manufactured by McMaster-Carr, or equal.
  - c. Provide hinged cabinet access doors and include latches to provide a toolless entry for servicing.
  - d. Provide door lock on the power exhaust cabinet to meet ETL safety requirements.
  - e. Provide belt driven exhaust blowers, double inlet, forward curved centrifugal type. Provide gravity backdraft dampers with gasketed blades at fan outlets.
  - f. Provide fully programmable factory programmed variable frequency drive (VFD) package for each fan, driven by 4 to 20 mA signal from a differential pressure transmitter. Pressure transmitters shall measure 0 - 0.1 in wg.
  - g. Support power exhaust unit as detailed on the Drawings. Support shall not interfere with unit access or functionality.
  - h. Provide with wiring harness. Install harness per manufacturer's instructions.
5. Gas Flue Extensions:
- a. Provide at all locations where gas flue outlet will be within 10 feet of an adjacent building forced air inlet, or mechanical unit air intake, and where indicated on Drawings.
6. Other features, accessories, and equipment scheduled on Drawings.
- T. Replenish for a period of one year without cost to the Owner all refrigerant and oil required to maintain the proper levels.

## **2.04 CONTROLS**

- A. Interface Requirements for HVAC Instrumentation and Control System:

## **2.05 CONTROLS**

1. Refer to control diagrams on Drawings and to Section 230923, "Direct Digital Control System for HVAC."

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of RTUs.
- B. Examine roughing-in for RTUs to verify actual locations of piping and duct connections before equipment installation.
- C. Examine roofs for suitable conditions where RTUs will be installed.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.02 INSTALLATION**

- A. Roof Curb: Install on roof structure or concrete base, level and secure. Install RTUs on curbs and coordinate roof penetrations and flashing with roof construction specified in Section 077200 "Roof Accessories." Secure RTUs to upper curb rail, and secure curb base to roof framing or concrete base as detailed on Drawings.

### **3.03 CONNECTIONS**

- A. Comply with duct installation requirements specified in other HVAC Sections. Drawings indicate general arrangement of ducts. The following are specific connection requirements:
  1. Install ducts to termination at top of roof curb.
  2. Remove roof decking only as required for passage of ducts. Do not cut out decking under entire roof curb.
  3. Connect supply and return ducts to RTUs with flexible duct connectors specified in Section 233300 "Air Duct Accessories."
  4. Cover roof inside each roof mounted air conditioning unit, heat pump unit, and heating and ventilating unit roof curb with 2 inch thick, 3 pound density fiberglass insulation board.
- B. Install condensate drain, minimum connection size, with trap and indirect connection to nearest roof drain or area drain.
- C. Where installing piping adjacent to RTUs, allow space for service and maintenance.
  1. Gas Piping: Comply with applicable requirements in Section 231123 "Facility Natural-Gas Piping." Connect gas piping to burner, full size of gas train inlet, and connect with union and shutoff valve with sufficient clearance for burner removal and service.
- D. Connect electrical wiring according to Section 260530 "Conduit and Wire."
- E. Ground equipment according to Section 260530 "Conduit and Wire."

- F. Install nameplate for each electrical connection, indicating electrical equipment designation and circuit number feeding connection.
  - 1. Nameplate shall be laminated acrylic or melamine plastic signs as specified in Section 260500 "Common Work Results for Electrical."
  - 2. Nameplate shall be laminated acrylic or melamine plastic signs as layers of black with engraved white letters at least 1/2 inch high.
  - 3. Locate nameplate where easily visible.

### **3.04 FIELD QUALITY CONTROL**

- A. Manufacturer's Field Service: Engage a factory-authorized service representative to test and inspect components, assemblies, and equipment installations, including connections.
- B. RTU will be considered defective if it does not pass tests and inspections.
- C. Prepare test and inspection reports.

### **3.05 STARTUP SERVICE**

- A. Engage a factory-authorized service representative to perform startup service.
  - 1. Complete installation and startup checks according to manufacturer's written instructions.
  - 2. Inspect for visible damage to unit casing.
  - 3. Inspect for visible damage to furnace combustion chamber.
  - 4. Inspect for visible damage to compressor, coils, and fans.
  - 5. Inspect internal insulation.
  - 6. Verify that labels are clearly visible.
  - 7. Verify that clearances have been provided for servicing.
  - 8. Verify that controls are connected and operable.
  - 9. Verify that filters are installed.
  - 10. Clean condenser coil and inspect for construction debris.
  - 11. Clean furnace flue and inspect for construction debris.
  - 12. Connect and purge gas line.
  - 13. Remove packing from vibration isolators.
  - 14. Verify lubrication on fan and motor bearings.
  - 15. Inspect fan-wheel rotation for movement in correct direction without vibration and binding.
  - 16. Adjust fan belts to proper alignment and tension.
  - 17. Start unit according to manufacturer's written instructions.
    - a. Start refrigeration system.
    - b. Do not operate below recommended low-ambient temperature.
    - c. Complete startup sheets and attach copy with Contractor's startup report.
  - 18. Inspect and record performance of interlocks and protective devices; verify sequences.

19. Operate unit for an initial period as recommended or required by manufacturer.
20. Perform the following operations for both minimum and maximum firing. Adjust burner for peak efficiency:
  - a. Measure gas pressure on manifold.
  - b. Inspect operation of power vents.
  - c. Measure combustion-air temperature at inlet to combustion chamber.
  - d. Measure flue-gas temperature at furnace discharge.
  - e. Perform flue-gas analysis. Measure and record flue-gas carbon dioxide and oxygen concentration.
  - f. Measure supply-air temperature and volume when burner is at maximum firing rate and when burner is off. Calculate useful heat to supply air.
21. Calibrate thermostats.
22. Adjust and inspect high-temperature limits.
23. Inspect outdoor-air dampers for proper stroke and interlock with return-air dampers.
24. Start refrigeration system and measure and record the following when ambient is a minimum of 15 deg F above return-air temperature:
  - a. Coil leaving-air, dry- and wet-bulb temperatures.
  - b. Coil entering-air, dry- and wet-bulb temperatures.
  - c. Outdoor-air, dry-bulb temperature.
  - d. Outdoor-air-coil, discharge-air, dry-bulb temperature.
25. Inspect controls for correct sequencing of heating, mixing dampers, refrigeration, and normal and emergency shutdown.
26. Measure and record the following minimum and maximum airflows. Plot fan volumes on fan curve.
  - a. Supply-air volume.
  - b. Return-air volume.
  - c. Relief-air volume.
  - d. Outdoor-air intake volume.
27. Simulate maximum cooling demand and inspect the following:
  - a. Compressor refrigerant suction and hot-gas pressures.
  - b. Short circuiting of air through condenser coil or from condenser fans to outdoor-air intake.
28. Verify operation of remote panel including pilot-light operation and failure modes. Inspect the following:
  - a. High-temperature limit on gas-fired heat exchanger.
  - b. Low-temperature safety operation.

- c. Filter high-pressure differential alarm.
  - d. Economizer to minimum outdoor-air changeover.
  - e. Relief-air fan operation.
  - f. Smoke and firestat alarms.
29. After startup and performance testing and prior to Substantial Completion, replace existing filters with new filters.

### **3.06 CLEANING AND ADJUSTING**

- A. Occupancy Adjustments: When requested within 12 months from date of Substantial Completion, provide on-site assistance in adjusting system to suit actual occupied conditions. Provide up to two visits to Project during other-than-normal occupancy hours for this purpose.
- B. After completing system installation and testing, adjusting, and balancing RTU and air-distribution systems, clean filter housings and install new filters.

### **3.07 DEMONSTRATION**

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain RTUs.
- B. Owner Training: Manufacturer shall provide two initial on-site 4-hour training sessions for Owners' maintenance personnel. Manufacturer shall provide one 4-hour follow-up training session to be scheduled by Owner within one year of the date of the final initial training session. Training session agenda shall be as follows:
  - 1. First session: Equipment.
  - 2. Second session: Controls.
  - 3. Follow-up session: Agenda by Owner.

END OF SECTION

**SECTION 238126.13**  
**VARIABLE REFRIGERANT FLOW SPLIT-SYSTEM HEAT PUMPS**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

**1.02 SUMMARY**

- A. Section includes variable refrigerant flow split-system heat-pump units consisting of separate evaporator-fan and compressor-condenser components.

**1.03 ACTION SUBMITTALS**

- A. Product Data: For each type of product indicated. Include rated capacities, operating characteristics, and furnished specialties and accessories. Include performance data in terms of capacities, outlet velocities, static pressures, sound power characteristics, motor requirements, and electrical characteristics.
- B. Sustainable Design Submittals:
  - 1. Product Data: For refrigerants.
  - 2. Product Data: For energy performance.
- C. Product Data for California Green Building Standards Code Compliance: For adhesives and sealants, including primers, documentation of compliance including printed statement of VOC content and chemical components.
- D. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
  - 2. Wiring Diagrams: For power, signal, and control wiring.
- E. Samples for Initial Selection: For units with factory-applied color finishes.

**1.04 INFORMATIONAL SUBMITTALS**

- A. Coordination Drawings: Plans, drawn to scale at 1/4 inch equals one foot, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
  - 1. System installation, indicating coordination with general construction, building components, and other building services. Indicate proposed changes to system layout.
  - 2. Suspended ceiling components.
  - 3. Structural members to which system components will be attached.



4. Size and location of initial access modules for acoustical tile.
  5. Penetrations of smoke barriers and fire-rated construction.
  6. Items penetrating finished ceiling including the following:
    - a. Lighting fixtures.
    - b. Air outlets and inlets.
    - c. Speakers.
    - d. Sprinklers.
    - e. Access panels.
    - f. Perimeter moldings.
  7. Refer to Section 23 00 50, "Common Work Results for HVAC Systems for additional requirements.
- B. Provide evidence of equipment certification to California Energy Code Section 110.1 or 110.2, if not providing Electrically Commutated motors for HVAC fans sized below 1 hp and above 1/12 hp. Refer to Section 230513, "Common Motor Requirements for HVAC Equipment."
  - C. Training Certificates of Completion: Submit certificate from equipment manufacturer, indicating attendance and successful completion of manufacturer's training program for variable refrigerant flow systems installation and service. Training shall include manufacturer's preferred methods for assembling and insulating refrigerant piping and accessories.
  - D. Submit system documentation for a fully engineered system, including shop drawings, and wiring and control diagrams, showing location of required manufactured system components, component model numbers and capacities, and size and location of all field-installed components, including piping, required expansion compensation devices, and wiring. Identify proposed deviations from system as shown in Contract Documents.
  - E. Roof Curb Data: For roof mounted equipment where combined weight of equipment unit and roof curb or rail exceeds 400 pounds, submit calculations from manufacturer for roof curbs proving compliance with the seismic requirements of the 2016 California Building Code, and ASCE 7-10. Manufacturer shall certify that roof curbs are suitable for use indicated on Drawings and in Specifications for the seismic design category indicated in structural Contract Documents. Calculations shall be stamped and signed by a State of California registered structural engineer.
  - F. Field quality-control reports.
  - G. Warranty: Sample of special warranty.

#### **1.05 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For split-system air-conditioning units to include in emergency, operation, and maintenance manuals.

#### **1.06 MAINTENANCE MATERIAL SUBMITTALS**

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.

1. Filters: Two set(s) of disposable filters for each air-handling unit indicated to accommodate disposable filters. One washable, permanent filters for each air handling unit designed to accommodate washable, permanent filters.

### **1.07 QUALITY ASSURANCE**

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. ASHRAE Compliance:
  1. Fabricate and label refrigeration system to comply with ASHRAE 15, "Safety Standard for Refrigeration Systems."
  2. ASHRAE Compliance: Applicable requirements in ASHRAE 62.1, Section 4 - "Outdoor Air Quality," Section 5 - "Systems and Equipment," Section 6 - "Procedures," and Section 7 - "Construction and System Start-up."
- C. ASHRAE/IES Compliance: Applicable requirements in ASHRAE/IES 90.1.
- D. Variable Refrigerant Flow Split-System Heat Pump Installer Training: Installing contractor shall have completed training in installation and service of VRF system, by equipment manufacturer.
  1. Installing contractor shall obtain, at his own cost, equipment manufacturer's VRF system service tool, unless service tool is normally resident on controller specified for this Project.

### **1.08 COORDINATION**

- A. Coordinate sizes and locations of concrete bases with actual equipment provided. Cast anchor-bolt inserts into bases. Concrete, reinforcement, and formwork are specified in Section 033000 "Cast-in-Place Concrete."
- B. Coordinate sizes and locations of roof curbs, equipment supports, and roof penetrations with actual equipment provided.

## **PART 2 - PRODUCTS**

### **2.01 MATERIALS**

- A. Insulation products, including insulation, insulation facings, jackets, adhesives, sealants, and coatings shall not contain polybrominated diphenyl ethers (PBDEs) in penta, octa, or deca formulations in amounts greater than 0.1 percent (by mass).

### **2.02 MANUFACTURERS**

- A. Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include the following, or equal:
- B. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following, or equal:
  1. Carrier/Toshiba.
  2. Daikin.

3. Mitsubishi.

## 2.03 INDOOR UNITS

### A. General:

1. Galvanized steel casing.
2. Ducted, ceiling-recessed, or in-room units per Drawings schedule. Available styles shall include:
  - a. Concealed (ducted) units:
    - 1) Horizontal/Vertical air handling unit for closet or above-ceiling installation.
    - 2) Ceiling concealed.
    - 3) Ceiling concealed, with high-static option.
3. Factory assembled and tested with factory wiring, piping, expansion valve, control circuit board, and fan motor. Units shall have, as a minimum, the following functions:
  - a. Self-diagnostic function.
  - b. Auto restart function.
  - c. Auto changeover function.
  - d. Emergency operation function.
  - e. 3-minute time delay shall provide minimum 3 minute run time for cooling and heating.
4. Indoor unit and refrigerant pipes shall be charged with dehydrated air prior to shipment from the factory.
5. The indoor units shall be equipped with a return air thermistor.

### B. Unit Cabinet:

1. The cabinet shall be insulated with foamed polystyrene and polyethylene insulation.

### C. Fan:

1. The fan shall be direct-drive type, statically and dynamically balanced impeller with multiple high and low fan speeds. Auto fan setting shall automatically adjust fan speed.
2. The fan motor shall be thermally protected.
3. The fan motor shall be equipped as standard with adjustable external static pressure (ESP) settings.
4. For single-phase fan motors sized larger than 1/12 hp and smaller than 1 hp, refer to Article, Electric Motors, in Section 23 05 13, "Common Motor Requirements for HVAC Equipment."

5. All units shall be provided with a condensate drain pan below the coil. Drain pans shall have primary and overflow drains.
- D. Coil:
1. Coils shall be aluminum fins bonded to internally grooved copper tubes. Fins shall have corrosion-resistant coating.
  2. The coils shall be pressure tested at the factory.
  3. Unit shall be provided with ball-type refrigerant service valves at each refrigerant piping connection.
  4. A condensate pan and drain connections shall be provided under the coil. Provide overflow cutoff switch to disable unit during overflow condition.
- E. Filters:
1. Concealed (ducted) units mixing boxes shall include filter rack designed to accommodate disposable filters, as specified in Drawings schedules and in Section 234100, "Particulate Air Filtration."
- F. Controls:
1. Units shall have controls provided by the manufacturer to perform input functions necessary to operate the system.
  2. Operating modes shall include Auto Changeover (heat recovery systems only), Heating, Cooling, Dry, and Fan Only.
  3. Units shall be compatible with a BMS system via optional LonWorks or BACnet gateways.

## **2.04 OUTDOOR CONDENSING UNITS**

- A. General:
1. Condensing unit shall be factory assembled and pre-wired with all necessary electronic and refrigerant controls. The refrigeration circuit of the condensing unit shall consist of scroll compressors, motors, fans, condenser coil, electronic expansion valves, solenoid valves (when required by manufacturer), 4-way valve, distribution headers, capillaries, filters, shut off valves, oil separators, service ports and refrigerant accumulator and regulator.
  2. The following safety devices shall be included as part of the condensing unit; high pressure sensor and switch, low pressure sensor, control circuit fuses, over- and under-current protection, phase failure and phase reversal protection, fusible plug or pressure relief valve, and crankcase heater.
  3. The system will automatically restart operation after a power failure without loss of settings.

4. The condensing units shall be modular in design and allow for side-by-side installation with minimum spacing. Provide kit for field piping between connected condensing units. Refer to Drawings schedules and diagrams for connected units.
  5. To ensure the liquid refrigerant does not flash when supplying to indoor units, the circuit shall be provided with a sub-cooling feature.
  6. Oil recovery cycle shall be automatic occurring 2 hours after start of operation, and thereafter every 8 hours of operation. Each system shall maintain continuous heating during oil return operation. Reverse cycle (cooling mode) oil return during heating operation shall not be permitted due to the potential reduction in space temperature.
  7. The condensing unit shall be capable of heating operation at 0°F dry bulb ambient temperature without additional low ambient controls or an auxiliary heat source.
- B. Unit Cabinet:
1. The condensing unit cabinet shall be weatherproof and corrosion resistant. The unit shall be constructed from rust-proofed galvanized steel panels coated with a baked enamel or powder coat finish.
- C. Fan:
1. The condensing unit shall consist of one or more direct-drive, vertical discharge propeller fans with blades constructed of thermoplastic polymer material.
  2. The condensing unit fan motor shall be variable-speed digitally commutating (DC) type. Fan motor dipswitch shall allow increase of external static pressure setting.
  3. The fan motor shall have inherent protection and permanently lubricated bearings and be mounted on vibration isolators.
  4. The fan motor shall be provided with a fan guard to prevent contact with moving parts.
- D. Condenser Coil:
1. Coils shall be aluminum fins bonded to internally grooved copper tubes. Fins shall have corrosion-resistant coating.
  2. The coils shall be pressure tested at the factory.
  3. Unit shall be provided with ball-type refrigerant service valves at each refrigerant piping connection.
  4. Condensing unit cabinet shall be provided with metal coil guard.
- E. Compressor:
1. The scroll compressors shall be variable speed pulse-width inverter (PVM inverter) controlled type, hermetically sealed, which shall vary the compressor speed to follow fluctuations in total cooling and heating load, determined by the suction gas pressure as measured in the condensing unit.

- a. The inverter driven compressor motor in each condensing unit shall be the reluctance DC (digitally commutating) type.
2. Each compressor shall be equipped with a crankcase heater, high pressure safety switch, and internal thermal overload protector.
3. Oil separators shall be provided as part of the compressor module together with an intelligent oil management system.
4. The compressor shall be isolated to avoid the transmission of vibration.
5. In the event of compressor failure the remaining compressors shall continue to operate and provide heating or cooling as required at a proportionally reduced capacity.
6. Multiple compressor operation sequencing: When multiple condenser modules are combined, operation hours of each compressor shall be balanced by means of a duty cycling function, enabling sequential starting of each module at each start/stop cycle, completion of oil return, and completion of defrost, or every 8 hours.
7. Refrigerant shall be R410a.

## **2.05 REFRIGERANT PIPING**

- A. All refrigerant lines shall be individually insulated between the condensing units and indoor units. Refer to Section 23 07 19, HVAC Piping Insulation, for insulation requirements.
- B. For interconnecting piping between outdoor and indoor equipment, refer to Section 232300, "Refrigerant Piping."

## **2.06 SYSTEM CONTROLS**

- A. General: The controls network shall be capable of supporting remote controllers, schedule timers, system controllers, centralized controllers, an integrated web based interface, graphical user workstation, and system integration to a Building Management Systems via BACnet® and/or LonWorks®.
- B. For additional information, Refer Section 23 09 23, Direct Digital Control System for HVAC.
- C. Programmable Local Remote Controller: The programmable local remote controller shall be capable of controlling a minimum of 16 indoor units serving a single zone, and of operation with or without a central controller. Controller shall have the following minimum functions:
  1. On/Off.
  2. Operating mode (cool, heat, auto, dry, and fan, depending on selected system type).
  3. Temperature setting.
  4. Fan speed setting.
  5. Air swing settings.
  6. Room temperature and humidity display.

7. Occupancy sensor capable.
  8. Schedule operations.
  9. Allow/Prohibit local remote control functions.
  10. Unit level error code display.
  11. Test run.
  12. Set temperature range limit.
  13. Override of scheduled functions for indoor unit groups.
  14. Lock out of On/Off, Mode, Set Temp., Hold-button, and Air Direction.
- D. Limited Function Local Remote Controller: The limited function local remote controller shall be capable of controlling a minimum of 16 indoor units serving a single zone. Controller shall have the following minimum functions:
1. On/Off.
  2. Operating mode (cool, heat, auto, dry, and fan, depending on selected system type).
  3. Temperature setting.
  4. Fan speed setting.
  5. Air swing settings.
  6. Allow/Prohibit local remote control functions.
  7. Indoor Unit intake temperature display.
  8. Unit level error code display.
  9. Test run.
  10. Set temperature range limit.
- E. Centralized Controller: The controller shall support system configuration, daily/weekly scheduling, monitoring of operation status, error email notification, online maintenance tool and malfunction monitoring. The controller shall have basic operation controls which can be applied to an individual indoor unit, a group of indoor units, or all indoor units. (cool, heat, auto, dry, and fan)The central controller shall be able to enable or disable operation of local remote controllers via a PC. Controller shall have the following minimum functions:
1. On/Off.
  2. Operating mode (cool, heat, auto, dry, and fan, depending on selected system type).

3. Temperature setting.
  4. Fan speed setting.
  5. Air swing settings.
  6. Room temperature display.
  7. Schedule operations.
  8. Morning warm-up/cool-down.
  9. Night setback setting.
  10. Allow/Prohibit local remote control functions.
  11. Unit level error code display.
  12. External input/output.
  13. PC data back-up.
- F. BACnet® and/or LonWorks® Gateway: Gateway to allow connection to Energy Management Systems shall allow changes to the following, as a minimum:
1. On/Off.
  2. Temperature setting.
  3. Alarm.
  4. Operating mode.
  5. Fan speed setting.
  6. Allow/Prohibit local remote control functions.
  7. High/Low limit setback temperature (heat recovery systems only).
  8. Air direction/swing settings.
- G. Web browser: The controls network shall allow multiple individual users to monitor and control user defined zones via a network PC web browser.

### **PART 3 - EXECUTION**

#### **3.01 INSTALLATION**

- A. The system shall be installed by a factory-trained and certified contractor, in strict conformance with unit manufacturer's instructions.
- B. Install units level and plumb.



- C. Install evaporator-fan components as detailed on Drawings.
- D. Install indoor heat recovery controllers as detailed on Drawings. Install condensate drain pan piping and run to nearest code-compliant receptacle, or as indicated on Drawings.
- E. Install roof-mounted condensing units as detailed on Drawings. Connected condensing units shall allow space for coil cleaning and other required maintenance tasks.
- F. Install seismic restraints as required by applicable codes. Refer to Section 230548, "Vibration and Seismic Controls for HVAC Piping and Equipment," for delegated design requirements for seismic restraints.
- G. Install and connect refrigerant piping as detailed in unit manufacturers' literature. Install piping to allow access to unit. Install ball-type refrigerant service valves in refrigerant piping at downstream connections of indoor heat recovery units. Refer to Section 232300, "Refrigerant Piping."
- H. Insulate all refrigerant piping, including headers, branches, and other components as detailed in unit manufacturers' literature. Refer to Section 230719 "HVAC Piping Insulation."
- I. Install air filters at each indoor unit. Install washable, permanent filters at indoor units designed to accept washable, permanent filters. Refer to Drawings schedule, and Section 234100, "Particulate Air Filtration," for filter requirements for ducted, above-ceiling units incorporating mixing boxes.
- J. Install cooling coil condensate primary drain pan piping, and run to nearest code-compliant receptacle, or as indicated on Drawings. Install secondary drain pan for units installed over permanent and suspended-tile ceilings. Install secondary drain pan piping and terminate 1/2 inch below ceiling, with escutcheon, in a readily visible location or as shown on Drawings.

### **3.02 CONNECTIONS**

- A. Piping installation requirements are specified in other Sections. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Where piping is installed adjacent to unit, allow space for service and maintenance of unit.
- C. Duct Connections: Duct installation requirements are specified in Section 233113 "Metal Ducts." Drawings indicate the general arrangement of ducts. Connect supply and return ducts to split-system air-conditioning units with flexible duct connectors. Flexible duct connectors are specified in Section 233300 "Air Duct Accessories."

### **3.03 FIELD QUALITY CONTROL**

- A. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect, test, and adjust components, assemblies, and equipment installations, including connections.
- B. Perform tests and inspections.
  - 1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect components, assemblies, and equipment installations, including connections, and to assist in testing.
- C. Tests and Inspections:
  - 1. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.

2. Operational Test: After electrical circuitry has been energized, start units to confirm proper motor rotation and unit operation.
  3. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- D. Remove and replace malfunctioning units and retest as specified above.
- E. Prepare test and inspection reports.

#### **3.04 STARTUP SERVICE**

- A. Engage a factory-authorized service representative to perform startup service.
1. Complete installation and startup checks according to manufacturer's written instructions.

#### **3.05 DEMONSTRATION**

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain units. Provide minimum 2 hours training.

END OF SECTION



**SECTION 26 05 00**  
**COMMON WORK RESULTS FOR ELECTRICAL**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances, tools, equipment, facilities, transportation and services necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete, as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to, the following:
  - 1. Examine all other Sections for work related to those other Sections and required to be included as work under this Section.
  - 2. Electrical General Provisions and Requirements for electrical work.
  - 3. Division-1; General Requirements; General Conditions.
- B. Organization of the Specifications into Divisions, Sections and Articles, and arrangement of Drawings shall not control the Contractor in dividing the Contract Work among Sub-Contractors or in establishing the extent of work to be performed by any trade.

**1.02 GENERAL SUMMARY OF ELECTRICAL WORK**

- A. The Specifications and Drawings are intended to cover a complete installation of systems. The omission of expressed reference to any item of labor or material for the proper execution of the work in accordance with present practice of the trade shall not relieve the Contractor from providing such additional labor and materials.
- B. Refer to the Drawings and Shop Drawings of other trades for additional details, which affect the proper installation of this work. Diagrams and symbols showing electrical connections are diagrammatic only. Wiring diagrams do not necessarily show the exact physical arrangement of the equipment.
- C. Before submitting a bid, the Contractor shall become familiar with all features of the Building Drawings and Site Drawings, which may affect the execution of the work. No extra payment will be allowed for failure to obtain this information.
- D. If there are omissions or conflicts between the Drawings and Specifications, clarify these points with the District's Representative before submitting bid and before commencing work.
- E. Provide work and material in conformance with the Manufacturer's published recommendations for respective equipment and systems.

**1.03 LOCATIONS OF EQUIPMENT**

- A. The Drawings indicate diagrammatically the desired locations or arrangements of conduit runs, outlets, equipment, etc., and are to be followed as closely as possible. Proper judgment must be exercised in executing the work so as to secure the best possible installation in the available space and to overcome local difficulties due to space limitations or interference of structure conditions encountered.
- B. Where outlets are placed on a wall, locate symmetrically with respect to each other, furniture, cabinets, and other features or finishes on the wall.

- C. In the event changes in the indicated locations or arrangements are necessary, due to developed conditions in the building construction or rearrangement of furnishings or equipment, such changes shall be made without cost to the Contract, providing the change is ordered before the conduit runs, etc., and work directly connected to same is installed and no extra materials are required.
- D. Lighting fixtures in mechanical spaces are shown in their approximate location only. Do not install light outlets or fixtures until mechanical piping and ductwork is installed; then install lights in a location to provide best lighting.
- E. Coordinate and cooperate in every way with other trades in order to avoid interference and assure a satisfactory job.
- F. The location of the existing utilities, building, equipment and conduit shown on the Drawings is approximate. Verify exact locations and routing of existing systems by potholing all trench routes prior to digging the trench. Pothole at least 100 feet ahead of the actual trenching to allow space to alter the new conduit routing to accommodate existing conditions.
- G. Underground Detection Services Existing Utility Structures
  1. Detection/location services shall be provided utilizing the latest detection equipment available. Services shall be performed by a company regularly engaged in the business of existing Underground Utility Structure Detection for the past 5-years.
  2. Prior to excavation and prior to directional boring the following work shall be performed:
    - a. Contractor to mark excavating and trenching/directional boring locations and indicate width and depth.
    - b. Locate, by way of vertical and horizontal control dimensions, existing subgrade petroleum product pipes, process piping, conduits, sewer, water, gas, storm drain, electrical, telephone, and irrigation lines in the affected areas of Contract Construction Work.
    - c. Arrange and meet with the District's Representative to review existing underground conditions.
    - d. The proposed route of each excavation shall be continuously surveyed along the entire excavation path using Ground-Penetrating Radar (GPR) operating from the surface grade. The GPR shall detect and map existing underground metal and non-metal, both private and public utility lines, pipes, conduits, conductors, etc. The GPR shall identify the horizontal and vertical location of existing underground conditions located at a depth of up to 3-meters below finish grade and located with a vertical and horizontal accuracy within  $\pm 12$ -inches of actual condition. The Contractor shall add this information to the existing Conditions Site Plan.
  3. Exercise extreme caution in directional boring, excavating and trenching on this site to avoid existing underground utilities and structures, and to prevent hazard to personnel and/or damage to existing underground utilities or structures. The Contract Documents, Drawings and Specifications do not include necessary components for construction safety, which is the responsibility of the Contractor.
  4. Repair/replace, without additional cost to the Contract, and to the satisfaction of the District any existing work damaged that was identified in the Record Drawings provided; Identified by the District's Representative; Identified by the Underground Detection

Services performed; or any existing work damaged as a result of failure to comply with all the Referenced Requirements.

5. The Contractor shall contact Common Ground Alliance (CGA) telephone #811 "Know What's Below-Call Before You Dig" and Underground Service Alert (USA), not less than 72-hours prior to excavation. Contractor shall not excavate until verification has been received from CGA and USA that existing underground utilities serving the site have been located, identified, and marked.
- H. The locations of existing underground utilities, where shown on Drawings, are shown diagrammatically and have not been independently verified by the District, the District's Representative, the Architect/Engineer. The District, the District's Representative, and the District's Architect/Engineer are not responsible for the location of underground utilities or structures, whether or not shown or detailed and installed under this or any other Contracts. The Contractor shall identify each existing utility line prior to excavation and mark the locations on the ground of each existing utility line.

#### **1.04 AIR CONDITIONING, HEATING, PLUMBING EQUIPMENT WIRING**

Provide electrical work, materials, and control components required for proper operation of the air conditioning, heating and plumbing systems as indicated on the Electrical, Mechanical, and Plumbing Contract Documents and specified herein.

#### **1.05 PERMITS**

Take out and pay for all Required Permits, Inspections and Examinations without additional cost to the District.

#### **1.06 QUALITY ASSURANCE**

- A. Work and Materials shall be in full accordance with the latest Rules and Regulations as follows. The following publications shall be included in the Contract Documents Requirements. If a conflict occurs between the following publications and any other part of the Contract Documents, the Requirements describing the more restrictive provisions shall become the applicable Contract definition:
  1. California Code of Regulations Title 24.
  2. California Part 3 "California Electrical Code" CEC, Title 24 and Title 8 "Division of Industrial Safety".
  3. California Building Code – CBC.
  4. California Fire Code – CFC
  5. The National Electrical Code – NEC/NFPA 70.
  6. International Building Code – IBC.
  7. National Fire Protection Agency – NFPA.
  8. National Fire Alarm Code – NFAC/NFPA 72.
  9. Underwriter's Laboratory – UL.
  10. Other applicable State and Local Government Agencies Laws and Regulations.

11. Electrical Installation Standards National Electrical Contractors Association (NECA) and National Electrical Installation Standards (NEIS):
  - a. NECA/NEIS-1: Standard of Practices for Good Workmanship in Electrical Contracting
  - b. NECA/NEIS-101: Standard for Installing Steel Conduit (Rigid, IMC, etc.)
  - c. NECA/NEIS-104: Recommended Practice for Installing Aluminum Building Wire and Cable
  - d. NECA/NEIS-105: Recommended Practice Installing Metal Cable Trays
  - e. NECA/NEIS-111: Standard for Installing Nonmetallic Raceways (RNC, ENT, LFNC) (ANSI)
  - f. NECA/NEIS-230: Recommended Practice for Installing Motors
  - g. NECA/FOA-301: Standards for Installing and Testing Fiber Optic Cables
  - h. NECA/NEIS-305: Standard for Fire Alarm System Job Practice
  - i. NECA/NEIS-331: Standard for Installing Building and Service Entrance Grounding and Bonding.
  - j. NECA/NEIS-400: Standard for Installing and Maintaining Switchboards
  - k. NECA/NEIS-402: Recommended Practice for Installing and Maintaining Motor Control Centers
  - l. NEIS/NECA and EGSA-404: Recommended Practice for installing Generator Sets
  - m. NECA/NEIS-405: Recommended Practices for installing and Commissioning Interconnected Generation Systems
  - n. NECA/NEIS-407: Recommended Practice for Installing Panelboards
  - o. NECA/NEIS-408: Standards for Installing and Maintaining Busways (ANSI)
  - p. NECA/NEIS-409: Recommended Practice for Installing and Maintaining Dry-Type Transformers
  - q. NEIS/NECA and IESNA-500: Recommended Practice for installing indoor Commercial Lighting Systems
  - r. NEIS/NECA and IESNA-501: Recommended Practice for Installing Exterior Lighting Systems
  - s. NEIS and IESNA-502: Recommended Practice for Installing Industrial Lighting Systems
  - t. NECA/BICSI-568: Standards for Installing Commercial Building Telecommunications System
  - u. NECA/NEIS-600: Recommended Practice Installing Medium-Voltage Cable
- B. All Material and Equipment shall be new and shall be delivered to the site in unbroken packages. All material and equipment shall be listed and labeled by Underwriters Laboratories or other recognized Testing Laboratories, where such listings are available. Comply with all Installation Requirements and restrictions pertaining to such listings.
- C. Work and Material shown on the Drawings and in the Specifications are new and included in the Contract unless specifically indicated as existing or N.I.C. (not in Contract).
- D. Keep a copy of all applicable Codes and Standards available at the job site at all times for reference while performing work under this Contract. Nothing in Plans or Specifications shall be construed to permit work not conforming to the most stringent of Building Codes.

- E. Where a conflict or variation occurs between applicable Codes, Standards and/or the Contract Documents, the provisions of the most restrictive provision shall become the Requirement of the Contract Documents.

### **1.07 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

#### **A. General**

1. Review of Contractor's submittals is for General Conformance with the design concept of the Project and General Compliance with the information given in the Contract Documents. Any action shown is subject to the Requirements of the Plans and Specifications. Contractor is responsible for quantities; dimensions which shall be confirmed and correlated at the job site; fabrication processes and techniques of construction; coordination of work with that of all other trades and satisfactory performance of their work.
2. The Contractor shall review each submittal in detail for compliance with the Requirements of the Contract Documents prior to submittal. The Contractor shall "Ink Stamp" and sign each item of the submittal with a statement "CERTIFYING THE SUBMITTAL HAS BEEN REVIEWED BY THE CONTRACTOR AND COMPLIES WITH ALL THE REQUIREMENTS OF THE CONTRACT DOCUMENTS". The Contractor shall clearly and specifically identify each individual proposed substitution, substitution of equal or proposed deviation from the Requirements of the Contract Documents with a statement "THIS ITEM IS A SUBSTITUTION".  

The burden of research, preparation of calculations and the furnishing of adequate and complete Shop Drawings information to demonstrate the suitability of Contractor's proposed substitutions and suitability of proposed deviations from the Contract Documents is the responsibility of the Contractor.
3. Departure from the submittal procedure will result in resubmittals and delays. Failure of the Contractor to comply with the Submittal Requirements shall render void any acceptance or any approval of the proposed variation. The Contractor shall then be required to provide the equipment or method without variation from the Contract Documents and without additional cost to the Contract.
4. The Contractor at no additional cost or delays to the Contract shall remove any work, material and correct any deficiencies resulting from deviations from the Requirements of the Contract Documents not approved in advance by the District prior to commencement of work.
5. Shop Drawings submitted by the Contractor, which are not specifically required for submittal by the Contract Documents, or Contractor Shop Drawings previously reviewed and resubmitted without a written resubmittal request to the Contractor, will not be reviewed, considered, or commented on. The respective Shop Drawing submittal /resubmittal will not be returned to the Contractor and will be destroyed without comment or response to the Contractor. The respective submittal shall be considered null and void as being not in compliance with the Requirements of the Contract Documents.
6. Refer to Division-1 for Additional Requirements.



## B. Material Lists and Shop Drawings

1. Submit material list and Equipment Manufacturers for review within 35 days of award of Contract. Give name of Manufacturer and where applicable, brand name, type and/or catalog number of each item. Listing of more than one Manufacturer for any one item of equipment, or listing items "as specified", without both make and model or type designation, is not acceptable. Shop Drawings shall not be submitted before review completion of Manufacturers list. The right is reserved to require submission of samples of any material whether or not particularly mentioned herein.
2. After completion of review of the Material and Equipment Manufacturers list, submit Shop Drawings for review. Shop Drawings shall be submitted in completed bound groups of materials (i.e., all lighting fixtures or all switchgear, etc.). The Contractor shall verify dimensions of equipment and be satisfied as to fit and that they comply with all Code Requirements relating to clear working space about electrical equipment prior to submitting Shop Drawings for review. Submittals, which are intended to be reviewed as substitution or departure from the Contract Documents, must be specifically noted as such. The Requirements of the Contract Documents shall prevail regardless of the acceptance of the submittal.
3. Shop Drawings shall include catalog data sheets, instruction manuals, Dimensioned Plans, elevations, details, wiring diagrams, and descriptive literature of component parts where applicable. Structural calculations and mounting details, signed by a Structural Engineer registered by the State of California, shall be submitted for all equipment weighing over 400-pounds, and shall be in compliance with Title 21 of the California Code of Regulations.
4. Each Shop Drawing item shall be identified with the Specification Section and paragraph numbers, lighting fixture types and Drawing sheet numbers; the specific Shop Drawing is intended to represent. Shop Drawings 11-inches by 17-inches or smaller in size shall be bound in three ring binders. Divider tabs shall be provided in the three ring binders identifying and separating each separate Shop Drawing submittal item. Shop Drawings larger than 11-inches by 17-inches, Shop Drawing pages/sheets submittals shall be sequentially numbered with unique alphanumeric numbering system to facilitate correspondence referencing identification of individual sheets.
5. The time required to review and comment on the Contractor's submittals will not be less than 14 calendar days, after receipt of the submittals at the office of FBA Engineering. The review of Contractor submittals and return to Contractor of submittals with review comments will occur in a timely manner conditioned upon the Contractor complying with all of the following:
  - a. The submittals contain complete and accurate information, complying with the Requirements of the Contract Documents.
  - b. Contractor's submittals are each marked with Contractor's approval "stamp", and with Contractor signatures.
  - c. The submittals are received in accordance with a written, Shop Drawing submittal schedule for each submittal. The Contractor distributes the schedule not less than 35-calendar days in advance of the Shop Drawing submittals, and the schedule identifies the calendar dates, the Contractor will deliver the various submittals for review.

6. Shop Drawings shall include the Manufacturers projected days for shipment from the factory of completed equipment, after the Contractor releases the equipment for production. It shall be the responsibility of the Contractor to insure that all material and equipment is ordered in time to provide an orderly progression of the work. The Contractor shall notify the District's Representative of any changes in delivery, which would affect the Project completion date.
7. Submittal Identification
  - a. Each submittal shall be dated: with submittal transmission date; sequentially numbered and titled with submittal contents identification and applicable Specification/Drawing references (*i.e., Submittal dated: 5/12/98 Submittal #4 Contents: Branch circuit panelboards Sheet #E5.1 and Transformers Specification Section 260501 Paragraph 2.11, etc.*).
  - b. Each resubmittal shall be dated: with original submittal date and resubmittal transmission dates; sequentially numbered with original submittal number and sequential resubmittal revision number and titled with submittal contents identification and applicable Specifications/Drawing references (*i.e., Original Submittal Date: 5/12/98 Resubmittal Date: 10/9/98 Original Submittal #4 Resubmittal Revision R2 Contents: Transformer Resubmittal Specification Section – 260501 Paragraph 2.11, etc.*).
  - c. Contractor shall provide a written response narrative with each resubmittal. Describe each response-action, resubmittal addition, change and deletion. Correspond to each response to A/E specific review comment.
- C. The Contractor shall be responsible for incidental, direct and indirect costs resulting from the Contractor's substitution of; or changes to; the specified Contract Materials and Work.
- D. The Contractor shall pay, upon request by the District's Representative, a fee for the District's Representative time involved in the review of substitution submittals and design changes resulting from the Contractor's requested substitutions. The fee shall be not less than \$125.00 per hour but, in no case, less than stated in Division-1, whichever is greater.
- E. Maintenance and Operating Manuals
  1. The Contractor shall furnish three copies of type-written Maintenance and Operating Manuals for all electrical equipment, fire alarm equipment, sound system equipment, etc., to the District.
  2. Instruct the District's Personnel in correct operation of all equipment at completion of Project. Provide the quantity and duration of instruction class as specified; but in no case less than two 4-hour durations separate instruction classes for each individual equipment group furnished as part of the Contract. Instruction classes shall be presented by Manufacturer's Authorized Field Service Engineer at the Project Site. Instruction class size shall be at the District's discretion, not less than one or more than fifteen students shall attend each instruction session. Submit fifteen written outline copies of the proposed instruction class curriculum, 14-days prior to the class-scheduled dates.
  3. Maintenance and Operating Manuals shall be bound in three ring, hard-cover, plastic binders with table of contents. Manuals shall be delivered to the District's Representative, with an itemized receipt.

- F. Portable or Detachable Parts: The Contractor shall retain in his possession, and shall be responsible for all portable and detachable parts or portions of the installation such as fuses, keys, locks, adapters, locking clips, and inserts until final completion of Contract Work. These parts shall then be delivered to the District's Representative with an itemized receipt.
- G. Record Drawings (Additional Requirements)
  - 1. Provide and maintain in good order a complete set of Electrical Contract "Record" prints. Changes to the Contract to be clearly recorded on this set of prints. At the end of the Project, transfer all changes to one set of transparencies to be delivered unfolded to the District's Representative.
  - 2. The actual location and elevation of all buried lines, boxes, monuments, vaults, stub-outs and other provisions for future connections shall be referenced to the building lines or other clearly established base lines and to approved bench marks. If any necessary dimensions are omitted from the Record Drawings, the Contractor shall, at the Contractor's own expense, do all excavation required to expose the buried work and to establish the correct locations.
  - 3. The Contractor shall keep the "Record" prints up to date and current with all work performed.
  - 4. Refer to Division-1 for Additional Requirements.

#### **1.08 CLEANING EQUIPMENT, MATERIALS, PREMISES**

All parts of the equipment shall be thoroughly cleaned of dirt, rust, cement, plaster, etc., and all cracks and corners scraped out clean. Surfaces to be painted shall be carefully cleaned of grease and oil spots and left smooth, clean and in proper condition to receive paint finish.

#### **1.09 JOB CONDITIONS - PROTECTION**

Protect all work, materials and equipment from damage from any cause whatever and provide adequate and proper storage facilities during the progress of the work. Provide for the safety and good condition of all the work until final acceptance of the work by the District and replace all damaged or defective work, materials, and equipment before requesting final acceptance.

#### **1.10 EXCAVATION, CUTTING, BACKFILL AND PATCHING ADDITIONAL REQUIREMENTS**

- A. General
  - 1. Perform excavation, cutting, backfill, core drilling, directional boring, and patching of the construction work required for the proper installation of the electrical work.
  - 2. Patching shall be of the same material, thickness, workmanship, and finish as existing and accurately match-surrounding work to the satisfaction of the District's Representative.
  - 3. Prior to penetrating, coring, drilling or cutting existing building elements, concrete and/or masonry, provide imaging equipment examinations of each specific location. The imaging process shall identify existing internal embedded components and locations, including structural elements/anchors, conduit, and piping that are present. Do not penetrate or damage the existing internal embedded elements.

Imaging shall employ one of the following, with GPR methodology preferred:

- a. Non-invasive imaging employing high frequency, Ground Penetrating Radar (GPR), single side echo reflection technology.
- b. Non-invasive imaging employing x-ray radiography, through-and-through imaging technology.

**B. Excavation Temporary Cover**

1. Excavations for Contract Work occurring in streets, vehicular drive areas, parking lots, sidewalks; any paved surface; or any area accessible to the public; provide temporary steel plating and shoring support for the plates, to completely cover the excavations under one or more of the following conditions:
  - a. Excavation shall not remain "open" for more than 4-calendar days; provide temporary plating.
  - b. Excavation shall not be "open" over weekends (Saturday, Sunday) or Holidays; provide temporary plating.
2. The temporary plating shall be a minimum of 0.75-inch thickness steel, but in no case shall the thickness be less than required to support AASHO-H20 traffic loading.
3. Provide a minimum of two 100% open lane(s) (12-foot lane width) for vehicular traffic at all times during construction, for vehicle access to all areas.

**1.11 IDENTIFICATION**

**A. Equipment Nameplates**

1. Panelboards, terminal cabinets, circuit breakers, disconnect switches, starters, relays, time switches, contactors, push-button control stations, and other apparatus used for the operation or control of feeders, circuits, appliances, or equipment shall be properly identified by means of descriptive nameplates or tags permanently attached to the apparatus and wiring.
2. Provide nameplate label on electrical service entrance equipment describing available short circuit information calculated by the Contractor, including:
  - a. Calculation date, month-day-year.
  - b. Calculate maximum available short circuit fault current.
  - c. Description of parameters and changes affecting the Requirements for recalculation of the fault current information.
3. Electrical equipment including switchgear, switchboards, electric panels and control panels, motor control centers, combination motor starters, transformers, disconnects, etc., shall each be labeled by the Manufacturer with "Electric-Arc-Flash" warning signs. The signs shall explain a hazard to Personnel may exist if the equipment is worked on while energized or operated by personnel while energized. The sign shall instruct personnel to wear the correct Protective Equipment/clothing (PPE) when working "Live", or operating "Live" electrical equipment and circuits.
4. Nameplates shall be engraved laminated phenolic. Shop Drawings with dimensions and format shall be submitted before installation. Attachment to equipment shall be with escutcheon pins, rivets, self-tapping screws or machine screws. Self-adhering or adhesive backed nameplates shall not be used.

5. Provide black-on-white laminated plastic nameplates engraved in minimum ¼-inch high letters to correspond with the designations on the Drawings. Provide other or additional information on nameplates where indicated.
- B. Plates: All cover and device plates shall be furnished with engraved or etched designations under any one of the following conditions (minimum character size not less than 0.188 inch. Engraving shall indicate circuits and equipment controlled or connected):
1. More than two devices under a common coverplate.
  2. Lock switches.
  3. Pilot switches.
  4. Switches in locations from which the equipment or circuits controlled cannot be readily seen.
  5. Manual motor starting switches.
  6. Where so indicated on the Drawings.
  7. As required on all control circuit switches, such as heater controls, motor controls, etc.
  8. Receptacles other than standard 15 amp 120 volt duplex receptacles; shall indicate circuit voltage, ampere, phase and source circuit number.
  9. Where outlets or switches are connected to emergency power circuit; provide panelboard and circuit number engraved on plate.
  10. Low voltage and signal system outlets.
- C. For equipment and access doors or gates to equipment containing or operating on circuits of more than 100 volts AC or DC nominal. Provide red-on-white laminated warning signs engraved in ½-inch high letters to read: "DANGER - 480 (*or applicable voltage*) VOLTS KEEP OUT AUTHORIZED PERSONNEL ONLY".
- D. Wire and Cable Identification
1. Provide identification on individual wire and cable including signal systems, fire alarm, electrical power systems (each individual phase, neutral and ground), empty conduit pull ropes, and controls circuit.
  2. Permanent identification shall be provided at each termination location, splice location, pullbox, junction box and equipment enclosure.
    - a. Individual wire and cable larger than #6AWG or 0.25-inch diameter, shall be provided with polypropylene identification tag holders, with yellow polypropylene tags interchangeable black alphanumeric characters, character height 0.25 inch. Attach identification tags with plastic "tie" wraps, minimum of two for each tag. As manufactured by Almetek Industries-"EZTAG" Series; or TECH Products - "EVERLAST" Series.
    - b. Individual wire and cable #6AWG and smaller or smaller than 0.25 inch diameter, shall be provided with water and oil resistant, flexible, self-laminating pressure sensitive machine embossed plastic tags that wrap a minimum of 360 degrees around the wire/cable diameter. The entire tag shall then be covered with a clear flexible waterproof plastic cover wrapped a minimum of 540 degrees around the wire/cable diameter and completely covering the identification. As manufactured by Brady Identification; or 3M; or Panduit.

- c. Each identification tag location shall indicate the following information: circuit number, circuit phase, source termination and destination termination equipment name (or outlet number as applicable).
- 3. Install permanent identification after installation/pulling of wire/cable is complete, to prevent loss or damage to the identification.
- E. Cardholders and cards shall be provided for circuit identification in panelboards. Cardholders shall consist of a metal frame retaining a clear plastic cover permanently attached to the inside of panel door. List of circuits shall be typewritten on card. Circuit description shall include name or number of circuit, area, and connected load.
- F. Junction and pull boxes shall have covers stenciled with box number when shown on the Drawings, or circuit numbers according to panel schedule. Data shall be lettered in a conspicuous manner with a color contrasting to finish.

### **1.12 TESTING**

- A. The Contractor shall obtain an independent Testing Laboratory, provide all instrumentation and perform tests on the electrical system and equipment as hereinafter described and further directed by the District's Representative. The test shall be performed after the completion of all electrical systems included in the Contract Scope of Work. All tests shall be recorded and documented and submitted to the District's Representative for review.
  - 1. All Equipment and Personnel required for set-up and testing shall be provided by the Contractor.
- B. Test for Phase to Ground and Neutral Condition:
  - 1. Open main service disconnects.
  - 2. Isolate the system neutral from ground by removing the neutral disconnects link located in the service switchboard.
  - 3. Close all submain disconnects.
  - 4. Close all branch feeder circuit breakers.
  - 5. Turn all switches to "on" position, unplug all portable equipment from outlet receptacles.
  - 6. Measure the resistance of each phase to ground and phase to neutral. A properly calibrated "megger" type test instrument shall be used. The test voltage shall be a nominal 500 volts.
  - 7. Record all readings after 1-minute duration and document into a complete report.
  - 8. Isolating Grounds: In the event that low resistance ground neutral connections are found in the system, they shall be isolated and located by testing each circuit individually as outlined above. Make proper corrections to restore the resistance values to an acceptable value.
- C. Method of obtaining ground resistance shall be in accordance with the latest edition of the James G. Biddle (Plymouth Meeting, Pennsylvania) manual published on this subject.
  - 1. Perform "fall-of-potential" three point tests on the main grounding electrode of system per IEEE Standard No. 81, Section 8.2.1.5. when suitable locations for test rods are not available, a low resistance dead earth or reference ground shall be utilized.

2. Perform the two point method test per IEEE Standard No. 81, Section 8.2.1.1, to determine the ground resistance between the main grounding system and all major electrical equipment frames, system neutral, and/or derived neutral points.
- D. The testing, calibrating and setting of all ground and ground fault equipment, circuit breakers, circuit device protection relays, and meters adjustable settings shall be by an independent Testing Laboratory. Set as recommended by the respective Manufacturer and Coordination Study so as to be coordinated with other protection devices within the electrical design. Bound and tabulated copies of the test and settings shall be sent to the District's Representative.
- E. Ampere and Voltage Measurements
1. Measure and record ampere and line voltage measurements under full load on all panel feeders, switchboard, and switchgear feeders, motor control centers and motor circuits provided in the Contract. Record measurements at the equipment tested and submit to the District's Representative for review.
  2. Ampere voltage readings shall be:
    - a. Phase A-B, A-C and B-C.
    - b. Phase A-Neutral, B-Neutral and C-Neutral.
  3. The ampere and voltage readings shall be not less than 20-minutes duration for each test. Record and submit the measured minimum, maximum and 20-minute average for each ampere and voltage value and test location. Voltage and ampere measurements shall occur at the connected load end of each respective feeder, not at the source of supply end of each feeder.
  4. Test equipment shall be accurate within plus or minus 1%.
  5. Branch circuit devices 40 amp or less and motor loads ten horsepower or smaller are excluded from Ampere and Voltage Testing Requirement.
  6. If, in the opinion of the District's Representative, the Voltages and Regulations are not met within acceptable limits, make arrangements with the serving utility for proper electrical service. Retest feeder line voltages, and submit to District's Representative for review, after the Utility Company has completed corrective actions. Reset "voltage taps" on transformers provided or modified as part of the Contract Work, to adjust line voltages to within acceptable values, as directed by the District's Representative.
- F. The Contractor shall complete the following work before any electrical equipment is energized.
1. All equipment shall be permanently anchored.
  2. All bus connections and conductor/wire connections shall be tightened per Manufacturer's instructions and witnessed by the District's Representative.
  3. All ground connections shall be completed and identified. Perform and successfully complete all required megger and ground resistance tests.
  4. Feeders shall be connected and identified.
  5. The interiors of all electrical enclosures including busbars and wiring terminals shall be cleaned of all loose material and debris, paint, plaster, cleaners or other abrasive's over spray removed and equipment vacuumed clean. The District's Representative shall observe all interiors before covers are installed.

6. All wall, ceiling, and floor work and painting shall be completed within areas containing electrical equipment prior to installation of equipment. The equipment indoor rooms and spaces shall be weather-tight and weather protected from environmental incursions.
7. All doors to electrical equipment rooms shall be provided with locks in order to restrict access to energized equipment.
8. Electrical spaces and rooms shall not be used as storage rooms after power is energized.
9. Outdoor electrical equipment enclosures and housings shall be weather protected.
10. The electrical system time current coordination and Arc-Fault study shall be complete for circuit breakers, ground relays sets, and circuit relay sets, fuses; set-up, tested and calibrated accordingly.

### **1.13 COMMISSIONING - CX**

#### **A. General**

1. The Commissioning shall verify the electrical systems for the term of the Contract, by observation; and by calibration; and by testing. The Commissioning shall ensure the electrical systems perform interactively and correctly, according to the Contract and Operational Requirements.
2. Commissioning shall provide startup, testing and documented confirmation of the Contract Constructed Systems, materials and work, functions in compliance within the criteria set forth in the Contract Documents to the satisfaction of the District's needs. The Commissioning Scope shall encompass each system identified as requiring "Commissioning" by the Contract Documents, including but not limited to:
  - a. Electrical circuits' protection, short circuit, overcurrent, and ground fault devices.
  - b. Electrical circuits monitoring and metering.
  - c. Light fixtures, lamps and ballasts.
  - d. Lighting control devices, equipment and lighting control systems.
  - e. Standby and emergency electric power supply equipment and systems.
  - f. Fire alarm, equipment, devices and fire alarm systems.
  - g. Additional systems described in the Contract Documents.
3. Commissioning process shall review all of the Shop Drawing submittals, including:
  - a. Controls, Operation and Maintenance Requirements.
  - b. Facility performance testing compliance.
  - c. Project Contract Requirements compliance.
  - d. Compliance with basis for design and operational descriptions provided in the Contract.
4. Commissioning shall be the process of ensuring all the systems described in the Contract Documents comply with the Contract Document design; all systems are installed properly; all systems are functional, tested and capable of being operated and maintained to perform within the Contract Requirements and design intent.
5. Functional setup, recalibration, correcting deficiencies, retesting and the associated costs, for system(s) that fail Commissioning, shall be the responsibility of the Contractor. The Contractor shall include all Commissioning costs in the Contract Scope of Work.



6. Complete all Commissioning functions prior to the occupancy of the facility by the District, unless directed otherwise by the District's Representative.
7. Submit six copies of Commissioning Documentation to District's Representative.
8. Commissioning unless specifically indicated otherwise, shall be performed by Factory-Trained Technician(s) Authorized and Certified by the Manufacturers of the respective equipment/systems. Where specifically indicated, Commissioning shall be performed by Independent Test Lab.

B. Commissioning Procedures

1. Prepare a Commissioning Matrix identifying components and systems included in the Commissioning Scope; the status; actions completed and actions to be completed.
2. Verify Contractor compliance with Contract Document Requirements Manufacturer's recommendations and approved Shop Drawings.
3. Perform startup, functional tests, reports, and document results.
4. Evaluate and document the setup parameters, software, operating condition and performance of each system at the time of functional test completion. Document and record each performance parameter and condition, in the Commissioning Report.
5. Schedule testing and prepare descriptions of testing.
6. Describe measures performed to correct deficiencies.
7. Verify that instructions to District's Representatives, Operations and Maintenance Manuals comply with Contract Documents.
8. Prepare warranty matrix identifying the start dates, expiration dates, routine preventative maintenance dates and the District's responsibility for performing preventative maintenance and keeping logs for each maintenance function and warranty claims.
9. Confirm completion of all punch list items that have been acceptably accomplished and a list of what has not been acceptably completed.
10. Describe uncorrected deficiencies accepted by the District.

C. Commissioning Phasing

The Commissioning Phases of work shall include the following activities:

1. SDQ – Shop Drawing Qualification shall verify complete and correct Shop Drawings have been submitted.
2. IQ – The Installation Qualification of Contract Work shall verify systems are correctly and properly installed.
3. OQ – Verify systems interfaces and software are correctly and properly operational.
4. ITM – Verify the Contract Inspection, Testing and Procedures for Maintenance are complete.
5. PQ – Performance Qualification complete the functional performance testing to validate each building system.

#### **1.14 POWER OUTAGES**

- A. All electrical services in all occupied facilities of the Contract Work are to remain operational during the entire Contract period. Any interruption of the electrical services for the performance of this work shall be at the convenience of the District and performed only after consultation with the District's Representative. Work involving circuit outages shall be only at such a time and of such a duration as approved in writing. Work involving circuit outages for the work required to connect new equipment and disconnect existing equipment shall be performed at the convenience of the District.
- B. Contract Work involving outages or disruption of normal function in electrical power systems, telephone/communication systems, fire alarms, shall be performed during the following time periods. The Contract Work shall be phased to limit outages in the respective systems to the stated periods:
  - 1. 11:30 p.m. Friday to 11:30 p.m. Sunday of the same weekend. Work shall occur on multiple weekend periods if a single weekend is not sufficient time to complete the work.
  - 2. The Contract Work involving outages shall be phased in multiple work time units, to comply with the permitted outage limitations.
- C. Work involving system outages to the building fire alarm system shall be performed only after consultation with the District and shall be only at such a time and of such duration as approved in writing. Contractor shall provide continuous "Fire-Watch" during fire alarm system outages and comply with AHJ "Fire-Watch" Requirements.
- D. Provide overtime work; double shift work; night time work; Saturday, Sunday, and holiday work to meet outages schedule.
- E. Provide temporary electrical power to meet the Requirements of this Article.
- F. Any added costs to Contractor due to necessity of complying with this Article shall be included in the Contract Scope of Work.
- G. When electrical work involving power disruptions to existing areas is initiated, the work shall proceed on a continuous basis without stopping until electric power is restored to the affected areas.
- H. The Contractor shall request in writing to the District's Representative a minimum of 3-weeks in advance, for any proposed electrical outage.

#### **1.15 TEMPORARY ELECTRICAL POWER**

- A. Provide temporary electrical power if work requiring power outages cannot be completed in time permitted and approved by the District's Representative.
- B. Temporary electrical power shall be a standby diesel engine generators. Voltage, frequency, regulation, etc. shall be equal to that of normal utility source. Exhaust system shall have a critical silencing muffler. Generator voltage shall match the existing secondary voltage required at the site. The Contractor shall furnish all necessary cables, switches, etc., to make all required connections to existing panels, feeders, etc. Generator shall be sized to adequately carry the demand load. If record of demand load is not available, size generator to match corresponding transformer, maximum capacity circuit as directed by the District's Representative.

- C. After completion of required usage of the temporary generators, prior to completion of the Project, the Contractor shall remove the generators. All temporary cables, switches, etc. shall be removed and all permanent equipment left in satisfactory condition.
- D. Each generator shall be housed in security type sound attenuated housing to prevent access by unauthorized Personnel. Temporary power cables, connections, etc. shall be protected from unauthorized Personnel.
- E. The Contractor shall be responsible for complete operation of the generator including Personnel, fuel supplies, proper safety precautions, etc. Generator shall not be left unattended while in operation.
- F. The Contractor shall provide temporary construction lighting and power as required in areas where work is being performed. Temporary power arrangements, outages, installation, work schedules, etc., shall be submitted in writing 3-weeks prior to requested outage date, and approved by the District's Representative prior to start of work.

#### **1.16 ASBESTOS, POLYCHLORINATED BIPHENYL (PCB) OR HAZARDOUS WASTE:**

- A. It is understood and agreed that this Contract does not contemplate the handling of asbestos, PCB or any hazardous waste material. If asbestos, PCB or any hazardous waste material is encountered, notify the District's Representative immediately. Do not disturb, handle or attempt to remove.
- B. Lighting Fixture Demolition Hazardous Materials
  - 1. The removal of existing lighting fixtures will generate Hazardous Material Waste Disposal Contract Documents.
    - a. The existing lighting fixture ballast contains PCB material.
    - b. The existing lighting fixture lamps contain mercury.
    - c. The existing lighting fixture internal wire insulation may contain asbestos.
  - 2. Remove, handle, store, contain, dispose of and document the hazardous materials resulting from existing lighting fixtures work, as part of the Contract Requirements.

#### **1.17 TIME/CURRENT COORDINATION, SHORT CIRCUIT, ARC-FLASH AND SERIES RATED EQUIPMENT**

- A. Series Rated Equipment.
  - 1. Circuit protective Devices identified as "Series Rated" or "Current Limiting" (i.e., CLCB - Current Limiting Circuit Breaker; CLF - Current Limiting Fuse, etc.) shall be Series Rated and Tested (UL 489 and CSA5) by the Manufacturer with all equipment and circuit protective devices installed down-stream of the identified series rated or current limiting device.
  - 2. Provide nameplates on all equipment located downstream, including the CLCB and CLF devices, to comply with CEC/NEC paragraphs 110-22 and 240-83 "CAUTION SERIES RATED SYSTEM - NEW DEVICE INSTALLATIONS AND REPLACEMENTS SHALL BE THE SAME MANUFACTURER AND MODELS".
- B. Short Circuit, Coordination and Arc-Flash
  - 1. Perform Engineering Analysis and submit engineered settings for each equipment location, fuse and circuit breaker device, showing the correct time and current settings to provide the selective coordination within the limits of the specified equipment. Shall comply with the latest application Standards of IEEE and ANSI. Provide electrical system

short circuit worst case bolted-fault analysis, both 3-phase line-to-line and 1-phase line-to-ground calculations as part of the Coordination Analysis recommendations. Provide Electric Arc-Flash calculations as part of the Coordination Analysis recommendations.

2. The information shall be submitted in both tabular form and on time current log-log graph paper, with an Engineering Narrative. Written narrative describing data, assumptions, analysis of results and prioritized recommendations, six copies.
3. The goal is to minimize an unexpected but necessary electrical system outage and Personnel exposure to the smallest extent possible within the fault occurrence location, using the specified Contract Equipment. Shall comply with, but not limited to:
  - a. IEEE-242, Recommended Practices for Protection and Coordination of Industrial and Commercial Distribution.
  - b. IEEE-399, Recommended Practices for Industrial and Commercial Power System Analysis.
  - c. IEEE-1584, Guide for Performing Arc-Flash Hazard Calculations.
  - d. CEC/NEC
4. Provide permanent warning labels on each equipment location. The labels shall describe Arc-Flash, Short-Circuit and Time/Current Coordination, including safety precautions and protective clothing. Also described actions to be taken if any circuit changes or equipment modifications occur.
5. Shall be submitted with the Shop Drawing submittals for the respective equipment.

#### **1.18 INDEPENDENT TESTING LABORATORY**

- A. Testing Laboratories Definition
  1. The Testing Laboratory shall meet Federal OSHA Criteria for accreditation of Nationally Recognized Testing Laboratories (NRTL) Title 29 Part 1907 and 29 CFR-1910.
  2. Membership in the National Electrical Testing Association (NETA) shall also constitute acceptance of meeting said criteria, for testing of electrical systems.

#### **1.19 SPARE FUSES**

Provide three spare fuses for each size and type at each location to match the installed fuses where the fuses are provided as part of the Contract. Provide spare fuse holders on inside door of each respective fuse compartment. Provide engraved nameplate on front of fuse access door indicating fuse type/catalog number ampere rating and Manufacturer of fuse.

#### **1.20 EQUIPMENT SEISMIC AND WIND LOAD REQUIREMENTS (ADDITIONAL REQUIREMENTS)**

- A. Refer to Structural, Architectural, and Soils Report Contract Documents for Additional Requirements.
- B. General
  1. Equipment supports and anchorage's provided as part of the Contract shall be designed, constructed and installed in accordance with the Earthquake Regulations of the California Building Code (CBC), International Building Code (IBC).
  2. Provide equipment anchorage details, coordinated with the equipment mounting provision, prepared, signed and "stamped" with PE Registration in good standing, by a

Civil or Structural Engineer Licensed as a Professional Engineer (PE) in the State of California.

3. Mounting recommendations shall be provided by the Manufacturer based upon approved shake-table tests used to verify the seismic design of that type of equipment.
4. The Equipment Manufacturer shall document the details necessary for proper wind-load and seismic mounting, anchorage, and bracing of the equipment for floor, ceiling, and wall/back installation location.
5. Seismic performance shall be based on actual install location of the respective equipment in the building and height above or below grade.
6. The Seismic Requirements are typical for each equipment item exceeding 19-pounds, including but not limited to the following:
  - a. Switchgear, switchboards, and motor control equipment
  - b. Transformers
  - c. Equipment racks and terminal cabinets
  - d. Panels
  - e. Conduits with floor, ceiling or wall attachment support and conduits with suspension attachments.
  - f. Busway, wire way and cable tray
  - g. Uninterruptable Power Supplies (UPS)
  - h. Inverters
  - i. Generators and related equipment
  - j. Lighting equipment
  - k. Fire alarm equipment

C. Certification

1. Electrical Equipment Manufacturers and Contractor shall provide Special Seismic Certification (SCC) for each specific equipment configuration with shake-table verification, all furnished as part of the Contract Documents Requirements. The SCC shall include the specific installation location characteristics of the respective equipment including as follows:
  - a. Ground or floor attachment
  - b. Wall attachment
  - c. Ceiling attachment
  - d. Roof attachment
2. Wind Loading

Electrical equipment and anchorages shall withstand the wind-load imposed at the install location. Wind Loading Withstand Requirements shall apply to all electrical equipment installed in outdoor locations and to all electrical equipment exposed to the weather. The equipment shall be Tested and Certified by the Manufacturer and Contractor. The Wind-Load Withstand Qualification of the equipment and anchorages shall be verified by the following methods:

  - a. Aerodynamic wind tunnel test method.

- b. Analytical calculation method, for oversized equipment too large for wind tunnel test method.
  - 3. The Wind-Load Withstand Rating and the SCC shall comply with the Requirements of the Authority Having Jurisdiction (AHJ), and include the latest revisions, but not limited to the following:
    - a. American Society of Civil Engineers; ASCE-7
    - b. CBC/IBC; including but not limited to Sections 1702, 1708, 1709, 1708A and 1709A.
    - c. California Office of Statewide Health Planning and Development OSHPD; OPA-Preapproval of Anchorage; Code Application Notice CAN 2-1708A.5 and OSP-Special Seismic Certification Approval.
    - d. US Department of Homeland Security; FEMA - (installing seismic restraints for electrical equipment).
- D. Wall Mounted Electrical Equipment
  - 1. Surface Mounted Equipment
    - a. Provide multiple horizontal sections of metal “C” channels for support and attaching wall mounted equipment to walls. Channels shall provide “turned lips” at longitudinal edges to hold “lock-in” fasteners and shall comply with ANSI-1008 and ASTM-A569 latest revision. The channels shall be steel hot dip zinc galvanized. As manufactured by Unistrut or Kindorf.
    - b. The “C” channels shall be positioned horizontally within 3-inches of the top and bottom of each, equipment section cabinet and located behind each equipment vertical section. Provide additional intermediate “C” channels at not less than 36-inches on center between the “top” and “bottom” “C” channel positions, located behind each equipment vertical Section.
    - c. The “C” channels shall be of sufficient length to provide connection to not less than two vertical structural wall framing elements separated by not less than 16-inches; but in no case shall the “C” channel length be less than the width of the respective Equipment Section.
    - d. Attach the “C” channels to the wall structural elements after the wall, finish surface, installation (including painting) is complete.
    - e. Attach the “C” channels with fasteners to the building wall framing structural elements as follows: welded to steel framing; bolted to wood framing; cast in place concrete inserts for masonry and concrete construction; drilled “afterset” expansion anchors for existing masonry and concrete construction.
    - f. Attach the equipment to the “C” channels with threaded and bolted fasteners to “pre-locate” and lock into the channel “turned lips” and channel walls.
  - 2. Flush mount equipment
    - a. Provide anchor attachment of equipment into adjacent wall structural elements.
- E. Housekeeping Pad
  - 1. Provide cast-in-place, steel re-enforced concrete raised “housekeeping” pads under all floor standing electrical equipment (except data network equipment racks).

2. Pad sizes
  - a. The raised housekeeping pad height shall extend 4-inches above the surrounding finished floor elevation for interior building locations.
  - b. The pad shall extend 8-inches below finish grade plus 4-inches above finish grade for outdoor equipment location on grade.
  - c. The pads shall extend 7-inches past the “footprint” edge of the respective floor standing equipment.
3. Anchor equipment to pads. Anchor pads to the building structural floor. Equipment pad, equipment re-enforcing and equipment anchoring shall comply with Seismic Earthquake Requirements and Wind Load Requirements.
4. Unless shown otherwise on Drawings. The equipment housekeeping pad steel re-enforcing shall consist of two layers of Number 4-size steel-rebar laid horizontally and uniformly spaced 6-inches on center. Position rebar in two directions (90-degrees opposed) and centered inside the concrete house-keeping pad. Horizontal rebar shall extend to within 3-inches of the edge of the concrete pad in all directions. Metal wire “tie-wrap” shall be provided at each rebar crossing.
5. Equipment anchor attachments shall extend through the housekeeping pad and into the structural concrete below the pad a minimum of not less than 2-inches.

#### **1.21 ELECTRICAL WORK CLOSEOUT**

- A. Prepare the following items and submit to the District’s Representative before final acceptance.
  1. Two copies of all test results as required under this Section.
  2. Two copies of Local and/or State Code Enforcing Authority’s Final Inspection Certificates.
  3. Copies of Record Drawings as required under the General Conditions, pertinent Division One Sections and Electrical General Provisions.
  4. Two copies of all receipts transferring portable or detachable parts to the District’s Representative when requested.
  5. Notify the District’s Representative in writing when installation is complete and that a Final Inspection of this work can be performed. In the event any defect or deficiencies are found during this Final Inspection they shall be corrected to the satisfaction of the District’s Representative before final acceptance can be issued.
  6. List of spare fuses and locations identified by equipment name and building designation.
  7. Prior to energizing, retighten to the proper torque, each circuit conductor lug landing, each bus bar (phases, neutral and ground) and circuit protection device threaded connections in all switchboards, switchgear, motor control centers, transformers, bus-ways, disconnect switches, motor starters, motor terminals and panelboards, after the equipment is installed/connected and prior to energizing the equipment. The torque values shall comply with Manufacturer's recommendations.
- B. Electrical Power Single Line Diagrams – SLD
  1. Provide single line diagrams showing the Contract Document Work complete electrical power system (normal and emergency). SLD shall show inter-connection circuits, electrical equipment, panels, and circuit protection devices, nominal 50% (½-size)

approximately 18-inches by 24-inches. Show installed voltages and electrical capacity sizes.

2. SLD shall be mounted in metal (picture frame) rigid enclosure frame with rigid-backing (backer-board) and clear/transparent front, for hanging on wall. Provide clear transparent cover over SLD inside the frame.
3. Provide a wall-hung ( $\pm 48$ -inches) SLD in each "main" and "sub" electrical equipment room. If wall space is limited, alternatively securely attach SLD frame to room door facing into the respective electrical room.

END OF SECTION 26 05 00  
022219/212220-ABR



This page is blank.

**SECTION 26 05 01**  
**BASIC ELECTRICAL MATERIALS AND METHODS**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances, tools, equipment, facilities, transportation and services necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other Sections for work related to those other Sections and required to be included as work under this Section.
  - 2. General Provisions and Requirements for electrical work.

**1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

- A. Submit product data sheets for all outlet boxes, floor boxes, wiring devices, device plates, relays, contactors, time switches, and disconnects fuses.
- B. Submit Detailed Shop Drawings including Dimensioned Plans, elevations, details, schematic and point-to-point wiring diagrams and descriptive literature for all component parts for transformers, relays, time clocks, and photocells.
- C. Submit Transformer Test Reports.
- D. Submit Material List for Outlet Boxes.

**PART 2 - PRODUCTS**

**2.01 OUTLET AND JUNCTION BOXES**

- A. General:
  - 1. Flush or concealed outlet boxes and junction boxes.
    - a. Non-masonry and/or non-concrete locations provide pressed steel boxes. Steel thickness not less than 0.062-inch, hot-dip galvanized. Knockout (KO) type with conduit entrances and quantities size to match conduits shown connecting to respective junction box and outlet box.
    - b. UL-514 listed and labeled.
    - c. Minimum required box depth is exclusive of extension-ring depth.
    - d. Provide all boxes with matching cover plates. Cover plates shall be gasketed water-tight in wet and outdoor locations.
    - e. Boxes installed in masonry or concrete shall be UL "concrete-tight" approved for installation in concrete, and shall allow the placing of conduit without displacing reinforcing bars.
  - 2. Provide outlet boxes of proper Code size for the number of wiring devices, connecting conduits, and conductors/cables or conduits passing through or terminating therein. In no case shall outlet box be less than 4.0-inches square by 2.125-inches deep. Unless

specified elsewhere or noted otherwise on the Drawings, 2.5-inches minimum depth for box width's exceeding 2-gang.

3. Increase the minimum outlet box size to 4.69-inches square by not less than 2.125-inches deep, where one or more of the following conditions occurs:
  - a. More than two conduits connect to the outlet box.
  - b. Circuit "Homerun" or Conduit "Homerun" connects to outlet box.
4. Signal, Communication and Low Voltage Outlet Boxes:
  - a. Individual or duplex audio/visual, telephone, computer or data outlets: 4.69-inches square by 2.125-inches deep minimum with single gang wide extension ring.
  - b. Combination AV/signal/telephone/data or computer outlets: 4.69-inches square by 2.125-inches deep minimum with 2-gang wide extension ring.
5. Junction boxes shall be sized to comply with the following:
  - a. Code Requirements size based on the conduit quantities, conduit sizes and wire-fill connected to the junction box.
  - b. Junction box minimum size shall not be less than 4.69-inches square by 2.5-inches deep, but not less than size indicated on the Drawings or required by Code.
6. Provide extension rings on flush outlet boxes and flush junction boxes, to finish face of extension ring flush to (within  $\pm 0.63$ -inches) of finished building surfaces. Extension ring shall match outlet box materials/construction and contain "attachment mounting-tabs" for wiring devices. Extension rings shall be "screw-attached" to respective box and maintain "ground" bonding continuity.
7. Outlet boxes installed in outdoor locations, or in wet locations, or in concrete/masonry, shall be cast-iron or cast-bronze, with threaded conduit hubs. UL rated for wet locations.
  - a. Aluminum boxes shall NOT be in contact with concrete or masonry. Die-cast aluminum or cast aluminum water-tight electrical outlet boxes with threaded hubs may be provided as an alternate to cast-iron or cast-bronze outlet boxes, only where one or more of the following conditions occur:
    - 1) Outdoor locations above finish grade.
    - 2) Indoor wet locations surface or flush in walls or ceilings.
    - 3) Not in contact with concrete or masonry.
8. Provide fixture-supporting device in outlet boxes for surface mounted fixtures as required.
9. Provide solid gang boxes for three or more devices, typical for line and low voltage switches, receptacles, low voltage/signal outlets, etc. for mounting devices behind a common device plate.
10. Provide isolation barriers in outlet boxes:
  - a. Between line voltage and low voltage devices.
  - b. Where more than one device is installed in an outlet box, between and separating each device.
  - c. Between 277-volt and 120-volt devices.
  - d. Between devices connected to emergency and non-emergency circuits of all volt-ages.

11. Outlet boxes installed penetrating into fire rated walls, fire rated floors, fire rated ceilings and all fire rated construction. The outlet boxes shall be UL listed, classified and labeled, for fire rated and temperature rated penetration of the respective fire rated surface and fire rated construction. The outlet box fire rating and temperature rating shall equal or exceed the fire/temperature rating of the surface/ construction being penetrated. Provide UL listed and labeled supplemental fire and temperature protection to maintain ratings:
    - a. Wall and ceiling penetrations, supplemental tumescent fire wrap (external or internal of outlet box).
    - b. Floors provide subfloor supplemental fireproofing below floor box.
  12. Outlet boxes installed in floors. The floor outlet boxes shall be UL listed and labeled for Scrub Water Exclusion Requirements, including but not limited to tiles, carpeting and exposed wood and concrete floor finishes.
  13. Outdoor flush in wall device outlet boxes:
    - a. Flush in wall outlet box with corrosion resistant gasketed water tight, hinged, key locking cast metal, self-closing cover. Tamper resistant and vandal resistant.
    - b. UL-listed and labeled for installation in masonry, cast-in-place concrete, hollow-framed walls and wet locations.
    - c. Flush cast-iron or cast-bronze or brass, device back-box, nominal 4.68-inch square by 2.25-inch deep.
    - d. Internal metal adapter plate for wiring device types, in the box as indicated on the Drawings.
    - e. As manufactured by Legrand/Pass and Seymour #4600 Series; or C.W. Cole #310 Series.
  14. PVC Coating
    - a. Metal outlet and junction boxes installed in outdoor or exposed non-weather protected locations shall be PVC coated.
    - b. PVC coating shall be factory applied, to comply with NEMA-RN1 and 5-19.
    - c. The adhesion of the PVC coating to the metal box shall exceed the strength of the coating itself, based on 0.5-inch "strip-pull" test.
    - d. Uniform coating thickness shall be continuous without "breaks" or "pinholes" and shall not be less than the following:
      - 1) Box exterior surfaces, 40-millimeter coating thickness.
      - 2) Box interior surfaces, 10-millimeter coating thickness.
  15. Refer to Architectural and Structural Contract Documents and Details for Additional Box and Install Requirements.
- B. Surface Outlet Boxes
1. Surface mounted outlet boxes, cast iron Type FS or FD, with threaded hubs as required. Box interior dimensions and interior volume capacity not less than required for "press steel boxes", and "sheet steel boxes". Provide plugs in all unused openings. Provide weatherproof gaskets for all exterior boxes.

## C. Floor Boxes

### 1. General:

- a. Outlet boxes installed in floors. The floor outlet boxes shall be UL listed and labeled for Scrub Water Exclusion Requirements, including but not limited to floor tiles, carpeting and exposed wood and concrete floor finishes.
- b. Electrical power receptacles in a floor box; shall be industrial grade wet location heavy-duty, high-abuse rated devices, tamper resistant. Grounding type, 125 volts, 60Hz AC, 20-amp, NEMA 5-20R (duplex), or other NEMA configurations noted on the Drawings. Standard length receptacle mounting strap as required by the Manufacturer of floor box being furnished.
- c. Tested, listed and labeled to comply with UL-514A and/or UL514C.

### 2. Poke-Thru floor boxes for "After-Set" Floor Outlets.

- a. Through floor wiring for power and communication shall be UL listed with a fire and temperature rating of not less than 2-hours. The units shall include an internally divided floor fitting; a divided through-floor conduit/ raceway, and a divided under floor junction "split-box" not less than 4.7-inches by 4.7-inches by 2.125-inches in size. Junction box shall be installed concealed in ceiling space of the floor below. The length of the floor "through-raceway" shall match the thickness of the finish floor and as recommended by the Manufacturer. Unit shall be self-supporting without the attachment of an above floor fitting. Internal isolation barriers between high potential and low potential circuits and sections. The integral fire barrier shall incorporate a cold smoke barrier to prevent the passage of smoke when heat is not present.
- b. Poke-Thru Floor boxes shall contain dual services for high potential and low potential devices and circuits.
- c. Non-Pedestal Poke-Thru flush in floor type; (internal divided high potential and low potential sections) die cast, flush with finish floor, metal cover flip-open, locking, hinged access covers. Open-close die cast aluminum port-covers for plug-in portable cable connections. ADA compliant, wide trim matching flange.
  - 1) Two 20-amp, 120 volt, 60Hz, AC, grounding duplex convenience receptacles for high potential power connections.
  - 2) Four RJ-45 keystone, snap-in retainers for low potential plug-in signal connections. The Contractor shall provide the type of outlet(s) at each poke-thru location as required by the Low Voltage-Signal Contract Documents.
  - 3) Cover shall close and lock after portable plug-in cables have been inserted into respective connections, under the cover.
  - 4) UL wet mop, scrub water rated for carpeted and non-carpeted floors.
- d. Die cast aluminum cover, nominal 8-inch diameter metal housing flush in "core-hole", outlet metal body size.
- e. Flush with floor or pedestal type as indicated on Drawings. As manufactured by Wire-mold/LeGrand# Evolution Poke-Thru 8AT Series, Smoke and Fire Rated Poke-Through fittings; no known equal.

4. Floor Boxes for Flush Floor Outlets (non-pedestal), recessed concealed inside outlet box, plug-in receptacles.
  - a. Provide cast-in-floor with concrete pour pan, rated for on grade to prevent direct earth contact, cast-in-place concrete floors on-grade and above-grade; adjustable "leveling-feet" for box.
  - b. UL wet mop, scrub water rated for carpeted and non-carpeted floors. UL-File E171211 installation fire rating and/or UL-Fire Resistance Classified.
  - c. Floor boxes shall contain dual services:
    - 1) High potential with not less than two 120 volt 60Hz AC 20-amp grounding duplex convenience receptacles.
    - 2) Low potential for low voltage system outlets and signal circuits with up to and including eight RJ-45 plug-in keystone snap-in retainer receptacles. The Contractor shall provide the type of outlet(s) at each poke-thru location as required by the low voltage-signal Contract Documents.
    - 3) Internal isolating barrier between high and low potential circuits and sections of box.
    - 4) Also refer to Drawings for Additional Outlet Requirements.
  - d. Conduit knockouts in bottom of box and in each side walls of box. Not less than one 1.25-inch and one 0.75-inch knockouts for both low potential and high potential conduits connections on each opposing box sides. Include the same configuration of knockouts on the bottom of the box, for high potential section and low potential sections.
  - e. Floor box cover:
    - 1) Flush tamper resistant "lock-down" removable main cover. Independent hinged "flip-out" port in the removable cover, to allow main box cover to be in a fully closed position with "plug-in" cords connected into box when the lock-down cover is closed. Main cover "lock-down" to prevent non-authorized access into box interior.
    - 2) Brass, removable recessed main cover, rated for carpet, or tile for floor finish, brass overlapping trim cover finish. Cover recess depth 0.25-inch, 0.5-inch or 0.75-inch as required to match respective floor covering thickness and type. ADA compliant, wide trim matching flange.
  - f. Floor box with metal body, nominal box size 10-inches by 12-inches by depth to match floor, but not less than 3.0-inches deep box.
  - g. Floor box as manufactured by FSR #FL-500P Series; no known equal.

## **2.02 PULL BOXES**

### **A. General**

1. Sizes as indicated on the Drawings and in no case of less size or material thickness than required by the Governing Code and AHJ.
2. Exercise care in locating pull boxes to avoid installation in drain water flow areas and to clear existing condition interferences.
3. UL listed and labeled for electrical circuits.

B. General Purpose Sheet Metal Pullbox

1. General purpose sheet steel pull boxes: Install only in dry protected locations with removable screw attached covers. Manufacturer's standard rust proofing and baked enamel finishes.
2. Weatherproof sheet steel pull boxes: Fabricate of Code gauge steel. All surfaces interior and exterior hot-dip galvanized steel. Gasketed weathertight cover of same material.

C. Concrete Pull Boxes and Hand-Holes for Electrical

1. AASHTO H-20 traffic loading rated box and cover, pre-cast concrete, steel reinforced pull boxes and hand-holes. Provide complete with pulling irons, hot-dip galvanized metal traffic cover with hot-dip galvanized metal cover frame, pull-box concrete base with sump. Four cable full height wall racks with porcelain cable support blocks.
2. Boxes shall be "Intercept" type with Multiple Box Sections. Extension cable-intercepts at both ends of box. Refer to Drawings for box size.
3. Covers shall be flush bolt down. Covers weighing more than 40-pounds shall be split cover type "Torsion-Spring" assist, hinged open-close.
4. Box covers shall comply with Federal ADA, UL, State and Local AHJ for slip resistance. Provide cast-or-bead weld on cover of pull box to indicate services within pull box (i.e., "480/277-VOLT, 3-PHASE, 4-WIRE ELECTRICAL" OR "SIGNAL/TEL/P.A./ CLOCK/FIRE ALARM" etc.).
5. Shall be set on a machine-compacted pea gravel base 12-inches thick with gravel base extend 6-inches beyond box base on all sides. Provide a 0.75-inch by 10-foot copper clad ground rod through the box bottom with 9-inch projection into box, for grounding all metal parts and frames with continuous #10 AWG copper bond wire.
6. Seal all box joints and seal box between cover and frame with a mastic compound similar to Parmagum or Dukseal. After cables have been pulled, connected, tested and inspected, seal box cover and bolt-close cover.
7. As manufactured by Jensen Precast; or Oldcastle Precast.

## 2.03 SWITCHES, WIRING DEVICES

A. General

1. Provide wiring device circuit switches totally enclosed, electrical insulating Bakelite or electrical insulating composition base, manual operator type with 277 volt 60Hz AC rating for full capacity contacts rated for incandescent lamp loads, fluorescent lamp loads and motor loads. Switch mounting-ears for screw attachment to outlet box. Switches shall be UL listed and labeled; conform to NEMA-WD1 and WD6.
2. Switch controlling (on-off) rated for all lighting loads and all non-lighting loads; switch ratings shall be 20-amp; unless indicated otherwise on Drawings.
3. Color as selected by Owner's Representative. Switches and wiring devices controlling circuits connected to emergency power shall be red.
4. All switches shall be of the same Manufacturer.
5. Where switches are mounted in multiple gang assembly and are operating at 277 volts and/or 277 volts and 120 volts or emergency/non-emergency and mounted in same outlet box, there shall be an insulating barrier installed between each switch.

6. Devices shall additionally be listed and labeled as UL-All Weather-Resistant wet-location for the following install locations:
    - a. Devices indicated on Drawings as Weather-Proof (W.P.).
    - b. Devices installed in outdoor locations
    - c. Installed in classified wet or damp area locations both indoor and outdoor.
  7. Wiring devices shall be listed and labeled for connection of both “solid” and “stranded” copper circuit conductors.
  8. Switches with ampere and voltage ratings different than described herein. The different rated switches shall have the same characteristics and performance as the respective described switches, except for differing ampere and voltage characteristics.
- B. Switches Heavy Duty (Toggle – Type)
1. Single Pole Switches – 20 amp at 277V
 

| <u>Manufacturer</u> | <u>Toggle Type</u> | <u>Lock Type</u> |
|---------------------|--------------------|------------------|
| Hubbell             | #HBL1221           | #HBL1221-L       |
| Legrand/P&S         | #20AC1             | #20AC1-L         |
| Leviton             | #1221              | #1221-L          |
| Cooper-Arrow/Hart   | #AH1221            | #AH1221-L        |
  2. Double Pole Switch – 20 amp at 277V
 

| <u>Manufacturer</u> | <u>Toggle Type</u> | <u>Lock Type</u> |
|---------------------|--------------------|------------------|
| Hubbell             | #HBL1222           | #HBL1222-L       |
| Legrand/P&S         | #20AC2             | #20AC2-L         |
| Leviton             | #1222              | #1222-L          |
| Cooper-Arrow/Hart   | #AH1222            | #AH1222-L        |
  3. Three-Way Switches – 20 amp at 277V
 

| <u>Manufacturer</u> | <u>Toggle Type</u> | <u>Lock Type</u> |
|---------------------|--------------------|------------------|
| Hubbell             | #HBL1223           | #HBL1223         |
| Legrand/P&S         | #20AC3             | #20AC3-L         |
| Leviton             | #1223              | #1223-L          |
| Cooper-Arrow/Hart   | #AH1223            | #AH1223-L        |
  4. Four-Way Switches – 20 amp at 277V
 

| <u>Manufacturer</u> | <u>Toggle Type</u> | <u>Lock Type</u> |
|---------------------|--------------------|------------------|
| Hubbell             | #HBL1224           | #HBL1224-L       |
| Legrand/P&S         | #20AC4             | #20AC4-L         |
| Leviton             | #1224              | #1224-L          |
| Cooper-Arrow/Hart   | #AH1224            | #AH1224-L        |
  5. Momentary Contact Switches – 20 amp at 277V
 

| <u>Manufacturer</u> | <u>3-Position Regular</u> | <u>3-Position Lock</u> |
|---------------------|---------------------------|------------------------|
| Hubbell             | #HBL1557                  | #HBL1557-L             |
| Legrand/P&S         | #1251                     | #1251-L                |
| Leviton             | #1251                     | #1251-L                |
| Cooper-Arrow/Hart   | #AH (extra)               | #AH (extra)            |



6. Maintained Contact Switches (Double Throw, Center Off) – 20 amp at 277V

| <u>Manufacturer</u> | <u>Toggle Type</u> |               | <u>Lock Type</u> |               |
|---------------------|--------------------|---------------|------------------|---------------|
|                     | <u>1-Pole</u>      | <u>2-Pole</u> | <u>1-Pole</u>    | <u>2-Pole</u> |
| Legrand/P&S         | #1225              | #1226         | #12250L          | #1226-L       |
| Hubbell             | #HBL1385           | #HBL1386-L    | #HBL1385-L       | #HBLM1386-L   |
| Leviton             | #1385              | #1386         |                  |               |
| Cooper-Arrow/Hart   | #AH (extra)        | #AH (extra)   | #AH (extra)      | #AH (extra)   |

7. Pilot lights used in conjunction with circuit switches shall be LED type with red jewel.

C. Switches

1. 120 volt 60Hz AC, rated 15 amp for lighting loads and rated 20 amp for non-lighting loads, unless indicated otherwise on Drawings.

2. Single Pole Switches

| <u>Manufacturer</u> | <u>Rocker Type</u> |
|---------------------|--------------------|
| Legrand/P&S         | #TM870             |
| Hubbell             | #RSD115            |
| Leviton             | #5621-2            |
| Cooper-Arrow/Hart   | #7501              |

3. Double Pole Switch

| <u>Manufacturer</u> | <u>Rocker Type</u> |
|---------------------|--------------------|
| Legrand/P&S         |                    |
| Hubbell             | #RSD215            |
| Leviton             | #5622-2            |
| Cooper-Arrow/Hart   | #7502 (extra)      |

4. Three-Way Switches

| <u>Manufacturer</u> | <u>Rocker Type</u> |
|---------------------|--------------------|
| Legrand/P&S         | #TM873             |
| Hubbell             | #RSD315            |
| Leviton             | #5623-2            |
| Cooper-Arrow/Hart   | #7503              |

5. Four-Way Switches

| <u>Manufacturer</u> | <u>Rocker Type</u> |
|---------------------|--------------------|
| Legrand/P&S         | #TM874             |
| Hubbell             | #RSD415            |
| Leviton             | #5624-2            |
| Cooper-Arrow/Hart   | #7504              |

6. Momentary Contact Switches

| <u>Manufacturer</u> | <u>3-Position Regular</u> |
|---------------------|---------------------------|
| Legrand/P&S         | #TM870 (extra)            |
| Hubbell             | #RSD (extra)              |
| Leviton             | #5624-2                   |
| Cooper-Arrow/Hart   | #7521                     |

7. Maintained Contact Switches (Double Throw, Center Off).

| <u>Manufacturer</u> | <u>Rocker Type</u> |               |
|---------------------|--------------------|---------------|
|                     | <u>1-Pole</u>      | <u>2-Pole</u> |
| Leviton             | #5685-2            | #5686-2       |

8. Pilot lights used in conjunction with circuit switches shall be LED type with red jewel.
- D. Weather-Proof (W.P.) Switches
1. Outdoor switches provide heavy-duty, tamper resistant gasketed weather proof metal, hinged door cover for each switch.
  2. Cover door shall be key locking-type or padlock-type.
- E. Other Switches, Receptacles, Devices, and Outlets
1. Special devices outlets and outlet locations shall be as indicated on the Drawings. Modify device and outlet characteristics to accommodate the actual install location conditions for each outlet.

## **2.04 ELECTRIC RECEPTACLE WIRING DEVICES**

### **A. General**

1. All receptacle wiring devices in flush type outlet boxes shall be installed with a bonding jumper to connect the box to the receptacle ground terminal. Grounding through the receptacle mounting straps is not acceptable. The bonding jumper shall be sized in accordance with the branch circuit protective device as tabulated herein under "Grounding". Bonding jumper shall be attached at each outlet to the back of the box using drilled and tapped holes and washer head screws 6-32 or larger (except isolated ground receptacles). For receptacles in surface mounted outlet boxes direct metal-to-metal contact between receptacle mounting strap (if it is connected to the grounding contacts) and outlet box may be used. Receptacle mounting-ears for screw attachment to outlet box. Receptacle shall be UL listed and labeled; conform to NEMA-WD1 and WD6.
2. All receptacles shall be a product of the same Manufacturer.
3. Receptacle color as selected by Owner's Representative. Receptacles connected to emergency power circuits shall be red.
4. Tamper Resistant Receptacle
  - a. Devices shall additionally be listed and labeled as tamper resistant, provide tamper resistant receptacles in buildings containing: dormitories, guestrooms, housing/residences, condominiums, apartments, dwellings, hotels/motels, class-rooms, secondary Schools K through 12<sup>th</sup> grade, childcare/daycare/kindergarten, hospital pediatric-care units and other locations required by AHJ.
  - b. The electrical receptacles shall be rated "Tamper-Resistant-Receptacle" (TR), UL-TR (RTRT). Spring loaded shutters shall automatically open-close (unblock-block) the receptacle slots, when the plug-in (cap) insertion and removal occurs.
  - c. Typical for 15-amp and 20-amp receptacles. Modify Manufacturer's catalog number description to include tamper resistant receptacle function.
5. Wiring devices shall be listed and labeled for connection of both "solid" and "stranded" copper circuit conductors.
6. Duplex convenience receptacles and 120-volt single phase branch circuits.
  - a. Duplex (convenience) receptacle, wiring device with two single receptacles with the same electrical rating, integrated into a single assembly by the Manufacturer.

- b. 20-amp branch circuits with a single duplex convenience receptacle connection on each circuit, receptacles shall be rated for 20-amp.
  - c. 15-amp and 20-amp branch circuits with two or more duplex convenience receptacle connections each circuit, receptacle shall be rated 15-amp or 20-amp.
7. Devices shall additionally be listed and labeled as UL-All Weather-Resistant, provide weather resistant receptacles for the following install locations. Modify Manufacturer’s catalog number descriptions, shall include all-weather-resistant UL listing and labeling:
    - a. Devices indicated on Drawings as Weather-Proof (W.P.).
    - b. Devices installed in outdoor locations.
    - c. Devices installed in classified as damp or wet locations both indoor and outdoor.
    - d. All GFCI (ground-fault) receptacles all locations.
  8. Receptacles with ampere and voltage ratings different than described for duplex convenience receptacles. The different rated receptacles shall have the same characteristics and performance as the respective duplex convenience receptacles, except for differing ampere and voltage characteristics. Refer to “Floor Boxes” for additional Receptacle Requirements”.
  9. Receptacles shall be GFCI type for the following locations:
    - a. located within 84-inches of a sink or hosebib shall be GFCI receptacles.
    - b. Devices installed in outdoor locations.
    - c. Devices installed in classified as damp or wet locations both indoor and outdoor.
    - d. Devices indicated on Drawings as GFCI or Weather-Proof (W.P.).
  10. “Split-wire” duplex convenience receptacles. Each split-wire receptacle plug connects on independent common circuit. Provide nameplate or graphic on face of receptacle describing the receptacle function and control source. Comply with California Title-24 and ASHRAE-90.1, latest revisions.
- B. Duplex convenience receptacles.
1. Shall be grounding type, 120 volt and shall have two current carrying contacts and one grounding contact which are internally connected to the frame. Outlet shall accommodate standard parallel blade cap and shall be side wired. Receptacles shall be tamper resistant–TR, UL-TR.
  2. GFCI receptacles shall be all Weather-Resistant and wet location rated. Duplex, rated 120 volt 60Hz AC, 20 amp, unless indicated otherwise on Drawings.
  3. Heavy Duty Industrial Grade
- | <u>Manufacturer</u> | <u>NEMA 5-15R</u> | <u>NEMA 5-20R</u> | <u>NEMA 5-20R-GFCI</u> |
|---------------------|-------------------|-------------------|------------------------|
| Legrand/P&S         | #5262             | #5362             | #2095HG                |
| Leviton             | #5262             | #5362             | #W7899                 |
| Hubbell             | #CR5252           | #5362             | #GFR8300               |
| Cooper-Arrow/Hart   | #AH5262           | #AH5362           | #WRVGF20               |
- C. Isolated Ground Receptacles-IGR
1. The receptacle insulation barrier shall isolate the receptacle ground contact system from ground. Connect the ground plug contact to a separate dedicated insulated ground-bonding conductor. The receptacle ground plug contact shall not be grounded to the raceway or outlet box. Isolated ground duplex convenience receptacle 20-amp

minimum, with two current carrying contacts and one grounding contact, or as noted on the Drawings.

2. High-abuse, heavy-duty industrial grade, NEMA 5-20R, duplex convenience receptacles.
3. Identify receptacle with an orange triangle on the receptacle face and orange receptacle body. Red body for receptacles connected to emergency power.

| <u>Manufacturer</u>       | <u>NEMA 5-20R</u> |
|---------------------------|-------------------|
| Legrand/P&S . . . . .     | #IG6300           |
| Leviton . . . . .         | #5362IG           |
| Hubbell . . . . .         | #CR5352IG         |
| Cooper-Arrow/Hart . . . . | #IG5362           |

D. Weather Proof (W.P.) Receptacle

1. Outdoor receptacles shall be duplex convenience GFCI type rated 20-amp 120 Volt 60Hz AC weather-proof, GFCI, unless indicated otherwise on Drawings. Test-reset buttons and visual pilot.
2. GFCI receptacles shall be wet location and Weather-Resistant rated weatherproof, gasketed, key locking tamper resistant, wet location.
3. Outdoor, flush mount outlet with hinged, key-locking, weather-proof cover (CEC/NEC – 406.8 compliant). As manufactured by Pass and Seymour/Legrand #4600 Series; or C.W. Cole #310 Series.
4. On exposed conduit runs, provide weatherproof ground fault circuit interrupter type GFCI receptacles installed in "FS" conduit water tight cast metal body, with weather-proof spring door type covers, gasket water tight. Door shall be key locking-type or padlock-type.

G. Other Switches, Receptacles, Devices, and Outlets.

Special devices, outlets and outlet locations shall be as indicated on the Drawings. Modify device and outlet characteristics to accommodate the actual install location conditions for each outlet.

## 2.05 PLATES

A. Metal Cover Plates for Devices

1. Provide cover plates for every line voltage and low voltage switch, receptacle, telephone, computer, television, signal and other device outlets.
  - a. All line voltage circuit plates shall be metal, 0.040-inch stainless steel Type 302 alloy, composed of 18% chromium and 8% nickel.
  - b. Plates for low voltage signal systems may be metal or non-metal. Non-metal plates shall be high-abuse, hard-service and high-impact resistant.
2. Plates shall be as manufactured by P&S; or Hubbell; or Leviton; or General Electric.

## 2.06 VANDAL-PROOF FASTENINGS

Provide approved vandal-proof type screws, bolts, nuts where exposed to sight throughout the Project. Screws for such items as switch plates, receptacle plates, fixtures, communications equipment, fire alarm, blank covers, wall and ceiling plates to be spanner head stainless steel, tamperproof type. Provide Owner with six screwdrivers for this type.

## 2.07 STRUCTURAL AND MISCELLANEOUS STEEL

Structural and miscellaneous steel used in connection with electrical work and located out-of-doors or in damp locations, shall be hot-dip galvanized unless otherwise specified. Included are underground pull box covers and similar electrical items. Galvanizing averages 2.0 ounce per square foot and conforms to ASTM A123.

## 2.08 FLASHING ASSEMBLIES

### A. General

1. Flashing shall be compatible with the material being penetrated and with the pipe passing through the flashing. Coordinate with and comply with Manufacturer's recommendations, for both the flashing and the material being penetrated.
2. Provide lead metal flashing assemblies at all roof penetrations, unless recommended otherwise by Manufacturer.
3. Seal the joint between the flashing and pipe passing through the flashing with waterproofing compound.
4. Lead flashing for roof penetrations, as manufactured by: Santa Rosa Lead Products; or Semco; or Flashco.

### B. Storm Collars

1. In addition to penetration flashing, provide a storm-collar counter-flashing for each roof penetration flashing. Shall attach to the structure of the penetration and form a water-tight "umbrella" counter flashing over the roof penetration flashing.
2. As manufactured by: STD-Storm collars; or ASI-Storm collars.

## 2.09 RELAYS, CONTACTORS, AND TIMESWITCHES

### A. Individual Control Relays (HVAC Plumbing of the Control Functions)

1. Individual control relays shall have convertible contacts rated a minimum of 10 amp, 600 volts regardless of usage voltage. Coil voltage, number and type of contacts shall be verified and supplied to suit the specific usage as shown in the wiring diagrams and/or schedules on the Electrical and Mechanical Drawings. Coil control circuit shall be independently fused, sized to protect coil. Relays shall be installed on prefabricated mounting strips. Each relay shall have a surge suppressor to limit coil transient voltages. Furnished in the NEMA Type I enclosure unless indicated otherwise.

2. The following relays are approved:

| <u>Manufacturer</u> | <u>Type</u>          |
|---------------------|----------------------|
| Cooper-Arrow/Hart   | IMP                  |
| General Electric    | Class CR 2811        |
| Square D Co.        | Class 8501, Type A   |
| Westinghouse        | Bul. 16-321, Type NH |
| Allen Bradley       | Approved Equal       |

### B. Contactors and/or Relays

1. Contactors and/or relays for control of lighting shall be 600 volt AC, electrically operated, and mechanically held units, open type for panel mounting with number of poles and of

size as indicated on the Drawings. Provide auxiliary control relay for operation of each contactor and/or relay with a 2-wire control circuit.

2. Contactors and/or relays shall be mounted in panelboards in barriered section under separate hinged lockable doors or in contactor and/or relay cabinets as called for on the Drawings. Contactors and/or relays shall be installed on Lord sound absorbing rubber mounts.
3. Contactors and/or relays shall be Automatic Switch Co. Bulletin #920 Series for 2-pole and 3-pole, Automatic Switch Co. Bulletin 917 Series with poles as indicated on Drawings. Coil control circuit shall be independently fused, sized to protect coil.
4. Contactors and/or relays shall be equipped with a switch, in the proper configuration, to disconnect the control circuit controlling the coil of the respective device. Control circuit disconnect switch shall be labeled showing function of device.

#### C. Time-Switches

1. All timeswitches shall have synchronous motor drive for operation on 120 or 277 volts, 60Hz, AC and shall be furnished with a 10-hour, spring-driven, reserve-power motor. Contacts shall be rated 40-amp per pole.
  - a. Exterior lighting timeswitches for control of individual circuits or electrically operated relays shall have astronomic dial and shall be Tork 7000ZL Series or approved equal by Paragon or Intermatic.
  - b. Interior lighting timeswitches for control of individual circuits or electrically operated relays shall be Tork 7000 Series or approved equal by Paragon or Intermatic.
  - c. Timeswitches for control of air conditioning or plumbing equipment shall have seven day dial and shall be Tork WL Series or approved equal by Paragon or Intermatic.
2. All timeswitches shall be mounted in separate section in top of panelboards under separate lockable door unless otherwise indicated on Drawings. Clear opening for time-switch shall be a minimum of 12-inches by 12-inches.

#### D. Contactors and/or Relays/Timeswitch Cabinet

1. Contactors, relays, and/or timeswitches not indicated to be mounted in electrical panels shall be mounted in a cabinet, size as required, with hinged lockable door keyed same as panelboards. Construction of cabinet shall be similar to terminal cabinets.
2. Each contactor, relay or timeswitch mounted in the contactor cabinet shall be barriered in its own compartment, and shall be installed on Lord sound absorbing mounts.
3. Contactor cabinets shall be of the same Manufacturer as the panelboards.
4. Where relays and/or contactors occupy the same enclosure as timeswitches they shall have a clear acrylic shield installed over each relay or contactor to guard line exposed parts from accidental contact by nonauthorized personnel.

### 2.10 DISCONNECTS (SAFETY SWITCHES)

#### A. General

1. Disconnect switches shall all be rated:
  - a. 600 volt 60Hz AC for all disconnect safety switches.
  - b. NEMA Type HD, quick-make, quick-break, H.P.-rated.

- c. Fused Class "R", in NEMA Type I indoor location enclosure. Where enclosure is indicated outdoor or W.P. (Weather-Proof) switches shall be rain tight NEMA 3R enclosure. Lockable access door.
  - d. Number of poles horse power rating and amperage as indicated on the Drawings.
2. Provide internal neutral bus, ground-lug and conductor landing lugs, size to match conductors shown on Drawings. Switch access door shall be interlocked with switch to prevent access inside switch when switch is "on" closed position.
  3. Maximum voltage, current and horsepower rating clearly marked on the switch enclosure and switches having dual element fuses shall have rating indicated on the nameplate.
  4. Disconnect switch and fuses ampere rating shall also comply with Manufacturer's recommendation for the connected load.

### **2.11 SPARE FUSE CABINETS**

Provide a cabinet in each room where a switchboard or motor control center is installed and contains fuses. Cabinets shall be as specified for "Terminal Cabinets" and shall be of sufficient size to contain all spare fuses hereinbefore specified. Provide clips (two per fuse) for each spare fuse. Mount clips in plywood backboard in cabinet. Label cabinet "SPARE FUSES".

### **2.12 CONCRETE WORK (ADDITIONAL REQUIREMENTS)**

#### **A. Portland Cement**

1. ASTM C33-(latest revision), Type II, Low Alkali Cement. Composed of Portland cement, coarse aggregate, fine aggregate, and water.
  - a. Concrete for use as electrical equipment footings, lighting pole bases and equipment slabs on grade, concrete shall attain minimum 28-day compressive strength of 4000psi, using not less than 5.75 sacks of cement per cubic yard of wet concrete.
  - b. Concrete for underground duct/conduit encasement, the minimum 28-day compressive strength shall be 2000 psi. Provide a minimum of 10-pounds of red oxide concrete coloring per yard of concrete.
  - c. Mix shall obtain a 6-inches slump, measured with standard slump cone per ASTM C143/ C143M (latest revision).
2. Coarse Aggregate: Uniformly graded between maximum size not over 1½-inch and not less than 0.75-inch and minimum size #4, crushed rock or washed gravel. For concrete encased conduit only, maximum aggregate size shall be ½-inch.
3. Fine Aggregate: Clean, natural washed sand of hard and durable particles varying from fine to particles passing ⅜-inch screen, of which at least 12% shall pass fifty mesh screens.

#### **B. Water: Clean and free from deleterious quantities of acids, alkalis, salts, or organic materials.**

#### **C. Reinforcement**

1. Bars: Intermediate Grade Steel conforming to ASTM A615/A615M Grade 60, with pattern deformations.
2. Welded Wire Fabric: ASTM A185/A185M.
3. Bending: Conform to Requirements of ACI 318.

- D. Form Material: For exposed work, use PS 1-66 "B-B Concrete Form" plywood forms, or equal. Elsewhere, forms may be plywood, metal, or 1-inch by 6-inch boards. Forms for round lighting pole bases shall be sono-tube.

## 2.13 SURGE PROTECTION DEVICE PROTECTOR (SPD) – DIRECT CONNECT

### A. General

1. The unit shall be modular in construction and operate in parallel with 60Hz AC line voltage, 4-wire or 5-wire, grounded or ungrounded systems, as applicable; voltage, kVA and ampere capacity as indicated on the Drawings. Suitable for direct connection through an external circuit breaker or combination switch/fuse protective device rated 30-amp, continuous duty, rated for Service Entrance equipment connection. Transient electrical surge protection sequences shall include circuit configurations as follows:
  - a. Line-to-Line (Phase-to-Phase).
  - b. Line-to-Ground (Phase-to-Ground).
  - c. Line-to-Neutral, where neutral is present.
  - d. Ground-to-Neutral, where neutral is present.
2. The unit shall operate correctly with any combination of resistive, inductive, or capacitate loads. The unit shall automatically shunt to ground the electrical transients and EMI/RFI noise occurring above the specified values. The unit shall automatically reset after transient condition has passed. Operating temperature minus 40° centigrade to plus 85° centigrade.
3. Provide one or more individual self-contained protection module(s) for each line voltage phase, ground and neutral, suitable for direct connect with line-side C/B protection and disconnect. Provide one spare individual plug-in protection module. Provide incoming line, neutral and ground conductor termination lugs rated CU/AL #14 through #4 AWG. Lugs shall be barriered from and prewired to the respective protection modules.
4. Provide a NEMA twelve housing to contain all unit modules, devices and conductor terminations. The housing shall include a hinged pad-lockable access door.
  - a. Flush housing for mounting internally inside related equipment.
  - b. Surface mounted, with conduit entrance knockouts for external mounting. Maximum housing size shall not exceed 36-inches wide by 72-inches high by 8-inches deep.
5. As manufactured by Total Protection Solutions Model #ST-SPD; or MCG Electronics; or Advantage Protection Technologies, Inc.

### B. Operational Characteristics

1. Transient voltage protection, testing, listing and certification.
  - a. UL 1449 (latest edition) and CSA listed and labeling, for Surge Protection Device Suppressor, UL 1283 for transient voltage electrical noise attenuation, ANSI/IEEE C62.45, C62.1 for C62.41, (latest edition) bi-directional transient clamping voltages for both Normal Mode and Common Modes against Category A and B ring wave and Category B impulse wave.
  - b. The unit connected to the service entrance shall also withstand a minimum of 2,000-sequential ANSI/IEEE C62.41 Category C surges without failure following IEEE Test procedures in C62.1, C62.41 and C62.45.



2. Transient voltage protection, EMI noise rejection, and RFI noise rejection shall be provided for Common Mode (line-to-neutral and line-to-ground), Normal Mode (line-to-line) and neutral to ground.

3. EMI and RFI noise rejection.

Conducted line noises interference both Electromagnetic (EMI) and Radio Frequency (RFI) shall be reduced by the unit over a continuous spectrum of 0.5MHz to 1.0MHz. The basis for reduction shall be a standardized 50-OHM insertion loss MIL -STD-220A test. Provide Spectrum Analysis Test dB attenuation reports showing RFI filtering over specified frequencies. Test data based on calculated or computer simulation is not acceptable.

4. Three phase and grounded "WYE" Performance Requirements.

| <u>Characteristics</u>  | <u>208/120 Volt</u> | <u>480/277 Volt</u> |
|---|---------------------|---------------------|
| Nominal line-to-line  | 208 Volt            | 480 Volt            |
| Nominal line-to-neutral   | 120 Volt            | 277 Volt            |
| Internal capacitance (Microfarads)  | 2.5                 | 2.5                 |
| Maximum response time   | 1-nano second       | 1-nano second       |
| EMI/RFI noise rejection   | 25-35dB             | 25-35-dB            |
| Nominal peak clamp voltage line-to- neutral and line-to-ground                        | 500 Volts           | 900 Volts           |
| Minimum transient energy dissipation per phase (at 8x20 microseconds waveform)        | 1000 Joules         | 1500 Joules         |
| Peak transient withstand (at 8x20 micro-seconds waveform) without failure of the unit | 50,000 amp          | 60,000 amp          |
| • Category-C3   | 300,000 amp         | 500,000 amp         |
| • Category-B3   | 100,000 amp         | 150,000 amp         |
| • Category-A3   | 60,000 amp          | 80,000 amp          |

C. Diagnostic Indicators

1. Shall display the "Normal" and "Fault" status of each line suppression circuit, along with protection circuit "on" indication.

2. Shall provide a sonic audible fault alarm with silence push-button.

D. Surge Suppressor Protection Categories

1. Surge protectors shall comply with ANSI C62.41 (Latest Revision) Standard Protection Categories for "impulse" and "ringwave" transients, based on the installation locations shown in the Contract Documents.

a. Service entrance, main switchboard or substation locations - Category "C3", high exposure, Type-1.

b. Mid building, distribution panels, distribution panels over 400-amp main bus rating locations - Category "B3", high exposure, Type-1.

c. Branch circuit panelboards 400-amp or less main bus rating - Category "A3", high exposure, Type-1.

2. The SPD short circuit current withstand rating shall exceed the actual short circuit current available at the SPD installation location

## 2.14 PLUG STRIP SURGE PROTECTION DEVICE SUPPRESSOR

### A. General:

1. Point-of-Use Type-3 self-contained unit rated 15-amp, nominal 120 volt plus-or-minus 10%, 60Hz, AC, 1875 watts full continuous load. Internal 15-amp resettable overload protection circuit breaker. Red illuminated on-off switch. 6-foot, 14 AWG 3-conductor, grounded, heavy duty jacketed AC line cord with NEMA 5-15 cap. Multi-outlet receptacles, suitable for use with the following types of plug in loads, data processing equipment, audio/video equipment, test instruments, medical equipment, photo graphic equipment and "switching type" power supplies.
2. Protected outlets shall be NEMA 5-15R 15-amp, AC 60Hz receptacles. Provide four protected outlet plugs on each plug strip, as indicated on the Drawings. Each group of two receptacles (duplex) shall be connected to separate protected load isolated filter banks. Each duplex shall be isolated from the other output receptacles, minimum isolation of 25dB at 1MHz line to line, line to neutral, line to ground and neutral to ground.
3. Non-blocking plug-in locations/orientation for plug-in "power-brick" power supplies, with out obstructing adjacent receptacles.
4. As manufactured by TRIPP LITE-Isobar Series; or Advanced Protection Technologies; or equal.

### B. Operation:

Self-contained RFI and EMF shielded housing with mounting slots for temporary mounting of the unit. Protected outlet receptacles shall supply filtered, electrical line voltage power to the connected equipment. Line noise RFI and EMI interference filtering suppression, and spike protection shall occur in all three modes of operation line to ground, line to neutral and neutral to ground rated as follows:

1. 13,000-amp, 210 joules (watt-seconds) peak withstands capacity.
2. Transient response time less than five nano seconds.
3. 140-volt AC RMS initiate spikes suppression 330 volt maximum let through.
4. RFI and EMI Suppression-Provide Spectrum Analysis Test dB attenuation reports showing RFI filtering over specified frequencies.
  - 50KHz greater than 20dB
  - 150KHz greater than 40dB
  - 1MHz greater than 80dB
5. Diagnostic indicator lights located on the SPD housing shall provide alarm alert for each of the following conditions:
  - a. Loss of AC power.
  - b. Damage, malfunction in the SPD suppression circuits.
  - c. Improper AC electrical outlet wiring.
6. Standards Testing, Listing, Labeling and Certification Compliance, latest revisions:
  - a. IEEE 587 A and B compliance.
  - b. UL 1449 surge suppressers.
  - c. UL 1363 temporary power taps.

- d. UL 1283 electromagnetic interference filters.
- C. Rack Mounted SPD
  - 1. SPD units installed in equipment racks shall comply with all of the same Performance Requirements, except as follows.
    - a. EIA/TIA – Equipment rack mount style (19-inches or 24-inches as applicable).
    - b. Minimum of two front mounted receptacle outlets and not less than six rear mounted receptacle outlets.
    - c. 20-amp 120 volt 60Hz AC electric circuit rating, instead of 15-amp.

## 2.15 WIREWAY

- A. General:
  - 1. Unobstructed lay in type, metal wireway, fittings and connectors UL listed for use as wireway and auxiliary gutter. Length, elbows and "T-S" as shown on Drawings. Minimum cross-section size 4-inches by 4-inches, but not less than shown on the Drawings. Suitable for mounting in any position orientation.
- B. Construction:
  - 1. Minimum metal gauge shall not be less than 14 gages.
  - 2. Cover shall be hinged entire length of cover. Cover shall be held in the closed position with bolts and nuts.
  - 3. Provide spring nuts on all hardware fastener penetrations into the interior of the wireway to protect against wire insulation damage.
  - 4. The inside of 90-degree corners in the wireway shall be a 45-degree bevel.
  - 5. Grounding continuity between wireway sections and fittings shall be continuous the entire length of the wireway.
- C. Finish:
  - 1. Indoor non-raintight, rust inhibitor phosphatizing base coating and baked enamel finish, Manufacturer's standard color.
  - 2. Raintight outdoor-galvanized metal, with corrosion resistant phosphate primer and baked enamel finish, Manufacturer's standard color, NEMA 3R construction.
  - 3. All hardware shall be plated to prevent corrosion.

## 2.16 TRANSFORMERS

- A. General
  - 1. Provide dry type transformers constructed to meet Underwriters' Laboratories Specification UL 506 and tested in accordance with ANSI and NEMA Standards. Performance on transformers equal to or better than ANSI, NEMA, IEEE and CEC/NEC published criteria.
    - a. 60Hz AC line and load.
  - 2. UL Class 220°C insulation with maximum winding temperature rise of 150°C in 40°C ambient at 100% continuous rated capacity with overload capacity per ANSI C57.12 and C57.96 vacuum impregnated core and coil insulation. Transformer efficiency shall meet or exceed NEMA-TP1 (latest revision) Requirements.

3. Transformers shall be equipped with not less than five 2.5% full capacity voltage taps, two above and three below normal voltage. Line and load terminals shall be accessible, located behind removable front cover plate. Transformer connects shall terminate in "conductor-lugs" to match line side incoming and outgoing secondary side conductors, shall occur on a common (same) side of transformer on insulated supports.
  4. Provide wall mount and ceiling mount transformers support brackets, platforms and attachment structures for transformers.
  5. Dry type transformers shall meet or exceed NEMA TP-1 (latest revision), Class-1 efficiency levels and shall be marked as energy efficient for United States Department of Energy and Environmental Protection Agency DOE/EPA "Energy Star".
  6. Transformer windings shall be copper or aluminum.
  7. Electrostatic Shield: Provide full width, copper, 100% electrostatic shield (Faraday Shield), between line and load transformer windings, on each transformer phase. Shield shall be low impedance grounded to the transformer metal frame and shall attenuate common mode electrical noise 120dB at 1-500MHz range and transverse mode electrical noise, 30dB at 1-500MHz range. Average effective coupling capacitance of thirty picofarads between line and load sides.
  8. Connect transformers by one of the following methods:
    - a. Under floor conduit resulting in no rigid connections to transformer (provide ground strap for equipment ground).
    - b. Liquid tight flexible metal conduit (provide ground wire for equipment ground).
    - c. Pullbox or wireways from transformer which are isolated from transformer with an approved sound absorbing neoprene gasket (provide ground strap for equipment ground).
  9. The physical dimensions of the transformer shall not exceed the size shown on the Drawings.
  10. Transformer and transformer mounting shall be designed and tested and comply with install location seismic earthquake resistance seismic loads, typical for floor, wall and ceiling mount/suspended transformers. Bolt floor-mounted transformers to floor and mounting brackets, provide isolation rubber mounts, on each attachment contact location.
- B. Test Requirements:
1. The transformers shall be subjected to the following production tests:
    - a. Applied Potential
    - b. Induced Potential
    - c. No Load Loss.
    - d. Voltage Ratio.
    - e. Polarity
    - f. Continuity

2. The Manufacturer shall have performed the following additional tests on transformer units identical to the design type being supplied to this Specification. Proof of performance of these tests in the form of test data sheets shall be provided at the Time Shop Drawings are submitted for approval.
    - a. Sound Levels
    - b. Temperature
    - c. Full Load and 50% Load Losses for linear and nonlinear loads
    - d. Voltage Regulation
    - e. Impedance
- C. Transformer Housing
1. Metal, air cooled enclosure
    - a. Removable metal NEMA 1 enclosure, indoor location
    - b. Removable NEMA – 3R enclosures, outdoor locations, with vent shields.
    - c. Provide screen protected ventilation for all openings, including bottom of housing, to prevent accidental contact with internal components and prevent rodent/insect entrance.
  2. Manufacture’s rust inhibitor primer and standard finish paint.
  3. Removable lifting and skidding provisions.
  4. Provide wall mount and ceiling mount transformers support brackets, platforms and attachment structures for transformers.
- D. Sound Levels: Transformer sound levels, between no loads to full load, shall be guaranteed by the Manufacturer not to exceed the following values:
- |                  |       |
|------------------|-------|
| 9kVA and below   | 40dba |
| 10kVA to 50kVA   | 45dba |
| 51kVA to 150kVA  | 50dba |
| 151kVA to 300kVA | 55dba |
| 301kVA to 500kVA | 60dba |
- E. K-Rated Transformers
1. Transformers shall comply with UL-1561 and IEEE-519, shall all be rated K4, for harmonic content electrical loads, in accordance with UL-1561 and IEEE C57.110 (latest revision), unless noted other-wise with other-K Ratings on Drawings.
  2. The transformers shall be specially designed and manufactured for non-linear electrical load which cause harmonic current and voltage distortion, with 3<sup>rd</sup>, 5<sup>th</sup>, 7<sup>th</sup>, 9<sup>th</sup> and 15<sup>th</sup> harmonic current and volt-age distortion.
  3. Transformers, which are simply oversized larger than the specified kVA rating and then de-rated to the specified kVA rating to compensate for harmonic overloading, are not acceptable.
  4. Secondary neutral connections rated at 200% of rated secondary phase current.
  5. Transformers Manufactured by; Cutler Hammer; or General Electric; or Square D Co.; or Siemens.

- F. Seismic Earthquake and Wind Loading Withstand, Testing and Certification (Additional Requirements)
1. The complete transformer assembly; including housings/enclosures, accessories, supports/anchors etc., shall be designed, manufactured and tested for wind loading for outdoor locations; earthquake seismic rated withstand for indoor and outdoor locations.
  2. Shall withstand, survive and maintain continuous non-interrupted energized operation (running) during the seismic event occurrences. Continued normal energized operation after the wind event and seismic event occurrences have abated.
  3. Shall include demonstrations of successful operation and run test after completion of seismic event shake-table simulation.
  4. Provide three dimensional finite element analysis demonstrating anchorage and operational withstand of wind loading as follows:
    - a. 110MPH-West Coast USA and Hawaii, per ASCE/SEI 7-10.
  5. Acceptance test seismic qualification of proposed equipment shall employ triple axis shake-table simulation of the Required Response Spectrum (RRS) seismic event motion, certified and approved by the AHJ.
  6. Seismic test shall be performed by a third party independent Test Laboratory. Wind Analysis and Seismic Testing and reports shall be certified, signed and "stamped" by PE Professional Engineer licensed and in good standing in the State, Civil Engineer or Structural Engineer.

### **PART 3 - EXECUTION**

#### **3.01 GROUNDING (ADDITIONAL REQUIREMENTS)**

- A. Grounding shall be executed in accordance with all applicable Codes and Regulations, both of the State of California and Local Authorities Having Jurisdiction.
- B. Each pull box or any other enclosure in which several ground wires are terminated shall be equipped with a ground bus secured to the interior of the enclosure. The bus shall have a separate lug for each ground conductor. No more than one conductor shall be installed per lug.
- C. The Maximum Resistance to Ground shall not exceed 5 ohms.

#### **3.02 OUTLET AND JUNCTION BOXES**

- A. General:
  1. Accurately place boxes and securely fastens to structural members. Where outlets are shown at same location but at different mounting heights, install outlets in one vertical line. Where outlets are shown at same location and mounting height, mount outlets as close together in a horizontal row as possible. Where the outlet boxes for switches and receptacles are shown at the same location and mounting height, mount in common outlet box with barriers between devices. Provide single piece multi-gang cover plate for close mounted outlet boxes. Where switches are shown on wall adjacent to hinge side of doors, box shall be installed to clear door when door is fully opened.

2. Flush mounted boxes shall be attached to not less than two parallel studs or structure members by means of metal supports. The supports shall span between and attach to the structure members.
  3. Boxes above accessible ceilings shall be attached to structural members. Where boxes are suspended, they shall be supported independently of conduit system by means of hanger rods and/or preformed steel channels. Boxes shall be supported independently of all piping, ductwork, equipment, ceiling hanger wires and suspended ceiling grid system.
  4. Surface mounted outlets shall be attached to concrete or masonry walls by means of expansion shields.
  5. Floor boxes shall be installed level with finish floor and within adjustable limits of floor ring. Where outlets are shown at same or adjacent location, use multi-gang boxes.
    - a. Provide cut-outs in the sub-floor assembly, to accept the recess depth of each electrical floor box. Provide added "fire-proof" applications on the bottom of each floor box location extending through the sub-floor. The "fire-proof" application shall be equal to the floor fire-assembly withstand rating.
    - b. Poke-thru floor outlets, core drill floor for installation of poke-thru. Install "split-box" in the ceiling space of the floor below. If the ceiling space of the floor below is not accessible ceiling type (lift-out), then provide 12-inches round removable fire-rated stainless steel access panel and trim-ring in the finish ceiling for hand-access to poke-thru "split-box" above the ceiling.
  6. Outlet Box Horizontal and Vertical Separation: Outlet boxes and device outlet rings installed flush in walls shall be horizontally and vertically separated by not less than 24-inches (edge of box to edge of box) from device outlet boxes and rings in common wall surfaces located on the opposite (back) side of the same wall.
    - a. Where the separation cannot be maintained, provide a solid backing behind and completely enclosing each outlet box.
    - b. The backing shall extend the width of the wall cavity (i.e., between "studs" or masonry cells) behind the box and 12-inches above and below the outlet box center-line, completely enclosing the outlet box.
    - c. The backing shall consist of the following:
      - 1)  $\frac{5}{8}$ -inch thick gypsum board anchored in place for "stud" wall construction.
      - 2) Solid "mortar" to completely fill the outlet box "cell" behind the box in masonry construction.
  7. Provide metal outlet box for each device. Install devices in metal outlet boxes. Typical for all wiring devices including, switches, receptacles, line voltage devices, and low voltage/signal system devices.
- B. Fire Wrap:
1. In fire rated walls and ceilings provide fire rated "box-wrap" around the outside of each outlet box placed in fire rated wall or ceiling. Install the fire wrap on exterior of box inside the wall or ceiling, to maintain the fire rating of wall or ceiling with the installed outlet boxes.

### 3.03 SWITCHES AND RECEPTACLES-DEVICES

#### A. General

1. Provide outlet boxes for all devices, switches, receptacles, both line-voltage and low-voltage.
2. Devices installed in wireways shall be installed flush in wireway assembly.
3. Install and screw attach devices into outlet boxes and wireways.
4. Provide ground circuit connections to all devices.
5. Provide branch circuit connections to all devices.
6. Provide testing and commissioning for proper operation and phase/ground connectors.
  - a. Test each GFCI devices and Arc-Fault devices after installation and circuit connection is complete.
  - b. Test all devices for correct polarity and proper electrical energization.
  - c. Test On-Off operation of automatically controlled outlets and receptacles.
7. Install and adjust all coverplates to be flush and level, with correct device and circuit identification.
8. Where one or more device occurs at the proximity with other similar devices, all of the devices shall be "granged" under one common coverplate as follows:
  - a. Duplex convenience receptacles with other proximity (within 18-inches) duplex convenience receptacles.
  - b. Lighting control switches not exceeding 20-amp switch rating with other proximity (within 18-inches) similar switches.

#### B. Line-voltage Plug-In Type Receptacle Installation Orientation:

1. The "ground-pin" shall face "up" at the receptacle top location (double duplex) 4-plex, individual and vertically mounted individual duplex receptacles.
2. The "neutral-blade" shall face "up" at the receptacle top location on horizontally mounted duplex receptacles.

### 3.04 CONCRETE WORK

#### A. Form:

1. Space forms properly with spreaders and securely tie together. Do not use twisted wire form ties. Keep forms wet to prevent joints from opening up before concrete is placed. Replace improper construction as directed. Do not use wood inside forms.
2. Build in and set all anchors, dowels, bolts, sleeves, iron frames, expansion joints and other materials required for the Electrical Work. Place all items carefully, true, straight, plumb, and even.
3. Carefully remove all exposed forms. Cut nails and tie wires below face of concrete and fill all holes. Rubbish will not be allowed to remain in, under, or around concrete.

- #### B. Mixing:
- Use batch machine mixer of approved type. After ingredients are in mixer, mix for at least 1½-minutes.



- C. Transit Mixing: In lieu of mixing at site, transit mixing may be used if rate of delivery, haul time, mixing time, and hopper capacity is such that concrete delivered will be placed in forms within 90-minutes from time of introduction of cement and water to mixer.
- D. Placing of Concrete
  - 1. Before placing concrete, remove wood, rubbish, vegetable matter and loose material from inside forms. Thoroughly wet down wood forms to close joints.
  - 2. Clean reinforcement; remove paint, loose rust, scale and foreign material. Bars with bends not called for will be rejected. Hold securely in place to prevent displacement. Lap bar splices 24-diameters, min; lap fabric one mesh min. Tie intersections, corners, splices with 16-gallon annealed wire, or as otherwise called for.
  - 3. Place concrete immediately after mixing. Do not use concrete that has begun to set; no tempering will be allowed. If chuting is used, avoid segregation. In placing new concrete against existing concrete, use bonding agent per Manufacturer's directions.
  - 4. Give careful and thorough attention to curing of concrete. Keep concrete and forms wet for a minimum of 10-days, after placing concrete.
- E. Concrete Finish
  - 1. Finish of Exposed Concrete: Horizontal surfaces, steel troweled monolithic finish; vertical surfaces, smooth and free of fins, holes, projection, etc.
  - 2. Exposed lighting pole bases shall be filled and sack finished to a smooth finish.
  - 3. Remove concrete pour-forms.

### **3.05 SURGE PROTECTION DEVICE INSTALLATION (SPD)**

- A. Direct Connect SPD Installation
  - 1. Install unit cabinet to insure a maximum connected circuit length of less than 5-feet from the equipment the surge protection unit is connected to, approximately plus 48-inches on wall.
  - 2. Alternately, factory install SPD unit directly into respective equipment, instead of remote from equipment. Install SPD inside respective switchgear, switchboards, distribution panels, panelboards, etc.
  - 3. Connect between surge protection unit and supply equipment with not less than 1.25-inch conduit containing 5#4 AWG, copper conductor, 600 volt THHN/THWN insulation, connection circuit.
  - 4. Provide a subfeed overcurrent protective device in the respective panel or switchboard to supply the SPD connection circuit, whether or not shown on the Drawings. The protective subfeed device shall be a thermal magnetic circuit breaker rated not less than 30-amp 3-pole or a safety switch and fuse unit rated not less than 60-amp 3-pole, voltage and short circuit fault interrupting class to match the respective circuit voltage.
  - 5. Connect surge protection unit to main building ground bus or electric distribution equipment ground bus (whichever is closer distance), with 1.25-inch conduit - 1#4 AWG copper conductor 600 volt, THHN/THWN insulation.
- B. Plug-in type SPD
  - 1. Install in respective equipment racks.

2. Install at respective workstation locations, cabinets and furniture.
  3. Connect to respective equipment and wall electrical outlets.
- C. Install, Connect, and Test each SPD Unit in Accordance with Manufacturer's recommendations.

### **3.06 WIREWAY INSTALLATION**

Wireway hangers shall provide clamp type, hanger rod type, direct bolted bracket type from ceiling or walls as indicated on the Drawings and required for field installation locations. Supports shall be installed a minimum of 5-feet on center.

END OF SECTION 26 05 01

022119/212220-ABR

This page is blank.

**SECTION 26 05 05  
ELECTRICAL DEMOLITION**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances, tools, equipment, facilities, transportation and services necessary for and incidental to performing all operations in connection with demolition, furnishing, delivery and installation of the work of this Section, complete, as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to, the following:
  - 1. Examine all other Sections for work related to those other Sections and required to be included as work under this Section.
  - 2. General Provisions and Requirements for electrical work.

**1.02 GENERAL SUMMARY OF DEMOLITION WORK**

- A. The Specifications and Drawings are intended to cover a complete installation. The omission of expressed reference to any item of labor or material for the proper execution of the work in accordance with present practice of the trade shall not relieve the Contractor from providing such additional labor and materials.
- B. Refer to the Drawings and Shop Drawings of other trades for Additional Demolition Requirements which affect the proper installation of this work. Diagrams and symbols showing electrical connections are diagrammatic only. Wiring diagrams do not necessarily show the exact physical arrangement of the equipment.
- C. It is the Contractor's responsibility to visit the site and become thoroughly familiar with all features of the building and site which may affect the proper performance of this work.
- D. Portions of these Plans have been derived from information taken from original Electrical Plans. The intent of the Drawing and Specifications is to provide a complete and operable system.

**1.03 LOCATIONS OF EQUIPMENT**

- A. The Drawings indicate diagrammatically the locations or arrangements of conduit runs, outlets, equipment, etc. Proper judgment must be exercised in executing the work so as to secure the best possible installation in the available space and to overcome local difficulties due to space limitations or interference of structure conditions encountered.
- B. In the event changes in the locations or arrangements are necessary, due to existing conditions in the building construction or arrangement of furnishings or equipment, such changes shall be made without cost, providing the change is ordered before the work directly connected to same is installed and no extra materials are required.

**1.04 UNDERGROUND DETECTION SERVICES**

- A. Services shall be provided utilizing the latest detection equipment available. Services available from Underground Technology Incorporated, phone (800) 366-7801. Services shall be performed by a company regularly engaged in the business of Underground Detection for the past 5-years.

- B. Prior to excavation the following work shall be performed:
1. Obtain all available Record Drawings of the site from the Owner.
  2. Obtain vellums of Civil Site Drawings for use in indicating existing underground systems.
  3. Contractor to mark trenching locations and indicate width and depth.
  4. Locate, by way of horizontal control, existing detectable sub-grade power conduits, fire alarm, communication, signal, sewer, water, gas, storm drain and irrigation lines in the affected areas.
  5. Arrange and meet with the Owner's Representative to review existing underground conditions.
  6. Exercise extreme caution in excavating and trenching on this site to avoid existing underground utilities, and to prevent hazard to personnel and/or damage to existing underground utilities or structures. These Drawings and Specifications do not include necessary components for construction safety, which is the responsibility of the Contractor.
  7. Repair/replace to the satisfaction of the Owner, any work damaged that was identified in the Record Drawings provided, noted by the Owner's Representative, or identified by the Underground Detection Services performed.
  8. The Contractor shall contact Underground Service Alert of Southern California, (800) 422-4133, at least 48 hours prior to excavation, and shall not excavate until verification has been received and that public utilities serving the site have located and marked.
- C. The locations of existing underground utilities, where shown on Drawings, are shown diagrammatically and have not been independently verified by the Owner or its Representative. The Architect and his Consulting Engineers are not responsible for the location of underground utilities or structures, whether or not shown or detailed and installed under this or any other Contracts.

#### **1.05 SUBMITTALS**

- A. Schedule: Submit proposed outage schedule.
- B. Provide a sequence of demolition to insure uninterrupted use of occupied facilities, which are to remain in operation during the Contract period.

#### **1.06 CUTTING AND PATCHING**

Perform cutting and patching of the construction work which may be required for the proper demolition of the electrical work. Patching shall be of the same material, thickness, workmanship and finish as existing and accurately match surrounding work to the satisfaction of the Architect. Cutting of Structural members shall not be done without notifying the Architect and obtaining structural approval.

#### **1.07 ASBESTOS, POLYCHLORINATED BIPHENYL (PCB) OR HAZARDOUS WASTE:**

It is understood and agreed that this Contract does not contemplate the handling of asbestos, PCB or any hazardous waste material. If asbestos, PCB or any hazardous waste material is encountered, notify the Owner immediately. Do not disturb, handle, or attempt to remove.

## **PART 2 - PRODUCTS**

NOT APPLICABLE

## **PART 3 -EXECUTION**

### **3.01 THE SCOPE OF THE DEMOLITION WORK SHALL INCLUDE ALL LABOR, MATERIALS, SERVICES, AND EQUIPMENT REQUIRED TO PROVIDE THE SPECIFIED NEW WORK. THIS WORK INCLUDES, BUT IS NOT LIMITED TO, THE FOLLOWING:**

- A. Exercise extreme caution in excavating and trenching on this site to avoid existing ducts, piping, conduits, and utilities.
- B. Refer to Architectural Drawings for ceiling removal locations. Except as noted otherwise, disconnect and remove all existing ceiling mounted lighting fixtures, smoke heat detectors, outlets and junction boxes, speakers, exposed wiring, raceways, and all other electrical devices and hardware attached to the ceiling structure.
- C. Refer to Architectural Drawings for wall removal locations. Except as noted otherwise, disconnect and remove all existing wall mounted receptacles, data outlets, telephone outlets, fire alarm devices, security devices, wiring, raceways, outlet boxes and all other electrical devices and hardware attached to the walls.
- D. All conduits rising from below grade to areas where partitions, walls, and/or other construction entities are indicated as being removed shall be cut to below finish floor, capped, and abandoned. Provide patching as required.
- E. Where new partitions or other construction will cover existing outlets or fixtures making them inaccessible, move these outlets and conduits as required, or make other provisions so that the outlets will remain accessible and operational.
- F. Relocate existing wiring, cabling, conduits and outlets from areas where plenums or roof openings are being provided.
- G. Where existing walls and ceilings are to remain, provide blank covers or plates for outlets where fixtures or devices are removed under this Contract. Prime blank plates and paint to match surrounding area.
- H. All existing panelboards, signal terminal cabinets, equipment racks, cabinets, disconnect switches; pullboxes, etc. shall remain unless noted otherwise on Plans.
- I. Disconnect and remove all existing signal system conduits, surface raceways wiring and cabling for telephone, data network, public address speakers, audiovisual systems, projectors, clocks, and fire alarm devices, intrusion detection device, television outlets unless noted otherwise on Plans.
- J. Seal all abandoned floor penetrations in manner acceptable to the Architect.
- K. Repair and/or replace roofing materials, ceiling tiles, fixtures, etc. damaged by this construction.
- L. Openings in existing fire rated partitions barriers, floors, ceiling etc. shall be sealed tight with UL and NEPA fire stop material equal to fire rating of the penetrated surface.
- M. Install all new conduits concealed in walls or furred ceilings.
- N. Remove all exposed conduit, wire, outlets, disconnect switches and electrical mounting hardware for equipment removed.

- O. Provide weatherproof caps on abandoned conduits penetrating the roof. Repair roofing damaged by removal of existing electrical equipment.
- P. For clarity, miscellaneous equipment, and raceways not related to Project are not shown.
- Q. All dimensions and locations of equipment are approximate. Contractor shall field verify all dimensions.
- R. Immediately notify the On-Site Inspector and Owner of any damage to new or existing work.
- S. Repair/replace all damaged or defective work, materials, and equipment to the Architects satisfaction.
- T. All removed materials and equipment, which in the opinion of Architect are salvageable, shall remain the property of the Owner. Deliver such salvaged materials and equipment on premises as directed, neatly pile or store them and Protect from damage. Where materials and equipment have been removed and not replaced the exposed surface shall be painted to match surrounding surfaces. Do not reuse materials and equipment, unless specifically indicated on Plans or specified. Remove from premises and dispose of all materials considered by Architect to be scrap.

END OF SECTION 26 05 05  
121918/212220-ABR

**SECTION 26 05 30**  
**CONDUIT AND WIRE**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances, tools, equipment, facilities, transportation and services necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
1. Examine all other Sections for work related to those other Sections and required to be included as work under this Section.
  2. General Provisions and Requirements for electrical work.

**1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

- A. Submit product data sheets for all wire, supports, conduit, fittings and splicing materials.
- B. Submit material list for all conduit and conduit fittings.
- C. Submit details and structural engineering calculations for conduit support systems.

**PART 2 - PRODUCTS**

**2.01 CONDUIT**

- A. General
1. The interior surfaces of conduits and fittings shall be continuous and smooth, with a constant interior diameter. Conduits and conduit fittings shall provide conductor raceways of fully enclosed circular cross section. The interior surfaces of conduits and fittings shall be without ridges, burrs irregularities or obstructions. Conduits and fittings of the same type shall be of the same uniform weight and thickness.
  2. Type of conduit, type of conduit fittings and conduit supports shall be suitable for the conditions of use and the conditions of location of installation, based on the Manufacturer's recommendations and based on applicable Codes.
  3. All fittings for metal conduit shall be suitable for use as a grounding means, pursuant to the applicable Code Requirements. All metal conduit and metal conduit fittings shall provide 3 second duration ground fault current carrying ratings, when installed and connected to the respective conduit, as follows:
    - a. RMC and EMT conduit fittings.
      - 1) 0.5 inch through 1.5 inch conduit/fitting size - 10,000 amp RMS.
      - 2) 2.0 inch and larger conduit/fitting size - 20,000 amp RMS.
    - b. FMC and LTFMC Conduit Fittings
      - 1) 0.5 inch through 1.25-inch conduit/fitting size-1,000 amp RMS (without external bonding jumper).
      - 2) 1.5 inch through 4.0-inch fitting size-10,000 amp RMS with bonding jumper.



4. Protective corrosion resistant finish for metal conduit fabricated from steel and metal conduit fittings fabricated from steel, shall be as follows:
    - a. Clean all metal surfaces (including metal threads) with acid bath “pickle” prior to coating, to remove dirt, oil and prepare surfaces for galvanizing.
    - b. Hot-dip galvanized zinc coating on all interior and exterior steel surfaces. Minimum finish zinc coating thickness shall not be less than 0.002 inches.
    - c. Threads shall be hot-dip zinc coated after machine fabrication.
    - d. Exterior metal surfaces shall be finished with clear organic polymer topcoat layer, after galvanizing.
    - e. The inner metal surfaces of conduit fittings shall be finished with a lubricating top-coat after galvanizing, to facilitate conductor pulling through the conduit/fitting.
  5. Threads for metal conduit and metal conduit fittings shall be taper-pipe-thread, National Pipe Standards (NPS) and shall comply with ANSI-B1.20.1.
  6. Metal conduit termination connector fittings shall be provided with a Manufacturer installed, insulating throat bushing inside the fitting. The bushing shall protect the wire conductor insulation from cutting, nicks and abrasion during conductor installation and electrical load “cycling” after installation is complete. The bushing shall comply with UL 94V-0 flammability.
  7. Provide conduit bonding/grounding jumper from metal enclosures with “concentric ring” knockouts, to positively ground/bond each respective conduit(s) to the metal enclosure.
  8. Metal conduit fittings connecting to PVC coated metal conduit shall be PVC coated to match the conduit.
  9. The conduit and fittings shall be watertight and airtight without cracks and pinholes.
- B. Rigid Metal Conduit (RMC)
1. Rigid metal, round tubing, machine threaded at both ends.
    - a. The conduit and conduit fittings shall comply with the Requirements for an equipment grounding conductor, pursuant to applicable Codes.
  2. RMC raceway types shall be as follows:
    - a. Rigid Galvanized Steel conduit (RGS), minimum yield strength shall be 35,000 PSI. Shall comply with NEMA Standard 5-19 (latest revision); ANSI C80.1 and ANSI-C80.4 (latest revision); UL 514-B and UL 6 (latest revisions); National Pipe Standard Specification (latest revision).
    - b. Intermediate steel Conduit (IMC). Shall comply with NEMA Standard 5-19 (latest revision) ANSI-C80.6 (latest revision); UL 2142 (latest revision).
  3. RMC fittings:
    - a. Fittings shall be compatible with RGS and IMC.
    - b. Fittings shall be rated “liquid tight”.
    - c. Fittings imbedded in concrete shall be rated “liquid tight” and “concrete tight”.
    - d. Connectors and couplings for terminating, connecting and coupling to RMC conduit shall be threaded metal.
    - e. Fittings shall comply with ANSI C80.4 and ANSI C33-84 (latest revision); NEMA FB1 (latest revision); UL 514 (latest revision).

- f. Conduit seal fittings:
  - 1) Conduit seals shall prevent the passage of gasses, liquids and vapors past the location of the seal installation in the conduit.
  - 2) Conduit seals shall be suitable for installation in both vertical and horizontal conduit locations.
  - 3) Conduit seals shall be visible and accessible for inspection after installation is complete.
  - 4) Conduit seals shall be rated for the following locations:
    - a) Wet locations
    - b) Classified hazardous location materials NEC Class 1 Division 1.
    - c) Temperature ranges from 0 degrees centigrade through 90 degrees centigrade.
  - 5) Conduit seals, sealing compound and sealing compound dam shall be the products of the same Manufacturer.
- 4. RMC fittings as manufactured by:
  - a. For threaded enclosure, termination connection.
    - 1) Thomas & Betts – 106 Series bonding locknut, 5302 Series sealing ring with stainless steel retainer.
  - b. For non-threaded enclosure, termination connector.
    - 1) Thomas & Betts – 370 Series watertight threaded sealing hub, 106 Series threaded bonding lock nut, Sta-Con Series enclosure bonding jumper and 3870 Series threaded ground bushing.
    - 2) Emerson-OZ/Gedney-CHMT/CHT watertight threaded hub with bonding locknut and GH50G Series enclosure bonding jumper.
  - c. For RMC to RMC conduit-to-conduit coupling
    - 1) Thomas & Betts/Erickson - 674 (threaded) Series
    - 2) Emerson-OZ/Gedney Type TPC (threaded) Series
    - 3) Threaded RMC conduit couplings, product of the same Manufacturer as the RMC conduit.
  - d. For RMC Conduit Seals
    - 1) Emerson-OZ/Gedney-EYA and EYAM (threaded) Series
    - 2) Appleton-EYF and EYM (threaded) Series
- C. Electrical Metallic Tubing (EMT)
  - 1. Rigid metal round tubing, “thin wall” steel construction, with non-threaded ends.
    - a. The conduit and conduit fittings shall comply with the Requirements for an equipment grounding conductor pursuant to applicable Codes.
    - b. The conduit shall be watertight and airtight without cracks and pinholes.
  - 2. EMT shall be allowed for conduit size ranges from 0.5-inch through 4.0-inches.
  - 3. Comply with ANSI C80.3, C80.4, and ANSI C33.98 (latest revisions); UL 594 and UL 797 (latest revisions); CEC Section 12500 (latest revision).
  - 4. EMT fittings:
    - a. Connectors and couplings for terminating, connecting and coupling to EMT conduit shall be non-threaded steel fabrication.

- b. EMT termination connector fittings shall be as follows:
    - 1) Set screw type “concrete tight” when installed in dry interior locations.
    - 2) Compression types “raintight” and “concrete tight” when installed in wet or damp locations, outdoors and in concrete or masonry construction.
  - c. Fittings shall comply with ANSI C33.84 (latest revision); UL 514 (latest revision); NEMA FB-1.
5. EMT fittings as manufactured by:
- a. For threaded and non-threaded enclosure, termination connector
    - 1) Thomas & Betts-TC721A (set screw type) Series (with locknuts).
    - 2) Emerson-OZ/Gedney-TC500I (set screw type) Series (with locknuts).
    - 3) Thomas & Betts-5123 (compression type) Series (with two locknuts).
    - 4) Emerson-OZ/Gedney-TC600I (compression type) Series (with locknut).
    - 5) Thomas & Betts-4240 (compression type) Series (90 degree angle with locknut).
    - 6) Emerson-OZ/Gedney-TWL (compression type) Series (90 degree angle with locknut).
  - b. For EMT to EMT conduit-to-conduit coupling:
    - 1) Thomas & Betts-TK121A (set screw type) Series (with locknut).
    - 2) Emerson-OZ/Gedney-5000 (set screw type) Series (with locknut).
    - 3) Thomas & Betts-5120 (compression type) Series.
    - 4) Emerson-OZ/Gedney-TC600 (compression type) Series.
  - c. For EMT to RMC conduit to conduit combination coupling:
    - 1) Thomas & Betts-HT221 (set screw type) Series.
    - 2) Emerson-OZ/Gedney-ESR (set screw type) Series.
    - 3) Thomas & Betts-530 (compression type) Series.
    - 4) Emerson-OZ/Gedney-ETR (compression type) Series.
- D. Flexible Metal Conduit (FMC)
- 1. Round flexible conduit, fabricated from a single continuous steel strip. The steel shall be factory formed into continuous interlocking convolutions to form a complete lock between steel strips and provide raceway flexibility.
  - 2. Metal to metal grounding contact shall be maintained throughout the length of the FMC conduit.
  - 3. FMC shall be allowed for conduit size ranges from 0.5 inch through 4.0-inches.
  - 4. FMC shall comply with ANSI-C.33.84 and ANSI C33.92; NEMA FB-1; CEC 12-1100.
  - 5. FMC Fittings
    - a. FMC fittings shall be malleable iron construction or steel construction.
    - b. Fitting shall automatically cause the FMC raceway throat opening to be centered with respect to the fitting throat opening.
    - c. Straight and angled connector termination fittings shall be threaded on one end and shall include a threaded locknut, suitable for connection to threaded and unthreaded enclosures.
    - d. The attachment of the fittings to FMC shall be angled saddle type, to engage and interlock with the FMC spiral groove, and shall be unaffected by vibration. Direct bearing screw type fittings shall not be used.

- e. Direct FMC conduit-to-FMC conduit coupling of FMC shall not be permitted.
  - f. Shall comply with ANSI C33.9, and ANSI C33.92 (latest revision); NEMA FB1 (latest revision); UL 514.
6. FMC fittings as manufactured by:
- a. Straight Termination Connectors                      45 and 90 Degree Angle Connectors  
       Thomas & Betts-3110 Series (w/ locknut)    Thomas & Betts-3130 Series (w/ locknut)
  - b. FMC to EMT conduit combination coupling: Thomas & Betts 503TB Series.
- E. Liquid Tight Flexible Metal Conduit (LTFMC)
1. The metal conduit core of LTFMC shall comply with the same Requirements as FMC conduit, with the addition of a thermoplastic exterior flexible jacket over the metal core.
  2. The exterior jacket shall be positively locked to the metal core to prevent jacket "sleeving".
  3. The LTFMC shall be rated for installation and operating service temperatures of between minus 20 degrees centigrade through plus 90 degrees centigrade.
  4. The LTFMC jacket shall be suitable for continuous exposure to sunlight, rainwater, water vapor, mineral oils and liquid solvents, without penetrating into the conduit and without deteriorating the jacket.
  5. LTFMC sizes from 0.5-inch through 1.25-inch shall include an additional internal ground conductor, fabricated by the Manufacturer, as an integral part of the conduit core.
  6. Direct LTFMC conduit-to-LTFMC conduit coupling of LTFMC shall not be permitted.
  7. LTFMC shall be allowed for conduit size ranges from 0.5-inch through 4.0-inches.
  8. In addition to the Requirements for FMC conduit, LTFMC shall also comply with ANSI C-33.84 (latest revision); NEMA-FB1 (latest revision); CEC 12-1400 (latest revision).
  9. LTFMC fittings
    - a. Fittings shall include an external mechanical ground/bond wire connector.
    - b. The attachment of the fitting to LTFMC shall be threaded compression type onto the conduit core with locknut and liquid tight jacket compression seal. The fitting shall automatically prevent "sleeving" of the jacket.
    - c. Straight and angled termination connector fittings shall be threaded on one end and shall include locknut suitable for connection to threaded and unthreaded enclosures.
  10. LTFMC fittings as manufactured by:
    - a. Termination connector fittings:
 

|  |   |
|--|---|
| <u>Straight</u>  | <u>45 and 90 Degree Angle Connectors</u>                                |
| 1) Thomas & Betts-5331 GR Series.                                  | Thomas & Betts-5341GR & 5351GR Series.                                  |
| 2) Appleton-STB & STN-L Series for use with preformed "knockouts". | Appleton-STB-L Series; STN-L Series for use with preformed "knockouts". |
| 3) Emerson- OZ/Gedney-4Q Series.                                   | Emerson-OZ/Gedney-4Q Series   |
    - b. LTFMC to RMC conduit to conduit combination coupling fittings:
      - 1) Thomas & Betts-5271 GR Series.
      - 2) Emerson-OZ/Gedney-4Q Series

F. Rigid Non Metallic Conduit (RNMC)

1. General

- a. Conduit and fittings shall be 90 degree centigrade conductor rated. Fabricated from homogeneous material, free from visible cracks, holes or foreign inclusions, with integral "end-bell". The conduit and conduit fittings shall be watertight and airtight.
- b. Conduit, conduit fittings and conduit fitting assembly "solvent cement" shall all be the product of the same Manufacturer. Conduit fittings shall be solvent cement welded watertight.
- c. Conduit and fittings shall be identified with legible markings showing ratings, size and Manufacturers name.
- d. RNMC and fitting shall be corrosion resistant, watertight.
- e. Conduit shall be suitable for conductor operating temperatures from minus 20 degrees centigrade to 90 degrees centigrade.
- f. RNMC shall comply with NEMA TC-2 (PVC 40 conduit, latest revision) NEMA TC-6 (EB conduit latest revision) and NEMA TC-3 (fittings, latest revision); UL 514 and UL 651 (latest revision).

2. Polyvinyl Chloride (PVC)-RNMC

- a. PVC-Schedule 40 heavy wall construction.
- b. PVC-Schedule 80 extra heavy wall construction.
- c. PVC-Type EB.

3. RNMC fittings connecting to metallic raceways shall be provided with a ground/bond jumper connection.

G. Combi-Duct

1. Rigid nonmetallic conduit combining a continuous linear outer raceway (duct) with factory installed (inside the outer duct) multiple, segregated inner raceway (ducts). Rigid, Schedule 40 PVC construction. Shall be modular lengths of 20-feet for each duct segment.
2. The conduit shall be suitable for use with signal/telecommunications, fiber optic, telephone and computer/data circuits, operating at 100 volts or less, UL listed and labeled.
3. Outer Duct, outer enclosing Schedule-40 PVC duct size. The outer enclosing duct shall be 4.2-inches inside nominal duct diameter and 4.5-inches outer duct nominal diameter.
4. Inner-ducts (contained inside the enclosing outer duct), non-metallic SDR-19 or Type-C/CAO-8546:
  - a. Triple Combi-Duct  
Quantity of three continuous round rigid inner linear ducts, nominal size inside diameter 1.5-inch for each inner duct.
  - b. Quad Combi-Duct  
Quantity of four continuous round rigid inner linear ducts, nominal size inside diameter 1.19-inch for each inner duct.
5. Manufacturer's standard bends and offsets, minimum 72-inches radius.
6. Combi-duct and combi-duct fittings shall be airtight and watertight. Approved for direct burial in earth and approved for encasement in concrete.

7. As manufactured by Carlon # Multi-Guard/Multi-Cell Series; American Pipe and Plastic (AMTEL) #Multi-Bore Series; or equal.
- H. Expansion Joint, Deflection Joint and Seismic Joint Conduit Fittings
1. Expansion Conduit Fitting – Fitting shall provide for a minimum of 2-inches straight line movement between two connecting conduits in each direction (total 4-inches conduit expansion and Contraction) parallel to the respective conduit lengths. Fitting shall be watertight.
  2. Deflection Conduit Fitting – Fitting shall provide for a minimum of 30 degrees angular deflection movement (“Shear” deflection) between two connecting conduits, in any direction perpendicular to the length of the respective conduits. Fitting shall be watertight.
  3. Combination Expansion/Deflection Conduit Fitting – Fitting shall provide the combined “expansion” and “deflection” movement capacity between two connecting conduits as described for separate “expansion” and “Deflection” conduit fittings. Fitting shall be approved for installation concealed in both masonry/concrete construction and exposed non-masonry/concrete construction. Fitting shall be watertight.
  4. Fittings shall comply with UL.
  5. Fittings as manufactured by:
    - a. Conduit expansion fittings exposed or concealed locations as manufactured by:
      - 1) Emerson-OZ/Gedney – AXB-8 Series for RMC conduit.
      - 2) Emerson-OZ/Gedney - TX Series for EMT conduit.
      - 3) Appleton – AXB or XJ8 Series for RMC conduit and EMT conduits. Provide RMC to EMT combination conduit coupling fittings for each end of the expansion fitting.
    - b. Combination expansion/deflection conduit fittings exposed or concealed conduit locations as manufactured by:
      - 1) Emerson-OZ/Gedney - AXDX Series for RMC conduit.
      - 2) Emerson-OZ/Gedney - AXDX Series for EMT conduit.
      - 3) Appleton-DX Series for RMC conduit.
      - 4) Provide RMC to EMT combination conduit coupling fittings for each end of the expansion/deflection fitting.
    - c. Conduit expansion/deflection fittings for FMC and LTFMC conduit.
      - 1) Provide a minimum of 12-inches of “slack” LTFMC in each FMC or LTFMC conduit at building and structure seismic or expansion joint conduit crossings.
      - 2) Note: Each FMC “slack” expansion/deflection location, shall be considered as not less than a 90 degree conduit bend location, for compliance with the maximum quantity of conduit bends allowed in a raceway.
  6. Conduit fitting bonding jumper:
    - a. The grounding/bonding path of metal conduit shall be maintained by the fitting.
    - b. Provide a bonding jumper at each expansion, deflection and combination expansion deflection conduit fitting.
    - c. The jumper shall be a bare flexible copper “braid”. The copper braid electrical current carrying capacity shall be equal to the metal conduit.

- d. Provide a factory terminated ground clamp on each end of the braid with adjusting steel conduit grounding clamps and connect to each respective conduit end.
  - e. The jumper braid length shall be 8-inches longer than the respective conduit fitting.
  - f. Bonding jumper for FMC and EMT fittings as manufactured by:
    - 1) Emerson-OZ/Gedney – BJ and BJE Series
    - 2) Appleton – BJ/XJ Series
- I. Conduit Bodies Conduit Fitting
- 1. Conduit bodies shall provide conductor access with a removable conduit body cover and wiring area enclosed in metal housing. The conduit body shall facilitate pulling conductors.
  - 2. In-line form “C” conduit bodies shall be prohibited.
  - 3. The interior space “length” of 90 degree “elbow” conduit bodies shall not be less than six times the diameter size of the largest conduit connecting to the conduit body.
  - 4. Conduit body covers shall be removable, gasketed; watertight “domed” metal covers “Mogul-Type” with threaded screw attachment to the conduit body.
  - 5. Lubricated, reusable, wire roller guards inside the conduit body shall protect wire from insulation damage during wire “pulling”.
  - 6. Conduit body fittings shall comply with UL 514.
  - 7. Conduit bodies as manufactured by:
    - a. For RMC Conduit
      - 1) Hubbell/Killark – LB/Mogul (90-degree elbow) Series – threaded body.
      - 2) Emerson-OZ/Gedney - LB 6X/Mogul (90 degree elbow) Series - threaded body.
      - 3) Appleton – NEC6X-LB/Mogul (90 degree elbow) Series - threaded body.
    - b. For EMT Conduit
      - 1) Same as for RMC conduit. Provide EMT to RMC conduit combination coupling fitting for each outlet body connection.

## 2.02 PVC COATING

- A. PVC coatings shall be provided as described for specified metal products.
- B. PVC coating shall be factory applied, to comply with NEMA-RN1 and 5-19.
- C. The adhesion of the PVC coating to the coated metal shall exceed the strength of the coating itself, based on 0.5-inch “strip-pull” test.
- D. Uniform coating thickness shall be continuous without “breaks” or “pinholes” and shall not be less than the following:
  - 1. Exterior metal surfaces, 40-millimeter coating thickness.
  - 2. Interior metal surfaces, 10-millimeter PVC or urethane coating thickness (i.e. interior of conduits, interior of conduit fittings etc.).

## 2.03 CONDUIT SUPPORTS

- A. General
  - 1. Conduit Supports, hangers and fasteners for metal conduit shall be steel, hot dip zinc galvanized.

2. Conduit supports, hangers and fasteners for PVC coated conduit shall be PVC coated to match the conduit PVC coating.
  3. Threaded hardware shall be continuous, free running threads.
  4. Conduit support systems, including support channels, pipe clamps, braces, anchors, hardware, fasteners, shall be sized to support the full capacity circuit conductors weight, plus the installed conduit weight, plus the conduit fitting weight and support hardware weight, plus a 300% additional weight capacity safety factor.
  5. Provide lock washer at each "bolted"/threaded connection.
  6. Conduit supports, fasteners, channels, braces, hardware, anchors, pipe clamps, and hangers as manufactured by Unistrut or Kindorf.
  7. Supports shall be free of "BURRS" and sharp edges.
  8. Metal supports cut in the field shall be zinc galvanized after cutting to prevent rust.
- B. Conduit Hangers
1. Threaded steel hanger rods.
    - a. Hanger rods smaller than 0.375-inches in diameter shall not be used for support of individual conduits.
    - b. Hanger rods smaller than 0.5-inches in diameter shall not be used for support of multiple conduits.
  2. Conduit hanger wires shall be not less than 12-gauge steel.
  3. Conduit hangers shall attach to structure fasteners with steel "Clevis" or "Swing" hangers and shall provide a minimum of 45 degrees of angular movement in any direction at the point of the conduit hanger attachment to the structure fasteners.
  4. Conduits individually suspended by conduit hangers shall fasten to the respective hangers with "Clevis" type pipe hangers. The pipe hangers shall be steel, adjustable to fit conduit size and shall completely enclose the conduit circumference.
- C. Conduit Support Channels
1. "C" channels shall be factory preformed with a minimum 12 gauge thickness metal. The channel shall be factory "punched" with regularly spaced slotted holes for fastener attachments along the length of the channel.
  2. The "C" channel shall not deflect more than 0.1 inch between channel supports at maximum installed design load, including required safety factor.
  3. Channels shall comply with ANSI-1008 (latest revision) and ASTM-A569 latest revision).
  4. Channels shall provide "turned lips" at longitudinal edges to hold (lock-in) fasteners.
  5. Conduit support channels suspended from conduit hangers shall attach to conduit hangers with treaded connections. Provide a minimum of two hangers (trapeze style) connected to each channel.
  6. Non-suspended conduit support channels shall connect to structure fasteners with threaded connectors.



D. Fasteners, Seismic Earthquake Rated

1. Channel fasteners:
  - a. Channel fasteners shall “prelocate” and lock into the channel “turned lips” and channel “walls”.
  - b. A separate metal strap shall “tie” each conduit to each channel with conduit channel fasteners.
2. Structure fasteners:
  - a. Structure fasteners for wall and floor mounted conduit attachments shall attach to existing masonry and concrete structures with structure fasteners using drilled, mechanical, expansion shield anchors.
  - b. Structure fasteners for wall and floor mounted conduit attachments shall attach to new masonry and concrete structures with structure fasteners using steel threaded inserts precast into the structures.
  - c. Structure fasteners shall center the support load above or below the beam flanges and reduce torsion-rotation forces exerted on the structural beam. Attach to steel structural members with “swing-beam clamps”, with set-locking screw structure fasteners.
    - 1) Beam clamps shall include integral safety rod, strap or “J”-hook to secure the attachment clamp to the beam flanges on both sides of the beam, with integral hanger rod attachment.
    - 2) Or double-ended beam clamp to secure the attachment clamp to the beam flanges on both sides of the beam, with integral hanger rod attachment.
  - d. Structure fasteners for wall and floor mounted conduit attachments shall attach to wood structural members with flush “through-bolted” wood beam/ wood framing stud structure fasteners.
  - e. Structure fasteners for wall mounted conduit attachments shall attach to steel framing studs and steel structural elements with spot welded steel structure fasteners or drilled and bolted structure fasteners.

E. Brace Connectors

1. Provide lateral brace connectors to resist horizontal, lateral and vertical movement of suspended conduits during seismic earthquakes.
2. The braces shall connect from each conduit support, attach as close to the conduit as possible, and attach to fixed rigid, nonsuspended building “main” structural elements with fixed anchoring.
3. Brace attachment connectors and fasteners shall be rigid preformed steel channels or flexible #10 gauge steel hanger wire.
4. Connect and attach the brace connectors to fixed structural elements in the same manner as conduit support hangers. The connection of braces to structural elements shall be independent of the conduit support hanger structure fasteners.

**2.04 ELECTRICAL POWER WIRE AND CABLE**

A. General

1. All wire and cable shall be single-conductor, annealed copper, insulated 600 volt, #12AWG minimum unless specifically noted otherwise on the Drawings.

2. Conductors #10AWG and smaller shall be solid. Conductors #8AWG and larger shall be stranded.
  3. Insulation of conductor connected to circuit protection devices required to be "100%" rated, shall be 90 degree centigrade rated insulation.
  4. Insulation of conductors installed outdoors, on grade or underground, insulation shall be rated for wet locations.
  5. Insulation of conductors installed outdoors, installed exposed to the sun, installed in exposed conduits, insulation shall be rated for high-temperature 90 degrees centigrade.
  6. Insulation of branch circuit conducts installed in light fixtures, insulation shall be rated for 90 degrees centigrade.
  7. Conductor exposed to oil, insulation and jacket shall be oil resistant, complying with "Oil Resistant-1" and "Oil Resistant-2" UL 83.
- B. Conductor Insulation
1. 600 Volt AC and/or DC insulated conductors installed entirely inside conduits, or enclosed inside wireways, or enclosed inside raceways, insulation shall be rated as follows.
  2. Indoor above Grade locations either concealed or exposed.
    - a. Dual rated THHN and THWN
    - b. Individually rated THHN-2
    - c. Individually rated THWN-2
    - d. XHHW-2
  3. Outdoor above Grade either concealed or exposed.
    - a. XHHW-2
    - b. THWN-2
    - c. THW-2
  4. Outdoor below Grade or outdoor on Grade.
    - a. XHHW-2
    - b. THWN-2
    - c. THW-2
  5. All other enclosed raceway locations not described above.
    - a. XHHW-2
    - b. THWN-2
    - c. THW-2
  6. Health Care facilities all circuits insulation shall be XHHW-2, rated Hospital-Grade.
  7. 600 Volt AC and/or DC insulated conductors installed in open cable tray or open wireway or exposed insulation also shall be rated for exposed install locations.
- C. Insulation Color Coding and Identification
1. The following color code for branch circuits:
    - a. Neutral . . . White (Tape feeder neutrals with white tape near connections)

- b. Normal Power
 

|                     |                     |
|---------------------|---------------------|
| <u>120/208 Volt</u> | <u>480/277 Volt</u> |
| Ground Green        | Ground Green        |
| Phase A Black       | Phase A Brown       |
| Phase B Red         | Phase B Orange      |
| Phase C Blue        | Phase C Yellow      |
  - c. Isolated ground insulation shall be green with a longitudinal yellow stripe.
  - d. Emergency power same insulation color as normal power except as follows:
    - 120/208 Volt  
Provide an additional continuous stripe on each conductor insulation, orange or yellow, except ground
    - 480/277 Volt  
Provide an additional continuous stripe on each conductor insulation blue or black, except ground
2. When individual neutral conductors are shown/required for each branch circuit, the color code for the neutral conductors shall be as follows:
    - a. 120/208 volt; Phase A - White with Black stripe; Phase B - White with Red stripe; Phase C - White with Blue stripe.
    - b. 277/480 volt; Phase A - White with Brown stripe; Phase B - White with Orange stripe; Phase C - White with Yellow stripe.
  3. Feeders identified as to phase or leg in each, switchboard, switchgear, panelboard and junction location with printed identifying tape.
  4. Fire alarm conductors: Use 600-volt, type THHN-2/THWN-2 conductors and color-coded per Equipment Manufacturer's recommendations and approved and listed for use on fire alarm systems by the State Fire Marshal.
  5. Color coding for mechanical and plumbing control wiring shall be an agreed upon color code between the Mechanical/Plumbing Contractor and the Electrical Contractor, and color code shall be submitted to the District's Representative in writing for approval prior to installation.

## 2.05 CHEMICAL GROUND ROD

### A. General

1. Self-contained ground rod(s) using chemically enhanced grounding shall be provided where specifically indicated on the Drawings. As manufactured by Lyncole XIT Grounding Systems, 22412 South Normandie Avenue, Torrance, CA. Telephone #(800) 962-2610; or Superior Grounding Systems, Irwindale, CA. Telephone # (800) 747-7925; or ERICO – Eritech Chemical Ground Electrode.
2. The ground rod shall operate from changes in atmospheric pressure pumping air through the ground rod, hygroscopically extracting moisture from the air to activate the ground electrolytic chemicals and improve the ground rod performance.
3. Ground rod system shall be UL-467 listed.
4. Ground rod system shall be 100% self-activating, sealed and maintenance free. The addition of chemical or water solutions shall not be required.

B. Ground Rod

1. Ground rod shall consist of a 2-inches nominal diameter hollow, copper tube. The tube shall be permanently capped on the top and bottom. Air breather holes shall be provided in the top of tube. Drainage holes shall be provided in the bottom and sides of the tube for electrolyte drainage into the surrounding soil.
2. The ground rod shall be chemically filled at the factory with environmentally non-hazardous water-soluble metallic salts to enhance electrical grounding performance.
3. Ground rod shall be a minimum of 10-feet long for straight (vertical) installation; or "L" shape minimum 20-feet long for horizontal installation.
4. Ground wire clamping "U-Bolt" with pressure plate on the top end of the tube sized for 1#2 through 500 MCM AWG ground electrode conductor connections, and stranded 4/0AWG copper pigtail exothermically welded to the side of rod for ground electrode conductor connection.

C. Ground Box

1. Precast concrete box with slots for conduit entrances. Approximately 10-inch diameter by 12-inches high. Cast iron grate flush cover with "Breather" slots XIT Box #XB-12.

D. Backfill Material

1. Natural volcanic, non-corrosive Bentonite Clay backfill material.
2. Shall absorb water at a minimum of thirteen times its dry volume or approximately 14 gallons for 50 pounds of clay.
3. PH Value 8-10 with maximum resistivity of 2.5 OHMS-M at 300% moisture content by weight.

## 2.06 FLEXIBLE CORDS AND PORTABLE CABLES

A. General

1. Multi-conductor insulated flexible cable with jacket rated extra heavy duty, extra hard-use and high abuse duty; ozone, sunlight, grease, oil resistant-UL 83 and water resistant; rated for indoor/outdoor use.
2. Quantity of conductors and conductor sizes as indicated on the Drawings but in no case less than five 16AWG.
3. Characteristics:
  - a. Conductors - stranded copper, soft annealed conforming to ASTM-B-174 and ASTM-B-172. 600 volt individually insulated and color-coded. Separate green insulated ground conductor. Aluminum conductors shall not be permitted for cords and cables.
  - b. Insulation - rubber conforming to UL 62; temperature range plus 105° Centigrade to minus 50° Centigrade.
  - c. Flame resistance shall conform with MSHA-P123-103.
  - d. Jacket - black for equipment connections and yellow for outlet connections. Rated for temperature range plus 105° Centigrade to minus 50° Centigrade, water, sunlight and ozone resistant. Permanently mark jacket a minimum of 40-inches on center with rated voltage, Manufacturer's name, wire/insulation type, AWG conductor size and quantity (minimum 24-inches on center).

## 2.07 CABLE RACKS

- A. Cable racks, installed on the vertical walls of the structure, including hooks and porcelain insulator cable cradles, shall be sufficient to accommodate the cables and splices.
- B. Vertical racks shall be installed on all walls of the structure a minimum of 24-inches on center within 6-inches of floor and top of wall. A rack shall be installed within 18-inches of each corner of each wall. Additional racks spaced equally on each wall shall be installed; spacing between vertical wall racks shall not exceed 24-inches.
1. Wall racks shall be slotted to accept removable hooks and lock hooks into place.
  2. Non-metallic, 50% (minimum) glass reinforced nylon or non-metallic material of the same characteristics.
  3. The installed cable racks, cable support hooks with arms and wall anchor bolts shall support the following minimum loads for each hook/arm, with a 200% minimum safety factor. Based on multiple hook/arms located not less than 9-inches on center along the entire vertical length of the support rack:

|    | <u>Hook/Arm Length</u> | <u>Min. Weight Each Hook/Arm Supported</u> | <u>Max. Allowable Hook/Arm Deflection</u> |
|----|------------------------|--|---|
| a. | 8-inches               | 450 pounds                                 | 0.25-inch                                 |
| b. | 14-inches              | 350 pounds                                 | 0.37-inch                                 |
| c. | 20-inches              | 250 pounds                                 | 0.37-inch                                 |

(Based on load concentrated 1-inch from the end of each hook/arm.)
  4. Racks shall be bolted to the precast and cast-in place structure walls, within 3-inches of each rack end and not less than 9-inches on center. Provide cast-in place or after-set drilled expansion concrete anchors.

## PART 3 - EXECUTION

### 3.01 TRENCHING, FOOTINGS, SLEEVES

- A. Provide trenching, concrete encasement of conduits, backfilling, and compaction for the underground electrical work, in accordance with applicable Sections of this Specification.
- B. Provide footings for all post and/or pole-mounted lighting fixtures: concrete shall conform to the applicable Sections of this Specification.
- C. Sleeves
1. Provide sleeves for raceways, conduit and wire/cables passing through the following construction elements:
    - a. Concrete and masonry foundations, floors, walls and slabs.
    - b. Gypsum, Lath, and plaster walls and ceilings.
    - c. Building structures (i.e., foundations, walls, floors, ceilings, beams, and roofs) with a fire rating exceeding 20-minutes.
  2. Sleeves shall extend 1.5-inch above and below floors, except under floor standing electrical equipment. Sleeves shall be flush with wall ceiling foundations and partitions exposed to public view and extend approximately 0.5-inch past penetration in fire rated construction. Sleeves shall be installed at exact penetration locations and angles to accommodate wire/cable, raceway and conduit routings.

3. Joists, girders, beams, columns or reinforcing steel shall not be cut or weakened. Where construction necessitates the routing of conduit or raceways through structural members, framing or footings, written permission to make such installation shall first be obtained from the District's Representative. Such permission will not be granted, however, if any other method of installation is possible.
4. The layout and design of raceways and conduits located in or routed through masonry or reinforced beams or the District's Representative shall review walls before any work is performed. All sleeving shall be accomplished according to the instructions of the District's Representative and shall be accepted before any concrete is poured.
5. Sleeves, raceways and conduit shall be located to clear steel reinforcing bars in beams. Reinforcing bars in walls shall be offset to clear piping and sleeves.
6. Provide a continuous clearance between the inside of a sleeve and exterior of wire/cables, conduits and raceways passing through the sleeve not less than the following:
  - a. 0.5-inch clearance except as required otherwise.
  - b. 1.0-inch clearance through outside walls below grade.
  - c. 3.0-inch clearance through seismic joints.
7. Sleeves set in fire rated construction shall be caulked between sleeve and building structure, additionally sleeves shall be caulked between the sleeve and the wire/cables, conduits/raceways passing through the sleeve. The caulking shall be a fireproof sealant, equal to the fire rating and temperature being penetrated. Clearance between components inside of sleeve and exterior of components passing through sleeve and between components inside the sleeve shall comply with Fire-proof Sealant Manufacturer's recommendations.
8. Sleeve material:
  - a. In floor construction: Schedule 40 black steel pipe, with upper surface to be sealed watertight.
  - b. In concrete or masonry walls roofs or ceilings: Schedule 40 black steel pipe. When installed in roofs or outside walls, seal outer surface watertight.
  - c. In fire rated construction; 24 gauge galvanized iron or steel.
  - d. Sleeves through waterproof membranes: Cast iron or Schedule 40 steel with flashing clamp device and corrosion resistant clamping bolts. Caulk space between pipe and sleeve and sur-faces between sleeve and conduits sealed watertight.

### **3.02 GROUNDING**

- A. Grounding shall be executed in accordance with all Applicable Codes and Regulations, both of the State and Local Authorities Having Jurisdiction.
- B. Where nonmetallic conduit is used in the distribution system, the Contractor shall install the proper sized copper ground wire in the conduit with the feeder for use as an equipment ground. The electrical metallic raceway system shall be grounded to this ground wire.
- C. The maximum ground/bond resistance to the grounding electrode shall not exceed 1 ohms from any location in the electrical system. The maximum ground resistance of the grounding electrode to earth shall not exceed 5 ohms.

D. Ground/Bond Conductors

1. Provide an additional, dedicated, green insulation equipment ground/bond wire inside each conduit type and raceway as follows. Size the ground/bond conductors to comply with CEC/NEC Requirements. The metal conduit or raceway shall not be permitted to serve (function) as the only (exclusive) electrical ground return path:
  - a. All types of nonmetallic conduit and all types of non-metallic raceways including but not limited to: RNMC – Rigid Nonmetallic Conduit.
  - b. FMC - Flexible Metal Conduit.
  - c. LTFMC - Liquid Tight Flexible Metal Conduit.
  - d. Metal and non-metal raceways.
  - e. RMC - Rigid Metal Conduit.
  - f. EMT - Electrical Metal Tubing.
  
2. The equipment ground/bond wire shall be continuous from the electrical circuit source point of origin to the electrical circuit end termination utilization point as follows:
  - a. Every conduit and raceway path containing any length of the above identified conduits or race-way.
  - b. Every conduit path and raceway path connected to any length of the above-identified conduits and raceways.
  
3. The equipment ground/bond wire shall be sized as follows, but in no case smaller than indicated on the Drawings. Install equipment ground/bond wire in each conduit/race-way, with the respective phase conductors:
 

|  |                                   |
|--|-----------------------------------|
| a. <u>Feeder, Subfeeders &amp; Branch Circuit Protection</u> | <u>Min. Equip. Grnd Wire Size</u> |
| 15 amp   | #12                               |
| 20 amp   | #12                               |
| 30 to 60 amp   | #10                               |
| 70 to 100 amp  | #8                                |
| 101 to 200 amp   | #6                                |
| 201 to 400 amp   | #2                                |
| 401 to 600 amp   | #1                                |
| 801 to 1000 amp  | 2/0                               |
| 1001 to 1200 amp   | 3/0                               |
| 1201 to 1600 amp   | 4/0                               |
| 1601 to 2000 amp   | 250 MCM                           |
| 2001 to 2500 amp   | 350 MCM                           |
| 2501 to 4000 amp   | 500 MCM                           |
  
4. Isolated grounds - Raceways containing branch circuit or feeder phase conductors connected to panel-boards equipment, or receptacles with isolated grounds or isolated ground bus shall contain a dedicated insulated ground conductor connected to the isolated ground system only. The isolated ground conductor shall be continuous the length of the raceways and connected only to the isolated ground terminals in addition to and independent of the equipment bonding/ground conductor. The isolated ground conductor shall be sized as indicated above, for equipment ground/bond wire.
  
5. Splices in ground/bond wires shall be permitted only at the following locations:
  - a. Ground buses with listed and approved ground lugs.

- b. Where exothermic welded ground/bond wire splices are provided.
- 6. Provide ground/bond wire jumpers for conduit fittings with ground lugs, expansion and deflection conduit fittings at conduit fittings connecting between metallic and non-metallic raceways and to bond metal enclosures to conduit fittings with ground lugs.
- E. Where conductors are run in parallel in multiple raceways, the grounding conductor shall be run in parallel. Each parallel equipment-grounding conductor shall be sized on the basis of the ampere rating of the over-current device protecting the circuit conductors in the raceway. When conductors are adjusted in size to compensate for voltage drop, grounding conductors, where required, shall be adjusted proportionately in size.
- F. Ground conductors for branch circuit wiring shall be attached at each outlet to the back of the box using drilled and tapped holes and washer head screws, 6-32 or larger.
- G. Each panelboard, switchboard, pull box or any other enclosure in which several ground wires are terminated shall be equipped with a ground bus secured to the interior of the enclosure. The bus shall have a separate lug for each ground conductor. No more than one conductor shall be installed per lug.
- H. UFER Ground
  - 1. In addition to all cold water and structural steel grounds provided to meet this Specification, there shall be a main ground system of the UFER ground style.
  - 2. The UFER ground electrodes shall be a minimum of two 20-foot lengths of #4/0 AWG bare stranded copper cable embedded horizontally in the cast in place concrete footing, extending in opposite directions in the footings. All portions of the ground electrodes shall be placed inside the concrete, between 2-inches and 4-inches from the earth surrounding the concrete.
  - 3. The lengths of cable shall extend in opposite directions in the footings, with the center end of each cable terminated onto the main electrical service ground bus for the main electrical service equipment.
  - 4. All wire cable connection terminations onto the ground bus shall be exothermic weld type.
  - 5. The "UFER" grounding electrode, embedded in concrete, shall be exothermically welded to each steel reinforcing bar (rebar) and each steel anchor bolt located within 18-inches of the grounding electrode inside the concrete. Note: Reinforcing steel (rebar), in concrete foundations, attached with metal "tie-wraps" and in direct physical contact to other adjacent rebar that is in turn exothermic welded to the UFER grounding electrode, may be classified as attached to the UFER grounding electrode, and does not require additional exothermic weld connections to the UFER grounding electrode.
- I. Provide a separate ground/bond insulated grounding electrode conductor, copper wire from the main electrical service ground bus to each of the following locations. The ground/bond conductor shall be sized to comply with applicable Codes and as indicated on the Drawings, but in no case smaller than the following:
  - 1. Main service entrance equipment ground bus:
    - a. Services smaller than 1200 amp 1.5-inch conduit with 1#4/0.
    - b. Services 1200 amp and larger 2.5-inches conduit with 1#500MCM.



- c. Where a separate ground bus is not required, connect ground to electrical equipment metal housing
- 2. Each telephone backboard and signal system backboard location, 1.25-inch conduit with 1#1.
- 3. Metal cold water pipe located inside the building, 1.5-inch conduit with 1#4/0.
- 4. Outdoor underground metal cold water pipe, make connection five feet from the building, 1.5-inch conduit with 1#4/0.
- 5. Each service entrance ground bus and each separately derived ground rod system:
  - a. Services smaller than 1200 amp 1.5-inch conduit with 1#4/0.
  - b. Services 1200 amp and larger 2.5-inches conduit with 1#500MCM.
- 6. Separate 1.25 inch conduit with 1#2 (AWG) bonding conductor to each interior metal pipe system located in the same building, including but not limited to, the following:
  - a. Fire sprinkler system each stand-pipe location (water based and non-water based).
  - b. HVAC chilled water supply and return, at each pump location.
  - c. Roof drains.
  - d. Waste liquid disposal systems.
  - e. Metal gas pipe service entrance and service meters.
  - f. Hydraulic elevator hydraulic pipes.

### 3.03 CONDUIT

#### A. General

- 1. The sizes of the conduits for the various circuits shall be as indicated on the Drawings, but not less than the conduit size required by code for the size and quantity of conductors to be installed in the conduit.
- 2. Conduits shall be installed concealed from view. Install conduits concealed in walls, concealed below floors and concealed above ceilings, except as specifically noted otherwise.
  - a. Conduits shall not be installed in concrete floors.
- 3. The following systems shall be considered as circuits 100 volts and less, all other circuits shall be considered to be over 100-volts (power circuits) unless specifically noted otherwise: Fire alarm, energy management control, telephone, public address, data, computer, television, intercom, intrusion alarm and nurse call.
- 4. Conduits shall be provided complete with conduit bends, conduit fittings, outlet boxes, pullboxes, junction boxes, conduit anchors/supports, grounding/bonding for a complete and operating conductor/ wire raceway system.
- 5. Metal and nonmetal conduits shall be provided mechanically continuous between termination connection points. Metal conduit shall be provided electrically continuous between termination connection points.
- 6. Individual conduit paths and home runs shown on the Drawings shall be maintained as separate individual conduits for each homerun and path.

7. Conduits, conduit fittings and installation work occurring in classified hazardous materials locations shall comply with applicable Code Class 1 Division 1 Requirements, unless specifically noted other-wise.
8. Transitions between conduits constructed of different materials and occurring in above grade locations shall be allowed only at outlet boxes, junction boxes, pullboxes and equipment enclosures unless specifically indicated otherwise. Provide outlet boxes and junction boxes.
9. Metal conduit terminating to nonmetal enclosures; terminating into metal enclosures with “concentric ring” knockouts; terminating into metal enclosures with knockout reducing washers, including but not limited to equipment housings, outlet boxes, junction boxes, pull boxes, cable trenches, manholes, shall be provided with a ground/ bonding lug integrated with the conduit termination conductor fitting construction, by the Fitting Manufacturer. The lug shall provide for connection of a grounding/ bonding conductor (insulated or uninsulated). The grounding lug shall be located on the fitting, inside the termination enclosure.
10. The type of conduit, type of conduit fittings, and type of conduit supports and method of conduit installation shall be suitable for the conditions of use and conditions of location of installation based on the Manufacturer’s recommendations; based on the applicable Codes and based on the Requirements of the Contract Documents.

**B. RMC Installation Locations**

RGS, IMC conduits and RGS, IMC fittings shall be installed in the following locations:

1. Embedded in floors, walls, ceilings, roofs, foundations, and footings constructed with concrete.
2. Embedded in walls and foundations constructed with brick and masonry.
3. Interior of buildings, within 9-feet of finish floor lines for exposed conduit locations.
4. Exterior of building for exposed conduit locations.
5. Damp or wet locations, exposed or concealed locations.
6. Exposed on roofs.
7. In hazardous materials areas and locations; below hazardous materials areas and locations; above hazardous materials areas and locations.
8. Exposed on utility service poles, for pole risers less than 9-feet above finish grade.
9. RMC conduit and RMC fittings may be installed in any location where EMT and FMC conduit is permitted to be installed.

**C. PVC Coated RMC Installation Locations**

PVC coated RMC conduit and PVC coated RMC fittings shall be installed in the following locations:

1. Underground conduit locations for elbows and bends with a radius of less than 36-times the conduit diameter.
2. Underground vertical risers extending above grade.
3. Entire length of underground conduits for the following circuits:
  - a. Audio microphones

- b. Lighting dimming controls
  - 4. Installed in contact with earth or corrosive materials.
  - 5. Exposed in “cold” rooms and “refrigerated” rooms, rooms with a maintained temperature below 65 degrees Fahrenheit.
- D. EMT Installation Locations
- EMT conduit and EMT fittings may be installed in the following locations, for circuit conductors operating below 600 volts to ground; locations containing only “non-hazardous materials”; only dry locations:
- 1. Concealed in hollow non masonry/non-concrete, metal stud frame and wood stud frame walls and floors.
  - 2. Concealed above ceilings.
  - 3. Exposed inside interior enclosed crawl spaces.
  - 4. Exposed interior locations placed 9-feet or higher above finished floors (except as described in paragraph below at lower heights).
  - 5. Exposed on walls and ceilings (any height) in the following dedicated function areas, interior enclosed room locations:
    - a. Indoor enclosed electrical equipment rooms and closets.
    - b. Indoor enclosed data and telecommunication terminal rooms and closets.
    - c. Indoor enclosed HVAC equipment rooms and closets.
  - 6. Any location where FMC is described to be installed, except as the final connection to rotating or vibrating equipment.
- E. FMC Installation Locations
- FMC conduit and FMC fittings may be installed in the following locations for circuit conductors operating below 600 volts to ground; locations containing only “non-hazardous materials”; only dry, interior locations:
- 1. Concealed in hollow non-masonry metal stud frame and wood stud frame fully enclosed walls.
  - 2. Concealed above fully enclosed ceiling spaces.
  - 3. FMC conduit shall be installed in continuous lengths between termination points. FMC shall not be “spliced” or coupled directly to FMC or any other conduit type under any circumstance.
  - 4. The maximum continuous length of FMC that shall be installed between termination end points is 15-feet. Circuits requiring continuous conduit lengths exceeding 15 feet between termination end points shall be installed using either RMC or EMT conduits. FMC lengths shorter than 16-inches are prohibited.
  - 5. The minimum size FMC conduit shall be as shown on the Drawings but not be less than the following:
    - a. FMC lengths of 6-feet or less, minimum FMC conduit size shall be 0.50-inch.
    - b. FMC lengths exceeding 6-feet, minimum FMC conduit size shall be 1.0-inch.

F. LTFMC Installation Locations

LTFMC conduit and LTFMC fittings shall be installed in the following locations for circuit conductors operating below 600 volts to ground; locations containing only “non-hazardous materials”:

1. Final electrical connection to vibrating or rotating equipment; control and monitoring devices mounted on vibrating and rotating equipment including the following. Minimum conduit length shall not be less than 24-inches:
  - a. Motor, engines, boilers, solenoids, and valves.
  - b. Fixed mounted “shop” (manufacturing) production equipment.
  - c. Fixed mounted food preparation equipment and “kitchen” equipment.
2. All locations where exposed flexible conduit connections are required, both indoor and outdoor.
3. Final connection to indoors electrical transformers. Minimum conduit length shall not be less than 24-inches; maximum conduit length shall not exceed 72-inches.
4. Do not install LTFMC located in environmental air plenums.

G. RNMC Installation Locations

RNMC conduit and RNMC fittings shall be installed in the following locations containing only “non-hazardous material”:

1. Underground, concealed below earth grade, unless specifically noted or specified otherwise.
2. Exposed on utility service poles, for pole risers at 9-feet or higher above finish grade, Schedule 80 PVC only.
3. RNMC type “EB” conduit(s) shall be concrete encased along the entire length of the conduits for all installation locations.
4. Non-metal type raceways and RNMC type conduit shall not be installed inside buildings.

H. Combi-Duct Installation Locations

Combi-duct conduits shall be installed where shown on the Drawings. Combi-duct shall be installed under-ground (below grade) as follows:

1. Do not install exposed or inside buildings above grade.
2. Provide a 0.25-inch pull rope in each inner duct.
3. Radius and elbows shall be rigid non-metallic, PVC, Manufacturer factory fabricated, in lieu of PVC coated RMC conduit.
4. Inner ducts shall be supported by internal spacers inside the enclosing outer duct.
5. Provide end bell and three-hole "snug-plugs" at each entrance end of Combi-duct into pullboxes, man-holes, equipment cabinets' stub-ups and Combi-duct terminations. Compression type “snug-plugs” shall provide watertight and airtight seal between inner and outer ducts and around future cables installed in inner duct.

## I. Conduit Installation

### 1. Conduit Supports

- a. Securely and rigidly support all raceways/conduits from the building structure. Raceways/Conduits shall be supported independent of all piping, air ducts, equipment ceiling hanger wires, and suspended ceiling grid systems. Secure conduit to structural element by means of UL listed and approved hangers, fasteners, "C" channels and pipe clamps.
- b. Provide conduit supports spaced along the length of the conduit as follows:
  - 1) RMC and EMT conduit, maximum not to exceed 96-inches on center; within 24-inches of each conduit bend and conduit termination location.
  - 2) FMC and LTFMC conduit, maximum not to exceed 24-inches on center; within 6-inches of each conduit bend and conduit termination location.
- c. Suspended conduit methods:
  - 1) Individual, suspended raceways/conduits separated by more than 12-inches from any other conduit and suspended from ceilings and roofs shall be supported as follows:
    - a) Conduits smaller than 1.5-inches by means of hanger rods or hanger wires.
    - b) Conduits 1.5-inches and larger by means of hanger rods.
    - c) The conduit shall attach to the hangers with pipe clamps.
  - 2) Suspended raceways/conduits positioned within 24 inches of any other conduit shall be grouped and supported by hanger rods using trapeze type conduit support channels ("C" channels). Conduits shall individually attach to common channels side-by-side, with pipe clamps.
- d. Non-suspended conduit methods:
  - 1) Individual raceway/conduits placed against wall/ceiling/floors, placed inside hollow wall/ceiling construction or structure framing (i.e., "drywall" or plaster hollow wall construction), shall be secured by means of individual pipe clamps and fasteners attached to the framing studs or other structural members and the conduit/raceway.
  - 2) Provide common "C" channel supports for all multiple raceway/conduits placed against vertical or horizontal surfaces and positioned within 24-inches of other raceways/conduits. Attach channels to the framing studs or other structural members. Attach the conduits/raceway individually to common channels, side-by-side, with pipe clamps.
  - 3) The use of toggle bolts is prohibited.
- e. Conduit rising from floor for motor connection shall be independently supported if extending over 18-inch above floor. Support shall not be to a motor or ductwork, which may transmit vibrations.
- f. Provide conduit anchoring, conduit support and conduit bracing systems conforming to Earthquake Requirements. The conduit support/anchoring system capacity shall include the weight of the conduits, conduit fittings, conduit supports and conductors /wires/cables installed in the conduits plus a 300% safety factor. Submit Shop Drawing details showing each typical conduit anchor, conduit support and conduit brace location. Submit structural calculations performed by and signed by a Professional Structural Engineer (P.E.) with a P.E. License, Registered in the State of California, U.S.A.

2. Conduit separation:
  - a. Conduit installed underground or below building slab without full concrete encasement: Shall be separated from adjacent conduits of identical systems (i.e. signal to signal, data to data, power to power, control to control etc.) by a minimum of 3-inches. Conduits of non-identical systems (i.e. signal to power; data to power; power to control; signal to control, etc.) shall be separated by a minimum of 12-inches.
  - b. Conduit installed underground with full concrete encasement; shall be separated from adjacent conduits of similar systems (100 volt and less) by a minimum of 2-inches; conduits for non-power systems (100 volts and less to ground) shall be separated by a minimum of 6-inches from power circuits (over 100 volts to ground); conduits for power circuits shall be separated from adjacent conduits of similar power systems (over 100 volts to ground) by a minimum of 3-inches.
  - c. Separation of conduits entering termination points or crossing other conduits may be reduced as required within 60-inches of the termination or crossing points.
  - d. Conduits containing Utility Company service circuits (i.e. electrical power, telephone, or cable television) shall be separated a minimum of 12-inches from all other utilities and conduits, with or without concrete encasement; metallic or non-metallic conduit, above grade or underground conduit locations.
  - e. Conduits shall be separated from hot water piping, exhaust flues/chimneys, steam piping, boilers, furnaces, ovens by a minimum of 12-inches.
3. Conduit stubs:
  - a. Branch circuit and telephone conduits turned up from floor at the following locations shall terminate each conduit in a flush conduit coupling at the floor and then extend into partition or to equipment. Refer to District's Representative's Drawings for location of walls and partitions.
    - 1) Interior demountable partitions.
    - 2) Below, into or adjacent to equipment not installed directly adjoining to a wall.
    - 3) Up from below the floor into hollow stud frame walls.
  - b. From each panel, and signal cabinet which is wall mounted, stub up from top of the panel/cabinet a minimum of three 1-inch conduits to the nearest accessible ceiling spaces or other accessible location. Where the floor below the panel is accessible or is a ceiling space, stub an additional three 1-inch conduits from the bottom of the panel into the accessible space below the panel. Cap conduits for future use.
  - c. Conduits stubbed underground outside of building line for future use shall be terminated a minimum of 5-feet clear (whichever distance is greater) of building or adjacent concrete walks and AC paving. The stubout conduit shall be capped. Provide concrete monuments, 6-inches by 6-inches by 15-inches deep, buried flush with grade over the capped ends. The face of monument shall be furnished with 3-inch square brass plates securely mounted and engraved with the number and size of conduits and type of service (i.e., "POWER", "TEL.", etc.).
  - d. Conduits stubbed into ceiling or floor spaces from outlets for telephone, video, computer/data or television shall be provided with an insulated throat bushing, on the end of each conduit stubout.

- e. Conduit stubouts from outlet boxes and equipment located in hollow stud walls, into ceiling and floor spaces, shall be EMT or RMC conduit. The stubouts shall terminate into the ceiling and floor spaces with a conduit termination connector fitting.
  - f. Empty conduit stubs into building spaces and equipment shall be individually identified with an "ID-tag" located at each end of the conduit. The ID-tag shall state the origination point and termination point of the respective conduit (i.e., "from PNL-A/to Room #121"; "from outlet #24/to outlet #17 in Room #120"; etc.).
  - g. Provide a conduit termination fitting with insulated throat bushing and mechanical ground lugs at each conduit "stub-up" location.
4. Conduit concrete encasement:
- a. Conduits which are run underground exterior to building slab shall be continuously concrete encased except, 15-amp and 20-amp power branch circuit conduits underground do not require concrete encasement.
  - b. PVC rigid-non-metallic-type EB conduit, of any size and any location shall be continuously concrete encased the full length of the conduit installation, including under building slab.
  - c. Concrete for encasement of underground conduits shall be 2000-PSI 28-days cure strength with a mix of cement, sand, water and maximum of ¾-inch gravel. Concrete encasement of conduits shall be continuous without voids. The encasement shall extend 3-inches past the edges of all conduits on all sides of the circuit. Provide 10-pounds of red oxide cement coloring uniformly mixed with each cubic yard of concrete for conduit encasement.
  - d. Conduits located below or adjacent to structural foundations shall be separated from the foundation by a minimum of 12-inches. Conduits located below structural foundations shall be fully and continuously concrete backfilled and encased between the bottom of the foundation to the bottom of the conduits. The concrete shall be 4000 PSI 28 day cure strength instead of 2000-PSI concrete.
  - e. Conduits of any size and type (including 15-amp and 20-amp power branch circuits) located under roads, paved areas and "transit-system" right of way shall be concrete encased.
5. Underground conduits:
- a. Three or more underground conduits larger than 1-inch in size and occupying the same trench shall be separated and supported on factory fabricated, non-metallic, duct/conduit support spacers. The spacers shall be modular, keyed interlocking type, "built-up" to accommodate quantity, size orientation and spacing of installed conduits.  
The spacers shall maintain a constant distance between adjacent conduit supports and hold conduits in place during trench backfill operations. Minimum support spacer installation interval along with length of the conduits shall be as follows:
    - 1) Concrete encased conduits, not less than 8-feet on center.
    - 2) Non-concrete encased conduits, not less than 5-feet on center.
  - b. Provide trenching, excavation, shoring and Backfilling required for the proper installation of underground conduits. Tops of backfill shall match finish grade.
  - c. Bottoms of trenches shall be cut parallel to "finish grade" elevation. Make trenches 12-inches wider than the greatest diameter of the conduit.

- d. Back-filling Trenches for Conduits without Concrete Encasement Requirements
  - 1) Conduits which are not required by the Contract Documents to be concrete encased and are located exterior to building slab, shall be set on a 3-inch bed of damp clean sand. Conduit trenches shall be backfilled to within 12-inches of finished grade with damp sand after installation of conduit is completed. Remainder of backfill shall be native soil.
  - 2) Conduits located under a building which are not required by the Contract Documents to be concrete encased, shall be completely backfilled and compacted with clean damp sand to the same level as the building foundation pad.
  - 3) Provide a continuous yellow 12-inches wide flat plastic tracer tape, located 12-inches above the conduits in the trench. The tracer tape shall be imprinted with "Warning-Electric Circuits" a minimum of 24-inches on center.
- e. Backfilling trenches for conduits under paved areas:
  - 1) In addition to the Requirements of conduit concrete encasement, conduits under walkways, roads, parking lots, driveways, and buildings shall be cast in place concrete "slurry mix" backfill. The slurry mix shall cover each side and top of conduits and conduit concrete encasement. The slurry mix shall be continuous to the underside of the finish subgrade surface.
- f. Backfilling trenches for conduits with Concrete Encasement Requirements by the Contract Documents:
  - 1) Trenches with all conduits concrete encased shall be backfilled with clean damp sand when located under building pads.
  - 2) Trenches with all conduits concrete encased and not located under a building pad and not located under paved areas shall be backfilled with clean damp sand or native soil.
- g. Backfill material:
  - 1) Sand and native soil backfill of trenches shall be machine vibrated in 6-inch lifts to provide not less than 90% compaction of backfill.
  - 2) Soil backfill shall have no stones, organic matter of aggregate greater than 3-inches.
  - 3) Concrete and slurry mix (2000-PSI) shall be machine vibrated during installation to remove "air-voids".
  - 4) The slurry mix shall consist of concrete, clean rock, clean sand and clean water mixture. Maximum shrinking of slurry mix shall not exceed 5% wet to dry.
- h. Do not backfill until District's Representative has approved Installation and As-Built Drawings are up to date. Promptly install conduits after excavation has been done, so as to keep the excavations open as short a time as possible. Excess soil from trenching shall be removed from the site.
- i. Install underground conduit, except under buildings, not less than 24-inches below finished grade in non-traffic areas and 30-inches below finished grade in traffic areas, including roads and parking areas. Not less than 48-inches below finished grade under public/private transit system right of way and railroad right of way. Dimensions shall be measured to the top of the conduit.



- j. Conduit crossing existing underground utilities shall cross below the bottom depth of the existing utilities. If the top portion of the existing utility depth below finish grade exceeds 72-inches and the specified separation and depths are maintained when crossing over the top of the existing underground utility, the conduit may cross above the existing underground utility.
- k. Provide long radius horizontal bends (minimum radius of 36-times the conduit diameter) in underground conduits where the conduit is in excess of 100-feet long.
- l. Conduits installed below grade and on grade below buildings, shall not be smaller than 0.75-inches. Conduits for circuits exceeding 600-volts shall not be smaller than 5.0-inches.
- m. Underground conduits entering a building shall be sloped. The conduit direction of slope shall be away from the building, and shall prevent water in the conduit from “gravity draining” towards the building. The conduit slope “high point” shall originate from the building, out to the first exterior pullbox, manhole etc. exterior conduit termination “low point”. The minimum slope angle shall be a constant 8-inches (or greater) of fall for each 100-feet of conduit length.
- n. Dewatering:
  - 1) Provide pumping to remove, maintain and dispose of all water entering the excavation during the time the excavation is being prepared, for the conduit laying, during the laying of the conduit, and until the backfill at the conduit zone has been completed. These provisions shall apply on a continuous basis. Water shall be disposed of in a manner to prevent damage to adjacent property. Trench water shall not be drained through the construction. Ground water shall not be allowed to rise around the pipe until joining compound has firmly set.
  - 2) The District’s Representative shall be notified 48 hours prior to commencement of dewatering.
- 6. Raceway/Conduits, which are installed at this time and left empty for future use, shall have 0.25-inch diameter polyvinyl rope left in place for future use. The pull rope shall be 500-pound minimum tensile strength. Provide a minimum of 5-feet of slack at each end of pull ropes.
- 7. Unless otherwise restricted by Structural Drawings and Specifications, the maximum size conduit permitted in concrete slab on-grade, walls, ceilings and roofs constructed of masonry or concrete shall not be greater than 20% of the concrete/masonry thickness. Conduits installed in these locations shall not cross.
  - a. Conduits shall not be installed in cast-in-place concrete floors.
- 8. Provide openings in building structures for conduit penetrations:
  - a. New construction shall be provided with conduit sleeves, to provide conduit penetrations.
  - b. Existing construction shall be drilled (core drill masonry and concrete) and provide conduit sleeves installed after drilling, to provide conduit penetrations.
  - c. Where the structure penetrations for underground conduits penetrating through foundations will not comply with the (restriction/penetration) shown in the Contract Documents, install the conduits below and clear of the foundation lowest point.

9. Conduit bends risers and offsets:
- a. The minimum bend radius of “factory or field” fabricated conduit bends shall not be less than the following. The bend radius shall be measured at the surface, inside radius of the conduit wall:
    - 1) FMC and LTFMC conduit - conduit minimum bend radius 12-times the conduit diameter.
    - 2) RMC and EMT conduit minimum bend radius – conduit for power circuits over 100 volts and less than 600 volts, 8-times conduit diameter. Conduit for power circuits over 600 volt, 12-times conduit diameter. Conduit for low voltage, signal and fiber optic circuits, 10-times conduit diameter.
    - 3) RNMC conduit - conduit minimum bend radius 36-times the conduit diameter. Under building reduce minimum bend radius to 10-times the conduit diameter. Conduit bends and offsets in RNMC with less than 36-times conduit diameter bend/offset radius shall be RNMC PVC Schedule 80 or PVC coated RGS.
    - 4) Conduits for Utility Company conductors. Conduit minimum bend radius shall comply with the respective Utility Company Requirements.
  - b. Bends and offsets in conduits shall be kept to an absolute minimum. The total summation of all bends and offsets permitted in a conduit segment, occurring between two conduit termination/ connection end points, shall not exceed the following, including conduit fittings:
    - 1) RMC and EMT conduit – 360 angular degrees
    - 2) FMC and LTFMC conduit – 180 angular degrees
    - 3) RNMC conduit – 270 angular degrees
  - c. Each field fabricated conduit offset, bend and elbow which are not the standard product of the Raceway/Conduit Manufacturer shall be mandrel tested. The test shall be conducted after the conduit installation is complete and prior to pulling-in any wire, in the same manner as for underground conduits.
  - d. Factory manufactured angle connector conduit fittings shall be installed in exposed conduit locations only. Installation in locations normally concealed from view shall not be permitted. Not more than one factory manufactured angle connector shall be permitted in any length of conduit between conduit termination end points.
  - e. RNMC conduit risers from below grade shall be PVC coated RGS. Conduit risers, bends or offsets entering into a building shall be PVC coated RGS.
  - f. If three or more conduit-bends of the same conduit size and same conduit material type, installed, as part of the Contract Work, fail to comply with the required minimum conduit bend radius or conduit angular degree limits. The following corrective actions shall occur:
    - 1) The Contractor shall remove all the non-complying conduit bends and the respective wire in the conduit from the project site. Provide new conduit and wire, complying with the Contract Documents.
    - 2) Where the conduit bends similar to the non-complying conduit bends are installed concealed in walls, floors, above ceilings or below grade, the Contractor shall expose the conduit bends to allow visual observation.
    - 3) The Contractor shall remove the non-complying conduit bends and dispose of the Project Site. The Contractor shall provide new conduit bends and conductors complying with the Contract Documents.

- 4) All the costs to correct the deficient material and work along with costs to repair the direct, indirect, incidental damages and Contract delays shall be the sole responsibility of the Contractor and shall be included in the bid price.
10. Expansion joint, deflection joint and seismic joint fittings.
- a. Provide a conduit expansion fitting for each conduit length and conduit type as follows (Note - The installation of specified combination expansion/deflection fittings at seismic joints shall satisfy this Spacing Requirement also):
 

|    | <u>Conduit Type</u> | <u>Conduit</u>                       | <u>Fitting Length Spacing</u> |
|----|---------------------|--------------------------------------|-------------------------------|
| 1) | RMC and EMT         | Exposed exterior locations           | 200-foot                      |
| 2) | RMC and EMT         | Interior weather protected locations | 200 feet                      |
  - b. Provide a conduit combination expansion/deflection fitting for each conduit, crossing the following elements:
    - 1) At each building or non-building structure seismic joint.
    - 2) At each building on non-building structure expansion joint.
    - 3) At each conduit penetration of a "sound-rated" wall, floor or ceiling.
11. Provide two locknuts and an insulated throat bushing at each metal conduit terminating at enclosures, including but not limited to outlet boxes, junction boxes, terminal cabinets, switchgear, transformers, switchboards, distribution panels and panelboards.
12. Provide metallic or plastic closure caps on all conduit ends during construction, until installation of conductors in the respective conduit.
13. Conduit run exposed, shall be run at right angles or parallel to the walls or structures. All changes in directions, either horizontally or vertically, shall be made with conduit outlet bodies as manufactured by Crouse Hinds, OZ or equal. Conduits run on exposed beams or trelliswork shall be painted to match surrounding surfaces.
14. Conduit exposed on roof:
- a. Conduits installed exposed on roofs shall be installed on conduit sleepers. Place the conduit sleepers a maximum 5-foot on center along the entire length of the conduit; under conduit expansion/deflection fittings; under each junction box and within 24-inches of each conduit bend.
  - b. Provide a conduit support "C" channel continuous along the top length of the sleeper and rigidly bolted to the sleeper. Conduits shall be loosely fastened to each sleeper "C" channel with pipe clamps to allow for relative movement between the sleeper and conduit.
  - c. Conduits shall not block or interfere with roof hatches, doors, ventilation openings, dampers, equipment access panels/doors, roof water drainage.
  - d. Conduit sleepers shall be fabricated from "clear" solid redwood 4-inches by 4-inches (nominal) size. Sleeper length shall extend a minimum of 9-inches past the conduits attached to the sleeper, but in no case shall the length of the sleeper be less than 24-inches.
  - e. Provide a pad under each sleeper; sleepers shall not be installed in direct contact with the roofing. Sleeper pads shall extend a minimum of 6-inches past each side of the sleeper. The sleeper pad shall be semi-rigid mineral surfaced composition board, not less than 0.375-inch thickness, bituminous impregnated, manufactured for application on the specific roofing material. Remove roofing "ballast" (gravel) under pad, prior to installation of sleeper pad. Do not puncture roof membrane.

- f. Position the “length” of the conduit sleepers’ perpendicular to the roof slope, to prevent obstruction of roof drainage water flow. Where the conduit routing prevents placing the conduit sleeper parallel to the roof slope, provide two separate sleeper pads for the conduit sleeper, with a continuous 3-inches wide water drainage gap between the sleepers. Align the water drainage gap to allow unimpeded water travel along the roof slope drainage flow line between the pads.
  - g. Sleepers and sleeper pads shall be set in nonhardening mastic, a minimum of 0.25-inch thickness. Mastic shall be inorganic, nonhardening, and complying with ASTM-D1227. Mastic shall be applied with continuous uniform coverage, minimum 0.25-inch thickness, on all the surfaces of each conduit sleeper and on the sleeper pad contact surface with the roof.
- 15. Rigid steel conduit or electrical metallic tubing shall not be strapped or fastened to equipment subject to vibration or mounted on shock absorbing bases.
- 16. RMC conduit threads:
  - a. Machine cut threads on RMC conduit required for field fabrication shall comply with NPS and ANSI-B1.20.1.
  - b. The length of bare metal exposed during thread fabrication shall be completely covered by conduit couplings and fittings. Additionally, the thread length shall insure that conduit joints will reach “torque” tightness and become secure before conduit ends “butt” together and before conduit ends “butt” into the “shoulders” of other conduit fittings.
  - c. Running threads or right/left handed threads shall not be used to connect RMC.
- 17. RNMC conduit:
  - a. Joints and fittings shall be solvent welded to RNMC conduit. Joints and fittings shall be watertight and airtight after fabrication.
- 18. Tighten each conduit fittings and fitting appurtenances, to the “torque” (allowable tolerance  $\pm 5\%$ ) value recommended by the Fitting Manufacturer and applicable Code. If three or more conduit fittings are found to not be in compliance with the Manufacturer’s “torque” (tightness) recommendations, the following corrective actions shall occur:
  - a. The Contractor shall tighten “re-torque” the defective fittings and all similar conduit fittings installed as part of the Contract Documents in the presence of the District’s Representative.
  - b. If the respective conduit fittings similar to the deficient “torque tightness” fittings are installed concealed in walls, floors, above ceilings or below grade, the Contractor shall expose the fitting, to allow retightening each similar conduit fitting to the Manufacturers recommended “torque” values.
  - c. All the cost to repair the direct, indirect, incidental damages and Contract delays resulting from complying with these Requirements shall be the sole responsibility of the Contractor and shall be included in the bid price.
- 19. Horizontal directional boring for underground conduit:
  - a. Provide a directional guided horizontal “bore-hole” underground conduit installation where one or more of the following conduits occur:
    - 1) Continuous trenching excavation and backfill for conduit installation is not permitted by the Contract.

- 2) Where continuous trenching excavation due to the existing surface and below grade conditions and restrictions, is not possible or practical to excavate a trench.
  - b. Provide “path-tracing” of the underground bore head, from the surface, along the entire horizontal bore length. Path tracing shall use electronic transmitters and receivers, continuously communicating the underground bore head locations and depth to the bore equipment operator. The directional boring system shall employ active tracking and directional position/steering control of the bore equipment drill head location. The active tracking system shall provide a portable receiver/transmitter unit for tracking the position of the moving drill head; a sensor “Sonde” unit on the drill head for tracking signals to the receiver/transmitter; and a drill head tracking data view display located at the boring equipment operator position to view the drill head position information sent from the portable receiver/transmitter. As manufactured by SPX-Radiodetection Company or similar products.
  - c. Provide vertical pilot excavations not more than 50-feet on center along the path of the bore-hole to intercept the horizontal bore-hole routing, provide excavations at the beginning and end terminals staging points of the horizontal bore-hole.
  - d. Provide full-depth “shoring” of the vertical pilot excavations. Remove the shoring, backfill, compact and repair the excavations when conduit installation is complete.
  - e. “Drilling-fluid” shall be used during “back-reaming” and “pullback”, pumped through the drill pipe to the bore drill head.
  - f. Directional guided horizontal drilling shall employ equipment specifically designed and manufactured for the process. The Equipment Manufacturer shall train bore equipment operating personal in the proper operation of said equipment.
  - g. Locate the position, size, depth and identify all underground “cross-bore” existing underground utilities, pipes, structures and conflicts along the entire bore path of each underground bore, prior to initiating directional boring work. Notify respective agency for each “cross bore” potential crossing. Comply with the recommendations of the Cross Bore Safety Association (CBSA).
  - h. Horizontal, directionally guided boring equipment, as manufactured by Ditch Witch; Vermeer Manufacturing; or Case Corporation.

J. Conduit Seals

1. Provide conduit seal fittings at each location where a conduit transitions or passes through the following areas and where indicated on the Drawings:
  - a. Refrigerated areas.
  - b. Temperature control rooms including warming rooms, steam rooms, saunas etc.
  - c. Classified hazardous material areas.
  - d. Water intrusion areas.
2. Provide conduit seals on each conduit entering a building from a below grade area located outside the building (i.e., basement, vault etc.) and connecting to the following types of equipment
  - a. Transformers
  - b. Panelboards
  - c. Motor control centers

- d. Switchboards
  - e. Switchgear
  - f. Motors
  - g. Terminal cabinets
  - h. Terminal backboards
  - i. Cable trenches
3. Conduit seals shall be installed in locations where the fitting is visible and accessible.
- K. Nailing Shields
1. Provide “nail” shields where FMC conduit and conductors not installed in a conduit are installed through wood stud and wood frame construction. The nail shield shall provide a barrier resistant to “nailing” fasteners through the stud, and penetrating into the FMC and conductors.
  2. The nail shields shall be flat nominal 1.5-inch by 3-inches, 14-gauge steel, and hot dip zinc galvanized with “nailing spurs”.
  3. Provide nailing shields on the front face and rear face of each FMC penetration. The shield shall be centered on each penetration through the respective framing, stud framing blocking, and stud framing plates.
- L. Conduit Bodies
1. Conduit bodies shall be installed in exposed conduit locations only or above accessible ceilings.
  2. Conduit bodies shall be accessible for removing body cover and pulling wire through the conduit body.
  3. Conduit bodies shall not be installed inside enclosed walls.
- M. Preparation of Reuse of Existing Conduits
1. Prepare existing conduits shown to be reused as part of Contract Work as follows: Complete the required work prior to installing any conductors or cables in respective existing conduits.
    - a. “Rod” out existing raceways to be used under this contract, with approved test and flexible mandrels to remove all obstructions to clear debris from inside conduits.
    - b. Use test mandrels at least 12-inches long, 0.25-inch less than diameter of duct at center, tapering to 0.5-inch less than duct size at ends.
  2. If test mandrels cannot be pulled through raceways, Contractor shall perform the following to clear the existing raceways:
    - a. Force rigid or semi-rigid rods through the raceways to clear the obstructions from one to both ends of the raceway.
    - b. Force a power driven rotating router device through the conduit from one or both ends of raceways. Device shall incorporate small diameter cutting blades. Repeat the “router” process in incremental stages to a cutting blade diameter approximately 1/8-inch smaller than the race-way inside diameter.
  3. After clearing the raceway of obstructions, pull a test mandrel or brush through the raceway to clear the remaining debris from the raceway.

### 3.04 WIRE AND CABLE

- A. Branch circuit and fixture joints for #10AWG and smaller wire shall be made with UL-approved connectors listed for 600 volts, approved for use with copper and/or aluminum wire. Connector to consist of a cone-shaped, expandable coil spring insert, insulated with a nylon shell and two wings placed opposite each other to serve as a built-in wrench or shall be molded one-piece as manufactured by 3M-"Scotchlok".
- B. Branch circuit joints of #8AWG and larger shall be made with screw pressure connectors made of high strength structural aluminum alloy and UL-approved for use with both copper and/or aluminum wire as manufactured by Thomas & Betts. Joints shall be insulated with plastic splicing tape, tapered half-lapped and at least the thickness equivalent to 1.5-times the conductor insulation. Tapes shall be fresh and of quality equal to Scotch.
- C. Use UL listed pulling compound for installation of conductors in conduits.
- D. Correspond each circuit to the branch number indicated on the panel schedule shown on the Drawings except where departures are approved by the District's Representative.
- E. All wiring, including low voltage, shall be installed in conduit.
- F. Control wiring to conform to the wiring diagrams shown on the Mechanical Drawings and the Manufacturer's Wiring Diagrams.
- G. All splices in exterior pull boxes and light poles shall be cast resins encapsulated.
  - 1. Power conductor splices - 3M Scotchcast Series 82/85/90; Plymouth or equal.
  - 2. Control and signal circuits 3M Scotchcast Series 8981 through 8986, Plymouth or equal.
- H. Neatly group and lace all wiring in panelboards, motor control centers and terminal cabinets with plastic ties at 3-inch on centers. Tag all spare conductors.

### 3.05 CHEMICAL GROUND ROD

- A. General
  - 1. Install ground rod system in compliance with Manufacturer's instructions.
  - 2. Install rods vertically. Where subterranean hard rock conditions prevent vertical installation horizontal "L" shape ground rod shall be installed.
  - 3. Where ground rod is installed in an indoors dry location set ground box flush with finish floor. Where ground rod is installed outdoors set the top of the ground box 4-inches above finish grade.
  - 4. Do not remove sealing tape from ground rod holes until time of installation in ground.
  - 5. Separate ground rods from all other grounding electrodes and from each other by not less than 12-feet horizontal distance.
- B. Excavation
  - 1. Vertical installation bore a 12-inches diameter vertical hole in the ground 6-inches deeper than ground rod length.
  - 2. Horizontal installations excavate a 12-inches wide trench, slope rod and trench to insure end cap of rod is 2-inches lower than the elbow.

- C. Backfill
  - 1. Surround the entire rod with a minimum of 10 inches of bentonite clay mixed with water at 6-times volume to form a paste. Approximately 14-gallons for each 50-pounds of clay. Remove any excavation liners from the rod excavation area.
  - 2. Install ground box and complete backfill.
- D. Connect grounding electrode conductor(s) to ground rod.

### **3.06 CABLE RACKS**

#### **A. General**

Provide cable racks in precast and cast-in place concrete pullboxes, manholes and cable trenches.

### **3.07 TESTING**

#### **A. Testing Conduit and Conduit Bends**

The Contractor shall demonstrate the usability of all underground raceways and field fabricated conduit bends installed as part of this Contract.

1. A round tapered segmented semi-rigid mandrel with a diameter approximately ¼-inch smaller than the diameter of the raceway, shall be pulled through each new raceway.
2. The mandrel shall be pulled through after the raceway installation is completed. Conduits which stubout only, may have the mandrel pulled after the concrete encasement is completed, but prior to completing the backfill.
3. District's Representative shall witness the raceway testing for usability. A Representative of the respective Utility Company shall witness the raceway testing where applicable.
4. Contractor shall repair/replace any conduit and conduit bend provided under this Contract which will not readily pass the mandrel during this test.

END OF SECTION 26 05 30  
022119/212220



This page is blank.

**SECTION 26 05 48**  
**SOUND CONTROL**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances, tools, equipment, facilities, transportation and services necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other Sections for work related to those other Sections and required to be included as work under this Section.
  - 2. General Provisions and Requirements for electrical work.

**1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

- A. Comply with pertinent provisions of Division 26.
- B. Submit product data sheets for vibration isolation devices.
- C. Submit Detailed Shop Drawings including Dimensioned Plans, showing equipment vibration isolation anchoring.

**PART 2 - PRODUCTS AND EXECUTION**

**2.01 QUIETNESS OF OPERATION**

Before the work will be accepted as complete, quietness of operation, to a degree satisfactory to the Architect shall be attained for apparatus, equipment, fixtures, etc., included under the electrical work. Provide isolation and vibration protection required.

**2.02 VIBRATION ISOLATION FOR ELECTRICAL EQUIPMENT**

- A. Objective: It is the objective of this Specification to provide the necessary design for the avoidance of excessive noise or vibration in the building due to the operation of machinery or transformers, and/or due to interconnected conduit.
- B. Contractor Responsibility
  - 1. Provide a submittal to the Architect for review prior to any installation of his equipment, containing the following information:
    - a. Catalog cuts and data sheets on specific vibration isolators to be utilized showing compliance with the Specification.
    - b. An itemized list showing the items of equipment to be isolated, the isolator loading and deflection and isolator placement.
    - c. Drawings showing methods for attachment of conduit to motors.
  - 2. Furnish and install the vibration isolation devices as specified herein.

3. Do not install any equipment or conduit as specified in the schedule, which makes rigid contact with the "building" unless it is approved in this Specification, or by the Architect. "Building" includes slabs, beams, studs, walls, lath, etc.
4. Coordinate work with other trades to avoid rigid contact between equipment and/or conduit as specified in the schedule and the building. Inform other trades following his work, such as plastering, to avoid any contact that would reduce the vibration isolation.
5. Bring to the Architect's attention, prior to installation, any conflicts with other trades which will result in unavoidable contact to the equipment or conduit as specified in the schedule, described herein due to adequate space, etc. Corrective work necessitated by conflicts after installation shall be at the responsible Contractor's expense.
6. Bring to the Architect's attention any discrepancies between the specifications and field conditions, changes required due to installation. Corrective work necessitated by discrepancies after installation shall be at the Contractor's expense.
7. Obtain approval from the Architect of any installation to be covered on enclosed, prior to such closure.
8. Obtain written and/or oral instructions from the vibration isolation Manufacturer as to the proper installation and adjustment of vibration isolation devices.
9. Notify the Architect, prior to the general installation of vibration isolation devices, so that the Architect can instruct and demonstrate the technique of proper installation with the Contractor's Foreman.
10. Correct, at no additional cost, all installations, which are deemed to be defective workmanship or materials by the Architect.

### 2.03 VIBRATION ISOLATION TYPES

#### A. Isolator Description

1. Isolate all transformers with Type MN molded neoprene units equipped with leveling bolts and design status deflection under load of 0.3-inch.
2. Isolate all switchgear connected directly to transformer with Type PN isolators. Limit loading to a static deflection of 0.06 inch. Choose the area of pad to match the load with the Manufacturer's recommended unit loading. An auxiliary steel plate may be required to distribute the load uniformly over the pad area.

#### B. Equivalent Vibration Isolators

|                             |                     |                       |     |     |    |     |      |
|-----------------------------|---------------------|-----------------------|-----|-----|----|-----|------|
| 1. Type Description         | A                   | B                     | C   | D   | E  | F   | G    |
| Neoprene Mount              |                     |                       |     |     |    |     |      |
| a) 0.2-inch max. deflection | N                   | FD                    | R   | RV  | CS | F   | T-44 |
| b) 0.4-inch max. deflection | ND                  | FDD                   | RD  | RFD | FU | RD  | T-44 |
| PN Neoprene Pad             | W                   | (1)                   | (2) | NR  | R  | (3) | 100W |
| 2. Notes                    | Manufacturer's Code |                       |     |     |    |     |      |
| (1) Elastogrip              | A.                  | Mason Industries      |     |     |    |     |      |
| (2) Shearflex               | B.                  | Korfund               |     |     |    |     |      |
| (3) Kinetic                 | C.                  | Vibration Mounting    |     |     |    |     |      |
|                             | D.                  | Amber/Booth           |     |     |    |     |      |
|                             | E.                  | Sausse                |     |     |    |     |      |
|                             | F.                  | Consolidated Kinetics |     |     |    |     |      |

G. Vibration Eliminator

**2.04 CONDUIT INSTALLATION**

- A. Provide flexible conduit or an approved vibration isolation device between any transformer and the building structure.
- B. Secure all electrical panels connected to transformers by flexible conduit to the floor. Do not contact stud or masonry partitions. Isolate panels from the floor as specified herein.
- C. Provide flexible conduit connections to all connections to air conditioning, plumbing, etc., or any rotating or oscillating equipment requiring electrical motors. Base the length of flexible conduit required for each motor upon the Requirements for a 360 degree loop in the conduit between the electrical motor and electrical box.
- D. As an alternative to the 360 degree loop, a Neoprene or rubber bushing between the conduit and the electric motor to break the metal-to-metal contact may be used. Provide a flexible ground strap to complete the electrical ground.

**2.05 DEVICE OUTLET BOXES (INSTALLED IN COMMON PARTY SEPARATION WALLS, IN CORRIDOR WALLS AND SERVICE WALLS)**

Device outlet boxes installed in walls shall be sealed on the exterior back and sides of the boxes, including wall openings around the box, with a 1/8-inch minimum thickness resilient sound absorbing, sealant. The sealant shall be free of asbestos, temperature rated from -30°F to 200°F, self-adhesive to metal and plastics, as manufactured by Lowry and Associates Inc., Sun Valley, California or equal.

END OF SECTION 26 05 48  
022119/212220

This page is blank.

**SECTION 26 09 10**  
**SUPPLEMENTAL METERING AND SUB-METERING**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances, tools, equipment necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete, as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other Specification Sections and Drawings for related work required to be included as work under Division 26.
  - 2. General Provisions and Requirements for electrical work.

**1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

- A. Provide Schematic Control Wiring Diagrams and "Point-to-Point" control wiring diagrams showing control and protective systems interlocks.
- B. Provide Nameplate Engraving Schedule.

**1.03 APPLICABLE STANDARDS (ADDITIONAL REQUIREMENTS)**

- A. The Equipment shall be designed, tested and assembled to comply with ANSI, IEEE, and NEMA and UL.
  - 1. UL 1244 Electrical and Electronic Measuring and Test Equipment.

**PART 2 - PRODUCTS**

**2.01 GENERAL**

- A. Function
  - 1. Electronic digital metering, microprocessor based data measurement and data recording of simultaneous occurring continuously operating analog conditions, simultaneously with data recording of individual occurrence instantaneous events.
  - 2. The supplemental metering is secondary to the utility revenue metering, as separate independent sub-metering systems. Shall provide tracking of the status, consumption and flow of the unit-values monitored by the respective supplemental metering systems.
  - 3. The meters shall connect analog to digital, not less than 24-bit analog to digital conversion, certified to National Accuracy Standards. UL listed and labeled. Provide local readable visual meter displays, local digital data storage and digital data communications with remote locations.
  - 4. Measurement accuracy shall be better than 0.5% and comply with IEC687 (Class 0.5%) and ANSI C12.20 (Class 0.5%). Combined meter and current transformers and related software systems operational accuracy for the electrical power sub-metering systems shall comply with ANSI-C 12.20 and the Public Utility Commission revenue grade accuracy compliance. The sub-metering systems accuracy shall also comply with Savings-

by-Design Program Requirements and U.S. Green Building Council Program Requirements, including but not limited to the following:

- a. +0.5% at 1.0 power factor and 1% through 100% of rated current.
  - b.  $\pm 0.75\%$  at 0.5 power factor and 1% through 100% of rated current.
5. Front of meter operator control of meter functions.
  6. Ambient operating temperature range minus 15-degrees centigrade to plus 50-degree centigrade.
  7. Flammability rating UL94-5V, self-extinguishing, non-flame propagating.
- B. Sub-Metering Communications
1. Each meter shall provide full duplex bi-directional network communications. Shall provide connection ports for laptop portable computer/PDA and for remote data collection and monitoring.
  2. Provide the following wired meter network connections in each meter
    - a. EIA RS-485 serial port for direct connect locally at each meter.
    - b. IEEE compliant TCP/IP Fast Ethernet, with RJ-45 port connect and with Power-Over-Ethernet (POE) for remote communications at each meter.
  3. Meters shall record and store monitoring data in static non-volatile memory. Not less than 60-calendar days of memory storage capacity. The stored data shall be available for local display on operator demand at the meter and for downloading from the meter by the following.
    - a. Portable laptop computer/PDA connected (plug-in) to the meter communication port.
    - b. Metering communications network for Automatic Metering Reading-AMR from remote locations using the metering LAN network.
  4. Meter electrical operating power.
    - a. Provide meter internal electrical power supplies, batteries shall not be the source of normal meter electrical power.
    - b. Meters monitoring electrical power circuits shall connect to the monitored electrical circuit for meter operating power. Provide protective fusing.
    - c. Meters monitoring non-electrical systems shall operate on 120 volt 60Hz AC branch circuit electrical power.
  5. Bi-directional monitoring for Net-Metering applications.

## **2.02 ELECTRICAL POWER METERING**

- A. General
1. The meters shall be microprocessor controlled, digital, measuring and indicating meters.
  2. Meter enclosure nominal size 8-inches x 8-inches by 4-inches deep, surface mounting, self-contained, dust proof, insulating electrical housing.
  3. The meter shall be rated for direct circuit connects up to 600 volt AC. Single-Phase; Three-phase "WYE" or "Delta" to match the monitored circuit configuration. Provide bus-tap voltage, with current limiting 15-amp 3-pole circuit breaker or 2-pole circuit breaker, as applicable.

4. The meter shall accommodate input connect through split core instrument Current Transformers (CT). Provide a CT for each phase, compatible with the install location. Three CT's for three-phase systems and two CT's for single-phase systems.
  5. The meter shall be compatible with the input voltage, CT input/output ratios.
  6. Shall provide proper operation over distance of up to 100 feet meter wiring circuit length from the meter to the respective CT location.
  7. Meter Withstand Ratings:
    - a. Continuous current overload 100%.
    - b. Surge 10-times rating for 3-Seconds
  8. As manufactured by Electro Industries-Shark Series; or equal.
- B. Meter Monitoring and Measurements Range.
1. The meter shall provide multi-function monitoring for three-phase and single-phase as applicable.
    - a. Real time kilowatt kW load
    - b. Cumulative kilowatt hour kWh load
    - c. Peak kilowatt demand with time and date adjustable window of 15-minute or 30-minute intervals
  2. Direct-read at each meter location, 8-digit LCD visual display of measured data parameters.

### **2.03 AUTOMATIC METER READING-AMR**

- A. General
1. Remote AMR communications data recovery and data analysis from the Sub-meters shall occur by the following methods:
    - a. Wired meter communications LAN network.
    - b. Typical for Switchboard Owner metering and Panelboard Owner metering.
  2. The monitor and communications software shall communicate with the Supplemental Metering and Sub-metering system using the AMR communications pathways.
  3. Provide meter LAN Network communications Gateway to translate metering system LAN communications protocols with the communications protocols for the Building Automation System BAS-EMCS. Coordinate with BAS EMCS.
  4. Provide communications port-card for the Supplemental Metering and Sub-metering system.
 

The port-card shall connect to the PC workstation computer. Operate and communicate with the metering system and the PC workstation monitoring/communicating metering software.
- B. Wired Meter Communications Meter LAN Network Pathway
1. Wired meter network operating over IEEE compliant TCP/IP Fast Ethernet LAN Network. ANSI/EIA/TIA Category-6, 4-pair UTP with RJ-45 connectors.



## 2.04 MONITORING AND COMMUNICATING SOFTWARE

### A. General

1. The monitoring and communicating software shall provide a complete and comprehensive enterprise wide operation of the metering system. Provide concurrent multi-user software site license for the entire system.
2. Graphic User Interface (GUI) operation, programming and configuration of meters.
3. Real-time viewing capability, data-logging and viewing of historical logs.
4. Communication with sub-meters through Ethernet TCP/IP, direct (plug-in) Serial port, and remote RF Wireless. Shall operate on pc-computers with Microsoft-Windows© operating system.
5. Provide charting, graphing, and analysis of data. Provide viewing of sub-meter records with comprehensive data analysis.
6. ODBC databases for all collected data.
7. Meter reading full reporting capability, utilizing artificial intelligence to diagnose events and provide possible cause scenarios.
8. Client billing and invoice statements for monthly payment by Clients of consumed measure values.
9. Audible and email alarms of selected conditions.
10. WEB Internet access to all meter data.
11. Install, set up and program all software for a fully functional AMR system.

### B. Software Functions

1. Connection between remote meters via Serial, Ethernet, RF wireless or Modem. Shall function with all the meters in the Supplemental Metering and Sub-meter system.
2. Viewing of real-time metered data, configuring of meters, and analyzing of collected information from the remote sub-meters.
  - a. View real-time readings of all measured parameters.
  - b. Configure and analyze collected data from remote sub-meters.
  - c. Collect and archive all data.
3. Computer screen display, graphing and reporting functions for collection and archiving of data. ODBC-compliant database structures, stored metering information integrated automatically into other 3<sup>rd</sup> party software packages. Shall also support .csv file format, auto-configurable.

Real-time viewing capability shall include:

- a. Volume, flow, voltage, current, power, and energy
- b. Time of usage and accumulations
- c. Alarms and limits
- d. Maximum and minimum for each parameter
- e. I/O device information

4. Real-time viewing of data in graphical format. Charting and graphing functions access to any desired data analysis.
  - a. Calculation of power quality on a scatter graph
  - b. CBEMA plotting information
  - c. 3D plots and histograms provided to aid in determining frequency and severity of monitored events.
  - d. Graphical data analysis by the base software.
  - e. Viewing of stored waveforms, events caused by monitored system problems, faults, transients, and other conditions.

C. Reports

1. Reporting software shall provide a comprehensive report on each meter, making use of Artificial Intelligence (AI) technology to diagnose the events and provide the possible cause of the event.
2. AI generated industry accepted solution as a result of the analysis of the monitored event. The AI program of the reporting software package shall make use of Fuzzy Logic, Neural Networks, embedded knowledge, and embedded rules to generate correct analysis and solutions.
3. Create tenant billing invoice statement for individual tenant consumption of measured values by the sub-metering system.
4. The software shall have a primary Reports server and a Standby Reports server. If the primary server is not running, the user shall be capable of connecting to the standby server.
5. User to specify report writing at project startup or other user-defined times, or on the occurrence of user-defined triggers or conditions.
6. User to specify report printing when run or saved to storage disk for later printing. The software shall allow user to format report variables.

D. Remote Server

1. Shall support the receiving of data strings from remote sub-meters in the field. The software shall check the monitoring system for connected remote sub-meters and assign incoming calls. Display warnings and to send email, pager, or phone notification of alarm conditions.

E. Security

1. The software shall have advanced security features, allowing password protection through up to five levels of privileges. The password protection shall allow restriction of access to specific screens and/or functions.
2. The operator shall be automatically logged out after a specified amount of inactivity time. The software shall still be active, but the user shall be restricted to 0 privilege level access after automatic logout.
3. Shall run as either a service or a shell under Microsoft Windows, to disable switching to other Windows applications while the software is running.
4. Allow disabling of the Ctrl-Alt-Delete shortcut key, to restrict operator access to other Windows applications.

5. Not less than two types of alarms: hardware alarms and configurable alarms. Issue alarms for devices going offline and other hardware conditions. User define alarm conditions for configurable alarms. Allow the following four types of configurable alarms: digital alarms, time-stamped alarms, analog alarms, and advanced alarms. Create a project page to display alarms and allow for operator intervention. Alarms must be able to be ordered into categories for prioritization and display.
  6. Online Help functions, including a complete Help guide, navigable with forward and back buttons, an Index, and a Search function. Shall have complete context-sensitive help in all of the development screens.
- F. Configuration
1. The software shall contain Wizards that allow quick and easy setup of configurable devices and the main control unit.
  2. Shall provide Genies already programmed for metering devices. These Genies shall be configured to access and show real-time readings.
  3. Shall contain pre-programmed tags for trending and graphing, reporting, events logging, and alarm conditions.
  4. The configuration mode shall use forms and templates for data entry during development.
  5. The configuration shall utilize Vectoral Graphics. The end user shall be capable of:
    - a. Importing graphics and editing them
    - b. Creating custom symbols and other objects and animating them, copying them and moving them on the screen
    - c. Connecting symbols and objects and moving them around on the screen
    - d. Assigning tags to objects, such as metering devices, to display information and perform functions
    - e. Creating links to other screens and programs from devices and/or buttons
    - f. Assigning access rights to objects on the screen
    - g. Assigning keyboard commands to objects on the screen, activated by clicking on an object, moving over an object, or releasing a “click” on an object
    - h. Configuring objects to change when the project is in Runtime Mode, or when a pre-defined condition exists, e.g., a metering device has gone offline
    - i. Assigning actions consequent on an object being clicked
    - j. Configuring more than one project at a time, utilizing the same workstation

## **PART 3 - EXECUTION**

### **3.01 INSTALLATION**

- A. A Branch Circuit Breaker shall be provided at the metering location to allow safe access to metering components without powering down the entire electrical system.
- B. All Meters, Metering Equipment and Software shall be installed to comply with Manufacturer’s installation instructions and recommendations.

- C. Wiring Connects (Additional Requirements)
  - 1. Provide communication connections,
  - 2. One 0.75-inch conduit with two Category-6 cables, homerun to nearest IDF/MDF room patch panel.
    - a. From each meter location

### **3.02 SYSTEM COMMISSIONING AND START-UP**

- A. Contractor to provide setup, testing and programming of metering system and “Commissioning”. Shall be performed prior to occupancy.
  - 1. Record the “cross reference” or the meter serial number (unique ID), meter point, to monitor load relationship.
  - 2. Check for power to the meter.
  - 3. Check the serial number inside the meter.
  - 4. Open the panel so that all CT’s are visible.
  - 5. Verify the CT ratio and write up the cross reference information for the meter.
  - 6. Confirm the “cross reference”. Turn on a known load in the respective monitor load unit on each phase.
  - 7. Verify the meter’s phase diagnostics for the assigned monitor load. Confirm that there is a significant increase on the load for each phase of the meter point.
  - 8. After phases have been checked and loads are still running, turn off the breaker serving the monitor load and confirm that all loads are disconnected.
- B. Test Results:
  - 1. Submit two draft copies of Test results to the Owner’s Representative.
  - 2. After approval submit the test results in two final printed copies and one computer readable copy.
- C. Testing shall include testing of Communications between Sub-meters, Communications modules, Transponders, and Remote monitoring AMR locations.
  - 1. Testing shall confirm that all power meters included in cross-reference are properly communicating.
  - 2. Testing shall confirm that remote connection is complete.
  - 3. Testing shall confirm that all Transponders and the networks are communicating properly.

END OF SECTION 26 09 10  
022119/212220

This page is blank.

**SECTION 26 09 43**  
**LIGHTING CONTROL SYSTEMS**

**PART 1 - GENERAL**

**1.01 SECTION INCLUDES**

- A. Digital-Network Lighting Control System and Associated Components (See Section 09113 for General Commissioning Requirements):
  - 1. Power panels.
  - 2. LED drivers.
  - 3. Lighting control modules (Lutron EnergiSavr Node).
  - 4. Lighting management hubs.
  - 5. Lighting management system computers.
  - 6. Lighting management system software.
  - 7. Control stations.
  - 8. Low-voltage control interfaces.
  - 9. Wired sensors.
  - 10. Wireless sensors.
  - 11. Accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 26 05 00 – Common Work Results for Electrical
- B. Section 26 50 00 – Lighting Fixtures

**1.03 REFERENCE STANDARDS**

- A. 47 CFR 15 - Radio Frequency Devices; Code of Federal Regulations; current edition.
- B. ANSI C82.11 - American National Standard for Lamp Ballasts - High Frequency Fluorescent Lamp Ballasts - Supplements.
- C. ANSI/ESD S20.20 - Standard for the Development of an Electrostatic Discharge Control Program for Protection of Electrical and Electronic Parts, Assemblies and Equipment (Excluding Electrically Initiated Explosive Devices).
- D. ASTM D4674 - Standard Practice for Accelerated Testing for Color Stability of Plastics Exposed to Indoor Office Environments
- E. CAL TITLE 24 P6 - California Code of Regulations, Title 24, Part 6 (California Energy Code).
- F. IEC 60669-2-1 - Switches for Household and Similar Fixed Electrical Installations - Part 2-1: Particular Requirements - Electronic Switches.
- G. IEC 60929 - AC and/or DC-Supplied Electronic Control Gear for Tubular Fluorescent Lamps - Performance Requirements.
- H. IEC 61000-4-2 - Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test.

- I. IEC 61000-4-5 - Electromagnetic Compatibility (EMC) - Part 4-5: Testing and Measurement Techniques - Surge Immunity Test.
- J. IEEE C62.41.2 - Recommended Practice on Characterization of Surges in Low-Voltage (1000 V and less) AC Power Circuits.
- K. ISO 9001 - Quality Management Systems-Requirements.
- L. NECA 1 - Standard for Good Workmanship in Electrical Construction.
- M. NECA 130 - Standard for Installing and Maintaining Wiring Devices; National Electrical Contractors Association.
- N. NEMA 410 - Performance Testing for Lighting Controls and Switching Devices with Electronic Drivers and Discharge Ballasts; National Electrical Manufacturers Association.
- O. NEMA WD 1 - General Color Requirements for Wiring Devices; National Electrical Manufacturers Association.
- P. NFPA 70 - National Electrical Code; National Fire Protection Association; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- Q. UL 94 - Tests for Flammability of Plastic Materials for Parts in Devices and Appliances; Current Edition, Including All Revisions.
- R. UL 489 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit Breaker Enclosures; Current Edition, Including All Revisions.
- S. UL 508 - Industrial Control Equipment; Underwriters Laboratories Inc.; Current Edition, Including All Revisions.
- T. UL 508A - Industrial Control Panels; Underwriters Laboratories Inc.; Current Edition, Including All Revisions.
- U. UL 924 - Emergency Lighting and Power Equipment; Current Edition, Including All Revisions.
- V. UL 1472 - Solid-State Dimming Controls; Current Edition, Including All Revisions.
- W. UL 1598C - Light-Emitting Diode (LED) Retrofit Luminaire Conversion Kits; Current Edition, Including All Revisions.
- X. UL 8750 - Light Emitting Diode (LED) Equipment for Use in Lighting Products; Current Edition, Including All Revisions.

#### **1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Coordination:
  - 1. Coordinate the placement of sensors and wall controls with millwork, furniture, equipment, etc. installed under other Sections or by others.
  - 2. Coordinate the placement of wall controls with actual installed door swings.
  - 3. Coordinate the placement of daylight sensors with windows, skylights, and luminaires to achieve optimum operation. Coordinate placement with ductwork, piping, equipment, or other potential obstructions to light level measurement installed under other Sections or by others.
  - 4. Coordinate the work to provide luminaires and lamps compatible with the lighting controls to be installed.

5. Notify Architect of any conflicts or deviations from the Contract Documents to obtain direction prior to proceeding with work.
- B. Pre-Wire Meeting: Conduct on-site meeting with Lighting Control System Manufacturer prior to commencing work as part of Manufacturer's standard startup services. Manufacturer to review with Installer:
1. Low voltage wiring Requirements.
  2. Separation of power and low voltage/data wiring.
  3. Wire labeling.
  4. Lighting management hub locations and installation.
  5. Control locations.
  6. Computer jack locations.
  7. Load circuit wiring.
  8. Network wiring Requirements.
  9. Connections to other equipment and other Lutron equipment.
  10. Installer responsibilities.
  11. Power panel locations.
- C. Sequencing:
- Do not install sensors and wall controls until final surface finishes and painting are complete.

#### **1.05 SUBMITTALS**

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Include ratings, configurations, standard wiring diagrams, dimensions, colors, Service Condition Requirements, and installed features.
  1. Occupancy/Vacancy Sensors: Include detailed basic motion detection coverage range diagrams.
- C. Shop Drawings:
  1. Provide schematic system riser diagram indicating component interconnections. Include Requirements for interface with other systems.
  2. Provide detailed sequence of operations describing system functions.
- D. Manufacturer's Installation Instructions: Include application conditions and limitations of use stipulated by Product Testing Agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- E. Title 24 Acceptance Testing Documentation: Submit Certification of Acceptance and associated documentation for lighting control acceptance testing performed in accordance with CAL TITLE 24 P6, as specified in Part 3 under "COMMISSIONING".
- F. Operation and Maintenance Data: Include detailed information on lighting control system operation, equipment programming and setup, replacement parts, and recommended maintenance procedures and intervals.



- G. Warranty: Submit Sample of Manufacturer's Warranty or Enhanced Warranty as specified in Part 1 under "WARRANTY". Submit documentation of final execution completed in Owner's name and registered with Manufacturer.

#### **1.06 QUALITY ASSURANCE**

- A. Conform to Requirements of NFPA 70.
- B. Maintain at the Project Site a copy of each referenced document that prescribes Execution Requirements.
- C. Manufacturer Qualifications:
  - 1. Company with not less than 10-years of experience manufacturing lighting control systems of similar complexity to specified system.
  - 2. Registered to ISO 9001, including in-house engineering for product design activities.
  - 3. Qualified to supply specified products and to honor claims against product presented in accordance with warranty.
- D. Title 24 Acceptance Testing Technician Qualifications: Certified by a California approved Acceptance Test Technician Certification Provider (ATTCP) as an Acceptance Test Technicians (ATTs) in accordance with CAL TITLE 24 P6.

#### **1.07 DELIVERY, STORAGE, AND HANDLING**

Store products in a clean, dry space in Original Manufacturer's packaging in accordance with Manufacturer's written instructions until ready for installation.

#### **1.08 WARRANTY**

- A. See Section 01 78 00 - Closeout Submittals, for Additional Warranty Requirements.
- B. Manufacturer's Standard Warranty, with Manufacturer Start-Up; Lutron Standard 2-year Warranty; Lutron LSC-B2:
  - 1. Manufacturer Lighting Control System Components, Except Lighting Management System Computer, Ballasts/Drivers and Ballast Modules:
    - a. First Two Years:
      - 1) 100% replacement parts coverage, 100% Manufacturer labor coverage to troubleshoot and diagnose a lighting issue.
      - 2) First-available on-site or remote response time.
      - 3) Remote diagnostics for applicable systems.
    - b. Telephone Technical Support: Available 24 hours per day, 7 days per week, excluding Manufacturer holidays.
  - 2. Lighting Management System Computer: One year 100% parts coverage, 1-year 100% Manufacturer labor coverage.
  - 3. Ballasts/Drivers and Ballast Modules: 5-years 100% parts coverage, no Manufacturer labor coverage.

- C. Include as part of the base bid additional costs for Manufacturer's Enhanced Warranty with Manufacturer Start-up; Silver Enhanced Warranty; Lutron LSC-E8S; coverage to include items listed under Manufacturer's standard warranty with Manufacturer start-up above, plus the following upgrades:
  - 1. Manufacturer Lighting Control System Components, Except Lighting Management System Computer, Ballasts/Drivers and Ballast Modules:
    - a. First Two Years:
      - 1) As-available Field Service response; no committed response time.
    - b. Additional Coverage for year's 3-5: 50% replacement parts coverage, no Manufacturer labor coverage.
    - c. Additional Coverage for year's 6-8: 25% replacement parts coverage, no Manufacturer labor coverage.

## **PART 2 - PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Basis of Design Manufacturer: Lutron Electronics Company, Inc.; [www.lutron.com](http://www.lutron.com).
- B. Substitutions: See Section 01 60 00 - Product Requirements.
  - 1. All proposed substitutions (clearly delineated as such) must be submitted in writing for approval by Architect a minimum of 10 working days prior to the bid date and must be made available to all Bidders. Proposed substitutes must be accompanied by a review of the Specification noting compliance on a line-by-line basis.
  - 2. By using pre-approved substitutions, Contractor accepts responsibility and associated costs for all required modifications to related equipment and wiring. Provide complete Engineered Shop Drawings (including power wiring) with deviations from the original design highlighted in an alternate color for review and approval by Architect prior to rough-in.

### **2.02 DIGITAL-NETWORK LIGHTING CONTROL SYSTEM - GENERAL REQUIREMENTS**

- A. Sensor Layout and Tuning: No Lighting Control Manufacturer Sensor Layout and Tuning service to be provided; Lutron LSC-NO-SENS-LT.
  - 1. Contractor to utilize Lighting Control Manufacturer Installation Instructions to place / install sensors.
  - 2. At Pre-wire and Startup, Lighting Control Manufacturer to provide a rough sensor calibration only. Sensor fine-tuning to be the responsibility of Contractor.
- B. Provide products listed, classified, and labeled by Underwriter's Laboratories Inc. (UL) as suitable for the purpose indicated.
- C. Unless specifically indicated to be excluded, provide all required equipment, conduit, boxes, wiring, connectors, hardware, supports, accessories, software, system programming, etc. as necessary for a complete operating system that provides the control intent indicated.
- D. Design lighting control equipment for 10 year operational life while operating continually at any temperature in an ambient temperature range of 32 degrees F (0 degrees C) to 104 degrees F (40 degrees C) and 90% non-condensing relative humidity.

- E. Electrostatic Discharge Tolerance: Design and test equipment to withstand electrostatic discharges without impairment when tested according to IEC 61000-4-2.
- F. Dimming and Switching (Relay) Equipment:
  - 1. Designed so that electrolytic capacitors operate at least 36 degrees F (20 degrees C) below the capacitor's maximum temperature rating when the device is under fully loaded conditions at maximum rated temperature.
  - 2. Inrush Tolerance:
    - a. Utilize load-handling thyristors (SCRs and triacs), Field Effect Transistors (FETs) and Isolated Gate Bipolar Transistors (IGBTs) with maximum current rating at least two times the rated operating current of the dimmer/relay.
    - b. Capable of withstanding repetitive inrush current of 50 times the operating current without impacting lifetime of the dimmer/relay.
  - 3. Surge Tolerance:
    - a. Panels: Designed and tested to withstand surges of 6,000 V, 3,000-amp according to IEEE C62.41.2 and IEC 61000-4-5 without impairment to performance.
    - b. Other Power Handling Devices: Designed and tested to withstand surges of 6,000 V, 200-amp according to IEEE C62.41.2 without impairment to performance.
  - 4. Power Failure Recovery: When power is interrupted and subsequently restored, within 3 seconds lights to automatically return to same levels (dimmed setting, full on, or full off) as prior to power interruption.
  - 5. Dimming Requirements:
    - a. Line Noise Tolerance: Provide real-time cycle-by-cycle compensation for incoming line voltage variations including changes in RMS voltage (plus or minus 2% change in RMS voltage per cycle), frequency shifts (plus or minus 2Hz change in frequency per second), dynamic-harmonics, and line noise.
      - 1) Systems not providing integral cycle-by-cycle compensation to include external power conditioning equipment as part of dimming system.
    - b. Incorporate electronic "soft-start" default at initial turn-on that smoothly ramps lights up to the appropriate levels within 0.5 seconds.
    - c. Utilize air gap off to disconnect the load from line supply.
    - d. Control all light sources in smooth and continuous manner. Dimmers with visible steps are not acceptable.
    - e. Load Types:
      - 1) Assign a load type to each dimmer that will provide a proper dimming curve for the specific light source to be controlled.
      - 2) Provide capability of being field-configured to have load types assigned per circuit.
    - f. Minimum and Maximum Light Levels: User adjustable on a circuit-by-circuit basis.
    - g. Line Voltage Dimmers:
      - 1) Dimmers for Magnetic Low Voltage (MLV) Transformers:
        - a) Provide circuitry designed to control and provide a symmetrical AC waveform to input of magnetic low voltage transformers per UL 1472.
        - b) Dimmers using unipolar load current devices (such as FETs or SCRs) to include DC current protection in the event of a single device failure.

- 2) Dimmers for Electronic Low Voltage (ELV) Transformers: Operate transformers via reverse phase control. Alternately, forward phase control dimming may be used if Dimming Equipment Manufacturer has recommended specific ELV transformers being provided.
- 3) Dimmers for Neon and Cold Cathode Transformers:
  - a) Magnetic Transformers: Listed for use with normal (low) power factor magnetic transformers.
  - b) Electronic Transformers: Must be supported by the Ballast Equipment Manufacturer for control of specific ballasts being provided.
- h. Low Voltage Dimming Modules:
  - 1) Coordination Between Low Voltage Dimming Module and Line Voltage Relay: Capable of being electronically linked to a single zone.
  - 2) Single low voltage dimming module; capable of controlling the following light sources:
    - a) 0-10V analog voltage signal.
      - Provide Class 2 isolated 0-10V output signal conforming to IEC 60929.
      - Sink current according to IEC 60929.
      - Source current.
    - b) 10-0V reverse analog voltage signal.
    - c) DSI digital communication.
    - d) DALI broadcast communication per IEC 60929:
      - Logarithmic intensity values complying with IEC 60929.
      - Linear intensity values for use with LED color intensity control.
    - e) PWM per IEC 60929.
6. Switching Requirements:
  - a. Rated Life of Relays: Typical of 1,000,000 cycles at fully rated 16A for all lighting loads.
  - b. Switch load in a manner that prevents arcing at mechanical contacts when power is applied to and removed from load circuits.
  - c. Provide output fully rated for continuous duty for inductive, capacitive, and resistive loads.
- G. Device Finishes:
  1. Standard Colors: Comply with NEMA WD1 where applicable.
  2. Color Variation in Same Product Family: Maximum delta E of 1, CIE L\*a\*b color units.
  3. Visible Parts: Exhibit ultraviolet color stability when tested with multiple actinic light sources as defined in ASTM D4674. Provide proof of testing upon request.

### 2.03 POWER PANELS

- A. Provide power panels with configurations as indicated on the Drawings.
- B. General Requirements:
  1. Listed to UL 508 as industrial control equipment.
  2. Comply with UL 508A and IEC 60669-2-1 as applicable.
  3. Delivered and installed as a listed factory-assembled panel.

4. Field wiring accessible from front of panel without removing dimmer assemblies or other components.
5. Passively cooled via free-convection, unaided by fans or other means.
6. Shipped with each dimmer in mechanical bypass position by means of jumper bar inserted between input and load terminals. Jumpers to carry full rated load current and be reusable at any time. Mechanical bypass device to allow for switching operation of connected load with dimmer removed by means of circuit breaker.
7. Provided with branch circuit protection for each input circuit unless the panel is a dedicated feed-through type panel or otherwise indicated on the Drawings.
8. Branch Circuit Breakers:
  - a. Listed to UL 489 as molded case circuit breaker for use on lighting circuits.
  - b. Provided with visual trip indicator.
  - c. Provide circuit breakers with interrupting capacity as required to provide the short circuit current rating indicated, but not less than:
  - d. Thermal-magnetic construction for overload, short-circuit, and over-temperature protection. Use of breakers without thermal protection requires dimmers/relays to have integral thermal protection to prevent failures when overloaded or ambient temperature is above rating of panel.
  - e. Equipped with provision for tag-out/lock-out devices to secure circuit breakers in off position when servicing loads.
  - f. Replaceable without moving or replacing dimmer/relay assemblies or other panel components.
  - g. Listed as Switch Duty (SWD) so that loads can be switched on and off by breakers.
9. Provide panels with listed short circuit current rating not less than the available fault current at the installed location as indicated on the Drawings.
10. Panel Processor; Lutron Circuit Selector:
  - a. Provide the following capabilities:
    - 1) Operate circuit directly from panel processor for system diagnostics and provide feed-back of system operation.
    - 2) Electronically assign each circuit to any zone in lighting control system.
    - 3) Determine normal/emergency function of panel and set emergency lighting levels.
  - b. React to changes from control within 20 milliseconds.
11. Diagnostics and Service:
  - a. Replacing dimmer/relay does not require re-programming of system or processor.
  - b. Include diagnostic LEDs for dimmers/relays to verify proper operation and assist in system troubleshooting.
  - c. Include tiered control scheme for dealing with component failure that minimizes loss of control for occupant.
    - 1) If lighting control system fails, lights to remain at current level. Panel processor provides local control of lights until system is repaired.

- 2) If panel processor fails, lights to remain at current level. Circuit breakers can be used to turn lights off or to full light output, allowing non-dim control of lights until panel processor is repaired.
- 3) If dimmer fails, factory-installed mechanical bypass jumpers to allow each dimmer to be mechanically bypassed. Mechanical bypass device to allow for switching operation of connected load with dimmer removed by means of circuit breaker.

C. Product(s):

1. Relay Panels:
  - a. Product: Lutron XP Series Switching Panels.
  - b. Provide surface-mounted or flush-mounted enclosures as indicated.
  - c. Switching Requirements:
    - 1) Utilize 20A continuous-use rated switching modules; able to switch 20 A receptacles.
    - 2) Rated Life of Relay: Typical of 1,000,000 cycles at fully rated 16 A for all lighting loads.
    - 3) Switch load in a manner that prevents arcing at mechanical contacts when power is applied to and removed from load circuits.
    - 4) Provide output fully rated for continuous duty for inductive, capacitive, and resistive loads.

## 2.04 LED DRIVERS

A. General Requirements:

1. Operate for at least 50,000 hours at maximum case temperature and 90 percent non-condensing relative humidity.
2. Provide thermal fold-back protection by automatically reducing power output (dimming) to protect LED driver and LED light engine/fixture from damage due to over-temperature conditions that approach or exceed the LED driver's maximum operating temperature at calibration point.
3. Provide integral recording of operating hours and maximum operating temperature to aid in troubleshooting and warranty claims.
4. Designed and tested to withstand electrostatic discharges incurred during manufacturing, installation, or field troubleshooting without impairment of performance when tested according to IEC 61000-4-2.
5. Manufactured in a facility that employs ESD reduction practices in compliance with ANSI/ESD S20.20.
6. UL 8750 recognized or listed as applicable.
7. UL Type TL rated where possible to allow for easier fixture evaluation and listing of different driver series.
8. UL 1598C listed for field replacement as applicable.
9. Designed and tested to withstand Category A surges of 4,000 V according to IEEE C62.41.2 without impairment of performance.
10. Class A sound rating; inaudible in a 27 dBA ambient.

11. Demonstrate no visible change in light output with a variation of plus or minus 10% change in line-voltage input.
  12. LED drivers of the same family/series to track evenly across multiple fixtures at all light levels.
  13. Offer programmable output currents in 10 mA increments within designed driver operating ranges for custom fixture length and lumen output configurations, while meeting a low-end dimming range of 100% to 1% or 100% to 5% as applicable.
  14. Meet NEMA 410 inrush Requirements.
  15. Employ integral fault protection up to 277 V to prevent LED driver damage or failure in the event of incorrect application of line-voltage to communication link inputs.
  16. LED driver may be remote located up to 100 feet (30 m) from LED light engine depending on power outputs required and wire gauge utilized by installer.
- B. Digital Control (when used with compatible Lutron lighting control systems):
1. Employ power failure memory; LED driver to automatically return to the previous state/ light level upon restoration of utility power.
  2. Operate from input voltage of 120 V through 277 V at 50/60Hz.
  3. Automatically go to 100% light output upon loss of control link voltage and lock out system commands until digital control link voltage is restored. Manufacturer to offer UL 924 compliance achievable through use of external Lutron Model LUT-ELI-3PSH interface upon request.
  4. Each driver responds independently per system maximum:
    - a. Up to 32 occupant sensors.
    - b. Up to 16 daylight sensors.
  5. Responds to digital load shed command. (Example: If light output is at 30% and a load shed command of 10% is received, the ballast automatically sets the maximum light output at 90% and lowers current light output by 3% to 27%).
  6. Digital low-voltage control wiring capable of being wired as either Class 1 or Class 2.
- C. Product(s):
1. Digital Control, Five Percent Dimming; Lutron 5-Series (LDE5-Series):
    - a. Dimming Range: 100% to 5% measured output current.
    - b. Typically dissipates 0.2 W standby power at 120 V and 0.3 W standby power at 277 V.
    - c. Complies with FCC Requirements of CFR, Title 47, Part 15, for commercial applications at 120-277 V.
    - d. Constant Current Reduction (CCR) dimming method.
    - e. Total Harmonic Distortion (THD): Less than 21% at full load; complies with ANSI C82.11.
    - f. Constant Current Drivers:
      - 1) Support for downlights and pendant fixtures in select currents from 350 mA to 1.4 A to ensure a compatible driver exists.
        - a) Support LED arrays up to 35 W.
        - b) Models available that meet Requirements for Energy Star compliance.

- 2) Support for troffers, linear pendants, and linear recessed fixtures from 150 mA to 2.1 A to ensure a compatible driver exists.
  - a) Support LED arrays up to 75 W.
  - b) Models available to meet the Design Lights Consortium (DLC) Power Line Quality Requirements.
2. Digital Control, 1% Dimming with Soft-On and Fade-to-Black Low End Performance; Lutron Hi-lume 1% Soft-on Fade-to-Black (LDE1-Series):
  - a. Dimming Range: 100% to 1% measured output current.
  - b. Features smooth fade-to-on and fade-to-black (Lutron Soft-On, Fade-to-Black) low end dimming performance for an incandescent-like dimming experience.
  - c. Typically dissipates 0.2 W standby power at 120 V and 0.3 W standby power at 277 V.
  - d. Complies with FCC Requirements of CFR, Title 47, Part 15, for commercial applications at 120-277 V.
  - e. Employs true Constant Current Reduction (CCR) dimming method from 100 to 5% light level and Pulse Width Modulation (PWM) dimming method from 5% to off.
  - f. Pulse Width Modulation (PWM) frequency of 240 Hz.
  - g. Total Harmonic Distortion (THD): Less than 20% at full output for drivers greater than 25 W; complies with ANSI C82.11.
  - h. UL Class 2 output.
  - i. Driver outputs to be short circuit protected, open circuit protected, and overload protected.
  - j. Constant Current Driver; Lutron K-Case Form Factor: Support for fixtures from 220 mA to 1.4 A over multiple operating ranges.
    - 1) Support LED arrays up to 40 W.
    - 2) Models available that meet Requirements for Energy Star compliance.
  - k. Constant Current Driver; Lutron M-Case Form Factor: Support for fixtures from 150 mA to 2.1 A over multiple operating ranges.
    - 1) Support LED arrays up to 75 W.
    - 2) Models available to meet the Design Lights Consortium (DLC) Power Line Quality Requirements.

## **2.05 LIGHTING CONTROL MODULES (LUTRON ENERGY SAVER NODE)**

- A. Provide lighting control modules as indicated or as required to control the loads as indicated.
- B. General Requirements:
  1. Listed to UL 508 as industrial control equipment.
  2. Delivered and installed as a listed factory-assembled panel.
  3. Passively cooled via free-convection, unaided by fans or other means.
  4. Mounting: Surface.
  5. Connection without interface to wired:
    - a. Occupancy sensors.
    - b. Daylight sensors.
    - c. IR receivers for personal control.



6. Connects to lighting management hub via RS485.
  7. LED status indicators confirm communication with occupancy sensors, daylight sensors, and IR receivers.
  8. Contact Closure Input:
    - a. Directly accept contact closure input from a dry contact closure or sold-state output without interface to:
      - 1) Activate scenes.
        - a) Scene activation from momentary or maintained closure.
      - 2) Enable or disable after hours.
        - a) Automatic sweep to user-specified level after user-specified time has elapsed.
        - b) System will provide occupants a visual warning prior to sweeping lights to user-specified level.
        - c) Occupant can reset timeout by interacting with the lighting system.
      - 3) Activate or deactivate demand response (load shed).
        - a) Load shed event will reduce lighting load by user-specified amount.
  9. Emergency Contact Closure Input:
    - a. Turn all zones to full output during emergency state via direct contact closure input from UL 924 listed emergency lighting interface, security system or fire alarm system.
    - b. Allow configurable zone response during emergency state.
    - c. Disable control operation until emergency signal is cleared.
  10. Supplies power for control link for keypads and control interfaces.
  11. Distributes sensor data among multiple lighting control modules.
  12. Capable of being controlled via wireless sensors and controls.
- C. 0-10V Lighting Control Modules:
1. Product(s):
  2. Coordination Between Low Voltage Dimming Module and Line Voltage Relay: Capable of being electronically linked to single zone.
  3. Single low voltage dimming module; capable of controlling following light sources:
    - a. 0-10V analog voltage signal.
      - 1) Provide Class 2 isolated 0-10V output signal conforming to IEC 60929.
      - 2) Sink current per IEC 60929.
    - b. 10V-0V analog voltage signal.
      - 1) Provide Class 2 isolated 0-10V output signal conforming to IEC 60929.
      - 2) Sink current per IEC 60929.
  4. Switching:
    - a. Rated Life of Relay: Typical of 1,000,000 cycles at fully rated 16 A for all lighting loads.
    - b. Load switched in manner that prevents arcing at mechanical contacts when power is applied to and removed from load circuits.
    - c. Fully rated output continuous duty for inductive, capacitive, and resistive loads.

- d. Module to integrate up to four individually controlled zones.
  - e. Utilize air gap off, activated when user selects "off" at any control to disconnect the load from line supply.
- D. Digital Fixture Lighting Control Modules:
- 1. Product(s):
    - a. Lutron EcoSystem Energi Savr Node; Model QSN-1ECO-S: One EcoSystem Digital Link.
    - b. Lutron EcoSystem Energi Savr Node; Model QSN-2ECO-S: Two EcoSystem Digital Links.
  - 2. Provides two-way feedback with digital fixtures for energy monitoring, light level status, lamp failure reporting, and ballast/driver failure reporting.
  - 3. Provide testing capability using manual override buttons.
  - 4. Each low-voltage digital communication link to support up to 64 ballasts or LED drivers capable of NFPA 70 Class 1 or Class 2 installation.

## 2.06 LIGHTING MANAGEMENT HUBS

- A. Product: Lutron Quantum Light Management Hub.
- B. Provided in a pre-assembled NEMA listed enclosure with terminal blocks listed for field wiring.
- C. Connects to controls and power panels via RS485.
- D. Enables light management software to control and monitor compatible dimming ballasts and ballast modules, power panels, power modules, and window treatments.
  - 1. Utilizes Ethernet connectivity to light management computer utilizing one of the following methods:
    - a. Dedicated network.
    - b. Dedicated VLAN.
    - c. Shared network with Building Management System (BMS).
    - d. Corporate network where managed switches are configured to allow multicasting and use of IGMP.
- E. Integrates control station devices, power panels, shades, preset lighting controls, and external inputs into a single customizable lighting control system with:
  - 1. Multiple Failsafe Mechanisms:
    - a. Power failure detection via emergency lighting interface.
    - b. Protection: Lights go to full on if ballast wires are shorted.
    - c. Distributed architecture provides fault containment. Single hub failure or loss of power does not compromise lights and shades connected to other lighting management hubs.
  - 2. Manual overrides.
  - 3. Automatic control.
  - 4. Central computer control and monitoring.
  - 5. Integration with BMS via BACnet.
- F. Furnished with astronomical time clock.

- G. Maintains a backup of the programming in a non-volatile memory capable of lasting more than 10-years with-out power.
- H. BACnet Integration License:
  - 1. Provide ability to communicate by means of native BACnet IP communication (does not require inter-face) to lighting control system from a user-supplied 10BASE-T or 100BASE-T Ethernet network.
  - 2. Requires only one network connection per system.
  - 3. Lighting control system to be BACnet Test Laboratory (BTL) listed.
  - 4. Basic BACnet integration license:
    - a. The BACnet integrator can command:
      - 1) Area light output.
      - 2) Area enables or disable after hours mode.
      - 3) Area load shed level.
      - 4) Area load shed enable/disable.
      - 5) Enable/Disable:
        - a) Area occupancy sensors.
        - b) Area daylighting.
      - 6) Daylighting level.
      - 7) Area occupied and unoccupied level
      - 8) Occupancy sensor timeouts.
    - b. The BACnet integrator can monitor:
      - 1) Area on/off status.
      - 2) Area occupancy status.
      - 3) Area fault.
        - a) Lamp failures.
        - b) Control devices not responding.
      - 4) Area load shed status.
      - 5) Area instantaneous energy usage and maximum potential power usage.
      - 6) Energy savings broken out by strategy (occupancy, timeclock, daylighting, personal control, tuning, load shed) down to the individual area.
      - 7) Enable/Disable:
        - a) Area occupancy sensors.
        - b) Daylighting.
        - c) Timeclocks.
      - 8) Daylighting level.
      - 9) Light levels from photo sensors or Radio Window sensors.
      - 10) Area occupied and unoccupied level.
      - 11) Occupancy sensor timeouts.
  - 5. Integration with other devices over Ethernet via Telnet using the Lutron Integration Protocol.
  - 6. Control other devices over Ethernet via TCP or Telnet by sending device specific strings.

## 2.07 LIGHTING MANAGEMENT SYSTEM COMPUTERS

### A. Computers:

1. Product: Lutron Q-Manager.
2. System PC (Desktop/Laptop):
  - a. Suitable for occasional programming, monitoring, and control of digital network lighting controls.
  - b. Unless otherwise indicated, computer(s) to be provided by others, meeting Lighting Control System Manufacturer's Minimum Requirements.
  - c. Minimum Hardware Requirements:
    - 1) Processor: Single Intel® Core® i3 processor with minimum speed of 2.4 GHz.
    - 2) 4 GB RAM.
    - 3) 250 GB hard drive (40 GB for application).
    - 4) One 10/100/1000 Ethernet network interface for communication with lighting management hubs.
    - 5) Monitor with 1280 x 1024 resolution.
    - 6) 4 USB 2.0 ports.
    - 7) Dedicated Graphics Card with 256 MB of memory.
  - d. Minimum Software Requirements:
    - 1) Licensed installation of US English 64-bit Microsoft® Windows® 7 Professional with Service Pack 1, US English 64-bit Microsoft® Windows® 8 Professional, or US English 64-bit Microsoft® Windows® 8.1 Professional.
    - 2) Microsoft® Internet Information Services (IIS) 7 or later.
    - 3) Microsoft® Internet Explorer 9 or later.
    - 4) Microsoft® .NET Framework 3.5.
    - 5) Microsoft® .NET Framework 4.5.
3. Server:
  - a. Suitable for 24 hour per day, 7 day per week programming, monitoring, control, and data logging of digital-network lighting controls.
  - b. Suitable to handle client machine request in multi-computer systems.
  - c. Unless otherwise indicated, computer to be provided by others, meeting Lighting Control System Manufacturer's minimum Requirements.
  - d. Minimum Hardware Requirements:
    - 1) Processor: Quad Core Intel® Xeon® processor.
    - 2) 8 GB Ram.
    - 3) 250 GB hard drive (40 GB for application and database).
    - 4) Two 10/100/1000 Ethernet network interfaces - one for communication with lighting management hubs and one for communication with corporate intranet to allow access from system PCs and/or energy saving display terminals. Only one Ethernet Network Interface is required if all lighting management hubs and client PCs are on the same network.
    - 5) Monitor with 1280 x 1024 resolution.
    - 6) 4 USB 2.0 ports.
    - 7) Dedicated Graphics Card with 256 MB of memory (only required if running client software from the server).

- e. Minimum Software Requirements:
  - 1) Licensed installation of US English 64-bit Microsoft® Windows® Server 2008 R2, Windows Server 2012 R1, or Windows Server 2012 R2.
  - 2) Microsoft® Internet Information Services (IIS) 7 or later.
  - 3) Microsoft® Internet Explorer 9 or later.
  - 4) Microsoft® .NET Framework 3.5.
  - 5) Microsoft® .NET Framework 4.5.

## **2.08 LIGHTING MANAGEMENT SYSTEM SOFTWARE**

- A. Provide system software license and hardware that is designed, tested, manufactured, and warranted by a single Manufacturer.
- B. Configuration Setup Software:
  1. Product: Lutron Q-Design.
  2. Suitable to make system programming and configuration changes using a Graphical Floor Plan view or a generic system layout.
  3. Windows-based, capable of running on either central server or a remote client over TCP/IP connection.
  4. Publish Graphical Floor Plan: Allows the user to publish new Graphical Floor Plan files, allowing users to monitor the status of lights, occupancy of areas, and daylighting status.
  5. Back-Up Project Database: Allows the user to back up the Project database that holds all the configuration information for the system, including keypad programming, area scenes, daylighting, occupancy programming, emergency levels, night lights, and time clock.
  6. Publish Project Database: Allows the user to send a new Project database to the server and download the new configuration to the system. The Project database holds all the configuration information for the system, including keypad programming, area scenes, daylighting, occupancy programming, emergency levels, night lights, and time clock.
  7. Allows Manufacturer (either remotely or with on-site service call) or end-user (with training) to:
    - a. Capture system design:
      - 1) Geographical layout.
      - 2) Load schedule zoning.
      - 3) Equipment schedule.
      - 4) Equipment assignment to lighting management hubs.
      - 5) Daylighting design.
    - b. Define the configuration for the following in each area:
      - 1) Lighting scenes.
      - 2) Control station devices.
      - 3) Interface and integration equipment.
      - 4) Occupancy/after hours.
      - 5) Partitioning.
      - 6) Daylighting.
      - 7) Emergency lighting.
      - 8) Night lights.

- c. Startup:
  - 1) Addressing.
  - 2) Daylighting.
  - 3) Provide customized conditional programming.
- C. Control and Monitor Software:
  - 1. Product: Lutron Quantum Vue.
  - 2. General Requirements:
    - a. Web-based; runs on most HTML5 compatible browsers (including Internet Explorer, Chrome, and Safari).
    - b. Supports multiple platforms and devices; runs from a tablet, desktop, laptop, or smartphone; optimized for displays of 1024 by 768 pixels or higher.
    - c. User interface supports multi-touch gestures such as pinch to zoom, drag to pan, etc.
    - d. Utilizes HTTPS (industry-standard certificate-based encryption and authentication for security).
    - e. All functionality listed below must be available via a single application.
  - 3. System Navigation and Status Reporting:
    - a. Performed using Graphical Floor Plan view or a generic system layout.
    - b. Graphical Floor Plan View: Utilizes customized CAD Based Drawing of the building. Pan and zoom feature allows for easy navigation; dynamically adjusts the details presented based on zoom level.
    - c. Area, scene, and zone names can be changed in real time.
    - d. Adjustments can be made based on area type.
  - 4. Control of Lights:
    - a. Control and monitor individual lights from a Graphical Floor Plan (with Lutron Eco-System digital ballasts/drivers).
      - 1) Individual lights can be monitored for on/off status.
      - 2) Individual lights can be turned on/off or sent to a specific level.
      - 3) High end of individual lights can be tuned/trimmed.
    - b. Control and monitor zone/area lights.
      - 1) Area lights can be monitored for on/off status.
      - 2) All lights in an area can be turned on/off or sent to a specific level.
      - 3) For areas that have been zoned, these areas may be sent to a predefined lighting scene, and individual zones may be controlled.
      - 4) Area lighting scenes can be renamed and modified in real-time, changing the levels that zones go to when a scene is activated.
      - 5) High and low end of area lighting can be tuned/trimmed.
    - c. Control and monitor area partition status from a Graphical Floor Plan.
  - 5. Occupancy:
    - a. Area occupancy can be monitored.
    - b. Area occupancy can be disabled to override occupancy control or in case of occupancy sensor problems.

- c. Area occupancy settings including level that lights turn on to when area is occupied, and level that lights turn off to when area is unoccupied can be changed in real-time.
  - d. Monitor energy savings due to occupancy down to an individual area.
6. Daylighting:
    - a. Daylighting can be enabled/disabled. Can be used to override the control currently taking place in the space.
    - b. Daylight calibration can be adjusted for each day lit area.
    - c. Daylight status can be monitored.
    - d. Monitor energy savings due to daylight harvesting down to an individual area.
  7. Load Shedding; Lutron IntelliDemand: Allows the building manager to monitor whole building lighting power usage and apply a customized load shed reduction to selected areas, thereby reducing a building's power usage; load shedding triggered via Quantum Vue Software or BACnet.
  8. Scheduling: Schedule time of day and astronomic time clock events to automate functions.
    - a. Adjust or disable a single occurrence of a repeating scheduled event.
    - b. Easily monitor and adjust scheduled events using a weekly calendar view.
  9. Reporting: Provide reporting capability that allows the building manager to gather real-time and historical information about the system as follows:
    - a. Energy Reports: Show a comparison of cumulative energy used over a period of time for one or more areas.
    - b. Power Reports: Show power usage trend over a period of time for one or more areas.
    - c. Energy Density Report: Show energy usage in W/sq. ft.
    - d. Energy Savings by Strategy Report: Show energy savings for any area broken down by strategy (tuning, occupancy, daylighting, scheduled events, personal control, and load shedding).
    - e. Space Utilization/Occupancy Reports: Show historical occupancy over a period of time for one or more areas using a graphical floor plan, generic system layout, and/or graphs and charts.
    - f. Activity Report: Show what activity has taken place over a period of time for one or more areas. Activity includes occupant activities (e.g. wall controls being pressed), building manager operation (e.g. controlling/changing areas using the control and monitor tool), and device failures (e.g. keypads or ballasts that are not responding).
    - g. Lamp Failure Report: Shows which areas are currently reporting lamp failures.
    - h. Sensor Level Report: Shows the light level in footcandles of any photo sensor in the system.
    - i. Alert Activity Report: Capable of generating historical reports of all alert activity within the system.
  10. Diagnostics: Allows the building manager to check on the status of all equipment in the lighting control system. Devices to be listed with a reporting status of OK, missing, or unknown.

11. Alerts and Alarms: Monitors the system for designated events/triggers and automatically generates alerts according to configured response criteria.
  - a. Capable of monitoring for the following events/triggers:
    - 1) A failed piece of equipment (e.g. ballast, control, sensor, etc.); alert cleared when equipment is replaced.
    - 2) A lamp outage (for compatible EcoSystem digital electronic dimming ballasts only); alert cleared when lamp is replaced.
    - 3) Low battery conditions in battery-operated sensors and controls; alert cleared when battery is replaced.
    - 4) Luminaires with lamp operating hours in excess of designated time.
    - 5) A load shed event; alert generated for beginning and end of trigger.
    - 6) Energy usage higher than designated threshold target.
    - 7) Potential light level condition discrepancies (daylight sensors not agreeing with expected lighting status).
    - 8) Potential sensor failures (Radio Window sensors that have not seen a change in light level).
  - b. View alerts on a customized Graphical Floor Plan.
  - c. Capable of generating alerts through visible changes in software or through email messages.
  - d. Capable of customizing the frequency of alerts and providing notifications immediately or through daily, weekly, or monthly summaries.
  - e. Capable of sending different alerts to different system users.
  - f. Capable of generating historical reports of all alert activity within the system.
12. Administration:
  - a. Users: Allows new user accounts to be created and existing user accounts to be edited.
    - 1) Supports Active Directory (LDAP) tying user accounts to network accounts.
  - b. Area and feature access can be restricted based on login credentials with assigned levels of access rights (Monitor, Control Only, Control and Edit, Admin) and customized access levels available.
13. Quick Controls: Create shortcuts to activate customized system-wide actions, such as updating lighting and/or shade levels.
14. Provides control/monitoring of partition status to automatically reconfigure how the space operates based on the partition's open/closed status.
15. Variables: Used for custom program of a system and/or to signal a third party system. Any change may cause a change in the behavior of the system.
  - a. View the current state of system variables across subsystems.
  - b. Update the current variable state across all subsystems.
16. Device Lock/Unlock: Allows the building manager to lock control station devices to prevent building occupants from activating their programming (button presses), until they are unlocked.
  - a. Keypads can be locked to help ensure occupants cannot change light and shade levels in a public space during specific events or business hours.



- b. Keypads can be unlocked after events/during afterhours to allow maintenance, cleaning, security, and others to perform their tasks without needing to contact a Building Manager.
- D. Contractor shall provide factory commissioning to support pre-functional and functional testing with CxA witnessing. See General Commissioning Requirements Section 01 91 13.

## 2.09 CONTROL STATIONS

- A. Provide control stations with configuration as indicated or as required to control the loads as indicated.
- B. Wired Control Stations:
  - 1. General Requirements:
    - a. Power: Class 2 (low voltage).
    - b. UL listed.
    - c. Provide faceplates with concealed mounting hardware.
    - d. Borders, logos, and graduations to use laser engraving or silk-screened graphic process that chemically bonds graphics to faceplate, resistant to removal by scratching and cleaning.
    - e. Finish: As specified for wall controls in "Device Finishes" under DIGITAL NETWORK LIGHTING CONTROL SYSTEM - GENERAL REQUIREMENTS article above.
  - 2. Multi-Scene Wired Control:
    - a. General Requirements:
      - 1) Allows control of any devices part of the lighting control system.
      - 2) Allows for easy reprogramming without replacing unit.
      - 3) Replacement of units does not require reprogramming.
      - 4) Communications: Utilize RS485 wiring for low-voltage communications link.
      - 5) Engrave keypads with button, zone, and scene descriptions as indicated on the Drawings.
      - 6) Software Configuration:
        - a) Customizable control station device button functionality:
          - Buttons can be programmed to perform single defined action.
          - Buttons can be programmed to perform defined action on press and defined action on release.
          - Buttons can be programmed using conditional logic off of a state variable such as time of day or partition status.
          - Buttons can be programmed to perform automatic sequence of defined actions.
          - Capable of deactivating select keypads to prevent accidental changes to light levels.
          - Buttons can be programmed for raise/lower of defined loads.
          - Buttons can be programmed to toggle defined set of loads on/off.
      - 7) Status LEDs:
        - a) Upon button press, LEDs to immediately illuminate.
        - b) LEDs to reflect the true system status. LEDs to remain illuminated if the button press was properly processed or LEDs to turn off if the button press was not processed.

- c) Support logic that defines when LED is illuminated:
  - Scene logic (logic is true when all zones are at defined levels).
  - Room logic (logic is true when at least one zone is on).
  - Pathway logic (logic is true when at least one zone is on).
  - Last scene (logic is true when spaces are in defined scenes).
- b. Wired Keypads; Lutron see Touch QS Wallstations:
  - 1) Style: Architectural Non-Insert Style.
  - 2) Mounting: Wall-box or low-voltage mounting bracket; provide wall plates with concealed mounting hardware.
  - 3) Button/Engraving Backlighting:
    - a) Utilize backlighting for buttons and associated engraving to provide readability under all light conditions.
    - b) Backlight intensity adjustable via programming software.
  - 4) Design keypads to allow field-customization of button color, configuration, and engraving using field-changeable replacement kits.
  - 5) Contact Closure Interface: Provide two contact closure inputs on back of unit which provide independent functions from front buttons; accepts both momentary and maintained contact closures.
  - 6) Terminal block inputs to be over-voltage and mis-wire-protected against reversals and shorts.
- c. Wired Keypads; Lutron QS Wired Palladiom Wallstations:
  - 1) Style: Architectural Style.
  - 2) Mounting: Wallbox; provide wall plates with concealed mounting hardware.
  - 3) Buttons and Faceplate:
    - a) Buttons to be greater than 0.65 inch (16.5 mm) in height to provide large target area for ease of use and actuation.
    - b) Front of buttons to be flush with faceplate.
    - c) Buttons and faceplate to be of the same material and finish (e.g. plastic/plastic, glass/glass, metal/metal).
    - d) Buttons to depress and provide tactile feedback of a successful button push. Controls utilizing capacitive or resistive touch technology are not acceptable.
    - e) Gaps to be less than 0.007 inch (0.18 mm) between buttons and less than 0.15 inch (3.8 mm) between buttons and faceplate.
  - 4) Button/Engraving Backlighting:
    - a) Backlighting to be visible through engraved text to provide clear readability in a variety of lighting conditions.
    - b) Indicate active scene through the intensity of the backlighting (brighter backlit text indicates the active state).
    - c) Backlight intensity adjustable via programming software; capable of dynamic adjustment during usage based on conditional logic (time of day, button press, etc.).
    - d) Backlight intensity automatically adjusts based on room ambient light level.
  - 5) Keypads to allow field-customization of button color and engraving using field-changeable replacement kits.

- 6) Terminal block inputs to be over-voltage and miswire-protected against reversals and shorts.
- C. Wireless (Radio Frequency) Controls:
1. Product(s):
    - a. Four-Button; Lutron Pico Wireless Control Model PJ2-4B.
      - 1) Button Marking: Scene keypads (light).
  2. Quantity: As indicated on the Drawings.
  3. Communicates via radio frequency to compatible dimmers, switches, and plug-in modules.
  4. Does not require external power packs, power or communication wiring.
  5. Allows for easy reprogramming without replacing unit.
  6. Button Programming:
    - a. Single action.
    - b. Toggle action.
    - c. Defined action on press and defined action on release.
  7. Includes LED to indicate button press or programming mode status.
  8. Mounting:
    - a. Capable of being mounted with a table stand or directly to a wall under a faceplate.
    - b. Faceplates: Provide concealed mounting hardware.
  9. Power: Battery-operated with minimum 10-year battery life.
  10. Finish: As specified for wall controls in "Device Finishes" under DIGITAL-NETWORK LIGHTING CONTROL SYSTEM - GENERAL REQUIREMENTS article above.

## 2.10 LOW-VOLTAGE CONTROL INTERFACES

- A. Provide low-voltage control interfaces as indicated or as required to control the loads as indicated.
- B. UL listed.
- C. Sensor Modules:
  1. Products:
    - a. Sensor module with both wired and wireless inputs; Lutron Model QSM2-4W-C.
  2. Wired Modules:
    - a. Provide wired inputs for:
      - 1) Occupancy sensors.
      - 2) Daylight sensors.
      - 3) IR receivers for personal control.
      - 4) Digital ballast wall stations.
  3. Wireless Modules:
    - a. Provide wireless communication inputs for:
      - 1) Occupancy sensors.
      - 2) Daylight sensors.
      - 3) Wireless controller.

- b. RF Range: 30 feet (9 m) between sensor and compatible RF receiving devices.
- c. RF Frequency: 434 MHz; operates in FCC governed frequency spectrum for periodic operation; continuous transmission spectrum is not permitted.
- 4. Communicate sensor information to wired low-voltage digital link for use by compatible devices.

## 2.11 WIRED SENSORS

### A. Wired Occupancy Sensors:

- 1. General Requirements:
  - a. Connects directly to compatible ballasts and modules without the need of a power pack or other interface.
  - b. Turns off or reduces lighting automatically after reasonable time delay when a room or area is vacated by the last person to occupy the space.
  - c. Accommodates all conditions of space utilization and all irregular work hours and habits.
  - d. Comply with UL 94.
  - e. Self-Adaptive Sensors: Continually adjusts sensitivity and timing to ensure optimal lighting control for any use of the space; furnished with field-adjustable controls for time delay and sensitivity to override any adaptive features.
  - f. Provide capability to:
    - 1) Add additional timeout system-wide without need to make local adjustment on sensor.
    - 2) Group multiple sensors.
  - g. Power Failure Memory: Settings and learned parameters to be saved in non-volatile memory and not lost should power be interrupted and subsequently restored.
  - h. Furnished with all necessary mounting hardware and instructions.
  - i. Class 2 devices.
  - j. Color: White.
- 2. Wired Dual Technology Sensors:
  - a. Passive Infrared: Utilize multiple segmented lenses, with internal grooves to eliminate dust and residue build-up.
  - b. Ultrasonic: Utilize an operating frequency of 32 kHz or 40 kHz, crystal-controlled to operate within plus/minus 0.005% tolerance.

## 2.12 WIRELESS SENSORS

### A. General Requirements:

- 1. Operational life of 10 years without the need to replace batteries when installed per Manufacturer's instructions.
- 2. Communicates directly to compatible RF receiving devices through use of a radio frequency communications link.
- 3. Does not require external power packs, power wiring, or communication wiring.
- 4. Capable of being placed in test mode to verify correct operation from the face of the unit.

5. RF Range: 30 feet (9 m) between sensor and compatible RF receiving device(s).
  6. Electromagnetic Interference/Radio Frequency Interference (EMI/RFI) Limits: Comply with FCC Requirements of CFR, Title 47, Part 15, for Class B application.
- B. Wireless Occupancy/Vacancy Sensors:
1. General Requirements:
    - a. Provides a clearly visible method of indication to verify that motion is being detected during testing and that the unit is communicating to compatible RF receiving devices.
    - b. Utilize multiple segmented lenses, with internal grooves to eliminate dust and residue build-up.
    - c. Sensing Mechanism: Passive infrared coupled with technology for sensing fine motions; Lutron XCT Technology. Signal processing technology detects fine-motion passive infrared (PIR) signals without the need to change the sensor's sensitivity threshold.
    - d. Provide optional, readily accessible, user-adjustable controls for timeout, automatic/manual-on, and sensitivity.
    - e. Turns off lighting after reasonable and adjustable time delay once the last person to occupy the space vacates a room or area. Provide adjustable timeout settings of 1, 5, 15, and 30 minutes.
    - f. Capable of turning dimmer's lighting load on to an optional locked preset level selectable by the user. Locked preset range to be selectable on the dimmer from 1% to 100%.
    - g. Color: White.
    - h. Provide all necessary mounting hardware and instructions for both temporary and permanent mounting.
    - i. Provide temporary mounting means to allow user to check proper performance and relocate as needed before permanently mounting sensor. Temporary mounting method to be design for easy, damage-free removal.
    - j. Sensor lens to illuminate during test mode when motion is detected to allow Installer to verify coverage prior to permanent mounting.
    - k. Ceiling-Mounted Sensors:
      - 1) Provide customizable mask to block off unwanted viewing areas.
  2. Wireless Combination Occupancy/Vacancy Sensors:
    - a. Ceiling-Mounted Sensors: Programmable to operate as an occupancy sensor (automatic-on and automatic-off), an occupancy sensor with low light feature (automatic-on when less than one footcandle of ambient light available and automatic-off), or a vacancy sensor (manual-on and automatic-off).
- C. Wireless Daylight Sensors:
1. Product: Lutron Model LFR2-DCRB.
  2. Open-loop basis for daylight sensor control scheme.
  3. Stable output over temperature from 32 degrees F (0 degrees C) to 104 degrees F (40 degrees C).

4. Partially shielded for accurate detection of available daylight to prevent fixture lighting and horizontal light component from skewing sensor detection.
5. Provide linear response from 0 to 10,000 footcandles.
6. Color: White.
7. Mounting:
  - a. Provide surface mounting bracket compatible with drywall, plaster, wood, concrete, and compressed fiber ceilings.
  - b. Provide all necessary mounting hardware and instructions for both temporary and permanent mounting.
  - c. Provide temporary mounting means to allow user to check proper performance and relocate as needed before permanently mounting sensor. Temporary mounting method to be design for easy, damage-free removal.
8. Meets California Title 24 Requirements.

### **2.13 ACCESSORIES**

- A. Emergency Lighting Interface:
  1. Product: Lutron Model LUT-ELI.
  2. Provides total system listing to UL 924 when used with lighting control system.
  3. Senses all three phases of building power.
  4. Provides an output to power panels or digital ballast interfaces if power on any phase fails and sends all lights controlled by these devices to an emergency light level setting. Lights to return to their previous intensities when normal power is restored.
  5. Accepts a contact closure input from a fire alarm control panel.
- B. Provide power supplies as indicated or as required to power system devices and accessories.

### **2.14 SOURCE QUALITY CONTROL**

- A. See Section 01 40 00 - Quality Requirements, for Additional Requirements.
- B. Factory Testing; Lutron Standard Factory Testing:
  1. Perform full-function factory testing on all completed assemblies. Statistical sampling is not acceptable.
  2. Perform full-function factory testing on 100% of all ballasts and LED drivers.
  3. Perform factory audit burn-in of all dimming assemblies and panels at 104 degrees F (40 degrees C) at full load for 2-hours.

## **PART 3 - EXECUTION**

### **3.01 INSTALLATION**

- A. Perform work in a neat and workmanlike manner in accordance with NECA 1 and, where applicable, NECA 130, except for mounting heights specified in those Standards.
- B. Install products in accordance with Manufacturer's instructions.

- C. Provide dedicated network between lighting management system computer and lighting management hubs.
- D. Define each dimmer/relay load type, assign each load to a zone, and set control functions.
- E. Sensor Locations:
  - 1. Where Lighting Control Manufacturer Sensor Layout and Tuning service is specified in Part 2 under "DIGITAL-NETWORK LIGHTING CONTROL SYSTEM - GENERAL REQUIREMENTS", locate sensors in accordance with layout provided by Lighting Control Manufacturer. Lighting Control Manufacturer may direct Contractor regarding sensor relocation should conditions require a deviation from locations indicated. Where Lighting Control Manufacturer Sensor Layout and Tuning service is not specified, locate sensors in accordance with Drawings.
- F. Ensure that daylight sensor placement minimizes sensor view of electric light sources. Locate ceiling-mounted and luminaire-mounted daylight sensors to avoid direct view of luminaires.
- G. Lamp Burn-In: Operate lamps at full output for prescribed period per Manufacturer's recommendations prior to use with any dimming controls. Replace lamps that fail prematurely due to improper lamp burn-in.
- H. LED Light Engine/Array Lead Length: Do not exceed 100 feet (31 m).
- I. System and Network Integration Consultation; Lutron LSC-INT-VISIT: Include as part of the base bid additional costs for Lighting Control Manufacturer to conduct meeting with Facility Representative and other related Equipment Manufacturers to discuss equipment and integration procedures.
  - 1. Coordinate scheduling of visit with Lighting Control Manufacturer. Manufacturer recommends that this visit be scheduled early in construction phase, after system purchase but prior to system installation.
- J. Identify system components in accordance with Section 26 05 53.

### **3.02 FIELD QUALITY CONTROL**

- A. See Section 01 40 00 - Quality Requirements, for Additional Requirements.
- B. Manufacturer's Startup Services; Lutron Standard Startup Services:
  - 1. Manufacturer's Authorized Service Representative to conduct minimum of two site visits to ensure proper system installation and operation.
  - 2. Conduct Pre-Installation visit to review Requirements with installer as specified in Part 1 under "Administrative Requirements".
  - 3. Conduct second site visit upon completion of lighting control system to perform system startup and verify proper operation:
    - a. Verify connection of power wiring and load circuits.
    - b. Verify connection and location of controls.
    - c. Energize lighting management hubs and download system data program.
    - d. Address devices.
    - e. Verify proper connection of panel links (low voltage/data) and address panel.
    - f. Download system panel data to dimming/switching panels.
    - g. Verify system operation control by control.

- h. Verify proper operation of Manufacturer's interfacing equipment.
  - i. Verify proper operation of Manufacturer's supplied PC and installed programs.
  - j. Configure initial groupings of ballast for wall controls, daylight sensors and occupancy sensors.
  - k. Provide initial rough calibration of sensors; fine-tuning of sensors is responsibility of Contractor unless provided by Lighting Control Manufacturer as part of Sensor Layout and Tuning service where specified in Part 2 under "DIGITAL-NETWORK LIGHTING CONTROL SYSTEM - GENERAL REQUIREMENTS".
  - l. Train Owner's Representative on system capabilities, operation, and maintenance, as specified in Part 3 under "Closeout Activities".
  - m. Obtain sign-off on system functions.
4. Correct defective work, adjust for proper operation, and retest until entire system complies with Contract Documents.

### **3.03 COMMISSIONING**

- A. See Section 01 91 13 - General Commissioning Requirements for Commissioning Requirements.
- B. Title 24 Acceptance Testing Service; Lutron LSC-SPV-DOC-T24: Include as part of the base bid additional costs for Lighting Control Manufacturer to perform lighting control acceptance testing in accordance with CAL TITLE 24 P6. Submit required documentation.

### **3.04 CLOSEOUT ACTIVITIES**

- A. See Section 01 78 00 - Closeout Submittals, for Closeout Submittals.
- B. See Section 01 79 00 - Demonstration and Training, for Additional Requirements.
- C. Demonstration:
  - 1. On-Site Performance-Verification Walkthrough; Lutron LSC-WALK: Include as part of the base bid additional costs for Lighting Control Manufacturer to provide on-site demonstration of system functionality to Commissioning Agent.
- D. Training:
  - 1. Include services of Manufacturer's Authorized Service Representative to perform on-site training of Owner's Personnel on operation, adjustment, and maintenance of lighting control system as part of standard system start-up services.
    - a. Include training on software to be provided:
      - 1) Configuration software used to make system programming and configuration changes.
      - 2) Control and monitor.

### **3.05 MAINTENANCE**

- A. See Section 01 70 00 - Execution and Closeout Requirements, for Additional Requirements relating to maintenance service.



- B. Software Maintenance Agreement; Lutron LSC-SMA: Include as part of the base bid additional costs for Manufacturer to provide quarterly compatibility testing results for PC-based lighting control software and new patches issued for Microsoft Operating System, Database, and Browser tools.
  - 1. If new Microsoft patches create a software conflict, Manufacturer to provide lighting control software patches to ensure continued operation.
- C. System Optimization Visit; Lutron LSC-SYSOPT: Include as part of the base bid additional costs for Lighting Control System Manufacturer to visit site 6-months after system start-up to evaluate system usage and discuss opportunities to make efficiency improvements that will fit with the current use of the facility.

END OF SECTION 26 09 43  
022219/212220

## **SECTION 26 24 13 SWITCHBOARDS**

### **PART 1 - GENERAL**

#### **1.01 SCOPE**

- A. Work Included: All labor, materials, appliances, tools, equipment necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete, as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other Specification Sections and Drawings for related work required to be included as work under Division 26.
  - 2. General Provisions and Requirements for electrical work.

#### **1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

- A. Provide Schematic "Ladder Type" logic control wiring diagrams and "point-to-point control wiring diagrams showing control and protective systems interlocks.
- B. Provide Nameplate Engraving Schedule.
- C. Submit Full-Scale Time/Current Transparencies on log/log paper for all fuses, circuit breakers, ground fault system devices, and relays. Additionally, provide software to generate time/current curves of each circuit protection device.
- D. Short Circuit, Coordination and Arc-Flash
  - 1. Perform and submit engineered settings for each equipment location, fuse and circuit breaker device, showing the correct time and current settings to provide the selective coordination within the limits of the specified equipment, per the latest applicable Standards of IEEE and ANSI. Provide electrical system short circuit fault analysis, both 3-phase line-to-line and 1-phase line-to-ground calculations as part of the coordination analysis recommendations. Provide Electric Arc-Flash calculations as part of the coordination analysis recommendations.
  - 2. The information shall be submitted in both tabular form and on time current log-log graph paper, with an engineering narrative. Written narrative describing data, assumptions, analysis of results and prioritized recommendations, six copies.
  - 3. The goal is to minimize an unexpected but necessary electrical system outage and Personnel exposure to the smallest extent possible within the fault occurrence location, using the specified contract equipment. Shall comply with, but not limited to:
    - a. IEEE-242, Recommended Practices for Protection and Coordination of Industrial and Commercial Distribution.
    - b. IEEE-399, Recommended Practice for Industrial and Commercial Power System Analysis.
    - c. IEEE-1584, Guide to Performing Arc-Flash Hazard Study.
    - d. CEC/NEC

4. Electrical equipment including switchgear, switchboards, electric panels and control panels, motor control centers, combination motor starters, transformers, disconnects, etc., shall each be labeled by the Manufacturer with “Electric-Arc-Flash” warning signs. The signs shall explain a hazard to personnel may exist if the equipment is worked on while energized or operated by personnel while energized. The sign shall instruct Personnel to wear the correct protective equipment/clothing (PPE) when working “Live”, or operating “Live” electrical equipment and circuits.
- E. Factory Tests: Equipment tests - ANSI C37.20. Certified copies of design tests, production tests, and conformance tests of the equipment shall be submitted and review comments shall be received before delivery of equipment to the Project site. In lieu of the above tests, a report of these tests previously performed on identical units of each rating will be acceptable.

### **1.03 APPLICABLE STANDARDS**

- A. The switchboard and switchgear equipment shall be designed, tested and assembled to comply with ANSI, IEEE, and NEMA and UL.
- B. Seismic Earthquake and Wind Loading Withstand, Testing and Certification (Additional Requirements).
  1. The complete switchboard/switchgear assembly; including circuit protection devices, meter, housings/enclosures, accessories, supports/anchors etc., shall be designed, manufactured and tested.
    - a. Wind loading all outdoor equipment locations.
    - b. Earthquake Seismic Requirements of CBC/IBC Seismic withstand all indoor and all outdoor equipment locations.
  2. Shall withstand, survive and maintain continuous non-interrupted energized operation during the seismic event occurrences and wind event occurrences. Continued normal energized operation after the wind event and seismic event occurrences have abated.
  3. Shall include demonstrations of successful operation and run test after completion of seismic event shake-table simulation. Acceptance test seismic qualification of proposed switchboard and/or switch-gear shall employ triple axis shake-table simulation of the Required Response Spectrum (RRS) seismic event motion, certified and approved by the AHJ.
  4. Provide three dimensional finite element analysis demonstrating anchorage and operational withstand of wind loading not less than as follows and as required by AHJ:
    - a. 110MPH-West Coast USA, California, and Hawaii, per ASCE/SEI 7-10.
  5. Seismic test shall be performed by a third party independent Test Laboratory. Wind Analysis and Seismic Testing and reports shall be certified, signed and “Stamped” by PE Professional Engineer licensed and in good standing in the State, Civil Engineer or Structural Engineer.
- C. Equipment components/devices, switchboards, and/or switchgear shall be manufactured by: General Electric; or Cutler-Hammer; or Square-D; or Siemens.

## **PART 2 - PRODUCTS**

### **2.01 BUSSING**

- A. Horizontal and vertical busses shall be full lengths in each Equipment Section. Buses shall have a minimum short circuit fault withstand rating equal to available fault current indicated on Drawings, plus a 25% additional capacity (safety margin). However, in no case shall the rating be less than 50,000-amp, symmetrical.
- B. Provide interconnected full capacity neutral bus in each Section with the same ratings and construction as the phase busses.
- C. Provide interconnected ground bus in each Section.
- D. Provide space and all hardware and mounting attachments for future devices as indicated on the Drawings.
- E. Main horizontal phase and neutral bussing shall be full capacity in all equipment sections. The through bus of the end distribution section shall be extended and pre-drilled to allow the addition of future sections.
- F. Vertical riser buss may be tapered, to not less than one third the ampacity rating of the main horizontal buss; but in no case shall the vertical buss be of less capacity than the sum of the frame size ampacities of over-current devices mounted in the respective sections including any indicated spares and spaces.
- G. The equipment bussing shall be of sufficient cross-sectional area to meet UL Standard 891 on temperature rise Bus shall be copper with silver plated bus joints or extruded aluminum with tin plated bus joints. The through bus shall have provisions for the addition of future sections. The through bus supports, connections and joints are to be bolted with Grade 5 hex head bolts and Belleville washers to minimize Maintenance Requirements.

### **2.02 CIRCUIT BREAKERS**

- A. General
  - 1. Circuit protective devices as indicated on the Drawings. All devices shall have a short circuit interrupting capacity not less than the maximum available fault current at the circuit breaker and as indicated on the Drawings, plus a 25% additional capacity (safety margin). However, in no case shall the circuit breaker interrupting capacity be less than 30,000 amp symmetrical interrupting for 480/277 volt devices and 42,000 amp symmetrical for 240 volt or 208/120 volt devices.
  - 2. Provide padlock-off devices on each device. Breakers shall provide automatic time over-current and instantaneous circuit protection. Shall be suitable for use as "Main" service disconnect, "Feeder" and "Branch-Circuit" functions.
  - 3. Circuit breakers shall employ a self-powered stored energy, quick make-quick break, and trip free operating system on each phase, with common trip. Circuit breakers shall not trip in the event of short term or long term electrical power failure. Dead front cover accessible close-open controls, monitors and visual indicator flags.
  - 4. Circuit breakers noted as "100%" on the Drawings shall be tested and rated to carry the breaker full rated (100%) ampere load continuously including the assemblies the circuit breakers are installed into.

5. Provide conductor lugs for circuit protection devices to accept conductor temperature rating, sizes and quantities shown on Drawings. Circuit protection devices shall be UL listed suitable for normal and reverse feed.
6. Provide auxiliary contacts on circuit breakers. Auxiliary "DRY" contacts shall provide supervised remote monitoring of "Open-Close-Trip" circuit breaker status. Typical for circuit breakers supplying the following types of connected electrical loads.
  - a. Fire alarm equipment and devices.
  - b. Mass-evacuation equipment and devices.
  - c. HVAC smoke control and smoke evacuation equipment.
  - d. HVAC fire/smoke electrically operated dampers.
  - e. Intrusion detection and access control equipment and devices.
  - f. Elevators and escalators.
  - g. Fire sprinkler pumps.
7. Plug-in communications port for circuit breaker portable test instrument connects.
8. Circuit breaker data monitoring and communications:
  - a. The circuit protection devices shall monitor, communicate and report circuit voltage, ampere, power, and harmonic parameters for the respective connected circuit. The circuit protection device monitor and communication parameters shall be the same and compatible with the specified "METERING" devices.
  - b. Additionally the circuit protection devices shall monitor and communicate the respective device status as follows:
    - 1) Open/close/trip device status
    - 2) Ground fault trip status (where applicable)
  - c. Provide circuit breaker data monitoring and communications for each of the individual feeder protection devices and main protection devices located in switchgear and switchboards, rated 400 amp or greater trip rating.
  - d. The respective "METER" display selection control functions shall provide selection and display of all information monitored and communicated by individual protection devices on the respective meter alphanumeric display.
9. Circuit breakers shall be Power Circuit Breaker type, Insulated Case Circuit Breaker type or Molded Case Circuit Breaker type. Time/current and instantaneous characteristics and selection of circuit breaker type shall comply with the recommendations in the coordination study and insure Optimal Code mandated time/current and instantaneous coordinated sequential tripping throughout the electrical system.

The Contract Document intent requires providing the selection and use of the circuit breaker types and performance characteristics for time/current and instantaneous trip coordination during electrical circuit overload conditions and during electrical short circuit fault conditions. Combined with the specified circuit breaker protection time/current performance characteristics.

- a. Insulated Case Circuit Breaker type-ICCB:
  - 1) NEMA-AB1 and AB3, comply with latest revision.
  - 2) UL-1087, UL-489 and IEC-60.947, comply with latest revision.
  - 3) 5Hz AC closing and 3Hz AC trip and clear.

- 4) Hybrid combination of Molded Case Circuit Breaker type and Power Circuit Breaker type circuit breakers. ICCB enclosed insulated housing and limited internal maintenance access.
  - 5) Two-step stored energy close mechanism.
  - 6) Extended function on-off instantaneous trip selection.
  - 7) Push-to-trip button.
  - 8) Mechanical operations counter.
- b. Molded Case Circuit Breaker type-MCCB:
- 1) NEMA-AB1 and AB3, comply with latest revision.
  - 2) UL-1087, UL-489 and IEC-60.947.2 rated devices, comply with latest revision.
  - 3) 5Hz AC closing and 3Hz AC trip and clear.
  - 4) Sealed enclosed housing.
- B. Protection Performance Requirements for circuit breakers conforming to one or more of the following applications:
- 600 amp or larger frame size.
  - Larger than 400 amp trip.
  - Service entrance in main switchboard or switchgear.
  - Noted as Main or Main Circuit breakers on the Drawings.
1. Circuit breaker shall employ current sensors and solid-state static digital electronic automatic trip system. Three phase or single-phase operation as noted on the Drawings. Current carrying components shall be completely isolated from the static trip units. The trip unit shall be independent of external power sources. Circuit breakers shall be rated for reverse connection.
  2. Circuit breaker solid state digital trip control functions shall provide the following time/current curve shaping field adjustable features;
    - a. Adjustable ampere setting to vary the long-time continuous current carrying capacity, minimum range of 80% through 100% of full load trip rating.
    - b. Adjustable long-time delay setting to vary the time the breaker will trip under sustained over-load conditions. Minimum of three settings, "minimum – intermediate - maximum".
    - c. Adjustable short-time pickup to vary the level of high current the breaker can carry for short periods of time, minimum range of two times through eight times of ampere setting.
    - d. Adjustable short time delay to vary the time of the short-time pickup. Minimum of three settings "minimum-intermediate-maximum".
    - e. Short time " $I^2t$ " switch to allow a current-squared multiplied by time ramp function in the short-time system. Two position setting "in-out".
    - f. Adjustable instantaneous pickup to vary the breaker ampere setting for immediate (instantaneous) interruption of severe overloads (short circuits). Adjustable minimum range of two times through nine times of circuit breaker ampere sensor rating. Instantaneous selective over-ride trip setting shall also include "on-off" function. When "off" or "override" is selected shall then function with the adjustable short time delay and adjustable short time pick-up (note where the coordination study requires a higher instantaneous setting, change the specified adjustable

instantaneous trip to fixed instantaneous trip at fifteen times the breaker ampere sensor setting also with on-off function).

- g. Individual fault trip indicators (flags) shall provide local indication on the breaker for overload and short circuit (and ground fault where applicable) conditions.
  - h. Provide quantity of one Manufacturer's Standard Test set for solid state trip circuit breakers.
- C. Protection Performance Requirements for circuit breakers conforming to one or more of the following applications:
- Smaller than 600 amp frame size.
  - 400 amp and smaller trip.
  - Larger than 100 amp frame size.
  - Larger than 100 amp trip.
1. Circuit breaker shall employ current sensors and solid-state static digital electronic automatic trip system. Time/current curve shaping field adjustable features
  2. Solid state digital trip breakers shall conform to the Requirements described above for solid state breakers larger than 400 amp trip. However, only the following field adjustments are required;
    - a. Long-time ampere setting adjustable minimum range of 80% through 100% of full load trip rating.
    - b. Short time pickup adjustable minimum range of two times through eight times of the ampere setting.
    - c. Fixed or field adjustable instantaneous trip (depending on the results of the coordination study).
- D. Performance Requirements for circuit breakers conforming to the following applications:
- 100 amp frame size and smaller.
  - 100 amp and smaller trip.
1. Circuit breaker shall be fixed or adjustable instantaneous current trip with thermal-magnetic trip or with solid-state static digital electronic automatic time/over current automatic trip (depending on the results of the coordination study).
- E. Current Limiting Circuit Breakers (CLCB)
1. Protection Performance Requirements for circuit breakers conforming to the following applications:
    - 600 amp and smaller trip and identified as current limiting (CLCB) in the Contract Documents.
    - a. Current limiting circuit breakers shall be supplied in integral fully enclosed insulating housing construction and shall consist of a common trip, thermal-magnetic or solid state static digital trip conventional circuit breaker (Depending on the results of the coordination study), with an independently operating limiter section in series with each pole.
    - b. The conventional breaker section shall have an over center, trip-free, toggle-type mechanism with quick-make, quick-break action and positive handle indication. A button shall be provided on the cover for mechanically tripping the circuit breaker. The current limiting breaker shall have permanent trip units containing solid state static digital trip or individual thermal and magnetic trip elements, in each pole.

Calibrated for 40-degrees C ambient temperature. The limiter section shall consist of current limiting elements on each phase, electrically coordinated with the conventional circuit breaker trip elements. The contacts of the limiter section shall be electro-magnetically and electro-dynamically opened and held open until interruption is complete.

- c. Current and Energy Limitations: On high-level fault currents the limiter portion of the circuit breaker shall operate to limit the rise of fault current. Integral resistance shall be introduced into the faulted circuit to dissipate and limit let-through energy and to provide a voltage transient-free interruption at near unity power factor. The Let-through short circuit fault current and energy levels shall be less than that permitted by Underwriters Laboratories to a value less than  $I^2t$  of a half cycle wave of the symmetrical prospective current. The CLCB limiter shall limit the asymmetrical short circuit fault current below the equipment symmetrical short circuit fault current.
  - d. On fault currents below the threshold of current limitation, the normal non-limiter breaker section shall provide conventional time/current overload and short circuit fault protection.
2. Protection Performance Requirements for circuit breakers conforming to the following applications:
- Trip ratings over 600 amp through 5000 amp or less. Identified as current limiting (CLCB) in the Contract Documents.
  - a. Integrally fused circuit breaker integrated with solid state static digital electronic automatic trip. Combined standard circuit breaker providing overload-short circuit protection within its interrupting capacity and ON-OFF switching function and on each phase current limiters internally mounted on the load side of the circuit breaker, of such ratings that their time current limiting characteristics will coordinate with the time current tripping characteristics of the circuit breaker elements.
  - b. The coordination shall result in the interruption by the circuit breaker alone of fault level currents up to the interrupting capacity of the circuit breaker and interruption by the current limiter in conjunction with the circuit breaker of fault level currents above the interrupting capacity of the circuit breaker.
  - c. A removable cover shall be provided over the current limiter section of the integrally fused circuit breaker. The current limiter housing covers shall be interlocked with the breaker tripping mechanism to insure the breaker will trip upon removal of the cover. The cover shall be interlocked with the breaker to insure the circuit breaker cannot be turned to the ON position with the cover removed. Current limiters shall have a spring loaded plunger which, when the limiter blows, is released to actuate the circuit breaker common trip bar mechanism opening all breaker poles simultaneously.
  - d. The limiters shall be individually interlocked with the breaker element tripping mechanism to insure the limiter cannot be inserted until the breaker is in the OFF position. The circuit breaker and limiters shall be interlocked to insure the circuit breaker cannot be closed if a limiter is either missing or has blown.
  - e. Fuse limiters shall be individually removable from the circuit breaker housing.



- f. The circuit breaker shall be ambient temperature compensating. The circuit breaker shall be provided with thermal magnetic or solid state static digital trip (depending on the coordination study).
  - g. The integrally fused circuit breaker shall be capable of interrupting available short circuit currents up to 200,000 RMS symmetrical amperes at voltage up to 600 VAC.
  - h. Ratings, clearances and performance of the integrally fused circuit breaker shall be in accordance with applicable Standards of NEMA, IEEE and UL.
- F. Series Rated Circuit Breakers (SR)
- 1. Performance Requirements for circuit breakers conforming to the following applications:
    - a. 400-amp and smaller trip and identified as Series Rated (SR) on the Drawings. Circuit breakers shall be UL listed for series rating with all downstream circuit breakers.

### 2.03 SWITCH AND FUSE FEEDER PROTECTIVE DEVICES

- A. Fusible Switches: Quick-make, quick-break type with rejection clips for use with Class "R" fuses Current Limiting Fuses (CLF). Switches with ratings up to and including 100-amp at 240-volts shall be twins mounted. Switches rated through 60-amp and 480 volts shall be twins mounted. Shall be UL listed suitable for normal and reverse feed. Switches shall be removable from front of switchboard without disturbing adjacent units or switchboard bus structure.
- B. Fuses shall be time delay current limiting types, UL Class RK-1 unless otherwise indicated on the Drawings. Provide one spare set of fuses of each size and type in each switchboard.
- C. Provide auxiliary contact on switch for remote status (on-off) signaling and monitoring. Provide conductor lugs to accept conductor temperature rating, sizes, and quantities shown on Drawings.

### 2.04 GROUND FAULT PROTECTIVE SYSTEM AS FOLLOWS:

- A. One control power transformer rated 480/120 volts of suitable capacity for shunt tripping of the main circuit breaker and subfeed circuit breakers as indicated on the Drawings. Fuse transformer on the 480-volt side.
- B. Ground sensor current transformer for each indicated ground fault relay, zero sequence type with integral test winding for each circuit indicated on Drawings (the 3-phases and neutral conductor shall be brought through the current transformer window per Manufacturer's recommendations). Shall be UL-listed suitable for normal and reverse feed.
- C. One ground break, solid-state relay, and monitor and test panel for each device indicated on the Drawings. Pick-up adjustment shall be continuous 100 amp through 1200 amp; time adjustment shall be continuous from instantaneous through sixty cycles. Monitor panel shall indicate relay operation and provide means for system testing with or without interruption of service, and shall not permit system to be inadvertently left in an inactive or off state. Provide resettable trip indicators.
  - 1. Ground fault system shall provide selective trip coordination with other upstream/downstream ground fault and phase over current circuit protection devices as determined by the coordination study.
    - a. Ground fault protection devices shall incorporate adjustable time/current trip settings.

- b. Ground fault protection devices shall incorporate adjustable inverse time and very inverse time adjustable/selective settings.
- D. The ground fault system may be integrated into each circuit breaker with solid state trip units, in lieu of the separate specified ground fault relay and monitor panel system. The solid state circuit breaker ground fault system shall provide the identical specified operational features of the described separate system.
- E. Each circuit breaker 100 amp and larger, located in the main switchboard(s) and distribution switchboard or main switchgear where the main bus is larger than 800 amp and operating above 240 volt phase-to-phase, shall be provided with ground fault system whether or not shown on the Drawings. Provide all inter-connecting control power and interlocking wire in switchboards/switchgear and between switchboards/ switchgear for an operational system.

## 2.05 MAIN SWITCHBOARDS

- A. Switchboard shall be floor-mounted, dead-front, dead-rear type, front and rear aligned, self-supporting, consisting of one or more vertical sections with bussing, circuit protective devices, instrumentation, auxiliary devices and control wiring as indicated on the Drawings and as specified herein.
  - 1. Shall be utility and service entrance rated and approved.
  - 2. Switchboards shall employ mounting configuration for circuit protective devices as follows:
    - a. Group-mount, fixed position, non-drawout switchboards. Front access only, shall not require rear access. Typical for all circuit protective devices or as indicated on Drawings.
  - 3. Switchboards shall employ circuit breakers types and circuit protection devices as follows:
    - a. All Main circuit breaker of all frame sizes – ICCB type circuit breakers.
    - b. 800 amp and larger frame size Feeder circuit breakers, ICCB type circuit breaker.
    - c. Smaller than 800 amp frame size Feeder circuit breakers, ICCB type; or MCCB type circuit breakers.
    - d. CLCB type circuit breakers. CLCB circuit type only where noted on the Drawings.
    - e. CLF with switch and fuse type. CLF with switch and fuse type only where noted on the Drawings.
  - 4. Surge Protection Device – SPD
    - a. Provide a 3-phase, 5-wire SPD in the switchboard, with 30-amp 3-pole subfeed circuit breaker.
    - b. See Specifications Section 26 05 00 for SPD Additional Requirements.
- B. Switchboard shall be designed, built and tested in accordance with applicable portion of the latest editions of NEMA PB-2, Underwriters Laboratories No. UL-891 and the National Electrical Code. Rated for service-entrance operation.
- C. Switchboard Sections Configuration
  - 1. Floor standing self-supporting, of the universal frame type using die formed, 12-gauge steel members bolted and welded together.
  - 2. Provide removable side and rear plates with formed edges all around.

3. Provide ventilation openings required for maintaining nominal operating temperature.
  4. Provide removable steel cover plates for all usable device spaces. Provide lifting means and provisions for moving by means of rollers or skids to installation location.
  5. Bolt individual sections together to form a single rigid switchboard assembly.
  6. Provide full height, hinged, vertical wireway metal covers, on each vertical wireway, of each distribution section of the switchboard.
  7. Typical for all switchboards, distribution switchboards and switchgear.
- D. Switchboard shall include, but not be limited to, the following:
1. Underground pull section as required by the serving utility incoming service.
  2. Metering facilities as required by the serving utility.
  3. Current transformer space.
  4. Main disconnects devices.
  5. Distribution and feeder circuit protective devices.
  6. District metering (where indicated on Drawings).
  7. Bussing, incoming utility compliant and outgoing distribution.
  8. Surge Protection Device (SPD).

## **2.06 DISTRIBUTION SWITCHBOARDS**

- A. Switchboards shall be floor mounted, dead-front, dead-rear type, front and rear aligned, self-supporting, consisting of one or more vertical sections with bussing, group mounted circuit protective devices, instrumentation and control wiring as indicated on the Drawings and as specified herein. Switchboards shall comply with UL Standard #UL-891 and NEMA-PB2.
1. Distribution switchboards shall be service entrance rated and approved, when located in a building separate and remote from the main service entrance switchboard.
  2. Distribution Switchboards shall employ circuit breaker types and circuit protection devices as follows:
    - a. All Main circuit breakers of all frame sizes - ICCB type circuit breakers.
    - b. 800 amp and larger frame size Feeder circuit breakers, - ICCB; or MCCB type circuit breakers.
    - c. Smaller than 800 amp frame sizes Feeder circuit breakers - ICCB; or MCCB type circuit breakers.
    - d. CLCB type circuit breakers, only where noted on the Drawings.
    - e. CLF with switch and fuse type. CLF with switch and fuse type only where noted on the Drawings.
- B. Distribution Switchboards shall include but not be limited to the following:
1. Main disconnect device (where indicated on Drawings).
  2. Feeder protective devices.
  3. District metering (where indicated on Drawings).
  4. Bussing.
  5. Surge Protection Device (SPD).

C. Switchboard Sections

1. Floor standing, self-supporting, of the universal frame type using die formed, 12 gauge steel members bolted and welded together.
2. Provide removable side and rear plates with formed edges all around.
3. Provide ventilation openings required for maintaining nominal operating temperature.
4. Provide removable steel cover plates for all usable device spaces. Provide lifting means and provisions for moving by means of rollers or skids to installation location.
5. Bolt individual sections together to form a single rigid switchboard assembly.
6. Provide full height, hinged, vertical wireway metal covers, on each vertical wireway, of each distribution section of the switchboard.

**2.07 MISCELLANEOUS INSTRUMENTS**

- A. Instrument and Control Transformers: ANSI C57.13 and NEMA ST20 as applicable. Transformers shall be specifically designed for use on respective protective relay or metering schemes utilized.
- B. Current transformers meter/relay grade shall be multi-ratio tap, tap setting as indicated on Drawings, (minimum of three field adjustable tap settings) with 5 amp secondary, insulation class, 600 volt, 60Hz, single ring type, and shall have an accuracy classification of 0.3 with the burden of B.01, B.02 and B.03.
- C. Control and transfer switches shall be of the rotary, oil-tight multi-position, cam-operated, multi-stage type, with dust cover and silver-to-silver contacts rated 600 volts, 20-amp and adequate for the duty performed in excess of 10-amp. Equip each switch with engraved plastic escutcheon nameplate identifying its function and position.

**2.08 CONTROL WIRING**

- A. Terminal blocks with barriered terminals for each connection shall be provided for all control wiring terminator points. Control wiring shall be run in horizontal and vertical, isolated, internal metal wireways and shall be carried across hinges in laced bundles. Wire terminators shall be crimp-on type spade terminal
- B. Secondary control wiring shall be a minimum of 14AWG stranded copper type SIS 600-volt insulation.
- C. Control circuits shall have circuit number tags at each termination or break in the wire to match circuit numbers on terminal strips and control wiring diagrams.

**2.09 WEATHERPROOF EQUIPMENT**

- A. Equipment indicated as weatherproof (W.P.) or outdoors should be NEMA 3R, non-walk-in, tamper resistant construction. Provide full height hinged doors with provisions for padlocking the doors in the closed position.
- B. Provide a nominal 300-watt sealed, resistance type, anti-condensation heater in each equipment section. Heaters shall be controlled automatically by Thermostats and Humidistats. A circuit breaker shall be provided to supply switchboard buss voltage to the heaters, all prewired by the Manufacturer to fused terminals.

- C. Finish shall be electrostatically applied finish paint over iron oxide rust inhibitor primer. Finish color shall be Manufacturer's standard color, olive green Munsel #7GY3.29/1.5. The bottom side and bottom 6-inches of the equipment shall be coated with 4-mil minimum thickness rust inhibitor undercoating over finish paint, on all interior surfaces. Finish withstand test without face corrosion or blistering:
  - 1. Salt spray withstands - 2000 hours ASTM B117.
  - 2. Humidity withstands - 750 hour ASTM D2247.
- D. Exposed Hardware and Hinges Shall be Stainless Steel Type 302 or 304, Tamper Resistant

### **PART 3 - EXECUTION**

#### **3.01 GENERAL**

- A. Install Equipment in accordance with Manufacturer's written instructions and applicable portions of NECA's "Standards of Installations" for switchboards, switchgear and motor control centers.
- B. Prior to Energizing and Testing, Manufacturer's Field Engineer shall visually inspect and verify devices are operational and bus connects complete.

#### **3.02 ANCHORING**

- A. Bolt Equipment to floor and wall where wall exists. Where units are free standing, provide preformed steel channel or angle iron bracing to nearest wall or building structural member.
- B. Equipment anchoring shall be designed for compliance with the earthquake seismic vertical and lateral acceleration of the equipment install location. Submit structural calculations and details.

#### **3.03 FIELD TESTING INSPECTIONS AND COMMISSIONING (ADDITIONAL REQUIREMENTS)**

- A. Test all Equipment after the installation has been completed, and the District's Representative has been given 10-days' notice of the proposed tests. The Contractor shall provide operating tests demonstrating that all equipment and devices operate in accordance with the Requirements of the documents.
- B. Adjustable Settings
  - 1. Shall be set and tested after the equipment installation is complete, for proper operation at set points, pickup, and/or drop-out points. Shall be performed by an independent Test Laboratory and trained certified Technicians actively engaged in testing and using test instruments designed and manufactured for the purpose.
  - 2. Provide protection device settings and test, to insure operation and coordination as described in the time/current coordination final submittal, and in accordance with the Contract Documents.
  - 3. Calibrate and testing shall comply with the Equipment Manufacturer recommendations.
  - 4. Correct deficiencies, non-compliant equipment and retest to demonstrate compliance.
  - 5. Submit reports to District's Representative, six copies.
- C. Testing shall be completed in accordance with ANSI/NETA Standards.

### **3.04 IDENTIFICATION (ADDITIONAL REQUIREMENTS)**

- A. Provide a red and white Bakelite nameplate with ½-inch high letters in each Section fastened to face of dead-front plate, to read: "DANGER 480 (actual volts) VOLTS, KEEP OUT, AUTHORIZED PERSONNEL ONLY".
- B. Manufacturer shall stencil the equipment name on each Device and Equipment Section to correspond to the identification of the Drawing.
- C. Devices mounted in equipment controlling protective devices shall be provided with nameplates indicating device controlled or monitored.

END OF SECTION 26 24 13  
022119/212220

This page is blank.

## SECTION 26 24 16

### BRANCH CIRCUIT PANELBOARDS AND TERMINAL CABINETS

#### PART 1 - GENERAL

##### 1.01 SCOPE

- A. Work Included: All labor, materials, appliances, tools, equipment necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete, as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other Specification Sections and Drawings for related work required to be included as work under Division 26.
  - 2. General Provisions and Requirements for electrical work.

##### 1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)

- A. Provide Manufacturers Catalog Data for Panels, Cabinets, and Circuit Breakers.
- B. Provide Shop Drawing showing Panel Circuit arrangements, size, voltage, ampacity, over-current protective devices, etc.
- C. Provide nameplate engraving schedule.
- D. Short Circuit, Coordination and Arc-Flash
  - 1. Perform and submit engineered settings for each equipment location, fuse and adjustable circuit breaker device, showing the correct time and settings to provide the selective coordination within the limits of the specified equipment, per the latest applicable Standards of IEEE and ANSI. Provide electrical system short circuit fault analysis, both 3-phase line-to-line and 1-phase line-to-ground calculations as part of the Coordination Analysis recommendations. Provide Electric Arc-Flash Calculations as part of the Coordination Analysis recommendations.
  - 2. The information shall be submitted in both tabular form and on time current log-log graph paper, with an Engineering Narrative. Written narrative describing data, assumptions, analysis of results and prioritized recommendations, six copies.
  - 3. The goal is to minimize an unexpected but necessary electrical system outage and Personnel exposure to the smallest extent possible within the fault occurrence location, using the specified Contract Equipment. Shall comply with, but not limited to:
    - a. IEEE-242, Recommended Practices for Protection and Coordination of Industrial and Commercial Distribution.
    - b. IEEE-399, Recommended Practice for Industrial and Commercial Power System Analysis.
    - c. IEEE-1584, Guide to Performing Arc-Flash Hazard Study.
    - d. CEC/NEC
  - 4. Electrical equipment including switchgear, switchboards, electrical panels, and control panels, transformers, disconnects, etc., shall each be labeled by the Manufacturer with "Electrical-Arc-Flash" warning signs. The signs shall explain a hazard to Personnel may exist if the equipment is worked on while energized or operated by Personnel, to wear



the correct Protective Equipment/clothing (PPE) when working “Live”, or operating “Live” equipment and circuits.

### **1.03 SEISMIC EARTHQUAKE AND WIND LOADING WITHSTAND, TESTING AND CERTIFICATION. (ADDITIONAL REQUIREMENTS)**

#### **A. General**

1. The complete panels and terminal cabinet assemblies; including circuit protection devices, meter, housings/enclosures, accessories, supports/anchors etc., shall be designed, manufactured and tested.
  - a. Wind loading all outdoor equipment locations.
  - b. Earthquake CBC/IBC Seismic withstand all indoor and all outdoor equipment locations.
2. Shall withstand, survive and maintain continuous non-interrupted energized operation during the seismic event occurrences and wind event occurrences. Continued normal energized operation after the wind event and seismic event occurrences have abated.
3. Shall include demonstrations of successful operation and run test after completion of seismic event shake-table simulation. Acceptance test seismic qualification shall employ triple axis shake-table simulation of the Required Response Spectrum (RRS) seismic event motion, certified and approved by the AHJ.
4. Provide three dimensional finite element analysis demonstrating anchorage and operational withstand of wind loading not less than as follows and as required by AHJ:
  - a. 110MPH – West Coast USA and Hawaii, per ASCE/SEI 7-10.
5. Seismic Test shall be performed by a third party independent Test Laboratory. Wind Analysis and Seismic Testing and Reports shall be certified, signed and “stamped” by PE Professional Engineer licensed and in good standing in the State, Civil Engineer or Structural Engineer.

B. Refer to General Commissioning Section 01 91 13 for Additional Requirements.

## **PART 2 - PRODUCTS**

### **2.01 PANELBOARDS AND DISTRIBUTION PANELS**

- A. Shall be flush or surface mounting as indicated with group -mount circuit protection devices as shown on panel schedule, hinged lockable doors, index cardholders and proper bussing.
  1. Panelboards shall comply with the latest versions:
    - a. NEMA – PB1.
    - b. UL – 50 and 67.
    - c. CEC/NEC.
    - d. ASTM-B187.
  2. Where indicated on the Drawings shall be furnished with subfeed breakers and/or additional conductor lugs, split bussing, contactors, time switches, relays, etc., as required.
    - a. Branch circuit panels up through 42-circuits shall be single section, to accommodate all of the circuits and components.

- b. Distribution panels shall be single section or multi-section, to accommodate all of the circuits and components.
  - 3. Panels shall be "Service-Entrance" equipment rated when the panel main incoming supply feeder originates from one of the following:
    - a. Originates outdoors exterior of the building in which the respective panel is located.
    - b. Originates from an electrical supply source not located in the same building as the respective panel.
- B. Housing and Painting, Panels and Terminal Cabinets
  - 1. Shall be finished with one coat of rust inhibitor zinc chromate and coat of primer sealer after a thorough cleaning.
  - 2. Finish color paint as selected by District's Representative where exposed to public view (e.g., corridors, covered passages, offices, etc.). Prime coated panelboard shall be painted to match surroundings after installation in public areas.
  - 3. Manufacturer's standard color in electrical rooms/closets, janitors, HVAC and storage rooms.
  - 4. Shall be fabricated of sheet steel of the following minimum gauges.
    - a. Full height hinged, locking door. Trim #12 gauge steel; enclosure - Code gauge steel.
    - b. Panels installed in indoor dedicated electrical equipment rooms and dedicated electrical equipment closets, omit full height hinged locking panel door. Dead front cover behind omitted panel door shall remain.
  - 5. NEMA-1 Metal Housing, for indoor locations.
  - 6. NEMA-3R Metal Housing, tamper resistant, for outdoor locations.
  - 7. Furnish all panels and terminal cabinets with the Manufacturers flush locks and keys except where indicated otherwise herein. Keys and locks shall be interchangeable for all panels. Provide two latches and two locks for door heights exceeding 36-inches.
  - 8. Fasten the trim to panel and terminal cabinets by means of concealed, bolted or screwed fasteners accessible only when the door is open.
- C. Panels 208/120 volt, three phase, 4-wire, S/N or 120/240 volt, single phase, 3-wire, S/N.  
Branch Circuit Panel as manufactured by:
  - 1. Cutler Hammer "Pow-R-Line 1 or 2" Series
  - 2. General Electric "A" Series
  - 3. Square D "NF/NQ" Series
  - 4. Siemens "P1/P2" Series
- D. Distribution Panels as manufactured by:
  - 1. Cutler Hammer "Power-R-Line 3 or 4" Series
  - 2. General Electric "Spectra" Series
  - 3. Square D "I-Line" Series
  - 4. Siemens "P4/P5" Series
- E. Top and bottom gutter space shall not be less than 6-inches high. Provide 6-inches additional gutter space in all panels where double lugs are required, or where cable ampere size exceeds

bus ampere size. Provide 12-inches additional gutter space in all panels for aluminum feeders where used.

F. Panel Dimensions.

1. Panels with buss sizes 50 amp thru 400-amp.
  - a. Shall be 20-inches wide. Surface or flush mounting as indicated.
  - b. Recess mounted type shall have a 20-inches wide (maximum) recess metal enclosure with overlapping edge trim plate cover extending 1-inch on all sides of enclosure.
  - c. Depth shall be 5.75-inches nominal. Height of panel as required for devices.
2. Panels with buss sizes greater than 400-amp.
  - a. Narrow panels 24-inches (maximum) wide by 6.5-inches (maximum) deep units. Wide panels' 25-inches to 44-inches (maximum) wide by 8-inches to 15-inches (maximum) deep units. Nominal 90-inch panel height.
  - b. The wider units shall be used only at locations where the narrow unit is not available with the quantity or size of large-ampere frame branch/subfeed circuit protective devices shown on the panel schedules, or where the main breaker size exceeds the narrow panel maximum.
  - c. Distribution panels shall be floor standing and also supported from behind the panels at walls.

G. Distribution panels and branch circuit panels maximum load rating

1. Panelboards and Distribution Panels exceeding 800-amp load rating shall not be permitted.
2. Provide Distribution Switchboards instead of Distribution Panels for bus load and circuit load ratings exceeding 800-amp.

H. Panel Auxiliary Cabinets

1. Panelboards shown on the Drawings with relays, time clocks or other control devices shall have a separate auxiliary metal barrier compartment mounted above panel.
2. Panelboards with circuits controlled by low voltage remote control relays shall be provided with separate auxiliary cabinets to contain the relays, adjacent to the panelboard.
3. Provide auxiliary cabinets with separate hinged locking door to match panelboard.
4. Provide mounting subbase in cabinet for control devices and wiring terminal strips.

I. Panels shall have a circuit index cardholder removable type, with clear plastic cover. Index card shall have circuit numbers imprinted to match circuit breaker numbers.

1. The panel identification nameplate shall describe the respective panel name and voltage, corresponding to the Contract Documents.
2. The electrical power source, name and location of each panel supply-feeder and supply equipment name shall also be identified and described on the respective panel nameplate.

J. SPD – Surge Protection Device

1. Provide each of the following branch circuit panel and distribution panel types with a SPD and RF filtering:
  - a. 208/120 volt - single phase and/or three phase.
  - b. 120/240 volt - single phase.
  - c. 480/277 volt - single phase and/or three phase.
  - d. All distribution panels.
2. The SPD shall be installed inside the respective panel housing and shall be factory connected to each main phase, ground and neutral bus inside the panel.
3. The SPD monitor/annunciator indicators shall be visible only when the panel access door is in the open position.
4. Provide a 20-amp 3-pole (2-pole for single-phase panels) branch circuit protection device in each panel for SPD connection.
5. The SPD and panel shall be UL labeled and listed for combined use. See related Specification Sections for Additional SPD Requirements.

K. Seismic Earthquake and Wind Loading Withstand, Testing and Certification (Additional Requirements)

1. The complete panel/panelboard assembly; including circuit protection devices, housings /enclosures, accessories, supports/anchors etc., shall be designed, manufactured and tested for Wind Loading and Earthquake withstand.
2. Shall withstand, survive and maintain continuous non-interrupted energized operation (running) during the seismic event occurrences. Continued normal energized operation after the wind event and seismic event occurrences have abated.
3. Shall include demonstrations of successful operation and run test after completion of seismic event shake-table simulation.
4. Provide three dimensional finite element analysis demonstrating anchorage and operational withstand of wind loading as follows:
  - a. 100MPH – West Coast States USA and Hawaii, per ASCE/SEI 7-10.
5. Acceptance test seismic qualification of proposed panels and panelboards shall employ triple axis shake-table simulation of the Required Response Spectrum (RRS) seismic event motion, certified and approved by the AHJ.
6. Seismic test shall be performed by a third party independent test laboratory. Wind Analysis and Seismic Testing and reports shall be certified, signed and “stamped” by PE Professional Engineer licensed and in good standing in the State, Civil Engineer or Structural Engineer.

## 2.02 SHORT CIRCUIT RATING

- A. Circuit protective devices and bussing as indicated on the Drawings. All devices and bussing shall have a short circuit fault withstand and interrupting capacity not less than the maximum available fault current at the panel and as indicated on the Drawings, plus a 25% additional capacity (safety margin).

However, in no case shall the short circuit fault interrupting and withstand capacity be less than the following symmetrical short circuit.

|    | <u>C/B and/or Bus Rating</u> | <u>Circuit Voltage</u>   | <u>Short Circuit Amp.</u> |
|----|------------------------------|--------------------------|---------------------------|
| 1. | 400A and less                | 240V and below           | 10,000A                   |
| 2. | 400A and less                | over 240V and below 600V | 14,000A                   |
| 3. | Over 400A, 800A and below    | 240V and below           | 42,000A                   |
| 4. | Over 400A, 800A and below    | over 240V and below 600V | 30,000A                   |

B. Panel Short Circuit Fault Rating

1. General

- a. Provide a “fully rated” for short circuit fault interrupt and full load ampere main circuit breaker in each branch circuit panel and/or each distribution panel. Provide the main circuit breaker whether or not a main circuit breaker is shown otherwise on the Drawings, Schedules or Diagrams. The “utility-source” plus the “motor-load” transient contributions shall be used to establish the available fault duty values, unless indicated otherwise on the Drawings.
- b. The panel main circuit breaker full load ampere capacity rating shall equal the respective panel main bus ampere rating.
- c. The panel assembly, buss and circuit protection devices bolted fault short circuit withstand and bolted fault short circuit interrupt ratings shall not be less than 125% greater (including a 25% safety margin) than the available utility-source symmetrical and asymmetrical bolted fault short circuit current when “series combined rated” with the panel main circuit breaker.
- d. The main circuit breaker rated “bolted-fault” short circuit fault interrupt and withstand short circuit rating shall not be less than 125% (including a 25% safety margin) of the upstream main service entrance “bolted-fault” available (symmetrical and asymmetrical) short circuit current.

2. Distribution Panelboards

- a. Distribution panel, main circuit breaker, all feeder circuit breakers, and all branch circuit breakers shall be “fully-rated” (plus safety margin) for the available bolted fault short circuit current (including safety margin).
- b. Shall provide time/current-tripping coordination with downstream equipment and upstream equipment.

3. Non-emergency branch circuit panelboards 400-amp buss and smaller; Non-emergency branch circuit panelboards 400-amp trip main circuit breaker and smaller.

- a. The branch circuit panel main circuit breaker shall be “fully-rated” (plus safety margin) Current Limiting Circuit Breaker type (CLCB). Shall provide time/current-tripping coordination with upstream equipment.
- b. The branch circuit panel main circuit breaker shall be “series-rated” with the panel downstream branch circuit devices and panel bussing. “The series-rating” shall provide short circuit bolted fault current withstand protection and short circuit bolted fault interrupt rating protection during a downstream 3-phase line-to-line and/or single-phase line-to-ground short circuit bolted faults.

- c. Typical for branch circuit panelboards connected to normal-power (non-emergency) power circuits.
- 4. Emergency branch circuit panelboards 400-amp bus and smaller; Emergency branch circuit panelboards 400-amp trip main circuit breaker and smaller.
  - a. The branch circuit panel main circuit breaker shall be short circuit bolted fault “fully-rated” (plus safety margin) Non-Current Limiting circuit breaker type (non-CLCB).
  - b. The panel bussing shall also be short circuit bolted fault “fully-rated”.
  - c. All of the branch circuit panel, branch circuit breakers shall be “fully-rated” non-fused Current Limiting Circuit Breaker Type (CLCB). Shall provide short circuit bolted fault interrupt rating. Coordinated time/current and instantaneous tripping with the upstream circuit protection devices.
  - d. Typical for branch circuit panelboards connected to emergency power circuits.

### **2.03 PANEL CIRCUIT BREAKERS, CIRCUIT PROTECTION DEVICES**

- A. Circuit Breakers General, for Distribution Panels and Panelboards
  - 1. NEMA-AB1 and AB3, comply with latest revision.
  - 2. UL-1087, UL-489 and IEC-60.947.2 rated devices, comply with latest revision.
  - 3. 5Hz AC closing and 3Hz AC trip and clear.
  - 4. Main circuit breakers for distribution panels exceeding 400-amp and larger;
    - a. Shall be Insulated Case Circuit Breaker type ICCB.
  - 5. Main circuit breakers for branch circuit panelboards 400 amp buss and smaller;
    - a. Shall be Current Limiting Circuit Breaker type-CLCB for non-emergency panelboards.
    - b. Shall be Molded Case Circuit Breaker type-MCCB for emergency panelboards.
  - 6. Branch circuit breakers and feeder circuit breakers smaller than 100-amp trip shall be Molded Case Circuit Breakers type-MCCB and/or Current Limiting Circuit Breakers type-CLCB.
  - 7. All circuit breakers 100-amp and larger trip shall employ sensors and solid state digital electronic automatic trip system. Short-time and long-time time/current curve shaping field adjustable functions and adjustable instantaneous trip. Typical for Molded Case Circuit Breaker type-MCCB, Insulated Case Circuit Breaker type-ICCB and Current Limiting Circuit Breaker type-CLCB.
  - 8. Refer to Specification Section 26 24 13 and/or 26 11 00 for additional Circuit Breaker Requirements.
- B. Manufacturer
  - 1. Circuit breakers as manufactured by the following companies only are acceptable:
    - a. Cutler Hammer
    - b. General Electric Co.
    - c. Square D Co.
    - d. Siemens

C. Configuration

1. Circuit breakers shall be arranged in the panels so that the breakers of the proper trip settings and numbers correspond to the numbering in the panel schedules on the Drawings.
2. Circuit numbers of breakers shall be black-on-white micarta tabs or other previously approved method. Circuit number tabs, which can readily be changed from front of panel, will not be accepted. Circuit number tabs shall not be attached to or be a part of the breaker.
3. Panelboard circuit protection devices shall be bolt on type for connection to panel bus. Removable and installable without disturbing adjacent devices.
4. Provide conductor wire terminations (lugs) on each circuit protection device for incoming main feeder, branch circuits and outgoing feeder circuits. Dual rated copper/aluminum and compatible with the respective conductor size, type, and quantity.
5. Where 2-pole or 3-pole breakers occur in the panels, they shall be common trip units. Single pole breakers with tie-bar between handles will not be accepted.
6. Branch circuit panels shall be field convertible for bottom entry main incoming feeder or top entry main incoming feeder.
7. Each panel section, the feeder and branch circuit protection devices (3-phase and/or 1-phase) shall be "twin-mount", side-by-side double row construction for the following circuit sizes:
  - a. 480/277 volt, 60-amp circuit size and smaller.
  - b. 240 volt – 208/120 volt, 100 amp circuit size and smaller.

D. Lock-Off and Lock-On

1. All circuit breakers shall be pad-lockable in the "off" position.
2. Where branch circuit breakers supply the power to motors and signal systems, the breakers shall also be furnished with lockout clips, mounted in the "on" position. The breakers shall be able to trip automatically with lockout clips in place.
3. Provide lock-on clips on branch circuit breakers supplying fire alarm equipment and fire alarm panels. Provide identification of the dedicated "fire alarm" circuit function and operation. Color-code the circuit breakers to comply with AHJ Requirements.
4. Locking facilities shall be riveted or mechanically attached to the circuit breaker (submit sample for approval. Other means of attachment shall not be accepted without prior written approval of the District's Representative.

E. Arc Fault Interrupter Circuit Breaker (AFCI-C/B)

1. AFCI-C/B provides automatic circuit interruption upon detection of any of these conditions: overload, short circuit fault and electric branch circuit arcing protection.
2. The AFCI-C/B shall detect intermittent "arcing" type electrical faults, and provide automatic circuit interruption (tripping).
3. Provide "test-pushbutton" on each C/B for manual AFCI-C/B Testing.
4. Single pole, 120-volt, 60Hz AC UL listed and labeled for installation in panelboard, #14 - #8AWG solid/stranded AL/CU load conductor.

F. Switch and Fuse Feeder Protective Devices for Distribution Panels

1. Locations where the Drawings show distribution panels employing switch-fuse circuit protection devices.
2. Fusible Switches: Quick-make, quick-break type with rejection clips for use with Class “R” fuses Current Limiting Fuses (CLF). Switches with ratings up to and including 100-amp at 240 volts shall be twins mounted. Switches rated through 60 amp and 480 volts shall be twins mounted. Provisions for padlocking in the “on” and/or “off” positions. Switches shall be removable from front of panel without disturbing adjacent units or panel bus structure.
3. Fuses shall be time delay current limiting types, UL Class RK-1 unless otherwise indicated on the Drawings. Provide one spare set of fuses of each size and type in each Distribution Panel.
4. Provide auxiliary contact on switch for remote status (on-off) signaling and monitoring. Provide conductor lugs to accept conductor temperature rating, sizes and quantities shown on Drawings.
5. Switch and fuse devices shall be permitted only in distribution panels and only where specifically indicated on the Drawings for feeders.

**2.04 PANEL BUSSING**

A. Bus Material

1. Bussing shall be rectangular cross section tin-plated copper or alternately silver or tin-plated aluminum.
2. Bussing shall be non-tapped, full length of the enclosure.

B. Ground Bus

Each panel shall be equipped with a ground bus secured to the interior of the enclosure. The bus shall have a separate lug for each ground conductor. No more than one conductor shall be installed per lug.

C. Provisions

Provide space and all hardware and bus mounting attachments for future devices as indicated on the Drawings.

D. Neutral Bus

The ampere rating of the neutral bus of panels and distribution panels shall be a minimum of 100% greater ampere capacity than the ampere rating of the corresponding phase bus, where the panel is indicated to be provided with an “oversize-neutral” or “200%” neutral on the Drawings.

**2.05 TERMINAL AND AUXILIARY CABINETS**

A. Cabinets

1. Fabricated of Code gauge sheet steel for flush mounting (except where noted as surface) of size indicated on the Drawings, and complete with hinged lockable doors, provide the quantity of 2-way feed through conductor terminals required for termination of all conductors, plus 15% spares of each type.



2. Cabinet locks to operate from same key used for panelboards. The trim to cabinets shall be fastened by means of concealed bolted or screwed fasteners accessible behind door into cabinets. All cabinets shall have 5/8-inch plywood backing, finished with fireproof intumescent primer and finish coat paint. Provide equipment ground bus in each cabinet.
  3. Cabinets shall be finished with one coat of zinc chromate and one coat of primer sealer after a thorough cleaning. Where exposed to public view (e.g., corridors, covered passages, offices, etc.) finish color paint to match surrounding and Manufacturer's standard gray color in switchboard, janitors, heater and storage rooms.
  4. Provide grounded metal barriers inside cabinet to isolate and separate line voltage and low voltage from each other inside the cabinet.
- B. Cabinet Dimensions.
1. Unless indicated otherwise on Drawings.
    - a. Shall be 20-inches wide. Surface or flush mounting as indicated.
    - b. Recess mounted type shall have a 20-inches wide (maximum) recess metal enclosure with overlapping edge trim plate cover extending 1-inch on all sides of enclosure.
  2. Depth shall be 5.75-inches nominal. Height of cabinet as required for devices, plus 25% spare unused interior space for future use, but not less than 36-inches high.
- C. Terminals
1. Non-digital analog circuits; line and low voltage modular signal systems, 15-amp dual row with isolation barriers, screw-down terminals insulated strips, heavy duty.
    - a. As manufactured by Molex, or ITT-Cannon, or General Electric.
  2. Digital circuits; low voltage signal systems, ANSI/EIA/TIA Category-6, 110-Block or 66-Block gas-tight punch down style, heavy duty.
    - a. As manufactured by: Leviton, or Ortronics, or AMP.
- D. Identification (Additional Requirements)
1. Provide engraved nameplate on each cabinet indicating its designation and system (i.e., "Life Safety System - Panel 2LS", etc.).
  2. Identify each terminal landing with unique circuit number and provide corresponding alphanumeric text-index card inside panel access door

## **PART 3 - EXECUTION**

### **3.01 MOUNTING**

- A. Flush Mounted Panelboards and Terminal Cabinets shall be securely fastened to at least two studs or structural members. Trim shall be flush with finished surface.
1. Panels and cabinets installed flush (recess or semi-recess) into fire rated or smoke rated walls. The wall recess shall be fully wrapped inside the recess with fire/smoke rated materials. The wrap-materials shall provide the same fire and/or smoke protection rating as the respective wall.
- B. Surface Mounted Panels and Terminal Cabinets shall be secured to walls by means of preformed galvanized steel channels securely fastened to at least two studs or structural members.

- C. Panelboards and Terminal Cabinets shall be installed to insure the top circuit protective device (including top compartment control devices) are not more than 6-feet-6-inches above finish floor in front of the panel and the bottom device is a minimum of 12-inches above the floor. Manufacturer shall specifically indicate on Shop Drawing submittals each panel where these conditions cannot be met.

**3.02 IDENTIFICATION (ADDITIONAL REQUIREMENTS)**

- A. Provide a red and white Bakelite nameplate with ½-inch high letters in each 277/480 volt panel fastened to face of dead-front plate, to read: "DANGER 480 (or as applicable) VOLTS KEEP OUT AUTHORIZED PERSONNEL ONLY".
- B. Manufacturer shall stencil the panel/cabinet number identification on the inside of door to correspond with the designation on the Drawings.
- C. Identification plates and numbers shall be attached with screws or twist lock fasteners. Adhesive attachment of any kind shall not be used.

**3.03 SPARE CONDUITS (ADDITIONAL REQUIREMENTS)**

Provide three 1-inch conduit only stubs from each panel and terminal cabinet into accessible ceiling space. Where floor level below panel or terminal cabinet is accessible, also provide an additional three 1-inch conduit only stubs into accessible floor space.

END OF SECTION 26 24 16  
022119/212220

This page is blank.

**SECTION 26 24 19**  
**MOTOR CONTROL EQUIPMENT**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances, tools, equipment necessary for, and incidental to, performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete, as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other Specification Sections and Drawings for related work required to be included as work under Division 26.
  - 2. General Provisions and Requirements for electrical work.

**1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

- A. Provide Schematic "Ladder-Type" Logic Control Wiring Diagrams and "point-to-point" control wiring diagrams showing the control system for HVAC equipment and other electrical equipment.
- B. Provide Nameplate Engraving Schedule.
- C. Submit Full-Scale Time/Current Transparencies on log/log paper for all fuses, circuit breakers, ground fault system devices, and relays.
- D. Short Circuit, Coordination and Arc-Flash
  - 1. Perform and submit engineered settings for each equipment location, fuse and adjustable circuit breaker device, showing the correct time and current settings to provide the coordination within the limits of the specified equipment, per the latest applicable Standards of IEEE and ANSI. Provide electrical system short circuit fault analysis, both 3-phase line-to-line and 1-phase line-to-ground calculations as part of the Coordination Analysis recommendations. Provide Electric Arc-Flash calculations as part of the Coordination Analysis recommendations.
  - 2. The information shall be submitted in both tabular form and on time current log-log graph paper, with an Engineering Narrative. Written narrative describing data, assumptions, analysis of results and prioritized recommendations, six copies.
  - 3. The goal is to minimize an unexpected but necessary electrical system outage and Personnel exposure to the smallest extent possible within the fault occurrence location, using the specified Contract Equipment. Shall comply with, but not limited to:
    - a. IEEE-242, Recommended Practices for Protection and Coordination of Industrial and Commercial Distribution.
    - b. IEEE-399, Recommended Practice for Industrial and Commercial Power System Analysis.
    - c. IEEE-1584, Guide to Performing Arc-Flash Hazard Study.
    - d. CEC

4. Electrical equipment including switchgear, switchboards, electric panels and control panels, motor control centers, combination motor starters, transformers, disconnects, etc., shall each be labeled by the Manufacturer with "Electrical-Arc-Flash" warning signs. The signs shall explain a hazard to personnel may exist if the equipment is worked on while energized or operated by Personnel while energized. The sign shall instruct Personnel to wear the correct Protective Equipment/clothing (PPE) when working "Live", or operating "Live" electrical equipment and circuits.

## **PART 2 - PRODUCTS**

### **2.01 GENERAL**

#### **A. Division 24 HVAC/Plumbing**

Refer to Division 26 Mechanical and Plumbing Contract Documents and Shop Drawings for Additional Electrical Work and Material Requirements.

1. Provide all control devices including timeswitches, relays, auxiliary contacts, voltage transformers, and interlocks.
2. Provide all raceways, conduit wire, circuits, outlets, and interconnections of starters as required for HVAC and Plumbing systems.

#### **B. Special Considerations**

1. Mount all auxiliary relays and timeswitches in an isolated compartment inside motor control equipment unless otherwise indicated.
2. Whether or not shown on Mechanical and Plumbing Contract Documents and/or control schedules, where motors are controlled by external devices (i.e., thermostats, relays, float or pressure switches, etc.) or interlocked with other motors, provide each magnetic motor starter with a "Hand-Off-Auto" selector switch in starter cover. Other magnetic motor starters provide a "Start-Stop" push-button station in starter cover.
3. Motor starters, motor controllers and circuit feeder tap devices for motor circuits shall be rated and labeled for control of all electric motor design types A, B, C, D, and E pursuant to the Requirements of the NEC

#### **C. Seismic Earthquake and Wind Loading Withstand, Testing and Certification (Additional Requirements)**

1. The complete motor control equipment assembly; including circuit protection devices, motor controllers, housings/enclosures, accessories, supports/anchors etc., shall be designed, manufactured and tested.
  - a. Wind loading for outdoor locations.
  - b. Earthquake Withstand and CBC Seismic Withstand all indoor and all outdoor equipment locations.
2. Shall withstand, survive and maintain continuous non-interrupted energized operation (running) during the seismic event occurrences. Continued normal energized operation after the wind event and seismic event occurrences have abated.
3. Shall include demonstrations of successful operation and run test after completion of seismic event shake-table simulation.

4. Provide three dimensional finite element analysis demonstrating anchorage and operational withstand of wind loading not less than as follows and as required by AHJ:
    - a. 110MPH-West Coast States USA and Hawaii, per ASCE/SEI 7-10.
  5. Acceptance Test Seismic Qualification of proposed motor control equipment shall employ triple axis shake-table simulation of the Required Response Spectrum (RRS) seismic event motion, certified and approved by the AHJ.
  6. Seismic test shall be performed by a third party independent Test Laboratory. Wind Analysis and Seismic Testing and Reports shall be certified, signed and “stamped” by PE Professional Engineer licensed and in good standing in the State, Civil Engineer or Structural Engineer.
- D. Motor Control Equipment as Manufactured by:  
General Electric; or Square D; or Cutler-Hammer; or Allen-Bradley; or Siemens.

## **2.02 MANUAL MOTOR STARTERS**

- A. Provide flush or surface mounting manual motor starters with number of poles and size of thermal overload heaters as required for the motor being controlled (equipped with overload heaters, one for each motor lead). Back boxes shall be supplied with all flush mounting starters, whether they are toggle type requiring only a 4-inch square outlet box or the larger type requiring a special box. Provide cover designed to accept the particular unit.
- B. Unless otherwise noted on the Drawings, all manual starters for single phase motors, smaller than 1 h.p. shall be the compact toggle type. Manual starters for all single phase motors, 1 to 5 h.p. and all three phase motors up to 5 h.p. shall be the heavy-duty type.
- C. Where Manual Motor Starter is shown with pilot light, the pilot light shall be installed in a separate outlet box adjacent to the starter outlet with engraved nameplate to indicate function of pilot light. Pilot lights shall be push-to-test style.

## **2.03 FEEDER TAP DEVICES**

- A. General
  1. Feeder tap devices shall be coordinated with the motor starter unit’s electrical and mechanical characteristics. Operating handle shall be accessible and operable from the unit front with positive visible indication of the on, off and tripped operating handle positions.
  2. Feeder tap devices shall have a short circuit and motor locked rotor interrupting capacity, series rated with the respective motor starter of not less than the maximum available fault current at the device as indicated on the Drawings, but in no case shall the interrupting capacity be less than 30,000 amp symmetrical interrupting for 480/277 volt devices and 42,000 amp symmetrical for 240 volt or 208/120 volt devices. Provide four key interlocking and padlock-off devices on each feeder tap unit.
  3. Feeder tap device (i.e. circuit breakers, switch and fuse or motor circuit protector) shall be as indicated on the Drawings. Where feeder tap device type is not indicated, provide switch and fuse type device.

4. Circuit breakers shall provide time overcurrent and instantaneous circuit protection. Motor circuit protectors shall provide instantaneous magnetic only circuit protection. Feeder tap devices shall be UL component listed and rated with the respective motor starters.
  5. Feeder tap device shall provide an auxiliary contact to automatically connect and disconnect control power when the feeder tap device is open, tripped or closed.
  6. Provide an auxiliary contact on feeder tap device for remote status (on-off) signaling and monitoring.
  7. Provide conductor lugs to accept conductor temperature rating, sizes, and quantities shown on the Drawings.
- B. Feeder Tap Devices shall be as indicated on the Drawings:
1. Circuit breaker feeder tap
    - a. Circuit breakers shall employ a stored energy, quick make-quick break, and trip free operating system on each phase, with common trip. Breakers shall comply with UL 489 and 1087, NEMA AB1 AB3 latest revisions. Circuit breakers noted as "100%" on the Drawings shall be rated to carry the breaker full rated (100%) ampere load continuously.
    - b. Protection Performance Requirements for circuit breakers conforming to one or more of the following applications:
      - 600-amp or larger frame size.
      - Larger than 400-amp trip.
      - Service entrance motor control center.
      - Noted as main circuit breakers on the Drawings.
      - 1) Circuit breaker shall employ current sensors and solid state static digital electronic automatic trip system. Three-phase or single-phase operation as noted on the Drawings. Current carrying components shall be completely isolated from the static trip units. The trip unit shall be independent of external power sources. Circuit breaker shall be UL listed for reverse connection.
      - 2) Circuit breaker solid state trip control functions shall provide the following time /current curve shaping field adjustable features;
        - a) Adjustable ampere setting to vary the long-time continuous current carrying capacity, minimum range of 80% through 100% of full load trip rating.
        - b) Adjustable long-time delay setting to vary the time the breaker will trip under sustained overload conditions. Minimum of three settings, "minimum-inter-mediate-maximum".
        - c) Adjustable short-time pickup to vary the level of high current the breaker can carry for short periods of time, minimum range of 2 times through 8 times of ampere setting.
        - d) Adjustable short time delay to vary the time of the short-time pickup. Minimum of three settings "minimum-intermediate-maximum".
        - e) Short time "I<sup>2</sup>t" switch to allow a current-squared multiplied by time ramp function in the short-time system. Two position setting "in-out".

- f) Adjustable instantaneous pickup to vary the breaker ampere setting for immediate (instantaneous) interruption of severe overloads (short circuits). Adjustable minimum range of 2.0 times through 13 times of circuit breaker ampere sensor rating. Circuit breaker shall incorporate adjustable instantaneous trip settings to allow coordinated instantaneous trip settings when protecting energy efficient motors.
  - g) Individual fault trip indicators shall provide local indication on the breaker for overload and short circuit (and ground fault where applicable) conditions.
  - h) Provide one Manufacturer standard test set for solid state trip circuit breakers.
- c. Protection Performance Requirements for circuit breakers conforming to one or more of the following applications:
- Smaller than 600 amp frame size.
  - 400 amp and smaller trip.
  - Larger than 100 amp frame size.
  - Larger than 100 amp trip.
- 1) Circuit breaker shall employ current sensors and solid-state static digital electronic automatic trip system. Time/current curve shaping field adjustable features.
  - 2) Solid state trip breakers shall conform to the Requirements described above for solid state breakers larger than 400 amp trip. However, only the following field adjustments are required;
    - a) Ampere setting adjustable minimum range of 80% through 100% of full load trip rating.
    - b) Short time pickup adjustable minimum range of 2 times through 8 times of the ampere setting.
    - c) Adjustable instantaneous trip (circuit breaker shall incorporate adjustable instantaneous trip settings to allow coordinated instantaneous trip settings when protecting energy efficient motors).
- d. Performance Requirements for circuit breakers conforming to the following applications:
- 100-amp frame size and smaller.
  - 100-amp and smaller trip.
- 1) Circuit breaker shall be fixed or adjustable instantaneous trip with thermal-magnetic trip or with solid-state static digital electronic automatic time/over current automatic trip depending on the results of the Coordination Study.
- e. Current Limiting Circuit Breakers (CLCB):
- 1) Performance Requirements for circuit breakers conforming to the following applications:
    - 600 amp and smaller trip and identified as Current Limiting (CLCB) on the Drawings.
    - a) Current Limiting Circuit Breakers shall be supplied in unit molded case construction and shall consist of a common trip, thermal-magnetic or solid state trip circuit breaker with an independently operating limiter section in series with each pole.



- b) The conventional breaker section shall have an over center, trip-free, toggle-type mechanism with quick-make, quick-break action and positive handle indication. A button shall be provided on the cover for mechanically tripping the circuit breaker. The current limiting breaker shall have permanent trip units containing solid state static digital trip or individual thermal and magnetic trip elements in each pole. Calibrated for 40 degrees C ambient temperature. The limiter section shall consist of three current limiting elements electrically coordinated with the conventional circuit breaker trip elements. The contacts of the limiter section shall be electro-magnetically and electro-dynamically opened and held open until interruption is complete.
  - c) Current and Energy Limitations: On high-level fault currents the limiter portion of the circuit breaker shall operate to limit the rise of fault current. Integral resistance shall be introduced into the faulted circuit to dissipate and limit let-through energy and to provide a voltage transient-free interruption at near unity power factor. The Let-through short circuit fault current and energy levels shall be less than that permitted by Underwriters Laboratories to a Value less than  $I^2t$  of a half cycle wave of the symmetrical prospective current. The CLCB limiter shall limit the Asymmetrical short circuit fault current below the equipment symmetrical short circuit fault current.
  - d) On fault currents below the threshold of current limitation, the thermal-magnetic breaker section shall provide conventional overload and short circuit protection.
- 2) Performance Requirements for circuit breakers conforming to the following applications:
- Trip ratings over 600-amp identified as Current Limiting (CLCB) on the Drawings.
  - a) Integrally fused circuit breaker integrated with solid state static digital electronic automatic trip. Combined standard circuit breaker providing overload-short circuit protection within its interrupting capacity and ON-OFF switching function and on each phase current limiters internally mounted on the load side of the circuit breaker, of such ratings that their time current limiting characteristics will coordinate with the time current tripping characteristics of the circuit breaker elements.
  - b) The coordination shall result in the interruption by the circuit breaker alone of fault level currents up to the interrupting capacity of the circuit breaker and interruption by the current limiter in conjunction with the circuit breaker of fault level currents above the interrupting capacity of the circuit breaker.
  - c) A removable cover shall be provided over the current limiter section of the integrally fused circuit breaker. The current limiter housing covers shall be interlocked with the breaker tripping mechanism to insure the breaker will trip upon removal of the cover. The cover shall be interlocked with the breaker to insure the circuit breaker cannot be turned to the ON position with the cover removed. Current limiters shall have a spring loaded plunger which, when the limiter blows, is released to actuate the circuit

breaker common trip bar mechanism opening all breaker poles simultaneously.

- d) The limiters shall be individually interlocked with the breaker element tripping mechanism to insure the limiter cannot be inserted until the breaker is in the OFF position. The circuit breaker and limiters shall be interlocked to insure the circuit breaker cannot be closed if a limiter is either missing or has blown.
  - e) Fuse limiters shall be individually removable from the circuit breaker housing.
  - f) The circuit breaker shall be ambient temperature compensating. The circuit breaker shall be provided with thermal magnetic or solid state static digital trip (depending on the coordination study).
  - g) The integrally fused circuit breaker shall be capable of interrupting available short circuit currents up to 200,000 RMS symmetrical amperes at voltage up to 600 VAC.
  - h) Ratings, clearances and performance of the integrally fused circuit breaker shall be in accordance with applicable Standards of NEMA, IEEE and ASA.
2. Switch and fuse feeder tap:
- a. Fusible Switches: Quick-make, quick-break type with rejection clips for use with Class "R" fuses. Switches shall be removable from front of equipment without disturbing adjacent units or equipment bus structure.
  - b. Fuses shall be time delay current limiting types, UL Class RK-1 for motor circuits unless otherwise indicated on the Drawings. Provide one spare set of fuses of each size and type in each switchboard.
  - c. Provide auxiliary contacts on switch for remote status (on-off) signaling and monitoring.

## **2.04 MOTOR STARTERS - 50/60HZ AC INDUCTION ELECTRIC MOTORS**

### **A. General**

- 1. Motor starters shall be horsepower rated for the motor connected to the starter, air insulated, with NEMA rating.
- 2. Motor starter coils and controls shall be designed to operate on the control voltage indicated on the Control Diagrams and Specifications. The motor starters shall reliably pick-up and seal-in at 80% through 110% of their coil control voltage.
- 3. Under voltage release for motor starter coil circuit shall automatically drop motor starter off the line when the line voltage drops below normal operating voltage. Under voltage release shall be field adjustable 80% to 95% of nominal voltage with field adjustable dropout delay 0.1 to 3 seconds minimum for starters larger than NEMA Size 1. The under voltage release shall reset automatically when line voltage level returns too normal. The reset time delay shall be a 0.1 to 60-second field adjustable time range for starters larger than NEMA Size 1.
- 4. Each motor starter control circuit shall be independently fused.
- 5. Three-phase motor starters controlling three-phase motors, 5-horsepower and larger shall provide integral motor single phasing protection. The starter shall automatically "open", turn off electrical power to the connected motor in the event of the loss of one

or more circuit phases, lock out and require manual resetting of the single phase protection to restart the magnetic motor starter. Provide single-phase annunciator. Provide adjustable time delay, minimum range 0.1 to 3 seconds for initiating single phase shut down.

6. Starter units shall be equipped with individual control power transformers (grounded type) with secondary and primary control power fuses. One secondary lead shall be grounded in the unit.
  - a. The unit disconnect shall be equipped with a normally open contact to isolate the control circuit from the source when the controller disconnect is open.
  - b. The control power transformer VA load rating shall include the motor starter, additional internal and external control devices connected to the motor starter, to insure control power voltage drop does not exceed 5% of nominal rating.
7. Starter units shall be equipped with three motor overload elements, one for each phase, with automatic lockout, external overload indicating flag/pilot light and manual reset external push-button. Trip rating characteristics of the overload elements shall be as recommended by Motor Manufacturer.
  - a. Motor overload protection relays shall be bi-metal (non-melting) "heater-element" type or solid-state type, for motor starters NEMA Size 1 and smaller.
  - b. Motor overload protection relays for motor starters larger than NEMA Size 1 shall be solid-state type.
8. Pilot light indicators shall be provided with "Push-to-Test" feature. Provide a capacitor in parallel with the starters stop-start control relay circuit, to permit the motor starter control circuit to "drop-out" (turn-off) and prevent "capacitive-holding" (capacitive coupling) on control circuits with "long" (excessive distance) control circuit wiring.
9. Each starter shall be equipped with a minimum of one normally open and one normally closed auxiliary spare contact. Provide additional auxiliary control contacts for interlocking with system control circuits as indicated on the Drawings and Specifications. Auxiliary contacts shall be field convertible for normally open or normally closed operation. Contacts shall be rated not less than 10-amp at 120 volt 60Hz, AC, but in no case shall the auxiliary contacts be rated for less ampere or lower voltage than the connected control circuit.
10. Motor starters larger than NEMA Size 1, provide a running time meter 0 to 99999 hours minimum range, and an operations counter 0 to 9999 meter minimum operations start count range. Meters shall be field resettable with maintained memory during power outages of any length.
11. Minimum starter size shall be NEMA 1, but in no case less than indicated on the Drawings or Specifications.
12. Verify the exact Motor Connection Requirements; motor locked rotor/full load current, NEMA Code letter and voltage characteristics with the Supplier of each motor. Motor starters shall comply with the Identified Requirements.
13. Each starter shall be equipped with "Hand-off-Auto" switch or stop-start push-button as required.

14. An auxiliary relay contact for remote alarm annunciation shall provide common trouble annunciation for any of the starter automatic protection systems. The alarm contact shall automatically reset when the starter is reset.
  15. Provide each motor starter main "start" control relay or starter coil as applicable, with a magnetic coil auxiliary control "pilot" relay. The contacts of the auxiliary control relay shall directly control the starting, running and stopping control voltage of the motor starter main control coil circuit. The coil of the auxiliary relay shall condition and match the voltage and inrush of each motor starter to the Requirements of the incoming control circuit.
  16. Provide a surge protection device for each motor starter coil, to limit voltage transients induced by the motor starter coil operation and to protect the motor starting circuit from voltage transients.
  17. Motor starters connected to engine generator emergency power supply source (either direct connection or connection through an automatic transfer switch) shall each be provided with a field adjustable (0.1 - 180 seconds) "start" (on delay) time delay, to provide "staggered" sequenced starting of the connected motor load.
- B. Full Voltage Non Reversing (FVNR), Unless Noted Otherwise
1. Across the line full voltage magnetic electromechanical motor starter.
  2. Provide FVNR motor starter for motor sizes through 50-horsepower (241 to 600 volt) and through 30-horsepower (240 volt and under) where the motor is connected to normal power utility source, unless noted otherwise on Drawings.
- C. Two Speed Motor Starters
1. The two speed motor starters shall be compatible with the connected motor and shall provide automatic two speed control of separate high speed and low speed motor winding or consequent pole two speed motors as applicable. The starters shall be constant horsepower, constant torque or variable torque as applicable for the motor connected to the starter.
  2. Low speed compelling control shall compel the motor starter to always start the motor on low speed before switching to high speed. Compelling control shall be manual switch selectable as either "in" or "out" (bypass) of the motor control circuits.
- D. Reduced Voltage Non-Reversing (RVNR)
1. General
    - a. The reduced voltage starter shall reduce both motor starting current and motor starting torque.
    - b. Reduced voltage starters shall be closed transition types.
    - c. Provide RVNR motor starters for motors larger than 30-horsepower (240 volt and below) and larger than 50-horsepower (over 240 volts), reduced voltage type (Where the motor starter circuit is connected to engine generator emergency power source for motors larger than five horsepower, provide each respective motor with RVNR reduced voltage motor starters).
    - d. Starters shall provide field adjustable time periods for acceleration (reduced voltage) and transition (transfer to full voltage) modes, with failure to transfer lockouts and pilot light annunciators. Adjustable time range shall be 0.1 to 15 seconds.

- e. Duty cycle - NEMA rated medium duty, starters shall provide for not less than one 15-second duration starter operation in each 4-minute interval for a 1-hour period, followed by a cool down rest period of 2-hours before the duty cycle is repeated. Provide automatic temperature lockout to prevent exceeding starter duty cycle.
  - f. Reduced Voltage Non-Reversing RVNR Motor starters shall be types described in the following paragraphs.
2. Autotransformer type reduced voltage starter
    - a. Auto transformers on each phase with field adjustable transformer voltage taps for 50%, 65%, and 80% motor terminal starting voltages.
    - b. Magnetic electromechanical motor contactor type.

## **2.05 COMBINATION MOTOR STARTERS**

### **A. General**

1. Combination motor starters shall consist of a feeder tap device, motor starter and enclosure. Voltage and amperage rating as indicated on Drawings.
2. Combination motor starter shall not be less than NEMA Size 1, but in no case less than indicated on the Drawings.
3. Unit shall be self-contained floor standing, wall mounted NEMA 1 enclosures or as indicated on the Drawings. Constructed, tested and listed in accordance with NEMA, ANSI and UL Standards.
4. Combination motor starters as manufactured by General Electric, Westinghouse, Square D, Cutler Hammer or equal.
5. Provide incoming line and outgoing load terminations, size and capacity to match connections shown.

### **B. Construction**

1. NEMA styles metal enclosed, with full height hinged access door. 12-gauge welded frame members and 14 gauge panel members. All parts shall be removable and accessible from the front for ease of maintenance and rearrangement.
2. Provide removable lifting points and permanent anchor mounting points on the enclosure.
3. Hinged doors shall be mounted with removable pin hinges and secured with quarter turn indicating fasteners. A door interlock with manual defeat override shall prevent access to unit interior when the feeder tap device is in the "on" position.
4. Each metal surface shall be phosphatizing prime rust inhibitor painted and Baked Enamel Finish Painted Manufacturer's standard color.

### **C. Combination Motor Starter Short Circuit Coordination Protection**

The combination motor starter shall be constructed and tested to comply with the following Requirements.

#### **1. Type 1 Coordination:**

Under short circuit conditions the contactor/motor starter shall cause no danger to persons or installation. Continued re-use shall be permitted after service, repair or replacement of parts.

2. Type 2 Coordination:
  - a. Under short circuit conditions the contactor/motor starter shall cause no danger to persons or installation. Continued re-use shall be permitted without requiring any service, repair or replacement of parts.
  - b. Motor starters shall also comply with International Electromechanical Committee (IEC) Type-2 short circuit protection, as recommended by the Manufacturer's published protection tables and as certified by UL.
- D. Energy Efficient Motor Protection
  1. Where a combination motor starter is connected to a high efficiency motor, provide one of the following modifications to the starters or circuit disconnects. The modification shall prevent unnecessary tripping from locked rotor high inrush motor starting current:
    - a. Circuit breaker or MCP short circuit protection - Provide Circuit Breaker/MCP with adjustable magnetic current trip for high inrush motor starting current, or adjustable time delay trip for high magnetic current motor inrush damping.
    - b. Switch and fuse motor short circuit protection - Provide fuses with sufficient inherent time delay to allow passage of high magnetic current inrush motor starting current.

## **PART 3 - EXECUTION**

### **3.01 MOTOR CONTROL AND INDIVIDUAL COMBINATION MOTOR STARTERS**

- A. Install Motor Control Equipment in accordance with Manufacturer's written instructions and applicable portions of NEMA "Standards of Installations" for switchboards and motor control centers and individual motor starters.
- B. Bolt Motor Control Equipment to floor and wall where wall exists. Where units are free standing provide preformed steel channel or angle iron bracing to nearest wall or building structural member. Motor control equipment anchoring shall be designed for a 1.0 gravity lateral acceleration of the equipment. Submit structural calculation and details.

### **3.02 IDENTIFICATION**

- A. Provide a red and white bake lite nameplate with ½-inch high letters fastened to face of dead-front plate, to read: "DANGER 480 (actual volts) VOLTS, KEEP OUT, AUTHORIZED PERSONNEL ONLY".
- B. Manufacturer shall stencil the panel number and name of the connected motor circuit on each device and equipment section to correspond to identification on the Drawing.
- C. Identification plates and numbers shall be attached with screws or twist lock fasteners. Adhesive attachment of any kind as the only method of attachment shall not be used.

### **3.03 SETTINGS AND ADJUSTMENTS**

- A. Program and Set Control Function Sequences, time delays, and protective device settings for correct system operation.
- B. Test all Timing, Control Sequences and motor rotation direction for proper operation. Correct Deficiencies and Retest until proper operation is confirmed.

END OF SECTION 26 24 19  
121918/212220

**SECTION 26 50 00**  
**LIGHTING FIXTURES**

**PART 1 - GENERAL**

**1.01 SCOPE**

A. Work Included:

All labor, materials, appliances, tools, equipment necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete, as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:

1. Examine all other Specification Sections and Drawings for related work required to be included as work under Division 26.
2. General Provisions and Requirements for electrical work.

**1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

A. General

1. Submit certification letter from Manufacturers of Lamps and Ballasts and Power/Driver Supplies, (or alternately, Manufacturer's published catalog data) stating/showing the specific lamp, ballast, or power/ driver supply combination comply with Manufacturer recommendation and approval for the combined use, shown on the Drawings.
2. Provide complete Manufacturers catalog data information for each light fixture (luminaire), ballast, power/driver supplies, lamps, materials, auxiliary equipment/ devices, finishes and photometrics.

B. Performance Certification

1. Submit Manufacturer's Certified Test Report data showing compliance with Contract Document.
2. Submit Manufacturer's letter of certification for each fixture type, confirming the proposed combination of specific lamp, ballast, power/driver supply and auxiliary components for each light fixture (luminaire) type will function together correctly and perform in compliance with the Requirements of the Contract Documents as follows:  
*"The proposed drivers, (where, applicable), lamp sockets and fixture have been tested as an assembly. The proposed fixture products assemblies are certified by the Manufacturer to function within the required temperature, lumen output, electrical characteristics and operational life described in the Contract Documents".*

C. Light Fixture Samples

1. If requested by the District's Representative, provide a sample of each fixture proposed as a substitution for a specified fixture. Sample fixture shall be complete with specified lamps, 3-wire grounding "SO" cord and plug for 120-volt 60Hz, AC plug-in operation. Sample fixtures shall be delivered to the District's Representative's Office for review, the samples shall be picked up within 10-working days after review comments have been received; any samples left beyond this time will be discarded by the District's



Representative. Decision of District's Representative regarding acceptability of any lighting fixture is final.

### **1.03 QUALITY ASSURANCE (ADDITIONAL REQUIREMENTS)**

- A. Work and Materials shall be in full accordance with the latest Rules and Regulations as follows. The following publications shall be included in the Contract Document Requirements. If a conflict occurs between the following publications and any other part of the Contract Documents, the Requirements describing the more restrictive provisions shall become the applicable Contract definition:
1. UL – Underwriters' Laboratory:
    - a. UL – 8750 and 1598C: Light Emitting Diode – LED Equipment for use in Lighting Products and Replacements
  2. NEMA – National Electrical Manufacturers Association:
    - a. NEMA – LE4: Recessed Luminaires Ceiling Compatibility
    - b. NEMA – SSL #1, #3 and #6: Electronic Drivers for LED; LED and Incandescent Lamp Replacement
    - c. NEMA – LSD #44, #45, #49 and #51: SSL - Solid State Lighting
  3. United States Federal Government:
    - a. FCC – Part 18: EMI and RFI emissions limitations.
    - b. EPA: Energy conservation publications and waste disposal regulations.
  4. ETL and C.B.M. certified and approved.
  5. Electrical installation standards, National Electrical Contractors' Association:
    - a. NEIS/NECA and IESNA – 500: Recommended Practice for Installing Indoor Commercial Lighting Systems.
    - b. NEIS/NECA and IESNA – 501: Recommended Practice for Installing Exterior Lighting Systems
    - c. NEIS/NECA and IESNA - 502: Recommended Practice for Installing Industrial Lighting Systems.
  6. Illuminating Engineering Society – IES (IESNA):
    - a. IES – LM41: Photometric and Reporting.
    - b. IES – 587: Surge Protection.
    - c. IES – LM79: Solid State Lighting (SSL) Testing and Measurement.
    - d. IES – LM80: Testing for Lifetime of LED.
  7. ANSI-American National Standards Institute:
    - a. ANSI – C81
    - b. ANSI – C82
    - c. ANSI – C62.41: Transient Withstand
    - d. ANSI – C78: Lamps
  8. State California Code of Regulations - Title-24: Energy Code

## **PART 2 - PRODUCTS**

### **2.01 GENERAL**

- A. Complete Fixture
  - 1. Provide light fixtures complete including lamps, drivers, housings, ceiling and wall trim "rings" for each ceiling type, mounting and adapter support brackets, diffusers/lenses and outlet boxes.
  - 2. Include an allowance of \$300.00 to provide a light fixture for each lighting fixture outlet shown on Drawings without a fixture type designation.
- B. Specific Fixture Requirements and Fixture Schedule Information
  - 1. The catalog numbers included in the description of the various types of lighting fixtures shall be considered to establish the type or class of the fixture with a particular Manufacturer only. The fixture length, number of lamps and lamp types, component materials, accessories, mounting type, ceiling, wall and install adapters, operation voltage, and all other components required to fulfill the total description of the fixture based on all Drawing information, Branch Circuits, Voltages, Specification information, and shall be included in the Contract Requirements regardless of whether or not the catalog number specifically includes these components.
  - 2. Lighting fixtures shall be the types as indicated in Fixture Schedule on the Drawings and as described in the Specifications.
  - 3. All fixtures of the same fixture type shall be the same Manufacturer and of identical finish and appearance, unless indicated otherwise on Drawings.
- C. Manufacturer Certification of Operation
  - 1. Lamps and lamp ballasts and power supplies (drivers) shall be recommended and certified by the respective Manufacturer(s), to be "matched" to operate correctly together, within the published characteristics, for efficacy, lamp starting, operating life hours, lumen output, power factor, power input, operating line ampere, sound intensity, and temperature.

### **2.02 POWER SUPPLIES (DRIVER-POWER SUPPLIES FOR LED-SOLID STATE LAMPS)**

- A. General
  - 1. All ballast, power supplies, lighting fixtures assemblies and components shall be ANSI, ETL approved C.B.M. Certified and UL labeled.
  - 2. Ballasts shall comply with FCC Part 18 Class-A and NEMA limits as to EMI or RFI and not interferes with normal operation of electrical or electronic data processing equipment.
  - 3. Open circuit voltage, starting voltage, crest voltage and lamp-operating voltage shall comply with Requirements of the respective Manufacturer of the installed lamps.
  - 4. Lamp ballasts, power supplies and transformers shall be for use with the specific lamps provided as part of the Contract.
  - 5. Shall be suitable for use with automatic occupancy motion sensing type switching "on-off" control systems, with multiple "on-off" cycles per hour, on a 24-hours a day basis. Operation shall be without loss of performance in operating characteristics described in the Contract Documents.

6. Fusing
  - a. Shall be independently fused on the incoming line side within the fixture compartment.
  - b. Alternately the Ballast Manufacturer may install the equipment fuse inside the ballast/power supply.
  - c. Provide a label next to ballast cover reading: "Ballast (Power Supply) is fused, check fuse prior to relamping". Provide an additional quantity of 10% spare fuses and deliver to District's Representative.
7. Ballast sound rating Class-A or better. Where sound-rating classification is not published, the ballast sound rating shall be the best of product manufactured. Ballasts, which are judged by the District's Representative to be excessively noisy, shall be removed and replaced at the Contractor's expense with low noise ballasts.
8. Electronic solid-state ballasts and power supplies shall be the product of Manufacturer that has been producing electronic ballasts/power supplies for a minimum of 5-consecutive years prior to the date of the Contract.
9. Shall be designed and supplied to operate on the incoming line voltage system circuits to which the respective light fixtures are connected.
10. Shall not contain any PCB (polychlorinated biphenyl).
11. Power factor shall be not less than 0.90, starting and operating. The input starting transient line input ampere should never exceed lamp normal operating ampere by more than 10%.
12. Ballast and power supply disconnect:
  - a. Lighting Fixture Manufacturer factory installed and prewired inside each light fixture, for lamp-ballast or lamp-driver power supply.
  - b. Shall comply with UL-2459 and CEC/NEC. Shall disconnect (load-break) energized or de-energized ballast/driver from respective line voltage circuit and dimming circuit. UL-94V-0 flame retardant.
  - c. Hot pluggable, multi-pole, insulated connectors, with strain relief and finger-safe squeeze-to-release latching function.
  - d. Suitable for available voltage and ampere dimming and non-dimming lamp-ballasts and lamp-power supplies.
13. Ballast and power supplies as manufactured by General Electric, Advance, Philips, Universal, Sylvania/Osram or equal.

### **2.03 LIGHT FIXTURES (LUMINAIRES)**

#### **A. General**

1. Lighting fixtures shall have all parts, ballasts, sockets, support attachments, trim flanges and fittings necessary to complete and properly install the fixture at the indicated installation locations. All fixtures shall be provided with lamps of size and type specified.
2. Ceiling and/or wall surface mounted lighting fixtures shall not have any exposed chase nipples or conduit knockouts visible to view within fixture housing. Lighting fixtures mounted in continuous rows shall have chase nipples or conduit knockouts between

lighting fixture housing, but shall not have visible chase nipples/conduit knockouts on the visible ends of the continuous row of lighting fixtures.

3. Where fixture color is indicated to be selected by the Architect and/or District's Representative, provide two color chip samples for each color for review.
4. Recessed fixtures with attached junction box shall be provided with a junction box permanently attached to the plaster ring so that the junction box is accessible through the fixture opening when the fixture is removed. Connection between fixture and pull box shall be flexible metal conduit with not less than 16 AWG "AF" or "CF" type fixture rated copper wires, high temperature wire insulation for not less than 600 volts AC. The flexible conduit shall be sufficient length, so that when the fixture is removed, the pull-box is readily accessible.
5. Recessed fixtures shall be Underwriters' Laboratory approved for recessed installation with plaster frame and attached pull box. Lamp enclosure, reflectors and finish wiring shall not be installed until plastering is completed. Exposed finish trim shall not be installed until finish painting of the adjacent surface is completed.
6. The fixture shall bear Underwriters' Laboratory label of approval for the wattage and installation indicated.
7. Light fixtures installed outdoors, in damp or wet locations shall be UL labeled for said location as "damp-location" and "wet-location" for the respective installation location.
8. Fixtures in contact with thermal/building insulation shall be UL listed and rated for direct contact installation in thermal insulation systems.
9. Lamp auxiliary support brackets shall be heat-resistant, non-dielectric. Alternatively, metal auxiliary lamp support brackets shall be electrically isolated from the fixture, to prevent glass decomposition.
10. Lighting fixtures installed in masonry and/or concrete construction. The fixture housing shall be rated for "concrete-pour" installation location.
11. Provide a permanent label inside each light fixture stating the following relamping information. Not less than 0.125-inch high black alphanumeric characters on white background.

*"Replacement lamp(s) installed in this light fixture must comply with the following criteria:*

*\_: CRI           \*: Lamp Watts  
    \*: CCT-K       \*: Lamp Lumens*

*Only lamp rated \_\* type lamp ballast shall be installed in this fixture."*

*\*Insert the value required for the specific lamp required by the Contract Documents for each light fixture.*

#### B. Lens and Diffusers

1. Acrylic plastic or Plexiglas for the light fixture diffusers or fixture lenses shall be 100% virgin material.
2. Thickness of not less than 0.125-inch, as measured at the "THINIST" portion on the diffuser or lens. However, thickness shall be increased to sufficient construction and camber to prevent the lens and diffusers from having any noticeable sag over the entire normal life of the installation.

3. Diffusers shall be formed from cast sheet by a vacuum and/or pressure technique.
4. Lighting fixtures containing lamps with dichroic reflectors and light fixtures with non-dichroic lens/ diffuser shall be rated for high temperature lamp operations resulting from lamp heat redirected (reflected) back into the fixture.

## **2.04 SOLID STATE LIGHTING (SSL), LIGHT EMITTING DIODES (LED) LAMPS, POWER SUPPLIES, AND LIGHT FIXTURES (ADDITIONAL REQUIREMENTS)**

### **A. General**

1. Solid State LED light source (lamps), related control equipment (driver-power supply), and luminaire (light fixture) optics for light output distribution.
2. Shall comply with the US-DOE Energy Star Program for SSL-LED. Submit documentation with Shop Drawings.
3. Shall comply with the latest revision IESNA LM-79 and LM-80. Submit documentation with Shop Drawings.
4. SSL chromaticity shall comply with latest revision NEMA and ANSI – C78.377. Submit documentation with Shop Drawings.
5. Submit with Shop Drawings two samples of each light fixture type employing SSL, with prewired 120 volt, 60Hz AC “SO” cord and plug-in cap.

### **B. LED Lamps**

1. Lamp lumen output and overall efficiency shall be based on the LED lamps installed in specified fixture and ambient operating temperature.
2. Lamp Color Rendition Index (CRI) shall equal or exceed CRI – 80, unless noted otherwise on Drawings.
3. Lamp color output shall be 4000-degree K ( $\pm 100K$ ), unless noted otherwise on Drawings.
4. CRI and lamp color temperature shall be same for all light fixtures of the same fixture type.

### **C. LED Power Supply (Driver)**

1. Combination of power supply and SSL – lamp shall be tested and certified by respective Manufacturers for performance and proper operation.
2. Provide dimming type driver where indicated on Drawings. Driver and dimming equipment shall be Tested and Certified by respective Manufacturers for performance and proper operation.

### **D. Self-Contained LED Lamp and Driver, Integral “Screw-Base” and/or “Pin-Connect”, replacement assembly for incandescent lamps.**

1. Shall be dimmable. Dimmer and lamp shall be certified by respective Manufacturers for compatible correct operation with each other.
2. Optical system and operating temperature thermal performance shall be compatible with light fixture.
3. Comply with latest revisions of NEMA LSD-49 and SSL-6.

## 2.05 EMERGENCY BALLAST LIGHTING AND EMERGENCY DRIVER LIGHTING

### A. General

1. Self-contained emergency ballast and power supply (driver) containing batteries, battery charger, solid-state electronic control and lamp/ballast/driver operation, contained within a metal case, red finish case color.
2. UL-924, listed Emergency Lighting and Power Equipment, for installation inside and/or attached to lighting fixtures.
3. The emergency battery supply unit(s) shall be provided inside each respective emergency light fixture by the Fixture Manufacturer.
4. Normal operating temperature range from 0-degrees Centigrade up to operating ambient temperature inside respective lighting fixture, but not less than 50-degrees Centigrade.
5. Provide a permanent label inside each emergency light fixture stating as follows, not less than 0.125-inch high black alphanumeric characters on a white background:  
*"Warning – this fixture provides more than one electric power source. Disconnect both normal and emergency sources including battery sources prior to opening fixture. Written permanent records documenting regular (every 30 days) emergency lighting function testing results shall be kept on file by the District."*
6. UL and Manufacturer rated to supply the lamp and ballast/driver (power-supply) combination occurring in the respective light fixture, both dimming-type and non-dimming type light fixtures.
7. As manufactured by Bodine Inc. or IOTA-Engineering Inc.

### B. Operation

1. Emergency mode  
When external AC electrical power fails, the emergency unit shall immediately and automatically switch to emergency mode. Maintain emergency lamp(s) illumination, while operating from the internal battery/electronics during the power failure for not less than 90-minutes continuous duration.
2. Normal Mode  
When AC electrical power is restored, automatically switch lamp(s) operation to external AC operation and begin battery-charging mode.
3. Battery Recharge Mode  
The battery charger shall automatically fully recharge discharged batteries in less than 24-hours, and prevent overcharging of the batteries, while maintaining a "float-charge" on the batteries.
4. The emergency battery unit shall operate not less than two lamps in multi-lamp light fixtures and one lamp in single lamp light fixtures. When operating in emergency mode and battery power, the lamp lumen output of each lamp shall be not less than 40% of the lamp normal full lumen output rating of the lamp operation on normal power. The lamp-lumen output shall be 100% of the lamp normal full lumen output rating when operating in normal mode.

5. The emergency ballast shall provide cold-strike start and hot-restrike operation of the fixture lamp(s).
  6. Periodic automatic, internal self-test, simulating normal power loss and actual operation of emergency lamps on internal battery power. Auto self-test shall occur not more than 30-day intervals. Audible and visual trouble alarm display, with manual alarm reset/silence, for problems identified by auto-test functions.
- C. Electrical Characteristics
1. Emergency equipment shall operate on the same input AC voltage as the normally "hot" branch circuit supplying the respective light fixture. Maximum line input load shall not exceed 15% more than normal fixture electrical load.
  2. The emergency equipment shall be compatible for correct operation with the specific lamp/ballast/ driver combination contained in the respective light fixture.
  3. The emergency equipment shall be compatible with switched (on-off), non-switched (continuously on) and dimmer controlled lighting fixtures/circuits.
- D. Components
1. Sealed nickel cadmium batteries, maintenance-free, rated for continuous operation in high ambient temperature, with 7 to 10 year operational life expectancy.
  2. When standing on the floor below the fixture the emergency ballast test/monitor control panel shall be visible and readily accessible when the fixture is installed. The control panel shall provide:
    - a. Charging indicator visual annunciator to display the charger and battery status.
    - b. Momentary test switch/pushbutton to manually simulate power failure test.

## **PART 3 - EXECUTION**

### **3.01 LIGHT FIXTURE INSTALLATION**

- A. General
1. The Contractor shall verify actual ceiling and wall construction types as defined on the Architectural Drawings and furnish all lighting fixtures with the correct mounting devices, trim rings, brackets whether or not such variations are indicated by fixture catalog number. The Contractor shall verify depth of all recessed lighting fixtures with Architectural Drawings prior to ordering fixtures. Any discrepancies that would cause recessed lighting fixtures not to fit into ceiling shall be reported to the District's Representative prior to release of order to the Supplier of the fixtures.
  2. On acoustical tile ceilings, fixture outlets shall be accurately located in the center, at the intersection of the four corners or at the center of the joints of two tiles.
  3. The Contractor shall aim the exterior adjustable lighting fixtures after dark in the presence of, and at a time convenient to the District's Representative.
  4. Fixtures shall be ordered and furnished to operate correctly on the branch circuit voltage connected to the respective fixture as shown on the Site Plan and Floor Plan Electrical Drawings. The voltages shown on the fixture schedule are for generic fixture information only.

5. Install and connect lighting fixtures to the circuits and control sequences indicated on the Drawings and to comply with respective Manufacturer's instructions/recommendations.
  6. Lighting fixtures in building interstitial spaces, in mechanical plumbing and electrical spaces/rooms, are shown in their approximate locations. Do not install lighting outlets or light fixtures until the mechanical, plumbing and electrical equipment/pipes/ductwork are installed; then adjust and install lighting in revised clear (non-interfering) locations to provide best even-illumination. Coordinate the locations with all other trades prior to lighting installation.
- B. Lighting Fixtures Installed in Ceiling Support Grids – Suspended Lay-in "T-bar" and Concealed Spline Ceilings.
1. Provide two seismic clips at opposite ends of each recessed light fixture, the clip shall connect to the ceiling grid main runners and the light fixture. The light fixture with seismic clips and ceiling grid runner connections shall resist a horizontal seismic force equal to the total weight of the light fixture assembly.
  2. Each light fixture weighing 40-pounds or less and where the respective ceiling grid system is "heavy duty" type, shall be suspended directly from the ceiling grid or shall be suspended independent of the ceiling grid support system as approved by the AHJ. Each light fixture weighing more than 40-pounds or where the ceiling grid system is not a "heavy duty" type shall be supported independent of the ceiling grid and independent of ceiling grid support system.
  3. Each light fixture supported independent of the ceiling grid system shall be supported with a minimum of four taut independent support wires, one wire at each fixture corner.
  4. Each light fixture supported directly from the ceiling grid or ceiling grid support system shall be additionally connected with a minimum of two independent slack safety support wires. One wire at each opposite diagonal fixture corner. Each 3-feet by 3-feet and larger light fixture shall be supported in the same manner, except provide a minimum of four independent slack safety wires, one at each fixture corner.
  5. Light fixtures surface mounted to a suspended ceiling shall be installed with a 1½-inch steel – "C" channel which spans across and above a minimum of two parallel main ceiling grid "runners" and concealed above the ceiling. Each channel or angle member shall be provided with a minimum of two threaded studs for attaching to the fixture housing through the lay-in ceiling tile. Two steel "C" channel members shall be installed for each 4-feet (or smaller) fixture. Install the channels within 6-inches of each end of the light fixture to span a minimum of two ceiling grid parallel main runners. Provide two seismic clips connecting the ceiling grid main runners to each steel – "C" channel. Provide a not less than two taut independent support wires connecting to each channel. Bolt the light fixtures to the threaded studs on the channels or angles, to support the light fixture tight to the ceiling surface.
- C. Fixture Supports
1. The support wires for light fixture support shall be 12-gauge steel (minimum). The wires including their building and light fixture attachments shall provide support capacity of not less than four times the weight of the light fixture assembly. Provide additional light fixture support wires and building anchors to meet these Requirements, as part of the Contract. The support wires shall be anchored to the building structural elements above the ceiling.



2. Pendant mounting fixtures shall be supplied with swivel hangers. Fixtures shall swing in any direction a minimum of 45 degrees of gravity, position. Fixtures shall have special stem lengths to give the mounting height indicated on the Drawings. Stem to be single continuous piece without coupling, and to be finished the same color as the canopy and the fixture, unless otherwise noted. The Contractor shall check all lock nuts and set screws to rigidly secure the swivel socket to the stem, and the stem to the outlet box.  
  
Fixtures shall be plumb and vertical. Where obstructions occur restricting 45-degrees free-swing of fixtures, the fixtures shall be "guy" wired to prevent fixtures from striking obstructions. The District's Representative shall approve method of guying. Swinging fixtures shall have an additional safety hanger cable attached to the structure and the fixture at each support, with the capacity of supporting four times the vertical weight of the light fixture assembly.
  3. Suspended fixtures weighing in excess of 40-pounds shall be supported independently of the fixture outlet box. Provide "air craft" (minimum 12 gauge) steel hanger cable for suspended fixtures route cable concealed or in pendant where possible. Each cable attachments shall support four times the weight of the fixture assembly. Securely attach the cable to the building structure.
  4. Surface mounted fixtures installed on drywall or plaster ceilings and weighing less than 40-pounds may be supported from outlet box. Provide structural supports above drywall or plaster ceilings for installation of fixtures weighing more than 40-pounds and secure fixture to structural supports. The use of toggle bolts is prohibited.
- C. Recessed Lighting Fixtures - Fire Rated Building Surfaces
1. Lighting fixtures recessed in ceiling or wall which has a fire resistive rating of 1-hour or more shall be enclosed in a fully enclosed backbox (except over fixture lens/diffuser). The material used to fabricate the "enclosed backbox" shall have a fire rating equal to that of the respective ceiling or wall.
  2. The space from the fixture to the box enclosure shall be a minimum of 3-inches.
  3. The backbox shall be concealed behind the fire rated ceiling and wall finish surface. The light fixture shall be provided with lamp ballast rated for (normal light output) operation in a "high" ambient temperature.

### 3.02 LENS AND DIFFUSERS

Lens, diffusers, internal reflectors shall be completely cleaned of all dust, dirt and fingerprints after the installation of the light fixtures and lamps, and after all trades have completed work and prior to occupancy of the facility by the District.

### 3.03 COMMISSIONING LIGHTING FIXTURES (ADDITIONAL REQUIREMENTS)

- A. General
1. Verify correct lighting control configurations and operation in each room.
  2. Simulate normal source power failure by "opening" (turn off) building main service disconnect and verify connections and operation of each emergency lighting fixture.
  3. Confirm "EXIT" sign directional arrows are visible in each "EXIT" sign.
  4. Verify light fixture support-hangers, ceiling grid clips and seismic restraints comply with the Contract Documents.

5. Remove protective shipping/installation shields on fixtures. Verify fixtures and lamps are clean and free of construction debris. Clean light fixtures found to be contaminated or dirty.
  6. Setup, program, and function test lighting control systems to perform each of the indicated control functions, area/room zones and sequences.
  7. Provide "aiming", directional adjustment of light fixtures, both indoor and outdoor. Aiming shall comply with Manufacturer's aiming diagrams, and as directed by District's Representative.
- B. Sample Spot-Check in each room the following lighting fixture information:
1. Lamp type and performance data.
  2. Ballast type and performance data.
  3. Combined Lamp/Ballast Certification of performance and compatibility by respective Manufacturer.
  4. Verify instructional signage is placed inside each lighting fixture in compliance with Contract Documents.

END OF SECTION 26 50 00  
022119/212220

This page is blank.

**SECTION 26 52 00**  
**EMERGENCY LIGHTING CENTRAL BATTERY**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances, tools, equipment, facilities, transportation and services necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other Sections for work related to those other Sections and required to be included as work under this Section.
  - 2. General Provisions and Requirements for electrical work.
- B. Demonstration and Instruction (Additional Requirements)
  - 1. Provide on-site instruction classes and operation manuals to the District's Personnel.

**1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

- A. General
  - 1. Submit Manufacturer product data, dimensional data, ambient environmental data and derating factors, electrical performance data.
  - 2. Submit performance and technical information on battery calculations and/or factory tests demonstrating capacity capabilities.

**1.03 APPLICABLE STANDARDS (ADDITIONAL REQUIREMENTS)**

- A. General
  - 1. The equipment shall be listed, labeled and approved for the application show in the Contract Documents, as a battery stored energy, emergency lighting electrical power inverter, complying with the most recent version of the following applicable Standards.
  - 2. The following Standards shall become Requirements of Contract Document and are included in the Contract Documents.
- B. Underwriters Laboratory - UL
  - 1. UL – 924 and 924A Standard for Emergency Lighting and Power Equipment.
  - 2. UL – 1778 Standard for Uninterruptible Power Supply Equipment.
- C. National Fire Protection Agency - NFPA
  - 1. NFPA – 111 Stored Electrical Energy and Standby Power systems.
  - 2. NFPA –70 Article 700 Emergency Systems. (NEC) Article 480 Storage Batteries.
- D. Federal Communications Commission - FCC
  - 1. FCC – Class A RFI emission limits.
- E. American National Standards Institute – ANSI
  - 1. ANSI – C62.41 Both Category-A and Category-B and C62.45 Transient Voltage Withstand.

- F. Institute of Electrical and Electronic Engineers-IEEE
  - 1. IEEE – 587 Surge Voltages
- G. Seismic Earthquake and Wind Loading Withstand, Testing and Certification (Additional Requirements).
  - 1. The complete emergency lighting central battery inverter assembly; including circuit protection devices, meter, housings/enclosures, batteries, accessories, supports/anchors etc., shall be designed, manufactured, and tested.
    - a. Wind loading all outdoor equipment locations.
    - b. Earthquake Seismic Requirements of CBC/IBC Seismic withstand all indoor and all outdoor equipment locations.
  - 2. Shall withstand, survive and maintain continuous non-interrupted energized operation during the seismic event occurrences and wind event occurrences. Continued normal energized operation after the wind event and seismic event occurrences have abated.
  - 3. Shall include demonstrations of successful operation and run test after completion of seismic event shake-table simulation. Acceptance test seismic qualification of proposed equipment shall employ triple axis shake-table simulation of the Required Response Spectrum (RRS) seismic event motion, certified and approved by the AHJ.
  - 4. Provide three dimensional finite element analysis demonstrating anchorage and operational withstand of wind loading not less than as follows and as required by AHJ:
    - a. 110MPH-West coast states USA, California, and Hawaii per ASCE/SEI 7-10.
  - 5. Seismic test shall be performed by a third party independent test laboratory, shall include batteries. Wind Analysis and Seismic Testing and reports shall be certified, signed and “stamped” by PE Professional Engineer licensed and in good standing in the State, Civil Engineer or Structural Engineer.
- H. Short Circuit, Coordination and Arc-Flash (Additional Requirements)
  - 1. Perform and submit short circuit fault current, time/current coordination and Arc-Flash fault engineering analysis, for AC and DC circuits.
  - 2. Provide label equipment with warning and instructional signs.

## **PART 2 - PRODUCTS**

### **2.01 OPERATION**

#### **A GENERAL**

- 1. The Emergency Lighting Battery Unit (ELBU) shall be self-contained, automatic operation. Unit shall store electrical energy and supply standby back-up electrical energy upon failure of normal (utility source) power and provide operation of lighting and other connected equipment as described in the Contract Documents.
- 2. ELBU shall consist of an automatic circuit transfer system, input/output circuits, storage batteries, battery charger, voltage inverters, monitoring, test/monitoring equipment and operating program software. Manufactured with all components enclosed in modular cabinetry.

3. ELBU volt-ampere continuous load rating shall be sufficient to provide operation of the full unit rated load. But in no case less, than required to supply all of the connected loads shown on the Drawings, plus an additional 20% spare continuous load capacity "Safety-Factor". All at an 80% (0.80) lagging load power factor.
  - a. Normal mode load capacity operation duration shall be continuous.
  - b. Emergency mode full 100% rated load capacity operation shall be for the duration time indicated on the Drawings, but not less than 90 continuous minutes.
4. Unit shall operate properly in ambient temperatures from 15 to 25 degrees centigrade, sea level to 10,000 feet above sea level, at the specified ratings.
5. Emergency lighting central battery unit shall be as manufactured by Dual-Lite; or Myers Power Products.

**B. Operation**

1. During operation under normal mode 60Hz AC power, the supply voltage shall feed both the output load and the battery charger. Upon normal power failure, the output load shall be automatically transferred to internal 60Hz AC emergency mode power operation.
2. When normal power is re-established, the output load shall be automatically transferred back to the normal power AC line and the charger shall commence recharging the batteries to their full capacity.
3. Transfer to emergency mode operation shall occur when normal input voltage drops to less than 60% to 70% of nominal for brownout protection on any input line phase. The transfer to emergency mode shall also occur if there is an open circuit, or shorted circuit on the normal input side. A 15 to 60-second transfer time delay (nominal) back to normal mode operation shall be adjustable to reduce "cycling" operation between normal and emergency operating modes.

**2.02 LOAD REQUIREMENTS**

**A. Load Types**

1. Load output shall be provided for the following types of loads in any loading combination (0 to 100% of load rating), within the rated capacity (0 to 100% of load rating) for 50% (0.5) lag through 50% (1.5) lead load power factors.
2. Unit shall be suitable for operation and withstand inrush currents associated with the connected loads without damage or changes in its operation including:
  - a. Incandescent lamps and ballasts.
  - b. Fluorescent lighting fixtures and ballasts.
  - c. Electronic equipment including fire alarm equipment.
  - d. High Intensity Discharge (H.I.D.) lighting fixtures and ballasts (continuous ARC-sustain operation).
  - e. Solid state electronic lighting fixture ballasts and dimmers.
  - f. Electromagnetic lighting fixture ballasts and dimmers.
  - g. LED (Light Emitting Diode) solid-state lamps and drivers.
  - h. Fire door holds open devices.

B. Voltage

1. Normal power input and output voltage shall be 60Hz, AC single phase or three phase; 120 volt; 208 volt; 240 volt; 277 volt; 120/208 volt 3 wire or 120/240 volt 3 wire. All as indicated on the Drawings.
2. Provide multiple load output voltages, for both normally on and normally off loads, where indicated on the Drawings (i.e., 120-volt input - 120 volt and 277-volt load output; 277 volt input-120 volt and 277 volt output; etc.).
3. The total line input volt-amperes shall not exceed 135% of the unit rated full load output volt amperes and output line voltage, including battery-recharging loads.

C. Circuit Breakers Line and Load

1. Provide load output circuit breakers, ampacity and quantity as indicated on the Drawings, but in no case less than one 20-amp load output circuit breaker for each 1500 volt ampere (or portion thereof) of unit rated load capacity. Provide the circuit breakers on each normally off and each normally on load out connection and on each load out voltage connection.
2. Provide a unit main line input circuit breaker in the ELBU. The circuit breaker shall be sized to allow continuous full rated load operation of the ELBU, including battery-recharging loads.
3. Provide D.C. battery protection internal breakers.
4. The circuit breakers shall be thermal magnetic molded case type. The Main line input circuit breaker shall be rated a minimum of 42,000-amp symmetrical short circuit interrupting capacity, but not less than shown on the Drawings. Internal and load output circuit breakers shall be "series rated" or "fully rated" to the main input circuit breaker symmetrical short circuit interrupting capacity, at the specified input and output voltage(s).
5. Monitor and trouble-alarm each circuit breaker for "tripped" or "off" condition.

D. Load Output

1. Provide output load types as follows (in any combinations up to unit full rated output capacity).
2. Normally on - Output load is energized in both the normal and emergency modes.
3. Normally off - Output load is energized only when unit is in the emergency mode and de-energized when the unit is in the normal mode.
4. The unit shall function correctly with no load (zero-volt amp) connected to the output terminals. UNITS REQUIRING A MINIMUM CONNECT LOAD FOR CORRECT OPERATION ARE NOT ACCEPTABLE.

E. Load Output Voltage Characteristics

1. During the entire rated operation duration, output voltage shall be sinusoidal wave.
  - a. Total harmonic distortion shall not exceed 5% under any combination of the specified load conditions.
  - b. Voltage regulation shall not vary more than plus or minus 5% of rated voltage under all load conditions, no load 0% to 100% of full rated load.

2. Load output voltage frequency regulation shall be within plus or minus 0.5Hz under specified load conditions, when operating on the inverter and batteries.
- F. Efficiency When Operating In Any Mode
1. At 100% rated load – greater than 97%.
  2. At 50% rated load – greater than 94%.
  3. Efficiency shall be measured load output kW divided by the measured line input kW; with a connected load power factor of 0.8 lagging and the batteries fully charged operating on trickle float charge.
- G. Internal Bypass Switch
1. Switch shall keep all of the loads circuits energized while the ELBU is shut down (bypass) due to malfunction or maintenance.
  2. Three position switch: normal; unit bypass; loads off.

### **2.03 INVERTERS**

- A. General
1. Inverters shall be modular and completely solid state. Protected against overloads, in rush loads and short circuits.
  2. Inverter shall provide stable regulated output operation from the internal batteries under all specified load conditions.
  3. Low battery voltage cutout shall be provided to disconnect the inverter load when the battery output voltage drops below a preset value.
  4. Automatic unit restart after initiation and/or restoration of normal input power.

### **2.04 CONTROL, TESTING AND MONITORING EQUIPMENT**

- A. Internal control, monitoring and testing with programming software and microprocessor control operation shall be provided to verify proper system operation and trouble conditions. Control, testing, and metering display panel shall be installed in the door of equipment cabinet not more than 6-feet-0-inches above finished floor.
- B. System Display/Control Panel
1. The system's display panel shall include an array of visual indicators, multi-line alphanumeric character display, and a keypad to control and monitor the system.
  2. The array of visual indicators shall monitor and annunciate the AC utility presence, system ready status, battery charging status, battery emergency operation, and alarm functions.
  3. The system shall display alphanumeric meter functions including:
    - a. Input-voltage and input demand load.
    - b. Output-voltage, output-frequency, output-demand load and output-power factor.
    - c. Unit internal component temperatures.
    - d. Total quantity of power outages and inverter operating time.
  4. To ensure only authorized personnel can operate the unit, the system shall be password protected for all control functions, including parametric changes.



C. Alarms

1. The system shall have audible and alphanumeric visual alarm display, with automatic logging of the twenty most recent alarm events. Each alarm will have a corresponding audible signal associated with it to aid in the troubleshooting of the system.
2. The system's alarm acknowledge feature shall enable the user to silence only the current audible alarm(s), while not silencing other alarms and not clearing the alarming condition until the fault has been cleared.
3. Alarms shall monitor low, near low, and high battery voltage; high AC voltage input; high and low AC voltage output; volt-amp output overload; low runtime remaining; high ambient component temperature over limit; check charger, battery, inverter, and memory/logic; emergency power off activated; user test check; and call service.
4. Alarms on each internal circuit breaker, to indicate when the circuit breaker is in the open/off/tripped positions.

D. Manual and Programmable Testing

1. The system shall provide both manual test functions and software programmable automatic test modes. The user shall be able to perform a system test at any time.
2. The system shall also perform an automatic programmable, weekly, self-diagnostic test and load test of its subsystems to insure the system will operate in an emergency condition. A monthly load test for a user programmable discharge time and an annual test for a complete runtime discharge time and an annual test for a complete runtime discharge.
3. Automatic recording in memory, of the last twenty inverter events, including all automatic weekly and user programmed tests, shall be logged.

E. Remote Terminal Strip

1. An auxiliary terminal strip located within the system cabinet shall provide connection points for remote monitoring of inverter status and alarm indication.
2. Remote monitor/annunciator panel:
  - a. Provide a remotely mounted ELBU monitoring/alarm panel, with operating status and alarm conditions visual and audible indicators. Provide an audible alarm silence push-button with automatic resound on subsequent alarms.
  - b. The panel shall be enclosed in a Nema 1 for indoor locations, NEMA 3R for outdoor locations. Flush mounted housing, with "see-thru" front cover access door. Tamper resistant construction, suitable for installation in unsupervised public areas.
  - c. The remote monitoring and alarm panel shall operate over connecting circuit lengths up to not less than 300-foot distance from the respective ELBU.
  - d. Provide remote monitoring and alarm panels adjacent to each fire alarm annunciator panel unless noted otherwise on the Drawings.

## 2.05 BATTERIES

A. General

1. Batteries shall provide capacity to operate the unit and maintain specified inverter output for indicated years on a pro-rata basis when properly maintained as recommended by the Manufacturer.

2. Flame arresting caps shall be provided on batteries, with catalytic conversion to prevent hydrogen out gassing.
  3. Battery cases shall be translucent to allow visual observation of electrolyte level. Provide earthquake restraint battery mounting straps.
- B. Battery Seismic Restraint
1. Batteries shall be installed in the unit with seismic restraint anchors and straps.
- C. Battery Type
1. Batteries shall be nickel cadmium low maintenance type to reduce the need to replenish battery fluids. Batteries shall be 25-year design life expectancy at 77-degrees Fahrenheit ambient, pocket plate construction. Maximum battery discharge shall be automatically limited to the value recommended by Battery Manufacturer of nominal battery voltage, with full rated unit output during discharge.

## **2.06 BATTERY CHARGER**

- A. General
1. Battery charger shall be solid state specifically designed for the type of batteries used in the system.
  2. Battery charger shall have automatic protection against short circuits, low battery condition, DC-over voltage protection and protected against thermal runaway.
  3. Charger shall automatically maintain correct battery charge conditions, with float charging and periodic equalize battery charges, within plus or minus 0.05 volts of Battery Manufacturer's recommendations.
  4. The charger shall completely restore fully discharged batteries from the input line source, to full battery charge condition in less than 24 hours.

## **2.07 CABINET**

- A. General
1. The cabinetry shall contain all components, inverter, transformers, power supplies, battery charger, including the batteries, free standing with hinged locking door. All components shall be accessible from the front for maintenance and removal.
  2. Units requiring side access for cooling air or maintenance shall not be acceptable unless the Drawings specifically show the permitted side access space provisions.
  3. Provide water shields on cabinets, to protect the ELBU from fire sprinkler discharge water damage.
- B. Cabinet Construction
1. The cabinets shall be metal, NEMA 1 enclosure, equipped with a key-operated access lock.
  2. Manufacturer's standard finish color with rust inhibitor "primer" and acid-resistant finish paint.
  3. Battery shelves shall permit the batteries to be tested or have battery fluids added without having to remove the batteries.

4. The doors shall open full without affecting the operation of the unit. Conduit knockouts shall be provided on both sides, bottom and top of the cabinet for connection of line and load circuits. Provide dead front or insulated covers over exposed energized parts to prevent accidental contact, when doors are open.
- C. Electrical Connections
1. Provide line and load terminal lugs and identification tags on all circuits.
- D. Size
1. Maximum cabinet size including batteries shall not exceed those shown on Drawing, but in no case larger than as follows:
    - a. Up to 4600VA at 80% power factor rated load output: 43-inches wide by 84-inches high by 21-inches deep.
    - b. 4601VA to 11000VA at 80% power factor rated load output: 85-inches wide, by 84-inches high by 24-inches deep.
    - c. 11001VA to 17,500VA at 80% power factor rated load output: 128-inches wide by 84-inches high by 26-inches deep.

## **2.08 COMMUNICATION PORTS**

- A. General
1. The ELBU shall provide a standard RS-232 bi-directional serial communications port, for communicating with portable computers. Provide software with the ELBU for control, monitoring and diagnostic/maintenance operations of the ELBU. The software shall operate on Microsoft-Windows® based, PC style computers, using 3.5-inches “floppy-disk” magnetic storage media, or 5.25-inch “CD/DVD” ROM.
  2. The PC computer is not included in the contract scope of work.
- B. Remote Monitoring and Control
1. Facsimile/Modem Communications Panel: Shall automatically transmit system’s operating status reports over a dedicated “dial-up” telephone line to remote locations. Provide 1-inch conduit with (ANSI/EIA/TIA-568B) two Category-6, 4-pair, UTP cables and homerun to IDF/MDF telephone terminal.
  2. Each designated location shall automatically receive a unit status reports transmission following all monthly and annual test cycles or when an alarm conditions is detected by the system’s self-diagnostic electronics.
  3. Status reports shall be software programmable and include readings on key operating parameters as well as complete alarm and inverter log printouts.
  4. The ELBU Manufacturer shall provide 364 calendar days duration, remote monitoring and supervision of each ELBU. The start date shall begin from the Construction Contract substantial completion date, notice of completion. Provide not less than two written status reports, to the District’s Representative, at 180 calendar days and 330 calendar day milestones.
  5. The District and Manufacturer shall have the option to renew the Manufacturer’s Monitoring Control Contract at a negotiated fair market price and terms, at the end of the initial 364 calendar day periods.

C. Monitoring and Communications Circuits

1. Provide monitoring and communication circuits as follows:
  - a. One 0.75-inch conduit, homerun from each ELBU to nearest telephone/data terminal backboard, with two EIA/TIA-568C Category-6A 4-pair UTP communication cables in conduit.
  - b. One 0.75-inch conduit, homerun from each ELBU to Building Automation System (BAS) communications transponder, with two EIA/TIA-568C Category-6A, 4-pair UTP communications cables in conduit.

**PART 3 - EXECUTION**

**3.01 TESTING**

A. General

1. All units and batteries shall be inspected for damage as soon as they are received. Specifically check to see if wet cell batteries have been turned over in shipment and whether the equipment cabinets have received any severe dents which might cause internal damage. Remove and replace all damaged equipment with new undamaged equipment.
2. Use only the factory provided knock-out areas and conduit entry provisions on the equipment for wiring. Care shall be taken not to let metal slugs or chips get into the equipment cabinet.
3. Prior to energizing equipment, perform measurements on the incoming and load output AC lines to the equipment to insure that the proper voltage level is available and that there are no ground faults or high potentials between conductors or between phase conductor to neutral/ground.
4. Prior to installing the fuses, or closing the circuit breaker in the battery circuit, verify correct battery voltage, polarity markings, battery electrolyte level and all electrical connections are secure.
5. Prior to turning the system on for any tests, the unit shall be bypassed with the mains connected to feed the load directly and the currents in each conductor measured and balanced. Follow Manufacturer's instructions for installation, connection and energizing equipment.
6. Batteries which are shipped with the electrolyte in the battery cells shall be maintained on a float charger when not installed and energized, operating the emergency power unit. Batteries shipped without electrolyte installed in the battery cells shall not have electrolyte added until equipment is installed and ready to be energized. Batteries which are not handled with this procedure will be rejected, shall not be used and shall be replaced with new batteries at the Contractors expense.
7. Provide factory authorized Field Service Technician factory start-up to inspect, energize, test and certify the correct system installation, connections and operation. Provide written acceptance field service report, six copies, to District's Representative.

B. Commissioning (Additional Requirements)

1. Setup, testing, startup, and Commissioning shall be performed by factory Technician(s) trained, certified and authorized by the Equipment Manufacturer. Final Commissioning shall be performed after installation and connections are complete.
2. Provide system programming and setup of all control sequences for the emergency/exit lighting control system.
3. Simulate normal source power failure by opening (turn-off) building main service disconnect and verify connections and operation of each electrical system device connected to the system on both normal power source and emergency power sources. Simulated test time for operating duration connected on the emergency systems shall be not less than 90 continuous minutes without failure or anomalies in the system.
4. Record and document electrical demand load and sequence of operations on the ELBU system with all connected loads operating, including but not limited to:
  - a. Fire alarms
  - b. Egress/exit lighting
  - c. Doors
  - d. auto-loading and overload shedding controls
5. Test all control system functions after the installation and connections are complete and the system has been energized. Verify each control sequence of operation and each device to be controlled are each operating correctly.
6. Record and document each device setup and program setting.
7. Submit written report (six copies) to District's Representative certifying Commissioning has been performed; all respective systems are operating correctly and document all software setup and each device setting.
8. Refer to General Commissioning Section 01 91 13 for Additional Requirements.

**3.02 SEISMIC EARTHQUAKE**

A. General

1. The entire unit shall be installed and anchored to building structure to comply with Seismic Earthquake Requirements.
2. Install Seismic Restraints on all batteries.

**3.03 FACTORY SERVICE AGREEMENT (FIRST YEAR OPERATION)**

A. General

1. Provide site visits and written reports for each ELUB at unit start-up, Commissioning, and again approximately 12 months after completion of Testing and Commissioning. Shall be included as part of the base contract scope.
2. Factory authorized Technician shall test all ELUB options, accessories and functions, physical, electrical and mechanical inspection. Simulate normal source power outage and recharge functions.
3. ELUB factory remote monitoring and reporting of each ELUB status, using telephone communications line provided by the District.

4. The Base Contract initial first year operation service scope shall be renewable, if mutual agreement between the ELUB Manufacturer and the District is accomplished for service cost, scope and renew.
5. Provide three copies of factory service proposal renew agreement to the District's Representative.

END OF SECTION 26 52 00  
022119/212220

This page is blank.

**SECTION 27 08 00**  
**COMMISSIONING OF COMMUNICATIONS SYSTEMS**

**PART 1 - GENERAL**

**1.01 DESCRIPTION**

- A. The Requirements of this Section apply to all Sections of Division 27.
- B. This Project will have selected building systems commissioned. The complete list of equipment and systems to be commissioned is specified in Section 019100 General Commissioning Requirements. The Commissioning process, which the Contractor is responsible to execute, is defined in Section 019100 General Commissioning Requirements. A Commissioning Agent (CxA) appointed by the VA will manage the Commissioning process.

**1.02 SUMMARY**

- A. This Section includes Requirements for Commissioning the Facility Communications Systems, related subsystems and related equipment. This Section supplements the General Requirements specified in Section 01 91 00 General Commissioning Requirements.
- B. Refer to Section 01 91 00 General Commissioning Requirements for more details regarding processes and procedures as well as roles and responsibilities for all Commissioning Team members.

**1.03 DEFINITIONS**

Refer to Section 01 91 00 General Commissioning Requirements for definitions.

**1.04 COMMISSIONED SYSTEMS**

- A. Commissioning of a system or systems specified in Division 27 is part of the construction process. Documentation and testing of these systems, as well as training of the VA's Operation and Maintenance Personnel in accordance with the Requirements of Section 01 91 00 and of Division 27, is required in cooperation with the VA and the Commissioning Agent.
- B. The Facility Exterior Closure Systems Commissioning will include the systems listed in Section 01 91 00 General Commissioning Requirements:

**1.05 SUBMITTALS**

- A. The Commissioning process requires review of selected Submittals that pertain to the systems to be commissioned. The Commissioning Agent will provide a list of Submittals that will be reviewed by the Commissioning Agent. This list will be reviewed and approved by the VA prior to forwarding to the Contractor. Refer to Section 01 33 23 Shop Drawings, Product Data, and Samples for further details.
- B. The Commissioning process requires Submittal review simultaneously with engineering review. Specific Submittal Requirements related to the Commissioning process are specified in Section 01 91 00 General Commissioning Requirements.



## **PART 2 - PRODUCTS (NOT USED)**

## **PART 3 - EXECUTION**

### **3.01 CONSTRUCTION INSPECTIONS**

Commissioning of Communications systems will require inspection of individual elements of the communications system construction throughout the construction period. The Contractor shall coordinate with the Commissioning Agent in accordance with Section 01 91 00 and the Commissioning Plan to schedule communications systems inspections as required to support the Commissioning Process.

### **3.02 PRE-FUNCTIONAL CHECKLISTS**

The Contractor shall complete Pre-Functional Checklists to verify systems, subsystems and equipment installation is complete and systems are ready for Systems Functional Performance Testing. The Commissioning Agent will prepare Pre-Functional Checklists to be used to document equipment installation. The Contractor shall complete the checklists. Completed checklists shall be submitted to the VA and to the Commissioning Agent for review. The Commissioning Agent may spot check a sample of completed checklists. If the Commissioning Agent determines that the information provided on the checklist is not accurate, the Commissioning Agent will return the marked-up checklist to the Contractor for correction and resubmission. If the Commissioning Agent determines that a significant number of completed checklists for similar equipment are not accurate, the Commissioning Agent will select a broader sample of checklists for review. If the Commissioning Agent determines that a significant number of the broader sample of checklists is also inaccurate, all the checklists for the type of equipment will be returned to the Contractor for correction and resubmission. Refer to Section 01 91 00 General Commissioning Requirements for Submittal Requirements for Pre-Functional Checklists, Equipment Startup Reports, and other Commissioning Documents.

### **3.03 CONTRACTORS TESTS**

Contractor tests as required by other Sections of Division 27 shall be scheduled and documented in accordance with Section 01 00 00 General Requirements. All testing shall be incorporated into the Project schedule. Contractor shall provide no less than 7 calendar days' notice of testing. The Commissioning Agent will witness selected Contractor tests at the sole discretion of the Commissioning Agent. Contractor tests shall be completed prior to scheduling Systems Functional Performance Testing.

### **3.04 SYSTEMS FUNCTIONAL PERFORMANCE TESTING:**

The Commissioning Process includes Systems Functional Performance Testing that is intended to test systems functional performance under steady State conditions, to test system reaction to changes in operating conditions, and system performance under emergency conditions. The Commissioning Agent will prepare Detailed Systems Functional Performance Test Procedures for review and approval by the Resident Engineer. The Contractor shall review and comment on the tests prior to approval. The Contractor shall provide the required labor, materials, and test equipment identified in the test procedure to perform the tests. The Commissioning Agent will witness and document the testing. The Contractor shall sign the test reports to verify tests were performed. See Section 01 91 00 General Commissioning Requirements, for additional details.

### **3.05 TRAINING OF VA PERSONNEL**

Training of the VA Operation and Maintenance Personnel is required in cooperation with the Resident Engineer and Commissioning Agent. Provide competent, Factory Authorized Personnel to provide instruction to Operation and Maintenance Personnel concerning the location, operation, and troubleshooting of the installed systems. Contractor shall submit Training Agendas and Trainer resumes in accordance with the Requirements of Section 01 91 00. The Instruction shall be scheduled in coordination with the VA Resident Engineer after submission and approval of Formal Training Plans. Refer to Section 01 91 00 General Commissioning Requirements and Division 27 Sections for additional Contractor Training Requirements.

END OF SECTION 27 08 00

022119/212220

This page is blank.

**SECTION 27 20 00**  
**ELECTRONIC NETWORK SYSTEMS INFRASTRUCTURE**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances, tools, equipment necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete, as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other Specifications Sections and Drawings for related work required to be included as work under Division 26 and 27.
  - 2. General Provisions and Requirements for electrical work.
- B. Provide Electronic Network Systems Infrastructure for the following systems:
  - 1. Computer Data Networks
  - 2. Telephone and Intercom Voice Communications
  - 3. Other special systems described in the Contract documents.

**1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

- A. Drawings Submittals
  - 1. Drawings shall be submitted on reproducible sepias and AutoCAD<sup>®</sup> Version 2.2 (or later revision) data files on CD/DVD-ROM disk, WINDOWS<sup>®</sup>-XP or Version-7 or Version-8 format.
  - 2. Submit redrawn Building Floor Plan for each building area, same scale as the Contract Drawing.
  - 3. Plans shall show walls, doors, windows, furniture, infrastructure, outlets and network systems equipment locations. Show point-to-point interconnecting cables, pathways, conduit, conduit sizes, circuit types, along with circuit identification names, numbers and quantities between all components.
  - 4. Provide scaled Elevation Drawings of each equipment rack, terminal blocks, terminal backboard and terminal room/closet showing location and arrangement of each equipment component, outlet and cable training provisions, with estimated weight of each complete assembly.
  - 5. Submit block wiring diagrams showing major system components, outlets, equipment racks, terminal blocks, signal loss with interconnecting circuit conductors, splices, portable patch cords and connectors. Riser type diagram shall be provided if the building has more than one floor level, with information shown on riser diagram corresponding for each respective floor.
- B. Submit Manufacturer's standard catalog data for each component. The submittal shall be arranged in the order of the Specification and shall list the Specification paragraph number, the name, the proposed model and Manufacturer for each item as well as a reference indicating the specific piece of data which can be easily located in the brochure. The Manufacturer's data sheets shall be marked to indicate the specific item being proposed in

cases where the sheet covers several types or sizes of items. The data sheet shall completely describe the proposed item. Where modification to the equipment is necessary to meet the operational Requirements of the Contract Documents, the brochure shall include complete Mechanical and Electrical Shop Drawings, detailing the modification. The brochure shall include a listing of the Outlet Rough-In Requirements for every device and equipment item. The applicable symbol which illustrates that rough-in item on the Job Plans shall be drawn on the proposal, opposite the description of the rough-in to facilitate locating the data by Field Personnel. Submit elevation and dimensional information.

C. Performance Calculation:

1. Provide engineered calculations showing the Passive Cable System Signal Attenuation losses of the proposed installed system. The intent is not to require calculations for every system segment, port and outlet. The intent is to require engineered calculations for proposed typical worst case port to port; head end to farthest distance outlet and patch port to outlet signal attenuations.
2. Provide calculations for a minimum of 50 complete channel/circuit paths. The calculations shall include attenuation insertion losses for each system component including individually itemized cable-fiber/wire; outlet, termination, connector, electronic component (if any), coupler and patch cord along the entire path from the head end equipment to the end use outlet.
3. The calculations shall serve as the basis for verifying the system performance with the system testing specified in the Contract Documents.

D. Provide proposed nameplate and outlet identification/color coding system. Indicate proposed identification naming sequence and methods, itemized for review.

E. Submit Manufacturer Certified Test Reports showing test documentation for the proposed material that the material meets or exceeds the performance standards defined in the Contract Documents. The testing and results shall reflect worst case performance based on a minimum of ten samples. Tests shall be certified by a Nationally Recognized Independent Test Lab (i.e., ETL, UL, etc.). The Manufacturer shall certify in writing the material has been manufactured and tested to comply with the Requirements defined in the Contract Documents.

F. Submit three samples of each of the following, fully assembled with 24-inches of cable type connected:

1. Copper wire outlet and connector, with each type of specified inserts.
2. Copper cables and patch cords, each type.
3. Fiber optic cables and patch cord each type.
4. Mechanical splice - fiber optic.
5. Fusion splice - fiber optic.
6. Fiber optic outlet and connector each type.
7. Fiber optic cable connector each type of termination, with interconnection coupler.
8. Patch panel each type.
9. Coverplate each type.

### 1.03 APPLICABLE STANDARDS

- A. Individual component Production/Manufacturer Testing and Labeling.
  - 1. The equipment shall be UL listed, labeled, and approved for the application shown in the Contract Documents.
  - 2. ETL (USA) each network systems infrastructure component. Third party testing, documentation and certification for performance compliance of each component with the UL, ANSI, TIA and EIA Applicable Standards specified in the Contract Documents.
- B. The complete system material, equipment, testing, installation, workmanship and installed performance shall comply with the Mandatory Requirements and the Guideline/ Recommendation Requirements of the following latest Published Version, Supplements, latest revision including Addendums and TSB. Both the mandatory and advisory criteria shall be included as Requirements of the Contract Documents:
  - 1. TIA-526 Optical Power and loss measurements – multimode and single mode fiber.
  - 2. ANSI/TIA/EIA-568C Commercial Building Telecommunications Standards.
  - 3. ANSI/TIA/EIA-569B – Commercial Building Standards for Telecommunications Pathways.
  - 4. ANSI/TIA/EIA-570A Residential Telecommunications Standard.
  - 5. ANSI/TIA/EIA-598B Optical Fiber Cabling Color-Coding.
  - 6. ANSI/TIA/EIA-606A Administrative Standard for Commercial Telecommunications Infrastructure.
  - 7. ANSI/TIA/EIA-607 Commercial Buildings Grounding and Bonding Requirements for Telecommunications.
  - 8. FCC – FYU/FT6.
  - 9. ISO/IEC 11801
  - 10. National Electrical Code (NEC) and California Electrical Code (CEC) including Articles 770 and 800 with ETL verified Testing and Local Code jurisdictions.
  - 11. NECA/NEIS, National Electrical Contractors Association, National Electrical Installation Standards:
    - a. 301 – Standard for Installation and Testing for Fiber Optic.
    - b. 568-Standard for Installing Building Telecommunications Bonding and Grounding.
    - c. 607-Telecommunications
  - 12. Manufacturer's recommendations for the respective equipment.
- C. Network Performance
  - 1. The entire completed Electronic Network Systems Infrastructure shall be tested and provide electronic data/network and telephone/voice multi-channel communications latest Revisions, Standards and Addendums for the following protocols:
    - a. IEEE 802.3/ETHERNET latest revisions.
  - 2. Twisted pairs copper wire (100 meter path length unless indicated otherwise)
    - a. 10Mbps 10Base-T, 100Mbps 100Base-Tx;
    - b. 1000Mbps (1Gbps) 1000 Base-Tx;
    - c. 10,000 Mbps (10Gbps) 10Gb Base-Tx.

- d. IEEE-802.3 for Power Over Ethernet (POE) and Power Over Ethernet-Plus (POE Plus).
- 3. Fiber optic, 550 meter communications pathway distance, OM4 standard multimode and OS2 single-mode.
  - a. 10Mbps 10Base-F1, 100Mbps 100Base-FX,
  - b. 1000Mbps 1000Base-Lx-Sx
  - c. 10,000 Mbps (10Gbps) for fiber optics
  - d. Single Mode path length performance increase Requirement to 3000 meters.
- 4. IEEE 802.5/TOKEN RING.
- 5. APPLETALK (Phone-net).
- 6. FDDI - Distributed data interface on fiber or copper wire, 100Mbps.
- 7. 100VG – Any LAN
- 8. TIA/EIA serial and Bi-directional RS-232 and RS-485, including Star-Hub repeaters.
- 9. ANSI - TPPMD 55Mbps, 155Mbps and 622Mbps Asynchronous Transfer Mode - ATM.
- D. The Complete Telephone/Voice Infrastructure System shall be suitable for the telephone/voice analog and digital communications and VoIP protocols. The system shall be compatible with the telephone/voice equipment installed as part of the Contract.
- F. Installation of All Infrastructure Equipment, Devices, Splices, Terminations, Cables, Outlets, etc. shall comply with Manufacturer's recommendations.

#### **1.04 EQUIPMENT QUALIFICATIONS**

##### **A. Equipment**

- 1. The Supplier of the equipment shall be the Factory Authorized Distributor and service facility for the brands of equipment and material provided.
- 2. Network systems infrastructure equipment and materials shall all be the product of one of the individual same Manufacturers as follows. Typical unless specifically described otherwise:  
 Belden – 10GX Series; or CommScope-Systimax X10D Series;  
 or AMP/Tyco – NetConnect Series;  
 or Ortronics/Legrand – NetClear Series;  
 or Siemon – ConvergeIT Series.

##### **B. Installation Certification**

- 1. Work and material for cables, cable terminations, outlets and related components for infrastructure systems shall be performed by Certified Installers. The Installer shall be certified by the respective Product Manufacturers.
- 2. The Manufacturers of the indicated work and material shall provide an Installer education/training and certification program for the supplied products.
- 3. The Installers performing the Contract Work for the indicated products shall have attended and successfully completed each of the respective Manufacturer's installation training education programs for the specified products.

4. Submit six copies of the Manufacturer's Certifications for each installer performing the work. The submittal shall be approved by the Owner's Representative prior to initiating any related Contract Work.
  5. Contract material installed and work performed by Installers not complying with these Requirements shall be removed. Removal of work and material not in compliance with these Requirements shall be done at the Contractor's expense, without any additional cost to the Contract and without any additional Contract completion due date extensions. New material and work required to replace the non-complying removed work and material shall be provided at the Contractor's expense, without any additional cost to the Contract and without any additional Contract completion due date extensions.
- C. Extended Material and Performance Warranties
1. In addition to the warranty Requirements described elsewhere in the Contract Documents, provide the following extended material and performance warranties. The warranty period shall be for not less than 15-years from the Contract Notice of Completion.
  2. Warranty scope includes materials and performance for network cables and terminations, network workstation plug-in outlets, and patch panel plug-in outlets, cable splices and connectors.
  3. Repair or replace the defective material with new material at the Project premise, to comply with the performance standards outlined in the Contract Documents during the warranty period.
  4. Submit seven copies of proposed warranty statements, with Shop Drawing submittals.

**1.05 ABBREVIATIONS**

| <u>Abbreviation</u>                                   | <u>Terminology</u>   |
|---|--|
| ACR.....  | Attenuation to Cross Talk.   |
| AHJ .....   | Authority Having Jurisdiction.   |
| Backbone.....   | Circuit interconnections between MDF and IDF patch panel locations.  |
| dB .....  | Decibel.   |
| dBm .....   | Decibel referenced to a milliwatt.   |
| Demarc.....   | Demarcation location where operational control change occurs or ownership change occurs.                                     |
| ft.....   | Feet.  |
| GHz.....  | Gigahertz.   |
| Gbps .....  | Gigabits per second.   |
| Horizontal Connection, and/or Horizontal wiring ..... | Circuit interconnections between individual workstation outlet location to respective IDF or MDF equipment rack patch panel. |
| IDF .....   | Intermediate Distribution Frame (horizontal or vertical cross connect) for an individual building area/ floor.               |
| km .....  | Kilometer-1km.   |
| kPSI.....   | 1000 pounds per square inch.   |
| m .....   | Meter = 39.37 inches.  |
| Mbps .....  | Megabits per second.   |



|                      |   |
|----------------------|---|
| MDF.....             | Main Distribution Frame (central/main cross connect) for multi-building site or for a single individual building.   |
| MHz.....             | Megahertz.  |
| MIC.....             | Micrometer  |
| mm.....              | Millimeter = 10 <sup>-3</sup> meter.  |
| NEXT.....            | Near end cross talk.  |
| nm.....              | Nanometer = 10 <sup>-9</sup> meter.   |
| pF.....              | Picofarad = 10 <sup>-12</sup> farad.  |
| Provide.....         | Furnish, install and connect.   |
| RTDE.....            | Equipment rack mount fiber optic termination distribution enclosure, with fiber optic patch panel.  |
| RMSE.....            | Equipment rack mount fiber optic enclosure, splice only (without patch panel).  |
| STP.....             | Shielded individual twisted pairs copper wire.  |
| ScTP.....            | Shield Screened Twisted Pairs copper wire.  |
| Trunking-Cable.....  | Individually insulated twisted pair copper wire cable, consisting of 24-pair or more of conductors inside a common cable jacket. Terminate and connect to common terminal-block location at each end of the trunking-cable. |
| um.....              | Micrometer = 10 <sup>-6</sup> meter.  |
| USE.....             | Universal Splice Enclosure.   |
| UTP.....             | Unshielded twisted pairs copper wire.   |
| VoIP.....            | Voice communications Over Internet Protocol.  |
| WGNA.....            | Wide Band Gigabit Networking Alliance.  |
| Workstation or.....  | Spaces remote from the MDF/IDF terminal room/closet, where user equipment interacts and connects with the electronic systems infrastructure equipment connection outlet device.   |
| Workstation location |   |
| WMIC.....            | Wall Mount fiber optic cable Interface Cabinet.   |

### 1.06 MATERIALS AND METHODS

- A. Material and Labor not complying with the Contract Documents shall be removed by the Contractor from the Project Site. Material and labor complying the Contract Documents shall be provided.
- B. All the cost to remove deficient work and material, provide work and material complying with the Contract Documents and the direct, indirect, incidental damages and Contract delays resulting from complying with these Requirements shall be the sole responsibility of the Contractor and shall be included in the bid price.

C. System Performance Requirements

1. The work, performance and type of materials provided as part of the Contract shall comply with the following ANSI/TIA/EIA-568C and related standards for all Electronics Network Systems Infrastructure work and materials described in the specifications and shown the Drawings:
  - a. Computer/data network systems: Category-6A
  - b. Telephone/intercom voice systems: Category-6A
  - c. Broadband transmission radio frequency for television, digital or analog cable television, digital satellite system, broadcast quality Coaxial-RG6 (QUAD SHIELDING).
  - d. Trunking-cable, analog circuits copper wire twisted pairs: Category-5E.
2. The Electronic Network Systems Infrastructure system shall be based on “Star-Topology”; for MDF to IDF backbone connections and workstation outlet to MDF/IDF horizontal connections.

## **PART 2 - PRODUCTS**

### **2.01 FIBER OPTICS CABLES**

A. General

1. Operating temperature range - 20 degrees centigrade through +60 degrees centigrade. Cables shall be flame retarding.
2. Electronic network systems infrastructure cables that are not installed inside conduit raceways. Electronic network systems infrastructure cables that are installed in concealed spaces including plenums and non-plenums; access floors, ceiling spaces, walls, floor, etc., and/or installed without continuous raceways. The cable insulation and jacket shall be listed and labeled “Limited Combustible Cable” (LC or LCC) and shall comply with the latest published revision of all of the following Additional Requirements.
  - a. Limited combustible “FHC-25/50” per UL-2424.
  - b. NEC/CEC;CMP, additional listing/labeling where the install location is an environmental air plenum, fiber optic “FHC-25/50-CMP and/or OFNP/OFCP”.
  - c. NFPA-90A; ceiling cavity plenums, wall cavity spaces and raised floor cavity plenums, limited-combustible.
  - d. NFPA-5000; defines combustible material including wire and cable.
  - e. NFPA-75 computer rooms and electronic equipment room.
  - f. NFPA-13; spaces containing “limited combustible loading”.
3. Cables shall qualify as 100% recyclable materials disposal, RoHS regulation complaint.
4. All fibers in a multi-fiber cable shall be fully operational within the performance characteristics specified prior to and after the cable is installed. The use of spare fibers in the cable to compensate for defective fibers is not permitted. Defective cables shall be removed and replaced with fully functional cables at no additional cost to the Contract.
5. Cables shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with Specified Requirements. ANSI/TIA/EIA-568C including related Standards, Amendments and TSB.

6. Each fiber shall be individually identified with factory color-coding or factory imprinted label. The outer cable jacket shall be imprinted with date, Manufacturer's model and catalog number, along with Agency listing identification.
7. Fiber optic cable shall be a product of the same Manufacturer, including portable patch cables.
8. Cables installed in raceways or conduits below grade, through in-grade manholes or pull-boxes shall be rated for installation in water/wet locations.
9. Provide overall outer jacket enclosing all fibers inside jacket. Cables containing less than seven fiber strands shall be provided with a color coded outer jacket (red or orange).
10. Multimode (62.5/125)
  - a. Fiber optic cables optical fibers, (62.5/125) graded index multimode optical glass fibers, 62.5 micron fiber core and 125 micron fiber cladding, 0.275 numerical aperture. Optical fibers shall be 100 kpsi proof tested, with maximum 0.7 micron flaw size for dual operation at 850nm and 1300nm wave lengths.
  - b. Minimum bandwidth:
 

|                        |                      |
|------------------------|----------------------|
| @ 850nm - wave length  | 160MHz per km length |
| @ 1300nm - wave length | 500MHz per km length |
  - c. Maximum attenuation:
 

|                      |                     |
|----------------------|---------------------|
| @ 850nm-wave length  | 3.4 dB @ 1km length |
| @ 1300nm-wave length | 1.0 dB @ 1km length |
  - d. Laser-optimized "OM2" optical multi-mode standards.
11. Multimode (50/125)
  - a. 50/125 fiber optic cables optical fibers, graded index multimode optical glass fibers, 50.0-micron fiber core and 125-micron fiber cladding, 0.2 numerical apertures. Optical fibers shall be 100 kPSI proof tested, with maximum 0.7 micron flaw size for dual operation at 850nm and 1300nm wave lengths.
  - b. Minimum bandwidth:
 

|                      |                       |
|----------------------|-----------------------|
| @ 850nm-wave length  | 3500Mhz per km length |
| @ 1300nm-wave length | 500Mhz per km length  |
  - c. Maximum attenuation:
 

|                      |                    |
|----------------------|--------------------|
| @ 850nm-wave length  | 3.0db @ 1km length |
| @ 1300nm-wave length | 1.0db @ 1km length |
  - d. Laser-optimized "OM4" optical multi-mode standards.
12. Single mode:
  - a. Fiber optic cables optical fibers, (8.3/125) single mode optical glass fibers, 8.3-micron core fiber and 125-micron fiber cladding, 0.11 numerical apertures. Optical fibers shall be 100-kPSI proof tested, with maximum 0.7-micron flaw size for operation at 1310nm and 1550nm wave lengths.
  - b. Maximum attenuation:
 

|                       |                     |
|-----------------------|---------------------|
| @ 1310nm- wave length | 0.5 dB @ 1km length |
| @ 1550nm- wave length | 0.4 dB @ 1km length |

- c. Maximum dispersion
  - @ 1310nm- wave length            2.8 ps/nm km length
  - @ 1550nm- wave length            8.0 ps/nm km length
- d. Laser-optimized "OS1"/OS2" optical single mode standards.

B. Loose Tube Gel-filled Cables

1. Multiple, loose tube buffer tubes, gel-filled. Each buffer tube shall contain the same quantity of optical fibers, but not more than twelve optical fibers in each buffer tube.
2. Buffer tubes shall be cabled around a central dielectric strength member. The central strength member shall be centered along the length of the cable.
3. Aramid yarn, non-optical, strength fibers shall extend continuously along the length of the cable.
4. The cable interstitial spaces shall be flooded to inhibit water migration, with non-flammable water blocking gel.
5. Each optical fiber shall be individually UV cured acrylate coated, 250-micron diameter coating over fiber cladding.
6. A seamless black polyethylene outer layer jacket shall envelope the entire cable.
7. The cable shall be fungus resistant, UV resistant, and moisture resistant for installation indoors with or without an enclosed raceway and outdoors in underground enclosed raceway/conduit and manholes/ pullboxes continuously flooded with water.

C. Indoor/Outdoor Cables

1. The cable shall be fungus resistant, UV resistant, moisture resistant for installation indoors with or without an enclosed raceway and outdoors in underground enclosed raceway/conduit and manholes/ pullboxes continuously flooded with water, and in conduits exposed to the sun.
2. Each optical fiber shall be primary coated with 500 micron uniform acrylate tight buffered and with elastomeric uniform 900-micron diameter tight buffered, secondary coating. Aramid yarn strength member elements shall be tensioned and symmetrically and uniformly distributed around the fibers, along the length of the cable.
3. An overall cable jacket uniformly extruded directly around and mechanically interlocked with the optical fibers/strength members. The extruded jacket shall form internal helical cusped ridges that interlock with the optical fibers and strength members. The interlocking jacket shall not allow cable fibers to move axially within the cable jacket.
4. Cables containing more than twenty-four optical fibers shall be constructed with sub-cable fiber bundles. Each sub-cable bundle shall contain equal quantities of optical fibers, with a separate PVC jacket around each sub-cable. Sub-cable and sub-cable jacket construction shall match the overall Cable Requirements and Jacket Requirements.
5. The cable shall be UL listed and comply with NEC and NFPA Requirements for each installation location shown in the Contract Documents. ETL tested and certified to comply with or exceed Specified Requirements.
  - a. NEC – OFNR (Vertical Riser Type Locations) OFNP (UL FHC-25/50 LC Plenum Type Locations and locations where not continuously enclosed inside conduits for entire cable length).

- b. NEC – OFNG (Where continuously enclosed inside conduits for entire cable length).

D. Tight Buffered Cables

1. Each optical fiber shall be coated, 900-micron diameter uniform coating, with uniform tight buffering over the coating, uniform dielectric strength member surrounding the buffering coating and an overall jacket around each optical fiber assembly.
2. Individual multiple optical fiber assemblies shall be symmetrically arranged around a central dielectric strength member. The central strength member shall be centered along the length of the cable.
3. A dielectric strength member shall surround the fiber assemblies.
4. An outer dielectric jacket shall envelope the entire cable.
5. The cable shall be UL listed and comply with NEC and NFPA Requirements for each installation location shown in the Contract Documents. ETL tested and certified to comply with or exceed Specified Requirements.
  - a. NEC - OFNP (UL FHC-25/50 LC Plenum type locations and locations where not continuously enclosed inside conduits for entire cable length).

## 2.02 COPPER WIRE CABLES (TWISTED PAIRS)

A. General

1. Conductors shall be copper wire, individually insulated and color coded, with multiple conductors arrange in twisted pairs.
2. An overall non-conductive jacket shall encase the copper wires and any shielding (where shielding is specified) shall also be encased by the jacket.
3. Cables shall be UL listed, complying with NEC National Electrical Code, National Fire Protection Agency and NFPA Requirements for each installation location shown. ETL tested and certified to comply with or exceed Specified Requirements.
  - a. NEC – MPP/CMP, FHC-25/50 (Plenum type locations and locations where not continuously enclosed inside conduit).
  - b. NEC – MPR/CMR (Vertical riser type locations).
  - c. ANSI/TIA/EIA-568C; including related Standards, Amendments and TSB.
4. Electronic network systems infrastructure cables that are not installed inside conduit raceways. Electronic network systems infrastructure cables that are installed in concealed spaces including plenums and non-plenums; access floors, ceiling spaces, walls, floor, etc., and/or installed without continuous raceways. The cable insulation and jacket shall be listed and labeled “Limited Combustible Cable” (LC or LCC) and shall comply with the latest published revision of all of the following Additional Requirements.
  - a. Limited combustible “FHC-25/50” per UL-2424.
  - b. NEC/CEC;CMP, additional listing/labeling where the install location is an environmental air plenum, copper wire “FHC-25/50-CMP”.
  - c. NFPA-90A; ceiling cavity plenums, wall cavity spaces and raised floor cavity plenums, limited-combustible.
  - d. NFPA-5000; defines combustible material including wire and cable.
  - e. NFPA-75 computer rooms and electronic equipment room.
  - f. NFPA-13; spaces containing “limited combustible loading”.

5. Cables shall qualify as 100% recyclable materials disposal, RoHS regulations complaint.
  6. Cables installed in air plenums, air-handling spaces and cables installed without raceway or conduit shall also be UL listed and labeled for installation in air plenums.
  7. Cables installed in raceways or in conduits below grade, or through in-grade manholes and pullboxes, shall be rated for installation in water/wet locations.
  8. The outer cable jacket shall be imprinted with date, Manufacturer's model and catalog number and Agency (AHJ) listing identification.
  9. Copper wire Electronic Network Systems Infrastructure cable shall be a product of the same Manufacturer, including portable patch cables.
  10. The outer jacket of cables with less than nine pair of conductors shall be color-coded. The jacket color shall be different for each system type; multimedia; telephone/voice; computer/data network; and fiber cable jackets.
  11. 300-volt RMS insulation material for each data conductor shall be the same material; shall be the same electrical characteristics and shall be the same dielectric constant, for all data conductors contained within the respective common cable jacket, along the entire installed length of the cable. Data cables employing differing insulation materials for individual data conductors contained within a common cable jacket are not acceptable and shall not be provided.
  12. Propagation and "Skew" Rate
    - a. Skew rate (nominal velocity of propagation delay) between any twisted pair in a combination of 4-twisted pair conductors grouped in the same cable, shall not exceed 35-nano seconds between any wire pair contained in the conductor group, and as required by the cable Category rating, over a cable length of 328-feet (100 meters), for all frequencies up to the cable maximum frequency rating.
    - b. Nominal velocity of propagation, exceeding 70% of the speed of light.
  13. Large capacity feeder cables and trunking-cables
    - a. Copper wire cables with more than 24-twisted pairs of conductors shall be constructed with 25-pair binder groups of conductors. The cable binder groups shall be enclosed in colored binders and assembled to form a single cable. The twisted pair/binder groups shall be enclosed with multi-layer dielectric protective sheaths underneath a cable jacket enclosing the entire cable assembly. A corrugated metal 100% shield shall be provided under the cable jacket enclosing all conductors.
    - b. Cables shall be wet location rated and listed for installation in conduit, where the conduit is in a wet environment and/or high-temperature environment, including:
      - Underground conduit.
      - Inside manholes and pull boxes.
      - Outdoor conduit exposed to weather and/or sunlight.
    - c. ANSI/TIA/EIA Category rating of cable assembly shall be Category-5E, trunking-cable.
- B. Category-5E Computer/Data Enhanced Cables – UTP (trunking-cable)
1. Category-5E cables shall be tested and shall pass ANSI/TIA/EIA test recommendations for Category-5E.

2. Operational characteristics:
  - a. Wire size 24AWG solid copper (24AWG stranded copper for portable patch cables)
  - b. Quantity of twisted pairs As indicated but in no case less than 4-twisted pairs
  - c. Impedance 100 OHM  $\pm$  15%, 3-100MHz
  - d. Maximum Signal Attenuation Per 300 feet (100 meters)
    - 6.3dB @ 1MHz
    - 13dB @ 4MHz
    - 18dB @ 8MHz
    - 20dB @ 10MHz
    - 25dB @ 16MHz
    - 28dB @ 20MHz
    - 32dB @ 25MHz
    - 36dB @ 31.25MHz
    - 52dB @ 62.5MHz
    - 67dB @ 100MHz
  - e. Mutual Maximum Capacitance of Any Pair 14pf/feet
  - f. Worst Pair "NEXT" Loss Per/328-feet (100 meters)
    - 62dB @ 1Mhz
    - 53dB @ 4Mhz
    - 48dB @ 8Mhz
    - 47dB @ 10Mhz
    - 44dB @ 16Mhz
    - 42dB @ 20Mhz
    - 41dB @ 25Mhz
    - 40dB @ 31.25Mhz
    - 35dB @ 62.5Mhz
    - 32dB @ 100Mhz

3. ScTP, all the wires in the cable shall be enclosed in a common, 100% metallic foil shield with copper "drain" wire, shield and drain wire located under the cable jacket.

C. Category-6 Computer/Data Enhanced Cables – [ScTP] [UTP]

1. Category-6 cables shall be tested and shall pass the ANSI/TIA/EIA test recommendations for Category-6.
2. Operation Characteristics:
  - a. Wire size 23AWG solid copper (23AWG stranded copper for portable patch cables)
  - b. Quantity of twisted pairs As indicated but in no case less than 4-twisted pairs
  - c. Impedance 100 OHM  $\pm$  15%, 1-500Mhz
  - d. Maximum Signal Attenuation Per 328-feet (100 meters)
    - 2.1dB @ 1Mhz
    - 3.8dB @ 4Mhz
    - 5.9dB @ 10Mhz
    - 7.5dB @ 16Mhz
    - 8.4dB @ 20Mhz
    - 10.5dB @ 31.25Mhz
    - 15.0dB @ 62.5Mhz

19.1dB @ 100Mhz  
27.6dB @ 200Mhz  
31.1dB @ 250Mhz  
34.3dB @ 300Mhz  
40.1dB @ 400Mhz  
45.3dB @ 500Mhz

- e. Mutual Maximum Capacitance of Any Pair 4.4nF/100m
- f. Worst Pair "NEXT" Loss Per/328-feet (100 meters)
  - 67.0dB @ 1Mhz
  - 67.0dB @ 4Mhz
  - 67.0dB @ 10Mhz
  - 67.0dB @ 16Mhz
  - 67.0dB @ 20Mhz
  - 67.0dB @ 31.25Mhz
  - 65.6dB @ 62.5Mhz
  - 42.3dB @ 100Mhz
  - 58.0dB @ 200Mhz
  - 56.5dB @ 250Mhz
  - 55.3dB @ 300Mhz
  - 53.5dB @ 400Mhz
  - 52.0dB @ 500Mhz

- 3. ScTP, all the wires in the cable shall be enclosed in a common, 100% metallic foil shield with copper "drain" wire, shield and drain wire located under the cable jacket.

### 2.03 COPPER WIRE CABLES (COAXIAL)

#### A. General

- 1. An overall non-conductive jacket shall encase the copper wires and shielding.
- 2. Cables shall be UL listed, complying with NEC National Electrical Code, National Fire Protection Agency and NFPA Requirements for each installation location shown. ETL tested and certified to comply with or exceed Specified Requirements. In addition to the UL Listing Requirements for Copper wire Cables twisted pair, coaxial cable shall additionally be UL listed and labeled for each install location.
  - a. NEC - CATVP (Plenum type locations and locations where not continuously enclosed inside conduit).
  - b. NEC - CATVR (Vertical riser type locations).
  - c. NEC - CATV (Locations where continuously enclosed inside conduit).
  - d. ANSI/TIA/EIA-568C; including related Standards, Amendments and TSB.
- 3. Electronic network systems infrastructure cables that are not installed inside conduit raceways. Electronic network systems infrastructure cables that are installed in concealed spaces including plenums and non-plenums; access floors, ceiling spaces, walls, floor, etc., and/or installed without continuous raceways. The cable insulation and jacket shall be listed and labeled "Limited Combustible Cable" (LC or LCC) and shall comply with the latest published revision of all of the following Additional Requirements.
  - a. Limited combustible "FHC-25/50" per UL-2424.



- b. NEC/CEC; CMP, additional listing/labeling where the install location is an environmental air plenum, "FHC-25/50-CMP".
  - c. NFPA-90A; ceiling cavity plenums, wall cavity spaces and raised floor cavity plenums, limited-combustible.
  - d. NFPA-5000; defines combustible material including wire and cable.
  - e. NFPA-75 computer rooms and electronic equipment room.
  - f. NFPA-13; spaces containing "limited combustible loading".
4. Cables shall qualify as 100% recyclable materials disposal, RoHS Regulation complaint.
  5. The outer cable jacket shall be imprinted with date, Manufacturer's model and catalog number and Agency (AHJ) listing identification.
  6. Cables installed in air plenums, air-handling spaces and cables installed without raceway or conduit shall be UL listed and labeled for installation in air plenums.
  7. Cables installed in raceways or conduits below grade, through in-grade manholes and pullboxes shall be rated for installation in water/wet locations.
  8. Copper wire Electronic Network Systems Infrastructure cable shall be product of the same Manufacturer, including portable patch cables.
- B. RG6 Coaxial Cables
1. ANSI/TIA/EIA-568C cables. RG-6, Quad-Shield cables, shall be tested and shall pass ANSI/TIA/EIA test recommendations for the cable type. Rated for both analog and digital RF signal circuits.
  2. Operational characteristics:
    - a. Single center conductor size 18AWG stranded or solid bare copper.
    - b. Velocity of propagation not less than 82%.
    - c. Impedance 75-OHM.
    - d. Maximum signal attenuation per 100-feet.
 

|                          |                       |
|--------------------------|-----------------------|
| ▪ Baseband Video         | 0.26dB @ 1MHz         |
| ▪ Upstream Digital Cable | 0.76dB @ 10MHz        |
| ▪ TV ch. 2               | 1.46dB @ 50MHz        |
| ▪ FM Radio               | 2.05dB @ 100MHz       |
| ▪ TV Ch. 12              | 2.83dB @ 200MHz       |
| ▪ CATV Ch. 54            | 4.05dB @ 400MHz       |
| ▪ CATV Ch. 109           | 5.60dB @ 700MHz       |
| ▪ CATV Ch. 142           | 6.23dB @ 900MHz       |
| ▪ DBS                    | 6.59dB @ 1000MHz      |
| ▪ DBS                    | 7.50dB @ 1200MHz      |
| ▪ DBS                    | 8.04dB @ 1450MHz      |
| ▪ PCS Cell Phones        | 8.50dB @ 1800MHz      |
| ▪ Wireless Cable         | 9.00dB @ 2200MHz      |
| ▪ High Frequency         | 13.7dB @ 3000-4500MHz |
    - e. Capacitance 16.2 pf/feet
    - f. ASTM-D4566, 5 thru 4500MHz Return Loss Headroom (RLH) not less than 20dB.
    - g. 100% sweep tested 5MHz thru 4500MHz

3. Four alternating layers of metal foil shielding and brass braiding shielding, 100% metallic shielding below the jacket and symmetrically enclosing the individual layers of dielectric insulation surrounding the center conductors.

## **2.04 FIBER OPTIC FIBER SPLICES**

### **A. General**

1. Fiber optic cable splices shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements, ANSI/TIA/EIA-568C including related Standards, Amendments and TSB.
2. Fiber optic splices shall be the product of the same Manufacturer.

### **B. Mechanical Splice**

1. Mechanically splice each fiber with a splice suitable for use with the type of fiber optic fibers. Re-enterable and reusable splice. Splice shall be recommended as compatible with the optical fibers by the Manufacturer. Splice shall not require the use of adhesives. Splice shall provide integral strain relief.
2. Performance Requirements after installation:
  - a. Operating temperature range minus 20-degrees centigrade through plus 60-degrees centigrade.
  - b. Loss variation over temperature range, 0.05dB or less at specified wave lengths.
  - c. Insertion loss, 0.3dB or less at specified cable wave lengths.
  - d. Reflection (return loss), -40dB at specified cable wavelengths.

### **C. Fusion Splicing**

1. Fusion splicing shall be performed with equipment providing the following features:
  - a. Cleaving and cleaning optical fiber.
  - b. Integral splice optimization verification system with local injection and detection.
  - c. Projection screen optics and fiber core alignment system.
  - d. Fiber cleaning/stripping.
  - e. Cleaning fiber ends and fusing of fiber together with an electric arc.
2. Fusion splice insertion loss as measured at the completion of the splice shall be less than 0.1dB at specified cable wave lengths.

## **2.05 FIBER OPTIC FIBER CONNECTORS AND INTERCONNECTION COUPLERS**

### **A. General**

1. The connectors and interconnection couplers shall be compatible, maintain the same Performance Category rating and be compatible with the corresponding fiber optic cable type attached to the connectors.
2. Fiber optic cable connectors and interconnection couplers shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements. Connectors and couplers shall comply with ANSI/TIA/EIA-568C, related Standards, Amendments, TSB, and TIA/EIA-Fiber Optic Connector Intermateability Standard (FOCIS) documentation.
3. Fiber optic connectors and couplers shall be the product of the same Manufacturer.

4. Shall be UL listed and comply with UL94V-0.
  5. Color code connectors for fiber optic cables to match the respective fiber optic strand/jacket color.
- B. Fiber Optic Fiber Connectors
1. LC – Small Form Factor (SFF) termination connector
    - a. Ceramic oxide 1.25mm ferrule. Mechanical durability not less than 500-mating cycles. Insertion loss of mated connector shall be less than 0.3dB at specified wavelengths.
    - b. Strain relief boot, long boot type unless indicated otherwise, short or angled boot type to match the connector installation application. Provide duct cover cap for each connector.
    - c. Locking type to automatically align mating fibers in the fiber cable and prevent accidental rotation and pullout.
  2. ST type bayonet termination connector
    - a. Ceramic aluminum oxide 2.5mm ferrule, multi-cure ultra violet or heat cured epoxy bonded, for multimode or single mode to match cable fiber. Insertion loss of each mated connector shall be less than 0.3dB at specified wavelengths.
    - b. Strain relief boot, long boot type unless indicated otherwise, short or angled boot type to match the connector installation application. Provide dust cover cap for each connector.
    - c. Locking type, to automatically align fiber cable and prevent accidental pullout.
  3. SC – Square/Subscriber termination connector
    - a. Ceramic oxide 2.5mm ferrule.  
Insertion loss of mated connectors shall be less than 0.3dB at specified wavelength.
    - b. Strain relief boot, long boot type unless indicated otherwise, short or angled boot type to match connector installation application. Provide dust cover cap for each connector.
    - c. Push-pull snap and lock type to automatically align mating fibers in the fiber cable and prevent accidental rotation and pullout.
  4. "FSD" fixed shroud duplex type termination connector
- C. FIBER OPTIC FIBER INTERCONNECTION COUPLERS
1. Interconnection couplers shall be "like-to-like" compatible, and shall provide "plug-in" coupling of two fiber optic cable connectors terminated with fiber optic fibers front-to-rear "in-line" together. The coupler shall provide interlocking, automatic optical self-alignment of two mating fiber optic connectors.
  2. The centerline to centerline spacing of the interconnection couplers shall allow removal and insertion of portable patch cords, fiber cable connectors for both "single" and "duplex" type fiber adapter connectors without interfering with adjacent connectors.
  3. Patch panel mounted interconnections couplers shall be factory pre-mounted to a modular nominal 0.09-inch thick metal panel, couplers aligned and anchored on the plate.
    - a. The metal panel shall be predrilled for Standard EIA mounting in high-density 19-inch wide metal patch panel frames.

4. Interconnection couplers in workstation outlets shall be installed in outlet boxes with cover plates.
5. Provide removable dust caps for the front side of each coupler.

## **2.06 COPPER WIRE OUTLET CONNECTORS**

### **A. General**

1. Connectors shall comply with FCC part-68 Subpart F for gold plating.
2. Connectors shall be UL listed and shall comply with UL94V-0.
3. Provide a removable blank dust cover for each plug-in outlet insert. The dust cover shall protect the insert from contamination until a workstation or patch cord is "plugged" into the outlet.
4. Copper wire outlet connectors shall be color coded to distinguish telephone/ voice separately from computer/data. The outlet cover plate shall be engraved to identify telephone/voice, computer/data and other infrastructure outlets separately.
5. Copper wire outlet connectors shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements, ANSI/TIA/EIA-568C including related Standards, Amendments and TSB.
6. Copper wire outlet connectors shall be the product of the same Manufacturer.

### **B. Universal Outlet Connector (for twisted pair Copper Wire Premise/Workstation Wiring and copper wire patch panels).**

#### **1. General**

- a. Connections for twisted pairs copper conductors shall provide a universal outlet connector between the building premise copper wire, and plug-in workstation locations. Patch panel/ equipment plug-in connectors. The connector components shall assemble with "snap-in" spring loaded retainers to prevent dislocation during insertion or removal of external plug-in devices.
- b. The contacts shall be gold plated with a 250 insertion/withdrawal cycle rating.
- c. Unless specifically noted otherwise the universal outlet connector shall comply with ANSI/TIA/ EIA-568C; related Standards, Amendments and TSB.
- d. Operational characteristics shall match or exceed and shall be compatible with the respective twisted pair's cable.
- e. A metal ground shield with EMI/RFI metal ground clip shall be provided where shielded cable is connected to the universal outlet connector for each universal outlet connector assembly.
- f. Each universal outlet connector shall consist of three major components.
  - 1) Universal edge connector assembly.
  - 2) Plug-in adapter inserts.
  - 3) Connector housing.
- g. Provide snap-in blank removable insert covers for connector installed without plug-in adapter inserts.

#### **2. Universal edge connector:**

- a. Insulated assembly shall connect to the premise copper wire. The connectors shall be multiple plug type connector contacts, one contact (total of eight contacts) for

- each individual premise wire connection interconnected to the individual wire terminations.
- b. Connector shall provide insertion of individual insulated copper wire, gas tight, 110-style punch down/displacement termination, for 22-26 AWG insulated premise wire.
  - c. The edge connector assembly shall provide termination of eight separate wire conductors, twisted or untwisted pairs, solid or stranded, shielded or unshielded, with color codes and numbered identification of each contact. Integral cable/conductor strain relief to prevent pullout of terminated premise wire conductors.
3. Plug-in adapter inserts:
- a. Plug-in adapter inserts shall be internally factory connected to the universal edge connector assembly to adapt the universal connector to the specific outlet type configuration (i.e. "RJ" style computer/data, telephone/voice, (multimedia) modular jacks, etc.).
  - b. Inserts shall be certified for shielded or unshielded wire, to match premise wire type connected to the universal edge connector.
  - c. Inserts shall provide correct pin-to-pin connections, electrical and mechanical matching characteristics for the specific equipment connected to the respective outlet.
  - d. Inserts for different infrastructures shall be color coded with different colors from each other, for system identifications.
  - e. Plug-in adapter insert type:
    - 1) Computer/data network systems:
      - a) ANSI/TIA/EIA-568C, female modular jack 8-position/contact "RJ-45" style.
    - 2) Telephone/intercom voice systems:
      - a) ANSI/TIA/EIA-568C female modular jack 8-position/contact RJ-45" style.
    - 3) Multimedia audio/video tv (baseband only):
      - a) ANSI/TIA/EIA-568C female modular jack 8-position/contact RJ-45 style.
      - b) Each multimedia audio/video outlet location provides a Balun to match the circuit impedance of the premise wiring to the multimedia outlet signal type.
    - 4) Intrusion detection/access control systems:
      - a) ANSI/TIA/EIA-568C female modular jack 8-position/contact RJ-45 style.
      - b) Each intrusion detection system outlet location provides a Balun to match the circuit impedance of the premise wiring to the intrusion system outlet signal type.
4. Connector housing:
- a. Connector housing shall contain the universal edge connector assembly and the plug-in adapter inserts in a rigid assembly. Connector housing shall provide integral cable strain relief for the premise wiring connection.
  - b. The connector housing shall mount to a metal panel, metal device cover plate or plastic device cover plate with spring loaded snap-in retainers. Nominal depth of connector housing behind the mounting panel and/or device cover plate shall not exceed 1.625-inch including premise wiring termination depth Requirements.

C. Coaxial Cable Connectors

1. General
  - a. BNC type connectors, for coaxial cable premise/workstation wiring and coaxial cable patch panel equipment.
  - b. Unless noted otherwise, the BNC connectors shall comply with ANSI/TIA/EIA-568C and related Standards, Addendums and TSB.
  - c. Brass body and male contact. Beryllium copper or bronze female contact. Bayonet coupling with threaded or cam-locking mating connection.
2. Operational characteristics shall match or exceed and shall be compatible with the respective coaxial cable. 75-OHM, operational frequency range 0-4500MHz.

**2.07 FIBER OPTIC FIBER DISTRIBUTION ENCLOSURES**

A. General

1. Fiber optic fiber distribution enclosures shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements, ANSI/TIA/EIA-568C including related Standards, Amendments and TSB.
2. Fiber optic fiber distribution enclosures shall be the product of the same Manufacturer.

B. Equipment Rack Mount Fiber Optic Termination Distribution Enclosure - RTDE

1. The RTDE enclosure shall mount in an EIA Standard 19-inch wide enclosed or open frame equipment rack assembly. The RTDE enclosure shall be metal, painted finish, Manufacturers standard color.
2. The RTDE shall provide the following self-contained functions internal to the RTDE assembly.
  - a. Fiber cable termination.
  - b. Fiber cable "pig-tail" splicing.
  - c. Fiber cable patch panel.
  - d. Fiber cable management, training and strain relief.
  - e. Individual fiber and patching port identification numbers, color-coding of incoming trunk and out-going distribution fiber ports.
  - f. Plug-in fiber optic interconnection couplers for port to port patching with portable fiber optic patch cords.
3. Fiber splice drawers:
  - a. Horizontal sliding metal drawers adjustable to approximately 30-degree angle when fully open, and removable for easy access. Each drawer shall contain two fiber optic splice trays with tray holders.
  - b. Drawers shall stack vertically one above the other in the RTDE and allow sufficient slack in all fiber cables for removal of the drawer and splice trays.
  - c. Provide one sliding drawer and two splice tray assemblies for each group (24-individual fibers or fewer fibers per group) of fiber optic fibers terminated in the equipment rack, but in no case provide not fewer than two sliding drawers with splice tray assemblies in each RTDE.

4. Fiber cable patch panel
  - a. Metal panel shall provide a patch port for each fiber consisting of metal panel mounted fiber optic interconnection couplers for each fiber optic fiber indicated to be terminated at the RTDE.
  - b. The fiber optic fiber interconnection coupler shall be provided to match and be compatible with the fiber cable connectors. Quantity shall match quantity of terminated fibers, unless indicated otherwise on the equipment rack schedules.
  - c. Nominal panel thickness 0.09 inches.
  - d. Provide a minimum of sixteen unused spaces for additional couplers in the patch panel.

5. Nominal height of the RTDE shall not be exceeded, as follows:

| <u>Quantity of Patch Ports</u> | <u>Quantity of Splice Drawers</u> | <u>Nominal Height</u> |
|--------------------------------|-----------------------------------|-----------------------|
| 24                             | 2                                 | 11-inches             |
| 48                             | 2                                 | 11-inches             |
| 72                             | 3                                 | 14-inches             |
| 144                            | 6                                 | 28-inches             |

C. Equipment Rack Mount Fiber Optic, Splice only (for use only where fiber patch panel is not required) enclosure - RMSE

1. The RMSE enclosure shall mount in an EIA standard 19 inch wide enclosed or open frame rack assembly. The enclosure shall be metal, painted finish, Manufacturer's standard color.
2. The RMSE shall provide the following self-contained functions internal to the RMSE assembly:
  - a. Fiber cable splicing for "thru splicing" of fiber optic cables where the cables do not terminate in the equipment rack.
  - b. Fiber cable management, training and strain relief.
3. Fiber splice drawers
  - a. Horizontal sliding metal drawers adjustable to approximately 30-degree angle when fully open and removable for easy access. Each drawer shall contain two fiber optic splice trays with splice tray holders.
  - b. Drawers shall stack vertically one above the other in the RMSE and allow sufficient slack in all fiber cables for removal of the drawers and splice trays.
  - c. Provide one sliding drawer and two fiber optic splice tray assemblies for each group (24-individual fibers or fewer fibers per group) for fibers optic fiber routed through but not terminated in the equipment rack, but in any condition provide not fewer than two sliding drawers with splice tray assemblies in each RMSE.

4. Nominal height of the RMSE shall not be exceeded, as follows:

| <u>Quantity of Thru Splices</u> | <u>Quantity of Splice Drawers</u> | <u>Nominal Height</u> |
|---------------------------------|-----------------------------------|-----------------------|
| 24                              | 2                                 | 4-inches              |
| 48                              | 2                                 | 4-inches              |
| 72                              | 4                                 | 8-inches              |
| 96                              | 4                                 | 8-inches              |

## 2.08 COPPER WIRE PATCH PANELS

### A. General

1. Copper wire patch panels shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements, ANSI/TIA/EIA-568C including related Standards, Amendments and TSB.
2. Copper wire patch panels shall be the product of the same Manufacturer.

### B. Equipment Rack Mounted Patch Panel

1. Standard EIA 19-inch wide metal panel, Manufacturers standard color. Prepunched for copper wire outlet connectors. Panel shall mount on an EIA standard 19 inch wide enclosed or open frame equipment rack assembly. Nominal 24-copper wire outlet connectors in a horizontal row, quantity of rows as required for total quantity of connectors. Provide not less than two spare empty rows for future copper wire outlet connectors.
2. The patch panel shall provide the following self-contained functions.
  - a. Copper wire cable termination including conductor/ shield termination and strain relief.
  - b. Plug-in copper wire outlet connectors for port to port patching with copper wire portable patch cords.
3. Patch panel height shall be based on the quantity of copper wire outlet connectors described plus the specified space for future outlets and shall not exceed the following dimension height:

| <u>Outlet Quantity</u> | <u>Nominal Patch Panel Height</u> |
|------------------------|-----------------------------------|
| 1-24                   | 3.5 inches                        |
| 25-48                  | 7 inches                          |
| 49-72                  | 10.5 inches                       |
| 73-96                  | 14 inches                         |

4. Horizontally mounted, cable support metal bracket shall be provided for each 24-outlet/connector groupings. The brackets shall be bolted to the equipment rack located at the backside of the patch panel; the brackets shall support and provide strain relief for each incoming copper wire cable connecting to the patch panel.
5. The copper wire connector installed in the patch panel shall be the same configuration, Manufacturer and type as the corresponding copper wire connector provided in the remote workstation outlet locations connecting to the respective patch panel outlet, unless indicated otherwise.
6. Each multimedia, audio/video/TV multimedia and intrusion detection/access control outlet. Provide a Balun, to match the circuit impedance of the premise wiring and to the outlet signal type.

## 2.09 TELEPHONE/VOICE TERMINAL BLOCKS

### A. General

1. Terminal blocks Type 110, shall consist of wiring blocks, connecting blocks, direct wire/patch cord cross connection and designation strips. Arrange in unitized, modular, vertical mounting sections, for telephone/voice.



2. Completely 100% front accessible for cross connections, terminating conductors, training, and fanning of cables. Rear access for any reason shall not be permitted.
3. Telephone/voice terminal blocks shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements. Telephone terminal blocks and connections performance shall comply with ANSI/TIA/EIA - 568C and related Standards, Addendums and TSB and shall comply with and be listed under UL 1863. Category rating shall match the cables connecting to the patch panel.
4. The telephone/voice terminal blocks shall provide cross connection of telephone/voice four pair premise copper wiring from telephone/voice handset outlets to multiple copper wire telephone/voice feeder cables and external free standing telephone equipment.
5. Each full height vertical section terminal block assembly shall terminate a minimum of 900 pairs (including specified spares for future construction phases) of telephone/voice conductors, plus associated cross connection wiring and patch cords in a nominal 20-inches wide by 90-inches high space. Provide multiple vertical sections of terminal block assemblies adjacent to each other, total quantity as required for quantity of telephone/voice conductor pairs and telephone/voice feeder cable pairs shown on the Drawings and Requirements, plus specified spares.
6. Each telephone/voice terminal block vertical section assembly shall provide 15% or 100 (whichever is the larger quantity) of spare unused conductor pair terminals for future telephone/voice connections.
7. Provide a common ground bus in each terminal block section with a minimum of six ground conductor termination positions, #10AWG through #6AWG.
8. Terminal blocks shall be the product of the same Manufacturer.

**B. Wiring Blocks**

1. One piece molded, die-electric thermoplastic blocks. The wiring block shall support and secure all the components of the terminal block assembly, and provide cable/conductor training and organization.
2. Fire retardant complying with UL 94V-0.
3. Standoff type support legs for mounting to backboard with pre-drilled anchor holes.
4. Non-conductive electrically quiet front assembly.
5. Horizontal index strip rows, for termination of not less than 25-conductor pairs on each row. Color coded and marked in groups of four pairs or five pairs to match connecting cables.
6. Removable retainers at the ends of each horizontal connecting block index strip row, shall support cross connect wires at corner turns.
7. Distribution rings shall retain cross connect wire horizontal routing between terminations.
8. A full width, horizontal trough between each 100 pair wiring block shall provide a path for patch cord training and retention.

### C. Connecting Blocks

1. Connecting blocks shall provide gas tight conductor electrical connections with conductor insulation displacement punch down slots, for insertion onto the telephone/voice wiring block index strips.
2. Connecting blocks shall electrically connect one-to-one between each conductor terminated at the wiring block index strips, and each cross connect/patch cord conductor terminated/connected to the opposite front side of the connecting block.
3. Both sides of the connecting blocks shall terminate telephone/voice UTP 22-26AWG stranded or solid copper wire individually insulated conductors. The front side of the connecting blocks shall also provide "plug-in" connections for portable patch cords, 110 style "plug-in" connectors.
4. Connection blocks shall be 4-pair insulated copper conductor type.
5. Provide insulated, removable termination caps for each connector block.
6. Connector blocks shall be marked to indicate tip and ring conductors and to indicate polarization.

### D. Designation Strips

1. Designation strips shall provide retention of interchangeable labels. The labels shall show circuit identification of each terminated conductor pair.
2. The designation strips shall mount on the center and outside positions of the wiring block.

### E. Telephone/Voice Cross Connection

1. The cross circuit connection between incoming and outgoing feeder cables and telephone voice outlet wiring shall be provided in the terminal block assembly.
2. The cross connection wiring shall terminate incoming and outgoing circuit conductors between respective connecting blocks.
  - a. Direct connect cross connection shall provide internally wired one-to-one conductor twisted pair cross connection. Provide cross connection of each 4-pair telephone/voice outlet cable to corresponding 4-pairs of the telephone/voice feeder cable and cross connection of feeder to feeder cables, as applicable.
  - b. Patch panel cross connect, 110-terminal connector style, plug-in. Provide two twisted pair, 110-connector type portable patch cords.
  - c. Prewired 50 pin-Amphenol connectors:
    - 1) Provide factory prewired 50-pin Amphenol connectors for connection from telephone/voice terminal blocks to the telephone switch equipment and Telephone Utility Company outside telephone service lines.
    - 2) Provide 50-pair ANSI/TIA/EIA-568C and related Standards, Addendums and TSB cables, connected to 50-pin Amphenol connectors at one end (telephone equipment connection) and connected to the respective telephone/voice terminal wiring blocks at the other end.
    - 3) The 50 pin Amphenol connectors shall group together and be positioned at the top of the respective terminal block section near the ceiling.
    - 4) The pin-to-pin conductor assignments shall conform to the Telephone Switch Manufacturer's Requirements.

- 5) The Amphenol connector/cable assemblies shall connect to and extend the telephone/voice outlet premise wiring from telephone/ voice terminal block to the telephone switch equipment. The Amphenol connector/cable assembly shall connect to and extend the Telephone Utility Company outside telephone service lines to the telephone switch equipment.
- d. Prewired "RJ" style modular jacks
  - 1) Provide factory prewired eight position/contact plug-in "RJ" style jacks for patch panel portable patch cord cross connects, located on the front side of the terminal blocks.
  - 2) The pin-to-pin conductor assignments shall conform to the Telephone Switch Manufacturer's Requirements.

## 2.10 EQUIPMENT RACK

### A. General

1. An equipment grounding bus, nominal 19-inches long, UL labeled as a ground terminal bus, shall be provided on each equipment rack. The ground bus shall be bolted to the rack main metal frame member with 1-inch standoff non-insulating bolts. Provide a minimum of ten drilled and taped bolt holes in the ground bus with ground lug bolts, for connection of equipment grounding conductors to the ground bus, size to accept ground conductors #14-#4AWG.
2. Vertically mounted, cable management metal rings (aluminum or stainless steel) shall be provided full height, continuously along the front and rear of each vertical rail of the equipment rack. The rings shall be bolted to the equipment rack. The rings shall train and dress portable patch cords connecting between outlet connectors located in the equipment rack or in adjacent equipment racks.
3. Provide horizontal cable management panels with multiple cable training rings on each panel (not less than five rings for each panel). Management panels (for up to 24-outlet grouping) nominal 19-inches wide by 1.75-inches high by 3-inches deep and/or (for up to 48-outlet groupings) 3.5-inches high by 3 inches deep, for EIA rack installation. Rings shall provide horizontal routing and support by grouping portable patch cords connecting between patch ports in the same equipment rack or adjacent racks. Patch cords shall be grouped and bundled with "Velcro" tie wraps and shall not overlap patch fields or rack mounted equipment.

The cable management panels shall be installed on both the front and rear of the equipment racks mounted both above and below horizontally between groups of patch ports as follows:

- a. One cable management panel (front and rear of rack) for each group of forty-eight or less copper wire outlets for patch ports.
- b. One cable management panel (front and rear of rack) for each group of 48-fiber optic outlet patch ports.
4. The entire rack assembly including any support arms shall comply with Seismic Earthquake Requirements for install location Structural Standards.
  - a. The assembly shall provide support for the weight of the equipment installed on the rack, but in no case less than 500-pounds of equipment, plus the weight of the rack

and connecting cables. A 2.0 time's safety factor shall be included in the equipment rack assembly structural design.

5. Provide plug strip Surge Protection Device with RF Suppressor (SPD) and Power Distribution Units (PDU). Horizontal strip, mounted in each equipment rack. Each unit shall contain not less than six "plug-in" on the rear of the SPD and not less than two plug-in on the front of the SPD protected outlet plugs.
    - a. Provide two SPD/PDU units in each equipment rack, to supply "dual-corded" equipment.
  6. Provide pre-drilled mounting holes the entire length of equipment vertical mounting frames, EIA-310D-19 inch (nominal) wide standard spacing for indicated equipment. Racks shall provide 17.75-inches (nominal) equipment horizontal mounting space between vertical rails.
  7. Provide all floor standing equipment racks with wall bracket support arms extending from the stationary portion of the rack to adjacent wall. Provide "dual-rail arm" cable "runway tray", horizontally from each equipment rack, to the wall directly behind the equipment rack
    - a. The tray shall extend from and bolt to the top of the equipment rack "fixed" top rail.
    - b. The tray side rail arms shall be a minimum of 6-inches deep, with "ladder" type rungs spanning horizontally between the side rail arms. The rail arms shall be parallel with each other. The rail-to-rail arm spacing shall be the same as the equipment rack width.
    - c. The rungs shall be spaced not more than 6-inches on center between the side rails, along the length of the side rail arms. The rungs shall have a minimum cable-bearing surface of not less than 0.75-inches, lengthwise along the tray.
    - d. The runway tray shall support a minimum of 200 pounds per linear foot live conductor/cable loading, with not more than 0.25-inches deflection at mid-span.
    - e. Provide a continuous horizontal support "C" channel along the wall behind the equipment racks and bolt the dual-rail arm cable runway tray to the channel at the wall. The channel elevation on the wall above the finish floor shall support the runway tray horizontally ( $\pm 0.2$ -inches), from the equipment rack to the wall.
    - f. Equipment racks shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements, ANSI/TIA/EIA-568C including related Standards, Amendments and TSB.
    - g. The wall mounted horizontal support channel shall be securely through bolt to wall structural member, a minimum of 16-inches on center. The horizontal support channel shall extend a minimum of 6-inches past each side of the runway tray. Support channels as manufactured by Unistrut-P1001C Series; or B-Line; or Kindorf.
  8. Provide a copper ground – bus for equipment bonding, in each equipment rack.
  9. Equipment racks shall be Manufacturer's standard rust inhibitor primer. Manufacturer's standard color finish paint over primer, unless noted otherwise.
- B. Swing Gate Open Equipment Rack Style:
1. Combination wall and floor mounted rack frame nominal 78-inches of usable equipment vertical space for mounting equipment into the rack. The equipment mounting portion of the rack shall be a hinged gate frame assembly. The rack shall provide access to the

rear of the installed equipment, the wall behind the rack assembly and wall mounted terminal blocks, when hinged open.

2. The gate assembly shall hinge open not less than 90 degrees from the closed (normal position) on a fixed frame combination floor/wall mounted support structure. A positive latching mechanism shall lock the gate in the fully open and fully closed positions. The rack construction shall allow opening the swing gate, with the installed equipment depth, without obstruction. The fixed stationary portion of the swing gate rack assembly shall be supported from both the fixed floor bracket and wall located behind the rack with adjustable length "dual rail arm" wall brackets. The arms shall provide field adjustment (approximately 24-inches) of the equipment rack spacing from the wall behind the rack. Provide a minimum of two support arms for each swing gate equipment rack.
  3. The rack assembly shall be constructed of extruded metal; aluminum gold irradiates finish, or hot dip galvanized steel. Bolted or welded assembly. Hardware shall be stainless steel.
  4. Provide steel caster rolling wheel support on the bottom rail of the moveable swing gate frame. The wheel shall provide additional support, but not the main support, of the moving gate assembly and rack mounted equipment along the floor travel "outside arc" of the gate in the open or closed position. The vertical height of the wheel assembly shall be adjustable  $\pm 3$  inches.
  5. Swing gate equipment racks as manufactured by B-Line; or Saunders; or Hendry.
- C. Floor Standing Equipment Rack Fully Metal Enclosed Style:
1. Floor mounted self-supporting rack, nominal 80-inches high by 24-inches deep, by 24-inches wide. Internal bolted or welded hot dip galvanized steel or gold irradiate finish aluminum, support frame. Metal enclosed with screw attached removable metal panels. Manufacturer's standard finish color.
  2. The front and rear of the rack shall be a full height hinged door, opening not less than 90 degrees from the closed position. The doors shall be readily removable with positive latching mechanism to lock to the doors in fully open or fully closed positions. Doors shall be pad-lockable. Rack shall provide a minimum of 4-inches of clear space between front door and internal mounting face for rack mounted equipment. Smoke/grey impact resistant, tamper resistant see-through windows in the doors, front and rear. Hardware shall be stainless steel.
  3. Provide six 120-volt 60Hz AC motor direct drive air ventilation, "muffin" style, nominal 4-inches square, exhaust air fans. Flush mount fans in the top of each equipment rack. The fans shall be low speed, low noise type with wire guards to prevent accidental contact with the fan blades. The fan motor shall be high impedance, self-protecting type motors. Provide "SO" cord with plug caps to connect from the fans to the 120 volt plug-strip in the equipment rack.
  4. Provide cooling air intake louver with a removable 19-inches wide air filter and air filter holder, mounted in the bottom of the rack front nominal 6-inches high.
  5. Floor standing metal enclosed equipment racks as manufactured by Stantron; or BUD; or equal.

- D. Fixed Position Floor Standing Open Frame Equipment Racks:
1. Floor mounted self-supporting rack, nominal 78-inches of usable mounting frame height for equipment.
  2. Bolted or welded hot dip galvanized steel or gold irradiate finish aluminum support frame. Hardware shall be stainless steel.
  3. Open frame rack construction, fixed, non-swing gate.
    - a. "Two-post" style for equipment racks not designated as containing UPS equipment nor server equipment.
    - b. "Four-post" style for equipment racks designated as containing UPS equipment and/or server equipment.
  4. Open frame equipment racks as manufactured by B-Line; or Saunders; or Hendry.
- E. Floor Standing Modular Frame Equipment Racks
1. Provide a modular frame equipment rack, bolt together modular rack system with all accessories for a completely assembled equipment rack unit. The rack system, when configured for specific equipment, shall support and organize network servers, keyboards, printers, tape drive units, RAID units, CRT's, UPS units, telephone switching equipment, desk top work spaces, etc.
  2. Nominal overall dimensions 31-inches deep by 72-inches wide by 84-inches high. Left/right or right/left orientation as indicated on Drawings. Minimum weight capacity of the entire rack assembly shall be 1500 pounds.
  3. Manufacturer's standard finish painting, crème white color for metal surfaces. Horizontal flat support surfaces shall be post-formed, laminate top finish, white color.
  4. "8L-01/8L-02" vertical support upright assemblies; shall be slotted the full height to "hook-on", lock in and support adjustable height (in 1-inch increments), modular components, with integral floor support "feet". Open back frame - "LF31". Minimum of three vertical support and open back frames in each complete assembly.
  5. Provide vertical (on upright supports) and horizontal (on modular "hook-on" components) wire management raceways integral to the assembly.
  6. Network server configuration - equipment rack unit:
    - a. "LE28" computer tower "roll-out" horizontal floor shelf; nominal 47-inches wide by 24-inches deep. Shelf shall pull out on "ball-bearing" rails, with 23-inch extension for access to computers. Provide one tower shelf for rack unit. Minimum weight capacity 750 pounds. Mount at floor.
    - b. "LE25"-computer tower horizontal shelf with  $\pm 12$  inch end panels and two shelf support brackets; nominal 47-inches wide by 22-inches deep, fixed mounted. Provide one tower shelf for rack unit. Minimum weight capacity 500 pounds. Mounting height  $\pm 30$ -inches.
    - c. "LB32" horizontal work surface; nominal 24-inches wide by 27-inches deep. Provide one work surface assembly for each rack unit. Minimum weight capacity 300 pounds. Install on left or right side of rack as shown on Drawings. Mounting height  $\pm 28$ -inches.

- d. LF10/LF11/W162 - General equipment shelf; nominal 72-inches wide by 15-inches high by 16.7 inches deep, with two horizontal shelf surfaces, full width of rack,  $\pm 10$ -inches nominal vertical height between shelves and five vertical shelf dividers. Minimum weight capacity 300 pounds. Provide one general equipment shelf assembly for each rack unit. Mount at top of rack.
  - e. "LA-09" - Keyboard platform. Retractable keyboard platform with auxiliary mouse pad and up-down 15 degree adjustable tilt and adjustable 360 degree swivel. Nominal 23-inches wide by 11 inches deep. Provide three keyboard platforms for each rack unit. Install below, upper tower computer shelf and work surface.
- F. Plug Strip Surge Protection Device (SPD).
- 1. General
    - a. Self-contained unit combining plug-in receptacle strip and SPD. Rated 20-amp, nominal 120-volt +10%, 60Hz, AC, 2400 watts full continuous load. Internal 20-amp resettable overload protection circuit breaker. Red illuminated on-off switch. 9-foot, 12AWG three-conductor grounded, high abuse heavy duty jacketed AC, line cord with NEMA 5-20P cap.
    - b. Multi-outlet receptacles, suitable for use with the following types of plug in loads; data processing equipment, audio/video equipment, test instruments, medical equipment, photo graphic equipment and "switching type" power supplies.
    - c. Protected 120-volt outlets shall be NEMA 5-15R 15-amp, or 20-amp NEMA 5-20R AC 60Hz receptacles, as applicable for connected equipment loads. Provide not less than eight protected outlet plugs on each unit. Each individual or group of two receptacles (duplex) shall be connected to separate protected load isolated filter banks.
    - d. Each duplex shall be isolated from the other output receptacles, minimum isolation of 25dB at 1MHz line to line, line to neutral, line to ground and neutral to ground.
    - e. Non-blocking plug-in locations/orientation, for plug-in self-contained "power-brick", equipment power supplies.
    - f. As manufactured by Liebert; or TRIPP LITE.
  - 2. Operation
 

Self-contained RFI and EMF shielded housing with mounting slots for temporary mounting of the unit. Protected outlet receptacles shall supply over current protected and filtered, electrical line voltage power to the connected equipment. Line noise RFI and EMI interference filtering suppression, surge protection device and spike protection shall occur in all three modes of operation line to ground, line to neutral and neutral to ground rated as follows:

    - a. 13,000 amp, 210 joules (watt-seconds) peak withstands capacity.
    - b. Transient response time less than 5-nano seconds.
    - c. 140-volt AC RMS initiate spikes suppression 330 volt maximum let through.
    - d. RFI and EMI Suppression-Provide spectrum analysis test dB attenuation reports showing RFI filtering over specified frequencies.
    - e. Diagnostic indicator lights located on the SPD housing shall provide alarm alert for each of the following conditions:
      - 1) Loss of AC power.

- 2) Damage, malfunction in the SPD suppression circuits.
- 3) Improper AC electrical outlet wiring.
- f. Standards Testing, Listing and Certification Compliance:
  - 1) IEEE 587 A and B compliance.
  - 2) UL 1449 surge suppressers.
  - 3) UL 1363 temporary power taps.
  - 4) UL 1283 electromagnetic interference filters.
- 3. Rack Mounted SPD
  - a. SPD units installed in equipment racks shall comply with all of the same Performance Requirements including as follows.
    - 1) EIA/TIA – Equipment rack horizontal mount style (19-inches or 24-inches as applicable).
    - 2) Minimum of two front mounted outlets and not less than six rear mounted outlets.
    - 3) Position in each equipment rack as directed by Owner’s Representative.
    - 4) Provide two SPD units in each equipment rack, for “dual-corded” network equipment.
- G. Power Distribution Unit (PDU)
  - 1. General
    - a. Self-contained unit combining main circuit breaker, multiple plug-in individual circuit breaker branch protection load receptacles, PDU metering status monitoring and network communication. All PDU components self-contained in a NEMA-1 metal enclosure.
    - b. Non-blocking plug-in locations oriented for plug-in self-contained “power-brick” equipment supplies.
    - c. Standards Testing
      - 1) UL 60950-1 Information Technology Equipment.
      - 2) CAN/CSA-C22.2 No.60950-1-03 Information Technology Equipment.
      - 3) FCC, Title 47, Part 15 Subpart B for Class B operation as defined by ANSI Standard C63.4.
      - 4) ROHS Complaint.
      - 5) ISTA Procedure 1A and 2A.
    - d. Provide two PDU units in each equipment rack, to supply two SPD units in each equipment rack.
    - e. Shall be a product of the same Manufacturer as the SPD unit. As manufactured by Liebert; or TRIPP LITE.
  - 2. System Description
    - a. Remote monitoring and/or control capabilities for power distribution at each load/ equipment rack level. For data/network equipment line voltage plug-in and SPD line voltage plug-in electrical distribution.
    - b. PDU shall meter and monitor electrical attributes of an individual Rack PDU, including real-time remote and local display of monitoring of aggregate and branch electrical parameters (status, thresholds, alarms) including voltage, ampere, and kW. Rack equipment PDU and Branch load monitoring and control.



- c. Self-contained metering and communications
    - 1) Local display ampere-meter demand load meter to monitor plug-in demand load and total PDU load.
    - 2) Digital Fast Ethernet LAN RJ-45 communications port for Ethernet SNMP and IP network monitoring of electrical status. Multi-user site-wide software license, compatible with PC-computer and IP-WEB HTTP protocols.
    - 3) Provide network array-interface for connection of multiple PDU units positioned in the same location.
  - d. Nine foot input power (heavy duty high abuse) cord with appropriate conductors and input NEMA plug-in connection. Provide input overload protection with Hydraulic-Magnetic main input circuit breaker. Provide load output NEMA plug-in branch connection with overload circuit breaker protection for each load receptacle.
  - e. Equipment rack mounting horizontal position form factor.
3. Electrical Power ratings shall be as follows and as additionally indicated on Drawings. Refer to Drawings for twist-lock versus straight-blade configurations.
    - a. Single main input circuit breaker 30 amp, 208/120 volt 3-phase 5-wire "WYE" grounded 60Hz AC.
    - b. Branch load circuit breakers with a single plug-in receptacles for each load circuit breaker. Balance loads on each circuit phase.
      - 1) Three 20 amp 1-pole circuit breaker and three NEMA 5-20R receptacles. Also provide matching caps.
      - 2) One 30-amp 2-pole circuit breaker and one NEMA 14-30R receptacle. Also provide matching cap.
      - 3) Additional circuits and receptacles as indicated on Drawings.
  4. Provide heavy duty high abuse flexible copper wire 300-volt insulated 15-foot long jacketed electrical cord. Connect from PDU to wall-outlet receptacle with same electrical rating as PDU. Rated for PDU voltages and amperes.
  5. PDU units installed in equipment racks shall comply with all of the same Performance Requirements including:
    - a. EIA/TIA – equipment rack horizontal mount style (19-inches or 24-inches) as applicable.
    - b. Position in each equipment rack as directed by Owner's Representative.
  6. Provide two Category-6A 4-pair UTP 15-foot long portable patch cable connects, PDU to respective network patch panel port.

## **2.12 WALL MOUNT FIBER OPTIC CABLE INTERFACE CABINET (WMIC)**

### **A. General**

1. Metal (14 gauge) enclosure, with full height hinged metal door. Door shall be pad-lockable. Nominal size 12-inches deep by 18-inches wide by 36-inches high. Enclosure shall mount directly on the wall.
2. WMIC shall be UL listed, complying with National Electrical Code, ETL Tested and Certified to comply with or exceed Specified Requirements, ANSI/TIA/EIA-568C including related Standards, Amendments and TSB.
3. Interface cabinets shall be the product of the same Manufacturer.

- B. The WMIC shall provide the following self-contained functions internal to the WMIC enclosure.
  - 1. Fiber cable splicing for "through splicing" of non-UL listed fiber optic cables, where the cables do not terminate in the building.
  - 2. Fiber cable management, training and strain relief.
  - 3. Transition from non-UL flame spread listed fiber optic cable, to UL flame spread listed fiber optic cables where the cables terminate in the building.
- C. Cable routing rings shall organize optic fibers in a 360 degree loop inside the WMIC housing and provide cable strain relief.
- D. Fiber Optic Splice Trays
  - 1. Provide fiber optic cable splice trays.
  - 2. Tray holders shall provide mounting and support for each splice tray.
  - 3. Provide two splice trays for each group (24 or less fibers per group) fiber optic fibers routed through the WMIC, but in no case provide not less than four splice trays in the WMIC.

### **2.13 UNIVERSAL SPLICE ENCLOSURES - USE**

- A. General
  - 1. The universal splice enclosure shall provide splicing for multiple cables containing multiple, network copper wire conductors or fiber optic fibers.
  - 2. The enclosure with the connecting cables installed shall be water tight, continuously submersible in up to 10-feet depth of water without leaking water into the enclosure interior.
  - 3. The enclosure with splices shall be completely re-enterable to allow access to the interior splices, adding cables, and removing cables, without compromising the water tight integrity of the enclosure.
  - 4. The universal splice enclosure assembly shall be UL listed.
  - 5. The USE shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements, ANSI/TIA/EIA-568C including related Standards, Amendments and TSB.
  - 6. USE shall be the product of the same Manufacturer.
- B. Fiber Optic Splices
  - 1. Provide fiber optic splice trays inside the USE. Each splice tray shall provide space for up to 12 splices in lieu of 24-splices on the tray.
  - 2. A splice tray holder shall rigidly anchor splice trays inside the USE, with sufficient slack cable, to allow individual removal of each splice tray.
  - 3. Provide one splice tray for each 12-fibers passing through the USE, but not less than eight splice trays in the use enclosure.
- C. Copper Wire Splices

## 2.14 SPLICE TRAY FIBER OPTIC FIBERS

### A. General

1. Trays shall be suitable for installation in USE, WMIC, RMSE and RTDE enclosures.
2. The trays shall be the product of the same Manufacturer as the respective enclosures.
3. Splice trays shall be UL listed, complying with national Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements, ANSI/ TIA/EIA-568C including related Standards, Amendments and TSB.

### B. Splice Trays

1. A metal or non-metal splice tray shall provide space for up to 24-splices of individual fiber cable single mode and multimode optical fibers. The trays shall provide individual splice holder inserts for each splice to adapt the tray for mechanical or fusion splices, with or without splice sleeves.
2. The tray shall incorporate integral fiber tie down clamps, fiber routing rings, provide strain relief and two full 360-degree fiber loops around the tray perimeter with sufficient slack fiber for removal of the tray for access and splicing of the fiber cable. The tray shall insure the minimum bending radius of the optical fibers is not violated.
3. Provide a removable clear plastic tray top cover for each tray, to protect and isolate the fibers.

## 2.15 WORK STATION OUTLETS

### A. General

1. Engrave outlet cover plates with the port number corresponding to the port number at the respective terminal block, patch panel, or head-end equipment.
2. The outlet cover plates shall be factory pre-punched and formed to accommodate the installed outlet connector with attachment screws.
3. Workstation outlets shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements, ANSI/TIA/EIA-568C including related Standards, Amendments and TSB.
4. Workstation outlets shall be the product of the same Manufacturer.

### B. Computer/Data Workstation Copper wire Outlets

1. The outlets shall be the same configuration and type as the corresponding connector provided in the copper wire patch panel outlet, unless noted otherwise.
2. ANSI/TIA/EIA-568C, and related Standards, Addendums and TSB.
3. The copper wire outlet connectors for twisted pair wire connections in computer workstation outlets shall be universal outlet connector RJ-45 type.

### C. Telephone/Voice Handset Twisted Pair Wire Connection Work Station Outlets

1. The copper wire outlet connectors provided in telephone/voice handset outlets, shall be universal outlet connector type, unless noted otherwise, ANSI/TIA/EIA-568C and related Standards, Addendums and TSB.
  - a. RJ-45 type
  - b. RJ-11 type

D. Fiber Optic Workstation Outlets

1. The fiber optic outlet connectors workstation outlets shall be fiber optic fiber inter-connection couplers, installed in universal outlet connectors. Provide one coupler for each fiber connecting to the outlet, but in no case less than the following for each outlet and as shown on the Drawing:
  - a. Computer workstation data network two couplers and fiber connectors.
  - b. Data network server - four couplers and fiber connectors.
2. The universal outlet connector housing and cover plates shall be the same as copper wire outlet connectors, except with adapters for fiber optic interconnection couplers, for the fiber optic fibers plug-in connectors.
3. The centerline-to-centerline spacing of the inter-connection couplers shall provide for "plug-in" insertion of "single or duplex" fiber connectors.
4. Color-code and identify the "in"-receiving and "out"-transmitting position for each inter-connection coupler.

E. Outlet Boxes

1. General for Low Voltage Outlets Requirements
  - a. Shall be UL approved and labeled for Life-Safety Appliances.
  - b. UL listed and label for low voltage CEC/NEC class-2 wiring and devices.
  - c. Shall be adjustable to fit into the wall/ceiling and attach into the wall/ceiling thickness at each install location.
  - d. Provide cable "Strain-Relief" attachment and "Sharp-Edge" protection for each outlet cable connections.
2. Wall mounted
  - a. Flush or surface wall mounted outlet box and size as indicated on the Drawings, but in no case less than 4.69-inches by 4.69-inches by 2.125-inches deep.
  - b. Two gang wide extension ring for outlet box to extend outlet flush with finish surface, or as noted on the Drawings.
  - c. Two gang wide cover plate, or as noted on the Drawings.
3. Pedestal Mounted "Poke-Thru".
  - a. Shall combine a computer/data and a telephone/voice copper wire universal outlet connector in a duplex outlet in the pedestal/poke-thru outlet.
4. Inside flush floor boxes and other locations where indicated in the Contract Documents.
5. Low Voltage Outlets in Fire rated walls and ceilings
  - a. Provide metal outlets for low voltage devices installed (recessed into) in fire rated walls or fire rated ceilings.
  - b. Provide metal outlet box enclosed type, for each outlet location. Provide UL labeled and listed "Fire-Wrap" complete coverage protection on the exterior of each outlet box. The combined outlet box and "Fire-Wrap" protection shall be equal or greater than the respective wall or ceiling fire-rating location.
6. Low Voltage Outlets in Non-Fire Rated walls and ceilings
  - a. Outlets for low voltage devices installed (recessed into) walls or ceilings, only where the wall/ceiling is not fire-rated.

- b. Provide the following for each outlet location
  - 1) Metal outlet box, enclosed type. All locations where one or more conduit(s) are required to connect to the outlet, then only metal outlet box shall be provided.
  - 2) Or device mounting bracket with trim ring, without (backless) enclosed outlet box. Do not use bracket-trim/ring configuration where conduit connection to the outlet with conduit is required, provide metal outlet boxes. Shall provide attachment for low voltage device(s), cover plates and low voltage wire strain relief.
- 7. Low Voltage outlet installed into accessible suspended ceiling with removable ceiling panels.
  - a. Support outlet independent of ceiling supports and ceiling.
  - b. Provide a minimum of three independent hanger wires for each outlet. Attach hanger wires to building structure above ceiling and to outlet.
- 8. Low Voltage Outlets in existing walls and existing ceilings
  - a. Outlets installed (recessed into) existing walls or (recessed into) existing ceilings. Cut and patch to match existing surfaces for outlet installation.
  - b. Provide "cut-in" retrofit mounting-attachment into existing ceiling/wall construction. Shall be UL rated for retrofit into "old-work".
  - c. Provide the following for each outlet location,
    - 1) Metal outlet box, enclosed type. Required for all Fire rated construction locations. Also permitted for non-Fire rated construction locations.
    - 2) Or device mounting bracket with trim ring. Permitted only for non-Fire rated construction locations only where no conduit connection to the outlet is required. Do not use in Fire rated construction locations. Do not use where conduit connection to outlet is required.
  - d. Where the existing wall/ceiling existing fire rating is indeterminate, Contractor shall assume the existing fire rating is not less than 2-hours. Provide metal outlet box and Fire-Wrap for each recessed outlet box.
- F. Multi-outlet Raceway Work Station Outlets
  - 1. Copper wire outlet:
    - a. Where copper wire connection is indicated for the workstation outlet, provide one universal outlet connector for each outlet.
    - b. Each universal outlet connector shall be single connector housing type.
    - c. Provide a rectangular cutout and metal device plate in the raceway sized to Outlet Manufacturer's recommendations. The workstation copper wire outlet shall mount a modular faceplate kit with outlet bezel and faceplate sized to match the workstation outlet.
    - d. Offset the location of outlets for electronic network systems 6-inches in the raceway from other outlets, do not "stack" outlets one above the other in the raceway.
- G. Combination Outlets
  - 1. Infrastructure outlet connectors shown at the same location for either wall box outlet locations and floor box outlets locations.

2. The outlet connectors shall be installed in a common outlet box with a common cover plate in the respective wall location or floor location.
3. In infrastructure patch panels install the connectors in the respective patch panels.

## 2.16 PORTABLE PATCH CORDS

### A. General

1. Provide portable patch cords for all copper wire and fiber optic cable infrastructure outlets:
  - a. For interconnecting electronic network equipment to electronic network workstation outlets.
  - b. For interconnecting equipment rack patch panel outlet patch locations with each other.
  - c. For interconnecting patch panel outlets equipment rack mounted hubs, switches, routers, telephone equipment, A/V equipment, access control and intrusion detection equipment etc.
2. Patch cords shall be factory assembled tested and certified with factory terminated plugs at each end. Field terminated portable patch cords shall not be permitted. Terminated plugs shall incorporate integral bending radius limiting molded "boots" and strain relief. Patch cord assemblies shall be rated for "heavy duty", "high-abuse" service.
3. Patch cords shall be UL listed, complying with National Electrical Code, ETL tested and certified to comply with or exceed Specified Requirements. ANSI/EIA/T1A-568C, related Standards, Addendums and TSB.
  - a. NEC - OFNG/OFN for fiber optic portable patch cords.
  - b. NEC - MPP/CMP/CMR/CMG/MPG for copper wire twisted pair portable patch cords.
  - c. NEC - CATV for coaxial cable portable patch cords.
4. Patch cords which are not installed shall be delivered to the Owner in cardboard boxes. The patch cords shall be neatly bundled and tied together. Mark each box with quantity and type of cords contained in the box.
5. Patch cords shall comply with the same Cable Communication Performance Requirements, Protocol Requirements and Testing Requirements as the respective infrastructure cables and outlets to which the patch cords are intended to be connected (plug-in). Patch cords shall be the product of the same Manufacturer.
6. The outer jacket of each portable patch cord shall be imprinted with date, Manufacturer's model and catalog number and AHJ listing identification.
7. Provide a permanent, visible, factory applied identification number on each end of each patch cord. The identification number shall be the same on each end. However, the numbers shall increase sequentially on each patch cord and shall be unique and not duplicated on other patch cords. Permanently apply the identification numbers on the cable jacket or connectors.

B. Twisted Pairs, Copper Wire Portable Patch Cords

1. Twisted Pairs portable patch cords, general:
  - a. "Male" eight-position modular "RJ" male style jacks install on each end of the patch cord cable. The jack shall be provided with a rear "fin" to prevent the plug tab from snagging when pulled backwards through adjacent wiring.  
RJ-45 style "male" jack, typical unless noted otherwise.
  - b. Patch cord cable shall be UTP and ANSI/EIA-Category rating, shall match respective premise wiring, 4-pair twisted, stranded copper individually insulated wires, thermosplastic jacket over all the wires and shield.
  - c. Connectors shall comply with FCC 68.5 and Part 68 Subpart F.
  - d. Connectors UL listed and shall comply with UL-94V-O.
  - e. Contacts gold plated with not less than a 750 insertion/withdraw cycle rating.
2. Portable patch cord quantities and lengths for connecting port-to-port equipment rack patch panels
  - a. Patch cord quantity: Provide one complete patch cord assembly for each copper wire equipment workstation outlet patch port in the equipment rack patch panels. One-to-one straight through pin-to-pin wiring. Provide additional spare patch cords, quantity equal to 25% of the total quantity of patch cords provided for copper wire computer workstation outlets in the equipment rack patch panels. Cable jacket color shall be blue:
  - b. Provide the following lengths of copper wire patch cables for copper wire equipment rack patch panel outlets.
    - 1) 2-feet long - 10% of total quantity
    - 2) 4-feet long - 30% of total quantity
    - 3) 6-feet long - 30% of total quantity
    - 4) 10-feet long - 20% of total quantity
    - 5) 16-feet long - 10% of total quantity
3. Portable patch cord quantities and lengths - for connection from equipment workstations to equipment workstation outlets, located remote from equipment racks.
  - a. Patch cord quantity: Provide one complete patch cord assembly for each copper wire work-station outlet located remote from the equipment rack patch panels. Provide additional spare patch cords, quantity equal to 15% of the total quantity of patch cords provided for each copper-wire computer workstation outlets. Cable jacket color shall be blue:
    - 1) Infrastructure network outlet segments the pin-to-pin patch cord wiring configuration and jacks shall be compatible with the equipment protocol communications interface, and the respective workstation outlet.
  - b. Provide the following lengths of copper wire patch cables for equipment copper wire infrastructure network workstation outlets. The patch cords shall provide internal cross-over wiring to conform the pin-to-pin connections required between the equipment workstation outlet and the equipment protocol communications interface installed in the respective work-station equipment:
    - 1) 8-feet long - 30% of total quantity
    - 2) 15-feet long - 70% of total quantity

4. Portable patch cord quantities and lengths for connection from electronic equipment rack patch panel ports to equipment installed in equipment racks, such as HUB's, servers, switches, router, telephone and concentrator equipment ports. Cable jacket color shall be white.
    - a. Patch cord quantity: Provide one complete patch cord assembly for each copper wire outlet port located in electronic equipment. Provide additional spare patch cords, quantity equal to 25% of the total quantity of the equipment rack equipment ports.
      - 1) The pin-to-pin patch cord wiring configuration and jacks shall be compatible with the respective equipment and patch panel outlets as applicable.
    - b. Provide the following lengths of copper wire patch cables for outlet ports located in electronic equipment installed in equipment racks. The patch cords shall provide quantity of conductors, wiring shall conform the pin-to-pin connectors and jack/ connectors to the ports in the equipment mounted in the equipment racks.
      - 1) 4-feet long - 15% of total quantity
      - 2) 6-feet long - 30% of total quantity
      - 3) 10-feet long - 35% of total quantity
      - 4) 16-feet long - 20% of total quantity
  5. Portable patch cord quantities and lengths for connection of equipment requiring customized pin-to-pin wiring configurations and/or customized port connector configurations. Cable jacket color shall be tan.
    - a. Patch cord quantity: Provide one complete patch cord assembly for each outlet port install as part of the Contract and not identified in any other patch cord descriptions. The patch cords shall be customized and configured to comply with the respective Manufacturers recommendations.
    - b. Provide one patch cord for each port-to-port connection length as required for actual installation condition.
      - 1) Provide 100% spare but not less than one spare patch cord for each custom configuration.
- C. Telephone/Voice Copper Wire Portable Patch Cords-110 style
1. 110 style jacks for plugging into the 110 style connecting blocks located in the telephone/ voice terminal blocks.
  2. Patch cords shall be UTP 4-pair twisted, 24AWG stranded copper individually insulated wires with a thermoplastic jacket over all the wires. Cable shall be ANSI/TIA/EIA-568C.
  3. Patch cord quantity and length - telephone/voice terminal block:
    - a. Provide one complete patch cord assembly for each copper wire telephone/voice outlet connecting to the telephone/voice terminal block. Provide additional spare patch cords, quantity equal to 25% of the total quantity of patch cords provided for telephone/voice 110 patch cords.
    - b. Provide the following lengths of copper wire patch cables for telephone/ voice 110 style connecting block portable patch cords.
      - 1) 3-feet long - 25% of total
      - 2) 5-feet long - 50% of total
      - 3) 15-feet long - 25% of total



D. Coaxial Cable Portable Patch Cords

1. BNC type connectors on each end of each patch cord. Shall be compatible with patch panel outlets, workstation outlets and respective equipment rack electronic equipment.
2. Patch cord quantity: Provide two complete patch cord assemblies for each coaxial cable outlet.
  - a. One patch cord for workstation outlet located remote from the equipment rack patch panel, 15-feet long each patch cord.
  - b. One patch cord for equipment rack (IDF/MDF) patch panel each outlet location, 10-feet long each patch cord.
  - c. Provide 15% additional spare patch cords of each patch cord length.

E. Fiber Optic Portable Patch Cords

1. General
  - a. Provide fiber optic fiber connectors installed on each fiber end of the patch cord cable. The fiber optic portable patch cord shall be "single" with one fiber strand type, for each patch cable. The connector shall be mechanically and optical compatible with the respective connecting patch panel couplers and network work equipment couplers.
  - b. The entire patch cord assembly total insertion loss shall be less than 1.0dB at the specified operating wavelengths.
  - c. Operating temperature range 30-degrees centigrade through +60 degrees centigrade. Cables shall be flame retarding.
  - d. Each fiber shall be individually identified with factory color-coding and factory imprinted label. The outer cable jacket shall be imprinted with date, Manufacturer's model and catalog number, along with Agency listing identification. The cable jacket color shall be yellow.
  - e. All fiber optic patch cord cable shall be a product of the same Manufacturer.
  - f. Optical fiber shall be coated, 900 micron diameter uniform coating, with uniform tight buffering over the coating, uniform dielectric strength member surrounding the buffering coating and an overall jacket around each optical fiber assembly.
  - g. A dielectric strength member shall surround the fiber assemblies.
  - h. An outer dielectric jacket shall envelope the entire cable.
  - i. The cable shall be UL listed and comply with NEC and NFPA Requirements for each installation location shown in the Contract Documents.
  - j. Patch cord quantity and length
    - 1) Patch cord quantity: Provide one complete patch cord assembly for each fiber optic patch panel outlet in the equipment rack.
    - 2) Provide one complete patch cord assembly for each computer workstation fiber optic outlet remote from the patch panel.
    - 3) Provide additional spare patch cords, quantity equal to 25% of the total quantity of patch cords provided.
  - k. Provide the following quantities and lengths of fiber optic patch cords.
    - 1) 3-feet long - 20% of total
    - 2) 6-feet long - 35% of total
    - 3) 10-feet long - 30% of total

- 4) 20-feet long - 15% of total
2. Multimode patch cords
  - a. Patch cord cable shall be fiber optic cable with equal or better characteristics as the premise fiber optic cables.

## **2.17 CIRCUIT PROTECTORS**

### **A. General**

1. The circuit protectors shall be UL listed, complying with National Electrical Code, ETL Tested and Certified to comply with or exceed Specified Requirements, ANSI/TIA/EIA-568C including related Standards, Amendments and TSB.

### **B. Circuit Protectors**

1. Cables containing non-dielectric electrical conducting components entering from the exterior of the building shall be provided with individual circuit protectors combining both lightning circuit protection and SPD circuit protection on each circuit conducting component, as required in CEC Articles 770 and 800.
2. Install circuit protectors in the respective backboard/equipment rack where copper wire conductors terminate, connect each protector to room/closet ground bus equipment with #10AWG green insulated bond/ground copper conductors.

## **PART 3 - EXECUTION**

### **3.01 NETWORK CABLE TESTING AND COMMISSIONING (ADDITIONAL REQUIREMENTS)**

#### **A. General**

1. In addition to the testing recommended in ANSI/TIA/EIA-568C and related Standards, Amendments and TSB. End-to-End test 100% of all individual optical fiber, individual copper wire conductors, each outlet and each connector in all terminated and unterminated cables, portable patch cord, outlets and patch panels provided in the Contract, shall be tested after installation as a complete channel pathway installation, splicing outlets and termination is completed, including the following end-to-end tests on each installed individual circuit;
  - a. Each circuit wire and fiber map and length
  - b. Each circuit insertion Loss
  - c. Each circuit NEXT (Pair-to-Pair) Loss
  - d. Each circuit NEXT Loss (Power Sum) PS
  - e. Each circuit ELFEXT Loss (Pair-to-Pair)
  - f. Each circuit ELFEXT Loss (Power Sum) PS
  - g. Each circuit return Loss (RL)
  - h. Each circuit propagation delay
  - i. Each circuit propagation delay-skew
2. The test equipment and (Tester) shall comply with the Accuracy Requirements for Field Testers as defined in the ANSI/EIA/TIA Standards for the specific cable type. The Tester including the appropriate interface adapter shall meet the Specified Accuracy Requirements. The Tester shall be within the calibration period recommended by the

Vendor in order to achieve the Vendor-specified measurement accuracy. The Tester shall be calibrated to extend the reference plane of the Return Loss measurement to the permanent link interface. The Contractor shall provide proof that the interface has been calibrated within the period recommended by the Vendor.

3. The Pass or Fail condition for the channel pathway link-under-test is determined by the results of the required individual tests (ANSI/EIA/TIA) Any Fail result yields a Fail for the link-under-test. In order to achieve an overall Pass condition, the results for each individual test parameter must Pass. A Pass or Fail result for each parameter is determined by comparing the measured values with the ANSI/EIA/ TIA test limits for that parameter. The test result of a parameter shall be marked with an asterisk (\*) when the result is closer to the test limit than the accuracy of the field test. The Field Test Equipment Manufacturer shall provide documentation as an aid to interpret results marked with asterisks.
4. Provide all test equipment, Certified Testing Personnel, and setups. Shall comply with ANSI/EIA/TIA and Equipment Manufacturer's recommendations and standards of practice.
5. Provide six copies of all test reports, bound in three ring binders. Provide three digital CD/DVD ROM copies. Organize test reports into rows-and-columns spread-sheet format, with data common groupings by IDF and NDF location. Submit to Owner's Representative.
6. The Contractor shall repair or replace equipment, cables, outlets, connectors, splices, terminations, etc. identified during testing as not complying with the Contract Documents, without additional cost to the Contract. Retest all replaced or repaired components at Contractor's expense.

B. Twisted Pair Copper Wire Testing

1. Channel insertion loss (dB).
2. Channel near-end cross-talk NEXT loss (dB).
3. Channel equal-level far-end cross-talk ELFEXT (dB).
4. Channel return loss (dB).
5. Channel power sum PSACR (dB).
6. Channel propagation delay, propagation speed, and delay skew.
7. Channel wire map and circuit length.
8. Channel ring-out test for continuity and correct point-to-point matching terminals.
9. Channel DC resistance and capacitance.
10. Channel attenuation-to-cross-talk ratio ACR.

C. Coaxial Cable Testing

1. Channel full specified frequency spectrum attenuation insertion loss (dB).
2. Channel wire mapping, ring-out and circuit length.
3. Channel propagation delay and propagation speed.
4. Channel impedance and continuity for center conductor and shields.

- D. Fiber Optic Cable Testing, Optical Testing for Each Specified Wave-Lengths for Both laser and LED sources.
  - 1. Channel link insertion losses (dB) OLTS.
  - 2. Channel loop-back attenuation (dB).
  - 3. Channel signature Optical Time Domain Reflectometer – OTDR, for installation characterization testing (event and attenuation resolution dead zone at specified wave lengths, shall be less than 10-feet).
  - 4. Channel continuity and correct point-to-point matching terminals.
  - 5. Channel propagation delay and propagation speed.
  - 6. Channel fiber optic mapping, circuit length, and tracing.

### 3.02 FIBER OPTIC CABLE TYPE

- A. General
  - 1. Cables shown as fiber optic type shall comply with the following installation locations.
  - 2. Provide matching compatible outlets and terminate all fiber optic cables into matching fiber optic connectors.
  - 3. Fiber optic cable installed in indoor locations without enclosed raceway or conduit.
    - a. Provide non-metallic, flexible corrugated continuous inner duct-raceway and install fiber optic cable in the innerduct.
    - b. Innerduct shall be heavy duty, plenum-rated, Limited-Combustible (LC) type UL FHC – 25/50, orange color. Support innerduct 36-inches on center, independent of ceiling supports and independent of other equipment supports.
    - c. Innerduct size shall be selected to insure percentage-fill with fiber optic cables shall not exceed 30%, but in no case less than 1.25-inch diameter innerduct.
- B. Provide loose tube gel filled or indoor/outdoor type fiber optic cable for any of the following installation location conditions.
  - 1. Inter building (between buildings)
  - 2. In a conduit or raceway located underground below grade.
  - 3. In an exposed outdoor conduit or raceway not located underground or below grade.
  - 4. Do not install loose tube gel filled type fiber optic cable inside a building or exposed on a building without providing Rigid Steel (RGS) conduit raceway for the loose tube gel filled fiber optic cable along the entire length of the cable inside the building or on the building.
- C. Provide tight buffered or indoor/outdoor type fiber optic cable for any of the following installation location conditions.
  - 1. Intra-building (inside a building) where raceway continuously encloses the cable and the raceway is not located underground, below grade.
  - 2. In an exposed outdoor conduit or raceway not located underground or below grade.

- D. Provide plenum rated type fiber optic cable for any of the following installation location conditions in building spaces.
1. Any building space air plenum (supply or return) when a conduit or enclosing raceway is not provided for the entire cable length. Additionally, Cables shall be rated Limited-Combustible (LC) type UL FHC-25/50.
  2. All building space locations where the cable is installed without a conduit or the cable is not fully enclosed in a raceway along the entire cable length in a building. Additionally, Cables shall be rated Limited-Combustible (LC) type UL FHC-25/50.
  3. Building spaces and/or cavities that are 100% fully protected with fire sprinklers, including fire sprinklers located above in ceiling cavities and fire sprinklers located below in access floor cavities. Cables installed in these locations shall be rated with one or more of the following additional characteristics.
    - a. Limited-Combustible (LC) UL FHC-25/50 plenum rated cable.
    - b. Or plenum rated cable without the UL FHC-25/50 Limited-Combustible (LC) rating.
- E. Optical Fiber Quantity:
1. The minimum fiber quantities in each fiber optic cable shall be as follows, but in no case less than indicated on the Drawings.
  2. Between main IDF (SUB-MDF) in separate buildings and the MDF main terminal rack fiber optic patch bay for the entire site/campus.
    - a. Twenty-four optical fibers, multimode plus six optical fibers, single mode.
  3. Between satellite IDF terminal rack fiber optic patch bays and the main terminal rack IDF (sub-MDF) patch bay located in the same building.
    - a. Twenty-Four optical fibers, multimode plus six optical fibers, single mode.
  4. Between a terminal rack patch bays (IDF or MDF):
    - a. To an individual workstation outlet located inside the same building - two multimode optical fibers, (typical only for locations where fiber is specifically shown on the Drawings for the specific work station outlet).
    - b. To each network file server outlet location whether or not shown on the Drawings, four optical fiber, and multimode.
  5. Between a terminal rack-patch bay and individual multimedia network (television/video/audio) workstation outlets and/or intrusion/access program display devices located inside the same building - two optical fibers, multimode.
  6. Other locations as indicated on the Drawings or described in the Contract Documents.

### **3.03 COPPER WIRE CABLE TYPE**

- A. General
1. Cables shown as copper wire type shall comply with the following installation conditions, unless noted otherwise on the Drawings.
  2. Provide matching compatible outlets and terminate all copper wire cables into matching copper wire connectors.

- B. Cable Types and Quantities - Cable types and quantities shall be as follows unless specifically noted other-wise on the Drawings. The following minimum type and quantity of copper wire cables from each individual workstation/device outlet, to the respective terminal equipment patch panel/bay, (unless specifically noted otherwise), but in no case less than what is shown on the Drawings and in no case less than one 4-pair cable to each outlet "Jack" position:
1. Two Category-6A, UTP 4-pair cable:
    - a. Each network workstation outlet location.
    - b. Each network "wireless-access-point" outlet location.
  2. One Category-6A UTP 4-pair cable, for each telephone handset (instrument) workstation outlet location.
  3. Trunking-Cables shall be Category-5E.
    - a. 100-pair between buildings main IDF (SUB-MDF) and campus main MDF.
    - b. 50-pair inside building between SUB-IDF to buildings main IDF (SUB-MDF).
  4. Other locations as indicated on the Drawings or described in Contract Documents.
- C. Provide plenum rated copper wire cable for any of the following installation location conditions in building spaces.
1. Any air plenum (supply or return) when a conduit or enclosed raceway is not provided for the entire cable length. Additionally, cables shall be rated Limited-Combustible (LC) type UL FHC-25/50.
  2. All building space locations where the cable is installed without a conduit or the cable is not fully enclosed in a raceway along the entire cable length in the building. Additionally, cables shall be rated Limited-Combustible (LC) type UL FHC-25/50.
  3. Building spaces and/or cavities that are 100% fully protected with fire sprinklers, including fire sprinklers located above in ceiling cavities and fire sprinklers located below in access floor cavities. Cables installed in these locations shall be rated with one or more of the following additional characteristics.
    - a. Limited-Combustible (LC) UL FHC-25/50 plenum rated cable.
    - b. Or plenum rated cable without the UL FHC-25/50 Limited-Combustible (LC) rating.
- D. OSP Insulated Copper Wire Cables
1. Outside – Plant (OSP) CEC/NEC rated, UL listed, labeled and approved insulated copper wire cable assemblies. Moisture barrier resistant and UV resistant cable jacket. Non-flammable, water blocking, non-conductive gel internally filled infrastructure cable assembly.
  2. Provide rated insulated copper wire OSP type cable for any of the following copper wire infrastructure cable install locations.
    - a. In underground conduit or in conduit under the building.
    - b. In conduit exterior to the building, or in conduit exposed outdoor on the building.
    - c. Outdoor aerial with aerial messenger wire cable carrier.
  3. Except for aerial install locations, install all OSP cable in continuous conduit pathways, end-to-end.

### 3.04 CABLE INSTALLATION

#### A. General

1. Cables connecting to equipment racks and terminal blocks shall be installed with not less than 6-feet of slack cable between the equipment rack/terminal block and terminal backboard. The slack cable shall be coiled and supported on the backboard and/or cable tray.
2. Cables in terminal closets and terminal rooms shall be trained, dressed and racked on the plywood backboards. Provide cable, metal support arms and re-enterable type cable support rings not less than 12-inches on center mounted onto the plywood along the entire length of all cables.
3. Provide separate routing paths on plywood backboards for fiber optic cables, computer data and copper wire cables and telephone/voice copper wire cables and multimedia, audio/video, TV cables. Provide separate routing paths on plywood backboards for shielded copper wire cables and unshielded copper wire cables.
4. Cables shall be routed parallel to floors and walls. Do not route cables diagonally on backboards.
5. Spare cable slack
  - a. Provide 25-feet of cable slack where unterminated cables are specified at terminal backboards.
  - b. Provide a minimum of 18-inches of slack cable in each workstation outlet box and outlet locations.
  - c. Provide 10-feet of cable slack in ceiling above each work station outlet.
  - d. Provide 24-inches of slack in each cable at patch panel locations.
  - e. Coil and "Velcro" wrap slack cable.
6. Provide "horizontal wiring" cables installed from individual equipment locations and workstation out-lets to respective MDF/IDF terminal closet/room patch panel. Cables shall be continuous without cutting or splices.
7. Provide "backbone" cables installed from each IDF location to respective MDF/ Sub-MDF location terminal closet/room patch panels. Cables shall be continuous without cutting or splices.

#### B. Cable Pulling Lubrication

1. Cable pulling lubricants shall be specifically approved by the Cable Manufacturer. The following lubricants shall be used where approved by the Cable Manufacturer.
  - a. Slip X -300, American Colloid Co.
  - b. Bishop #45, Bishop Electric.
  - c. MacLube CA51, MacProducts.
  - d. Minerallac H2B,- Minerallac Electric.
  - e. Winter grade #7437-PC, General Machine Products.
  - f. Gel-lube 7/5, Cable associates.
  - g. Polywater, A, C, G - American Polywater.
2. Lubricants shall be continuously applied as cable enters raceway.

#### C. Cable Installation:

1. Do not pull conductors until factory test reports have been submitted and reviewed.

2. Minimum bending radius of fiber optic cables shall not be less than the following. Maximum pulling tension shall not exceed the following. In no case shall the Manufacturer's recommendations be violated.

| <u>Cable Type</u> | <u>Cable Fiber Quantity</u> | <u>Minimum Bend Radius</u> | <u>Maximum Pulling Tension</u> |
|-------------------|-----------------------------|----------------------------|--------------------------------|
| Loose Tube        | 2-84                        | 9 inches                   | 600 pounds                     |
| Loose Tube        | 86-192                      | 10 inches                  | 600 pounds                     |
| Tight Buffered    | 2-12                        | 5 inches                   | 400 pounds                     |
| Tight Buffered    | 14-24                       | 7 inches                   | 600 pounds                     |
| Tight Buffered    | 26-28                       | 11 inches                  | 1100 pounds                    |
| Tight Buffered    | 48-72                       | 12 inches                  | 1200 pounds                    |

3. The minimum bending radius for copper wire cables shall be 10 times the cable outside diameter. The maximum pulling tension and minimum bending radius shall not violate Manufacturer's recommendations.
4. Cables installed in manholes and pullboxes on terminal backboards shall be installed on wall mounted cable support racks.
5. Provide a full 360-degree loop of cable around manhole and pullbox interiors.
6. The attachment of pulling devices directly to the cables shall be with individual split mesh basket grips. Direct connection for pulling cables to cable fibers and copper wires shall not occur. Securely tape cable ends to prevent moisture or pulling compound from penetrating cable.
7. The attachment of the pulling device to the cable basket grips shall be made through a swivel connector.
8. The Contractor shall ensure that the cables are fed straight into the raceway taking care to avoid short bends, sharp edges and cable "cross-overs".
9. All lashings used for temporary bunching of the individual cables shall be removed before the cables enter the raceway.
10. Cables shall be "pulled through" or pulled from a "center of run pull" without splices or terminations and minimize cable rolling tension. Lead-out the cables at all manholes, pullboxes and conduits taking care to feed them in again by hand for the next portion of the cable run.
11. For each cable pull where a cable direction change is required, flexible feed-in tubes, pullout devices, multi-segmented sheaves etc. shall be used to insure proper cable pulling tensions and side wall pressures. Cables shall not be pulled directly around a short right angle bend. Any device or surface the cable comes in contact with when under pull-in tension shall have a minimum radius 50% greater than the final specified minimum installed cable bending radius. The maximum possible size radius sheaves and feed-in tubes, usable in the available working space, shall be provided in all situations, to insure the minimum possible cable side-wall pulling pressure. Do not use devices with multi-segment "roller" type sheaves.
12. Cable lengths over 50 feet shall be machine pulled not hand pulled into and through all raceways. Cables shall be pulled in a continuous, smooth operation without jerking or stop-start motion after initiation of pull. Maximum cable pulling speed shall be less than



50 feet per minute. Minimum cable pulling speed shall be greater than 15 feet per minute.

13. Cables shall be pulled straight into or out of the raceway without bends at the raceway entrance or exit. Pull in cable from the end having the sharpest bend (i.e., bend shall be closest to reel). Keep pulling tension to minimum by liberal use of lubricant, hand turning of reel, and slack feeding of cable into duct entrance. Employ not less than one man at reel and one at manhole or pull-hole during this operation. Cables shall be pulled directly from cable reels.
14. Cables shall be trained or racked in trenches, vaults, manholes and pull boxes with consideration given for the minimum specified bending radius of the cable and the possibility of cable movements due to load cycling. The cables shall be racked and supported in such a manner that adequate space is allowed for splicing and the cables shall always be fanned out from the duct or conduit so as not to cross other ducts, conduits or cables. To prevent damage from falling objects or personnel entering the manhole the cables shall not pass directly under the manhole opening.
15. Cable shall be supported in manholes, pull boxes and vaults a minimum of 18-inch on center with cable racks. Provide hot dip galvanized, T-slot racks and support arms. Secure cables to racks with porcelain supports for each cable on the racks. Loosely lash cables to racks. Splices shall be directly supported, on racks. Do not install cables more than one feeder on the same rack hook.
16. Cables shall be routed the long way around manhole, pull-hole, etc. with not less than a full 360-degree loop around the perimeter walls unless noted otherwise.
17. Existing conductors shall be protected at all times when Contract work occurs in the same area, including but not limited to pullboxes, vaults manholes, cable trenches etc. Provide temporary electrical insulating blankets and barriers over existing conductors to reduce the possibility of accidental mechanical damage to existing conductors.
18. Where cable tray is provided, all cables shall be routed and trained on the cable tray. The cables shall enter the cable tray and route along the tray prior to entering any equipment racks or computer works station outlets.
19. A dynamometer to measure pulling tension shall be used on all cable runs in excess 200-feet or with more than 180 degrees in bends. The actual pulling tension value shall be calculated and recorded for each pull.
20. Bends shall not be made in cable splices or terminations.
21. The portions of cables installed without raceways or cable tray supports shall be installed with metal "J-hook" cable supports.
  - a. The "J-hooks" shall provide multi-tiered "J" shaped hooks, with wide flat cable support base (0.5 inch wide minimum) and smooth rounded corners. Specifically designed for copper wire and fiber optic infrastructure cable support as manufactured by Erico Inc.
  - b. The individual "J-hook" attachment to the building structure shall be metal, "beam clamp", "hanger rod", clevis hanger styles as applicable for each attachment location.

- c. Install “J-hooks” not more than 48-inches on center along the entire cable length and within 6 inches of each cable change in direction. Locations of “J-Hooks” and tension of cables shall insure between 4-inches and 6-inches of cable sag between adjacent hooks. Secure cables to “J-hooks” with re-enterable cable tie wraps. “J-hook” supported cables, bundle cables together with re-enterable tie wraps not less than 12 inches on center along the entire cable length.
  - d. Each J-hook shall not support more than 12 individual cables. Provide multiple “tiered” J-hooks for additional cable quantities at each location.
  - e. “Bridle rings” shall NOT be used to support cables.
  - f. Cables shall not lie directly on nor attach to ceilings, ceiling hangers, lighting fixtures, air ducts, piping, or equipment.
22. Re-enterable cable tie wraps shall be, “limited-combustible” and air plenum rated, reusable, color coded. Chemically and mechanically compatible with the respective cables and install locations. Shall allow multiple open-close operations for securing cables.

23. Electronic network cables containing non-dielectric components shall be installed with a minimum separation from other electrical power conductors and equipment as follows:

| <u>Equipment Type</u>  | <u>Minimum Separation</u> |
|--|---------------------------|
| a. Lighting fixtures   | 12 inches                 |
| b. Electric motors, electric solenoids, electric Heaters                             | 40 inches                 |
| c. Transformers  | 48 inches                 |
| d. Circuits over 100 volts to ground, in metallic raceways                           | 5 inches                  |
| e. Circuits over 100 volts to ground, in non-metallic raceway or without any raceway | 12 inches                 |
| f. Circuits over 100 volts to ground, suspended on overhead pole lines               | 48 inches                 |

D. Movement, Storage, and Handling of Cable:

- 1. Reels of cable shall not be dropped from any height, from trucks or other transporting equipment.
- 2. Lift and move cable reels using following methods:
  - a. Crane or boom type equipment-insert shaft (heavy rod or pipe) through reel hubs and lift with slings on shaft, with spreader or yoke to reduce or avoid sling pressure against reel head.
  - b. Forklift type of equipment may be used to move smaller, narrower width reels. Fork tines should be placed so that lift pressure is on reel heads, not on cable, and shall reach all the way across reels so lift is against both reel heads.
  - c. Reels may be moved short distances by rolling. Reels shall be rolled in the direction indicated by arrows painted on reel heads. Surfaces over which the reels are to be rolled shall be solid clear of debris, and also clear of protruding stones, humps, etc. which might damage the cable if the reel straddles them.
- 3. Storage of reels of cable:
  - a. Cable ends shall be sealed prior to shipment to prevent moisture entry into cable. Cable ends shall remain sealed at all times including during installation. Where ends seals are removed, reseal cable ends by stripping cable finishes back 2-inches down

to insulation. Then apply four layers of an insulating tape criss-cross over the cable end and carry back at least 4-inches onto cable outer finish. Add a containing cover of two layers of vinyl electrical tape completely over the end seal.

- b. Cable reels shall be shipped with factory applied lagging (protective cover) left in place until removal is absolutely necessary. Additional covering such as tarpaulin, plastic sheeting, etc. shall be used if cable is to be stored outdoors.
- c. Store reels of cable on a firm surface, paved, or on planking to prevent settling into soft ground.
- d. Use fencing or other barriers to protect cables and reels against damage by vehicles or other equipment moving about in the storage area.

### **3.05 CABLE SPLICES**

#### **A. General**

1. Splice(s) in cables shall occur only in the following locations:
  - a. Pullboxes or manholes.
  - b. Terminal backboard, closets or rooms.
  - c. Equipment racks.
  - d. Wall mounted interface cabinet.
  - e. Do not splice cables in conduit, cable tray, raceways or plenums.
2. Polarity and color-coding shall be maintained consistent through splices, terminations and outlets for the entire electronic network system.
3. Cable splices in outdoor areas, manholes, pullholes shall be water tight, inside universal splice enclosures.

#### **B. Fiber optic cable splices unless specifically indicated otherwise below, fiber optic cable splices between fiber optic cables fibers shall be fusion type splices.**

1. Splices between loose tube gel filled fiber optic cable fibers shall be fusion type splices.
2. Splices between indoor/outdoor fiber optic cable fibers shall be fusion type.
3. "Pigtail" splices of tight buffered and indoor/outdoor fiber optic cable fibers to loose tube gel filled cables shall be fusion type splice.
4. Splices between tight buffered fiber optic cable fibers to indoor/outdoor fiber optic cables shall be fusion type splice or mechanical type splice.
5. Splices between tight buffered fiber optic cable fibers shall be mechanical type splice or fusion type splice.
6. "Pigtail" splices of tight buffered fiber optic cable fibers to tight buffered fiber optic cable fibers shall be mechanical type splice or fusion type splice.
7. Fiber optic splices shall be performed to maintain the data transmission rates specified for the entire respective system.

#### **C. Copper Wire Splice**

1. Copper wire extending from infrastructure workstation outlets to respective equipment rack patch panel outlets shall not be cut or broken and shall be continuous end to end.
2. Copper wire extending from telephone/voice workstation outlets to respective terminal blocks shall not be cut or broken and shall be continuous end to end.

3. Continuity of cable shields (where occurs), polarity and color coding shall be maintained across all splices.
4. Copper wire splices shall be performed to maintain the data transmission rates specified for the entire respective system.

### **3.06 CABLE TERMINATIONS**

#### **A. General**

1. Infrastructure workstation outlets connecting to ports in patch panels and terminal blocks shall be grouped together in the patch panel and terminal block by outlet function, room location and building area location (i.e. Group #1 Room #120 1<sup>st</sup> floor; Group #2 Room #200 east wing, etc.). Each group shall be identified with engraved (etched) nameplates indicating grouping identification and individual port numbers.
2. Polarity and color coding of cable connections at splices, terminations and outlets shall be consistently maintained throughout the entire electronic network system.
3. Terminate all cables onto respective outlets connectors, interconnection couplers and terminals. Terminations shall comply with Manufacturer's recommendations; ANSI/TIA/EIA-568C related Standards, Amendments and TSB.
4. Fiber optic cable fiber strands and copper wire cable conductors terminated at outlet locations shall be connected with a strain relief device attached to the cable jacket to prevent cable tension from being transmitted to the termination connectors.
5. Cable terminations shall be performed to maintain the data transmission rates specified for respective entire system.

#### **B. Fiber Optic Terminations**

1. Individual fiber optic fibers shall each be terminated with a fiber optic fiber connector. The connector for each fiber shall be "plugged" into separate fiber optic fiber interconnection couplers on the rear of each respective outlet.
2. Each fiber optic termination ferrule shall be inspected, after completion of the termination, visually with a fiber optic inspection microscope and an interferometer, to insure fiber "undercut", "protruding" fiber, over polish and under polish of fiber termination ends does not exist in the finished termination ferrule.
3. Fiber optic cables terminated between two fiber optic patch panels located in separate equipment racks. The fibers shall be paired together (Duplex-Pair) for purposes of identification and connection transmit/receive pair. Each pair of connectors for fibers shall be "plugged" into separate, physically adjacent fiber optic fiber duplex-pair interconnection couplers at each patch panel. The horizontal/ vertical arrangement of paired patch panel fiber couplers shall match at both ends of the fiber cable.
4. Fiber optic cable fiber strands terminated at patch panels shall be installed with a minimum of 540 degrees of each fiber strand looped around the splice tray individual fiber "training" rings.
5. Fiber optic cable connecting from infrastructure workstation outlet to a fiber optic patch panel.
  - a. The connectors for fibers shall be "plugged" into separate, physically adjacent fiber optic fiber interconnection couplers.

- b. The patch panel coupler shall be color coded to identify the polarity of the transmitting and receiving optical fibers.
  6. Fiber optic cable connections at workstation outlets.
    - a. The connectors for fibers shall be "plugged" into separate physically adjacent fiber optic fiber interconnection couplers in the outlet.
- C. Copper Wire Terminations
  1. Where occurs, the shield on metal shielded copper wire shall be terminated and connected to the shield grounding connection at each termination point.
  2. Twisted wire pairs shall not be untwisted for a length of more than 0.4-inch at any location and the cable jacket shall not be striped back not more than 0.5 inch any location including splices and terminations.
  3. Unless specifically directed otherwise by the Owner's Representative, Pin assignment for wiring terminations shall comply with ANSI/TIA/EIA-568C type T568A or Type T568B as required for compatibility with the electronic network equipment. The termination type shall be consistent throughout the Project Contract area.
  4. Copper wire termination's shall be performed to maintain the transmission rates specified for the respective entire system.

### **3.07 EQUIPMENT RACKS**

#### **A. General**

1. Install, assemble, mount and connect devices and equipment in the respective equipment racks, bolted securely to the rack frame with stainless steel hardware. "Star" style lock washers shall be provided to insure an electrically continuous ground path between the equipment/devices and rack frames.
2. Provide blank metal filler panels to close unused equipment "front" mounting space in equipment racks, Manufacturer's standard finish color.
3. Provide a copper wire outlet connector in the respective equipment rack for each remote copper wire infrastructure workstation outlet and copper wire cable shown connected to the respective equipment rack, plus the spare copper wire outlet connectors required in the Contract Documents. The copper wire outlet connectors in the equipment racks shall be provided in equipment rack mounted copper wire patch panels. In no case shall the quantity of equipment rack mounted copper wire outlet connectors be less than the quantity of cables indicated on the Drawings, plus required spaces/spares.
4. Provide fiber optic fiber connectors and fiber optic fiber interconnection couplers in the respective equipment rack for each remote fiber optic infrastructure workstation outlet, and fiber optics cable fiber shown connected to the respective equipment rack, plus the spare fiber optic fiber connectors required in the Contract Documents. The fiber optic fiber connectors and fiber optic fiber interconnection couplers in the equipment racks shall be provided in equipment rack mounted fiber optic fiber distribution enclosures (RTDE). In no case shall the quantity of equipment rack mounted fiber optic fiber connectors and fiber optic fiber interconnection couplers be less than the quantity of cables indicated on the Drawings, plus required spaces /spares.

5. Fiber optics cable fibers specifically shown as non-terminated "splicing-thru" in the equipment rack shall route through fiber optic splice only enclosures (RMSE), mounted in the respective equipment rack.
6. The maximum quantity of cable terminations, in each equipment rack mounted patch panels shall not exceed the following. To insure not less than 50% of the rack space remains available for equipment installation:
  - a. 100% copper wire outlet connectors, 196 maximum per rack.
  - b. 100% fiber optic fiber terminations, 144 maximum per rack.
  - c. Combination of copper wire outlet connectors and fiber optic fiber terminations in the same rack; 48 maximum fiber optic fibers plus 144 maximum copper wire outlet connectors per rack. 18 maximum fibers plus 48 maximum copper wire in 30 inches high.
  - d. In addition to the quantity of patch panel outlets for termination of incoming and outgoing cables, provide not less than an additional 15% of patch panel spare outlets of each type, in each equipment rack for future use.
7. Provide additional equipment racks, quantity of racks to ensure the maximum specified quantity of terminations in single rack are not exceeded and the quantity of cable terminations complies with the Requirements of the Contract Documents.
8. Terminal racks, equipment locations, patch panels, and cross connects shall be arranged to allow for natural cabling progression, minimize crossing of cables and allow easy access to each system component.
9. Equipment Rack Anchorage:
  - a. Equipment racks installed on raised "access floor" systems, shall be supported and anchored with bolts that extend into the "structural" floor located below the "access floor".
  - b. Securely anchor the support arms of swing gate racks to the wall structural support system.
  - c. Securely anchor fixed support base of the racks to the floor.
  - d. Mounting method shall support the total rack weight including installed equipment, but in no case less than 500 pounds with a 2.0 times safety factor.
  - e. Attachments and anchorages shall comply with the Requirements for earthquake seismic rating at the install location.
10. Unless specifically noted, otherwise provide the following equipment rack types:
  - a. Floor standing equipment racks containing patch panel locations, computer/data network HUBS/switches and computer data network concentrators, shall be Swing Gate style equipment racks.
  - b. Floor standing equipment racks containing multimedia, audio/video, TV head end equipment, shall be Metal Enclosed equipment racks.
  - c. Wall mounted external to dedicated IDF/MDF terminal rooms/closets (i.e. inside individual classrooms), shall be Mini-Equipment racks.
11. Install ground bus, PDU/SPD, cable management rings, equipment, patch panel and patch panel out-lets, etc. in equipment racks.

12. Equipment rack terminology:
  - a. The location containing the main campus equipment rack location shall be identified as the Main Distribution Frame – (MDF).
  - b. The locations remote from the MDF containing satellite equipment racks shall be identified as Intermediate Distribution Frames (IDF).
  - c. A individual building located on a multi-building campus site with multiple equipment rack locations in the building, the building main rack location shall be identified as Sub-MDF (or building MDF) and the remaining equipment rack locations in the building shall be identified as IDF.
- B. Swing Gate Racks
  1. Position the swing gate rack frame to provide a minimum of 30-inches clear space behind the moveable swing gate, for deep recess rack mounted equipment enclosure clearance. 42-inches in front of each rack to allow space for swing-gate 90-degree open position and still allow personnel passage way with the swing gate open. Not closer than 30-inches from rack frame to side-adjacent walls, to allow rack to swing full open with installed equipment.
  2. All incoming cables shall enter from the back of the rack. The cables shall cross the hinge side of the rack with sufficient cable slack to allow opening and closing of the swing gate.
  3. Provide unobstructed open-close operation clearances of the moveable swing gate. Do not install the edge of the rack closer than 30 inches to an intersecting perpendicular surface or wall.
  4. The bottom of the moveable swing gate frame shall be approximately 6-inches above the finish floor.
  5. Multiple swing gate equipment racks installed adjacent to each other along a common backboard/wall shall be spaced not less than 44-inches center line to center line and to insure the rack-gate can swing open a full 90-degree Arc with 24-inches deep rack mount equipment enclosures. Adjacent equipment rack with side-by-side hinges on the same side of the rack (left-right) may reduce the edge-to-edge rack side by side spacing to 6-inches for the respective combined two rack location.
  6. The fixed non-moving bottom of the rack shall be securely anchored to floor.
- C. Floor Standing Equipment Racks
  1. General:
    - a. Securely anchor racks to floor.
    - b. All incoming cables shall enter through the top or bottom of the racks.
    - c. The front of the racks shall maintain a minimum of 42-inches of clear working space.
    - d. Multiple floor standing racks shall be installed directly adjacent to each other (i.e. side by side), with not less than 6-inches (edge-to-edge) space between adjacent racks.
    - e. Cables entering racks shall enter into the top of the rack from overhead cable tray, or from wall along wall support arms to rack.
  2. Floor standing metal enclosed equipment racks:
    - a. The rear of the rack shall maintain a minimum of 36 inches clear working space.

- b. Provide a minimum spacing between adjacent (edge-to-edge) racks of not less than 6-inches.
- 3. Floor standing open (non-swing gate) equipment racks.
  - a. The rear of the rack shall maintain a minimum of 54-inches clear working space behind the rack frame rails for adequate installation depth of HUBS/switches equipment, for "walk" behind access to equipment and for cable terminations access.
  - b. Provide a minimum spacing between (edge-to-edge) racks of not less than 6-inches.
- 4. Floor standing modular frame equipment racks:
  - a. The rear of the racks shall abut against the wall, or as shown on the Drawing.

### **3.08 TELEPHONE/VOICE TERMINAL BLOCKS**

- A. The telephone/voice terminal blocks shall be assembled in vertical sections, for wall mounting. Install adjacent vertical sections with not less than 8-inch blank space between sections, for cable training space.
- B. Install terminal blocks on plywood terminal backboard with #8 x 1-inch wood screws. Minimum 6-inches on center, along each side of each terminal block.
- C. Terminal block wire pair capacity:
  - 1. The minimum wire termination capacity shall not be less than 600 pairs of telephone/voice conductors, at any telephone/voice terminal block.
  - 2. The quantity of wire pair terminations provided at each terminal block shall be based on the following formula. However, under no case shall any terminal block wire pair capacity be less than the specified minimum.
 

Total quantity of telephone/voice feeder copper wire pairs connected to the terminal board = QFP

Total quantity of telephone/voice outlets connected to terminal board - QTO

(QFP) x (QTO x 4) + (specified spares) = Minimum terminal block pair capacity.

### **3.09 MDF AND IDF CIRCUIT TERMINAL ROOMS AND CLOSETS**

- A. Terminal Backboard
  - 1. A ¾-inch thick marine "A-C" grade plywood backboard shall fully cover each wall of terminal closets and terminal rooms, including all MDF and IDF rooms/closets. Provide backboard on the wall for equipment racks, incoming cable raceways and terminal blocks. Plywood shall extend continuous from the finish floor to 8-feet above the finish floor on all walls. "A" side of plywood shall be exposed.
  - 2. Attach plywood to wall structural framing with mechanical fasteners a minimum 6-inches on center vertically on walls at each framing vertical member, and along the length of the wall, but not less than 16 inches on center horizontally along the length of the wall.
  - 3. Paint plywood terminal backboards after installation and prior to mounting any equipment. One coat of wood paint fire resistant primer and two coats of fire resistant/intumescent, non-conductive finish coats of paint. Finish color matt/ flat white, acrylic enamel fire resistant/retardant latex paint.



## B. Cable Tray

1. Locations with equipment racks, and/or terminal blocks are installed in the same room/closet (MDF or IDF).
  - a. Provide a horizontal cable tray above the equipment racks and terminal blocks in each circuit terminal room and closet.
  - b. Provide a horizontal cable tray continuous "loop" around the perimeter inside each MDF and IDF room, within 12-inches of the ceiling. Parallel with and adjacent to all walls in the room.
2. Ladder type cable tray 18 inches wide by 6 inches deep; length-end wall to end wall, of the closet or room.
3. Install the cable tray centered above all equipment racks, and around the room perimeter at ceiling/ walls and terminal blocks with ceiling and wall suspension system. Install trays not more than 36-inches above and not less than 12-inches above the top of the equipment racks.
4. Where multiple segments of cable trays occur in terminal closets and rooms, provide interconnecting cable trays between each segment located in the respective room/closet.

## C. Conductor Training and Support

1. Provide conductor/cable training and racking support distribution rings installed on backboards. As manufactured by Newton 3042 series, Saunders or equal.
2. Support rings shall be spaced a minimum of 10-inches on center along all cable/conductor routing paths on backboards and within 4-inches of each change in cable/conductor direction.
3. The capacity of support rings shall be equal to the weight and quantity of conductors/cables passing through the respective support ring plus 100% spare capacity for installation future conductors/cables. In no case shall support rings be smaller than 3 inches.
4. Attach support rings to backboards with not less than two 3/8-inch diameter by 1½-inch long threaded wood anchor bolts for each individual bracket.

## D. Environment Space Monitoring (MDF and IDF)

1. In each room/closet provide one automatic environmental monitor. Self-calibrating, simultaneous monitoring and software programmable, with alarm set points. Shall measure and monitor ambient conditions and provide data-logging for conditions in the space for the following:
  - a. One ambient temperature port and plug-in indoor sensor.
  - b. One ambient humidity port and plug-in indoor sensor.
  - c. One spare plug-in port for an external digital sensor.
2. Digital Fast Ethernet LAN RJ-45 communications port, with alarm alerting and communications software for remote monitoring of the ambient conditions via the LAN. Multi-user site wide software license, compatible with PC-computer and IP-WEB HTTP remote operations.
3. Local internal audio and visual alert annunciators, with local silence and reset.

4. 120 volt, 60Hz AC input power supply operation. Equipment rack mount self-contained unit housing configuration. Provide all interconnect cabling and connectors.
5. Provide the environmental unit in one of the equipment racks located in each of the respective spaces.
6. As manufactured by Avtech-Room Alert; or SensaTronic-Environmental Systems; or IT Watch Dog-Climate Monitors.

### **3.10 GROUND (ADDITIONAL REQUIREMENTS)**

#### **A. Electronic Equipment MDF, IDF and Terminal Rooms and Closets**

1. Terminal Equipment Ground Bus (TEGB) - Provide a wall mounted TEGB ground bus in each MDF location. Also provide a TEGB where two or more equipment racks and/or terminal blocks are provided in each IDF. The TEGB ground bus shall be copper ¼-inch by 2-inches (nominal) by 12-inches long (minimum). Install the TEGB on the wall with a minimum of two "stand-off" electrical insulators. Drill and tap the ground bus and provide bolted type ground lugs for connection of each ground conductors size #10AWG - #1AWG. Provide four spare unused ground lugs on the TEGB.
2. Provide 1.25-inch conduit with 1#1AWG copper insulated ground conductor from the TEGB homerun to the building main ground reference bus. Provide 1.25-inch conduit with 1#1AWG copper insulated ground conductor from the TEGB homerun to the nearest building main structural steel member and to the nearest metal cold water pipe larger than 0.6-inch diameter pipe.
  - a. Provide the same ground connections from the equipment rack ground bus where only a single equipment rack occurs in the IDF location.
3. The ground conductor required from the TEGB to the building main ground reference bus may be looped and connected between separate TEGB ground bus locations if all of the following conditions are met.
  - a. The ground conductor is increased to 1.5-inch conduit with 1#2/0AWG copper insulated and the total end to end length does not exceed 300-feet.
  - b. The building exceeds two floors in height.
  - c. Not more than four TEGB buses are connected to the same "looped" ground conductor.
  - d. The TEGB ground conductor is continuous (not cut, spliced or broken) along its entire length.
  - e. The TEGB ground conductor is connected to the TEGB ground buses with a UL listed "Exothermic" welding process.

#### **B. Equipment Racks:**

1. Provide a separate 12AWG copper stranded green insulated ground conductor from each individual equipment element in the rack to the respective rack ground bus.
2. Provide a separate #8AWG copper insulated ground conductor from each equipment rack ground bus to the TEGB terminal equipment ground bus located in the same space.
3. Where only one equipment rack is installed, provide 1.25-inch conduit with 1#1AWG copper insulated ground homerun conductor from the equipment rack ground bus homerun to the building main ground reference bus and provide 1.25-inch conduit with 1#1AWG copper insulated ground conductor from the TEGB or single equipment rack

ground bus (as applicable), to the nearest building main structural steel member and to the nearest metal cold water pipe larger than 0.6-inch diameter pipe.

4. Provide 1.25-inch conduit with 1#4AWG copper insulated ground conductor from each wall mounted fiber interface cabinet to the respective TEGB ground buses.
  5. Provide a 1#10AWG copper insulated ground conductor connecting in a continuous loop to all miscellaneous cable trays and metal support equipment located in the terminal closet or room and connect to the TEGB ground bus.
- C. Telephone/Voice Terminal Blocks:
1. Provide a separate #8 copper insulated ground conductor from each terminal block section ground bus to the TEGB terminal equipment ground bus.
  2. Provide a separate #6 copper insulated ground conductor from the terminal room/closet to the lightning ground system.

### **3.11 WALL MOUNTED FIBER INTERFACE CABINET - WMIC**

### **3.12 IDENTIFICATION (ADDITIONAL REQUIREMENTS)**

- A. General
1. Fiber optic and copper wire cables shall be identified in each manhole, pull box, equipment rack, patch panel and computer workstation outlets.
  2. Infrastructure documentation, identification labels and color coding shall comply with ANSI/TIA/EIA-606A Administration Standard for Telecommunications Infrastructures, Class-1 thru Class-4. Provide management software MS-Windows-based single user license, with all as-built data entry documentation information complete.
- B. Identification tags shall include the following information:
1. Cable name as indicated on Drawings (i.e., HV1, F4, MSB3 etc.).
  2. Installation month and date (i.e., 3/92, 4/78 etc.).
  3. Conductor size conductor type (i.e., loose tube fiber; #24AWG ScTP Category 5, 200-pair, telephone/voice etc.).
  4. Feeder taps to equipment or building shall also be identified with equipment name or building (i.e. library, SW1, Rack #21, etc.)
- C. Identification Tags
1. Tags shall be 1/8-inch thick 98% lead, approximately 2-inch square with chamfered corners. Two holes shall be drilled for attachment to primary cable. Lettering shall be 1/8-inch high, engraved or die stamped. Attach tags to primary cables with two #14AWG (THWN insulated) solid copper conductors "twist-tied", with insulated CAP wire-nut on the tie-wire ends, to cover sharp edges of tie-wire conductor.
  2. Alternate identification tags, at the Contractor's option in lieu of lead tags. Provide polypropylene tag holders with interchangeable, yellow polypropylene tag with black alphanumeric characters sets. Characters shall be approximately .25-inch high. As manufactured by Almetek industries "EZTAG" - Ledgewood, New Jersey.

- D. Equipment and outlet naming identification and color-coding shall comply with ANSI/EIA/TIA latest revision.
1. Naming method for equipment, outlets and cables; where a position in the naming string is unused, provide multiple "\*\*\*\*" symbols.  
Typical naming string "ADM-02-1141-PP17-1271"
    - a. "ADM" - Abbreviated Building Name or Number (i.e., Administration, B127, etc.)
    - b. "02" - Floor Level #2 or as applicable.
    - c. "1141" - Outlet, Equipment or Terminal Room/Closet name or room number as applicable.
    - d. "PP17" - Terminal Rack Patch Panel Identification.
    - e. "1271" - Individual Outlet or Port Identification.
  2. Connecting hardware color coding shall be as follows:  
"Green" - Main central terminal location for entire site.  
"White" - Distributed terminal locations other than the main terminal.  
"Blue" - Horizontal wiring hardware systems for workstations.
- E. Provide warning nameplates on fiber optic patch panels, fiber optic outlets, and any location where fiber optic cables are terminated. Minimum 1/8-inch high engraved/etched letters.  
"WARNING - LASER LIGHT SOURCE. DO NOT LOOK DIRECTLY AT OUTLET OR FIBER CABLE ENDS. RISK OF SEVERE EYE DAMAGE OR BLINDNESS".

END OF SECTION 27 20 00  
022119/212220

This page is blank.

**SECTION 27 41 16**  
**AUDIO-VIDEO SYSTEMS AND EQUIPMENT**

**PART 1 - GENERAL**

**1.01 GENERAL CONDITIONS**

- A. The Invitation for Bids, Instruction to Bidders and General Conditions of the Contract including any supplementary conditions apply to all work under this Section.
- B. The Contractor acknowledges and warrants that he has closely examined all the Contract Documents, that they are suitable and sufficient to enable the Contractor to complete the work in the time allotted for the contract sum as accepted by the CM and AV Consultant, and that they include all work, whether or not shown or described, which reasonably may be inferred to be required or useful for the completion of the work in full compliance with all applicable Codes, Laws, Ordinances, Rules, and Regulations,
- C. Execution of the Contract by the Contractor or his Representative and warranty that the Contractor has carefully examined the Contract Documents, and represents and warrants that the Contractor is thoroughly familiar with the nature and location of the work, the site, the specific conditions under which the work is to be performed, and all matters which may in any way affect the work or its performance. The Contractor further represents that as a result of such examinations and investigations, the Contractor has thoroughly reviewed and understands the Contract Documents and their intent and purpose, and is familiar with all applicable Codes, Ordinances, Laws, Regulations and Rules as they apply to the Work, and that the Contractor will abide by same.
- D. Claims for additional time or additional compensation as a result of the Contractor's failure to follow the foregoing procedure and to familiarize it with all local conditions and the Contract Documents will not be permitted.
- E. Related Work Specified Elsewhere:
  - 1. All Division 1 Specification Sections apply to this Section.
  - 2. Power, signal conduits and back-boxes provided and installed under Division 26; except loudspeaker back-boxes and specialty back-boxes provided under this work for installation under Division 26.

**1.02 INSTRUCTIONS TO BIDDERS**

- A. Definitions:
  - 1. Bidding documents include the proposed Contract Documents, which consist of the Project Specifications herein and the associated AV Category Drawings.
  - 2. A bid is a complete and properly signed proposal to do the work as described in the Contract Documents, for the sums stipulated therein, submitted in accordance with the bidding documents.
  - 3. The work includes all tasks necessary to complete the Contract as described in the Contract Documents.
  - 4. A Bidder is a person or entity that submits a bid for coordinating and/or performing all the work as described in the Contract Documents.

5. A Sub-Bidder is a person or entity who submits a bid to a Bidder for materials, equipment, and/or labor for a portion of the work.
  6. The Owner is Compton Community College District and its affiliates and subsidiaries.
  7. The CM (CM) - Representative.
  8. The Architect is DLR Group.
  9. The AV consultant is Plan Net Consulting.
- B. Bidding Documents:
1. Copies:
    - a. The CM will issue bidding documents directly to the Bidders.
    - b. Bidders shall be responsible for providing copies of the bidding documents to Sub-Bidders to solicit services to be Sub-Contracted.
    - c. In making copies of the bidding documents available on the above terms, the AV Consultant does so only for the purpose of obtaining bids on the work and do not confer a license or grant permission for any other use of the bidding documents.
  2. Interpretation or Correction of Bidding Documents:
    - a. Bidders and Sub-Bidders shall carefully study and compare the bidding documents with each other to the extent that it relates to the work for which the bid is submitted, and shall promptly notify the AV consultant of any ambiguity, inconsistency, or error which they may discover.
    - b. Bidders and Sub-Bidders requiring clarification or interpretation of the bidding documents shall make a request to the AV Consultant through the General Contractor at least 5-working days prior to the date of receipt of bids. Requests for information (RFI) shall be written and faxed to the CM. No questions will be answered by telephone.
    - c. The AV Consultant will make clarifications by Addendum and/or by written response if deemed necessary.
  3. Addenda:
    - a. Each Bidder shall ascertain, prior to submitting a bid that the Bidder has received all Addenda issued, and the Bidder shall acknowledge their receipt in the bid.
    - b. Consideration of bids
  4. Rejection of Bids:
    - a. The CM and the AV Consultant shall have the right to reject any or all bids and to reject a bid not in compliance with Bidding Procedures and Requirements, no accompanied by data required by the bidding documents, or in any way incomplete or irregular.
    - b. The CM and the AC Consultant shall also have the right to reject any or all bids when, in their judgment, it is in their best interest to do so.
  5. Acceptance of Bid:
    - a. The CM and the AV consultant will be the final judge of which bid is accepted.
    - b. The CM and the AV consultant shall have the right to waive informalities or irregularities in a bid received and to accept a bid which, in their judgment, is in their best interest.

C. Related Documents

1. Drawings and General Provisions of the Contract, including general and supplementary conditions and Division 1 Specification Sections, apply to this Section.
2. Audio-Visual Drawings provide additional General Construction Requirements.
3. Exhibit B: Major Equipment and Approved Manufacturers List.
4. Specification 27 41 30 — Assistive Listening Systems (ALS).

**1.03 SUMMARY OF WORK**

- A. The AVC shall provide the AV system designs using the Owner furnished Contractor installed (IOFCI) to provide a complete turn-key solution with the equipment specified and additional parts required for a functional system.
- B. Classroom Type 1 — Short Throw Projector
  1. The audio-visual systems shall provide capability for presentations, and both audio and video playback. The following describes the equipment and capabilities of this room.
    - a. Video reproduction shall be via one wall-mounted 3300 lumen projector 800, 16:10 aspect ratio). The image shall be projected on an OFE whiteboard with the image filling the whiteboard top to bottom and the width as much as possible.
    - b. Stereo audio sources shall be summed and reproduced via four recessed loudspeakers in the drop tile ceiling. Audio content shall be a monaural output and evenly distributed through-out the ceiling using a 70V audio amplifier built into the switcher; the speakers shall be secured with a minimum of one seismic wire on each speaker to the hard-lid ceiling above the drop tile ceiling.
    - c. There shall be an Assisted Listening System (ALS) in each classroom with an inferred (IR) radiator and IR receivers (Stethoscope receiver, and Neck Loop for a T-Coil) for use by students with a hearing impairment.
    - d. There shall be one wireless lapel type microphone for use in the classroom. This shall be used for capturing the Instructor's voice for the ALS system and voice reinforcement for soft spoken instructors.
    - e. Sources shall include inputs with a HDMI and VGA/stereo audio cables for laptops and other portable equipment like a document camera if available.
    - f. There shall be one cable cubby in the AV rack/cart with one set of multimedia input cables (HDMI, VGA/stereo audio cables). These shall be located on the top of the rack/cart; the location in the top of the rack/cart shall be confirmed with the client and the cut out opening for the cubby shall be provided by the AVC.
    - g. There shall be a rolling AV rack/cabinet with doors front and back and a slim power strip with basic surge protection to house the AV equipment, cable cubby with control panel.
    - h. Control of the AV equipment and projector in the room shall be via control system in the AV switcher/scaler and through the control panel in the top of the cable cubby. The control system shall control source selection, ON/Off functionality for the complete system from a single button, room volume control, microphone volume level, and display image freeze if available. When a source button is pressed on the control panel, the displays shall turn on, switch to the appropriate input. Sources that have additional functionality or messages shall have a pop-up window with



additional controls or text for the button that was pressed (Laptop — HDMI, Laptop VGA, Help Desk) to guide the user for additional action.

**B. Classroom Type 2— Ceiling Mounted Projector**

1. The audiovisual systems shall provide capability for presentations, and both audio and video playback. The following describes the equipment and capabilities of this room.
  - a. Video reproduction shall be via one ceiling-mounted 5000 lumen projector (1280 x 800, 16:10 aspect ratio). The image shall be projected on an OFE whiteboard with the image filling the whiteboard top to bottom and the width as much as possible.
  - b. Stereo audio sources shall be summed and reproduced via four recessed loudspeakers in the drop tile ceiling. Audio content shall be a monaural output and evenly distributed through-out the ceiling using a 70V audio amplifier built into the switcher; the speakers shall be secured with a minimum of one seismic wire on each speaker to the hard-lid ceiling above the drop tile ceiling.
  - c. There shall be an assisted listening system (ALS) in each classroom with an inferred (IR) radiator and IR receivers (Stethoscope receiver, and Neck Loop for a T-Coil) for use by students with a hearing impairment.
  - d. There shall be one wireless lapel type microphone for use in the classroom. This shall be used for capturing the instructor's voice for the ALS system and voice reinforcement for soft spoken instructors.
  - e. Sources shall include inputs with a HDMI and VGA/stereo audio cables for laptops and other portable equipment like a document camera if available.
  - f. There shall be one cable cubby in the AV rack/cart with one set of multimedia input cables (HDMI, VGA/stereo audio cables). These shall be located on the top of the rack/cart; the location in the top of the rack/cart shall be confirmed with the client and the cut out opening for the cubby shall be provided by the AVC.
  - g. There shall be a rolling AV rack/cabinet with doors front and back and a slim power strip with basic surge protection to house the AV equipment, cable cubby with control panel.
  - h. Control of the AV equipment and projector in the room shall be via control system in the AV switcher/scaler and through the control panel in the top of the cable cubby. The control system shall control source selection, ON/Off functionality for the complete system from a single button, room volume control, microphone volume level, and display image freeze if available. When a source button is pressed on the control panel, the displays shall turn on, switch to the appropriate input. Sources that have additional functionality or messages, a pop-up window with additional controls or text for the button that was pressed (Laptop — HDMI, Laptop VGA, Help Desk) to guide the user for additional action.

**C. Conference Rooms**

1. Conference Rooms shall allow the end users to conduct meetings and presentations; there shall be sources such as a laptop, and other auxiliary portable equipment.
2. The Contractor shall provide and install one wall mounted 55-inches consumer LED flat panel display with a resolution of 1920 x 1080 (16:9) in the conference room.
3. Stereo audio sources shall be summed and reproduced via two loudspeakers mounted in the ceiling. Audio content shall be a monaural output and distributed throughout the

ceiling using a 70V audio amplifier built into the switcher; the speakers shall be secured with a minimum of one seismic wire.

4. Audio and video from inputs in the flip-top cubby on the rack/cabinet shall be reproduced via the ceiling mounted speaker.
5. There shall be an assisted listening system (ALS) in the conference room with an inferred (IR) radiator and IR receivers (Stethoscope and Neck Loop for a T-Coil) for use by people with a hearing impairment.
6. There shall be a rolling AV rack/cabinet with doors front and back and a slim power strip with basic surge protection to house the AV equipment, cable cubby with control panel.
7. One flip-top cable cubby shall be mounted into the rack/cabinet in the conference room and shall connect laptop computers and other auxiliary video equipment. The Contractor shall coordinate the integration of the cubbies into the rack/cabinet with the Architect and Owner. The cable cubby connections shall be VGA with stereo audio and HDMI connection. Power and data connections shall also be available at the cable cubby.
8. The opening in the rack/cabinet top for the flip top cable cubby shall be provided by the AVC. Before cutting the openings in the table top the Contractor shall provide a Drawing of the table top indicating the cubby location for review and signoff by the CM and Owner. Before actually cutting the Contractor shall markup the cubbies locations on the table top before making the first cut in the table top for a final review by the Client.
9. One set of multimedia input cables (HDMI, VGA / stereo audio) shall be available for connection of auxiliary portable devices such as laptop computers in the room.
10. Control of the AV equipment and projector in the room shall be via control system in the AV switcher/scaler and through the control panel in the top of the cable cubby. The control system shall control source selection, ON/Off functionality for the complete system from a single button, room volume control, microphone volume level, and display image freeze if available. When a source button is pressed on the control panel, the displays shall turn on, switch to the appropriate input. Sources that have additional functionality or messages shall have a pop-up window with additional controls or text for the button that was pressed (Laptop — HDMI, Laptop VGA, Help Desk) to guide the user for additional action.

#### D. Paging System

1. There shall be a paging system speaker provided by the AVC and installed by the GC. The paging speakers shall be installed in the Lobby, and hallways (public and office areas) on the first and second floors. Refer to Sheets T2.01 and T2, 02 for the approximate speaker locations.
2. The headend of the paging system shall be in the IDF room with the telephone systems. The AVC shall confirm the rack location and the connection to the telephone system for a line level output for the mixer/DSP unit. The AVC shall work with the Colleges' IT Department to set-up and test the connection to the telephone system, and test the paging levels in all areas.

#### **1.04 SCOPE**

- A. Supply and install sound and video systems including all apparatus and equipment, wiring, termination, labor, and services required to provide systems as specified and shown on Drawings.
- B. If equipment has been discontinued or at “end of life”, the equipment shall be substituted with the newest like model available from the same Manufacturer. If a different Manufacturer or model of equipment is to be substituted, the substitution must be reviewed by the Consultant and Client for approval.
- C. Supply and install any incidental equipment needed in order to meet the Functional Requirements stated herein and on Drawings. This shall include all support and restraint for the fixed loudspeakers and projection equipment.
- D. Set up and adjustment of specified hardware and software.
- E. Furnish all test equipment and the services of the Project Engineer and the Project Manager to assist the CM’s Representative in the acceptance testing.
- F. Make any adjustments to any part of the system, including the re-aiming of loudspeakers, which may be found necessary during the acceptance testing.
- G. Provide training in the operation of the systems to the person or persons selected by the CM.

#### **1.05 COORDINATION:**

- A. Schedule installation operations in sequence required in order to obtain best completion results.
- B. Coordinate the procurement and installation of the projection screens, projector mounts and all loudspeakers with the CM and Owner.
- C. Coordinate installation of different components to assure maximum accessibility for required maintenance, service, and repair.
- D. All specialty Sub-Contracting including coordination of all Telecommunications lines with other Sub-Contractors and equipment as shown on the Contract Documents to be coordinated by the Contractor.

#### **1.06 EQUIPMENT AND MATERIALS**

- A. The Contractor shall verify characteristics of elements of interrelated equipment specified under this Section are compatible; coordinate work having interdependent responsibilities for installing, connecting to, and placing in service, such equipment.
- B. By making requests for substitutions, the Contractor:
  - 1. Represents that he has personally investigated the proposed substitute product and determined that it is equal to or superior in all respects to that specified.
  - 2. Represents that he will provide the same warranty for the substitution that the Contractor would for that specified.
  - 3. Certifies that the cost data presented is complete and includes all related costs under this Contract, and waives all claims for additional costs related to the substitution which may later become apparent.
  - 4. Will coordinate the installation of the accepted substitute, making such changes as may be required for the Work to be complete in all respects, including, but not limited to, in

full compliance with all applicable Codes, Laws, Ordinances, Rules, and Regulations and completion in the time allotted for the Contract sum as accepted by the CM and AV Consultant.

### **1.07 SCHEDULE**

- A. Within 10-calendar days of the receipt of the "Notice to Proceed" the Contractor shall prepare and submit for approval, in accordance with the general conditions, a schedule which shall include, but is not limited to, the following:
1. Submission of Shop Drawings, samples and layouts for all items described herein.
  2. Start and Completion date(s) for field installation work.
    - a. Installation date(s) of all wires and cables in conduits and required cable trays.
    - b. Date when fully-operational equipment racks will be fully tested and ready for Consultant's observation.
    - c. Delivery date(s) of all systems and subsystems to the project site.
  3. Start and completion date(s) for shop fabrication work.
  4. Date of submission of samples for approval by the architect of all finishes/materials which will be visible to the public. Refer to Part 1 paragraph 1.8 entitled "Submittals" for additional information.
  5. Programming of all remote control and digital signal processing driven devices.
  6. Completion dates(s) for the following tests:
    - a. Performance tests on all individual AT components as they are received from the Manufacturer in the Contractor's shop.
    - b. Performance tests on completed assemblies and subassemblies assemblies, including all racks in the Contractor's shop,
    - c. Performance tests on the completed systems as a whole prior to shipment to the Project Site.
    - d. General performance testing of systems at the Project Site.
  7. Completion dates for the following shop and field observations.
    - a. Shop fabricated assembly and subassembly observation.
    - b. Substantial completion observation at the ProjectSite.
    - c. Final acceptance observation at the ProjectSite.
  8. Submission date for operating, maintenance manuals, As-Built Drawings, documentation and closeout materials.
- B. In the event the Contractor wishes to deviate from the schedule once it is established and approved, he may do so only after receiving written approval from the CM.

### **1.08 SUBMITTALS**

- A. All submittals shall be in accordance with the General Provisions of the Contract, including general and supplementary conditions and other Division 1 Specification Sections.
1. AV consultant will not review partial submittals.
  2. AV consultant will review up to two submittals of any one submittal topic.

- B. Substitutions of equal equipment beyond the alternatives listed will be permitted only in accordance with Division 1. If a requested substitution requires a change in any of the Contract Drawings, a revised Drawing must be submitted as part of the substitution request. If an alternative listed is discontinued prior to installation, the Contractor shall submit a substitution request to provide the Manufacturer's replacement model. The AV Consultant shall be the final judge of the acceptability of substitutions.
- C. All Drawings shall be clear and legible. The minimum text size for all Drawings shall be 1/8-inch high.
- D. Post Award Submittals: submit within 60 days of award.
  - 1. Submit electronic reproducible Drawings (as .dwg and .pdf), documents (as .pdf) and software as per Manufacturer's directions of the following:
    - a. A statement of Sub-Contractors, Franchises, Distributorship, Dealerships, Arrangements and Agreements with Manufacturers of equipment to be used for this work.
    - b. Complete bill of quantities, including all material, components, devices and equipment required for this work. The bill of quantities shall be tabulated respective of each and every system as specified, in the order of the Specification Section 2 below, and shall contain the following information for each item listed:
      - 1) Quantity
      - 2) Description
      - 3) Manufacturer's name and model number
      - 4) Manufacturer's specification sheet
  - 2. Samples of approval by the Architect of all finishes/materials which will be visible to the public. Including at least receptacles and controls with associates trim plate and each type of loudspeaker baffle and/or grille.
  - 3. Schedule for work as described herein showing all major milestones.
  - 4. Floor Plans, at scale of Contract Documents, showing the locations throughout the Project of all receptacles, conduits, wireways, trays, pull boxes, junction boxes, equipment racks equipment and other devices with appropriate designations and fill.
  - 5. Riser diagrams, showing all elevations, room numbers, conduit sizes, types and fills, box sizes and types, devices, equipment and rack designations.
  - 6. Functional Diagrams: single-line block diagram showing interconnection of all components, receptacles, terminal blocks, controls, transformers and loudspeakers in addition to the active elements. Include terminal and cable numbers, all system and component labels. Show detailed system component information including but not limited to Manufacturer's name, model number, any specialized part number option and all input and output connection information, for each piece of equipment. No Drawing codes shall be permitted. Mount one full-scale original or photograph (not blueprint) copy behind acrylic in the control booth for each system.
  - 7. Equipment rack elevation Drawings scaled (1½-inch = 1-foot-0-inch or larger):
    - a. Front Elevations: include equipment designation, Manufacturer's name, model number, rack location and rack designation.
    - b. Rear Elevations: include AC power wireways and route of wiring harnesses.

8. Samples for approval by the Architect of all finishes/materials that will be visible to the public including at least receptacles and controls with associated trim plate and each type of loudspeaker baffle and/or grille.
  9. Cable schedules and run sheets, associates with each equipment rack and/or any isolated piece of equipment or device, including cable designation, type, Manufacturer and Manufacturer's type number, wire color, device and terminal designation and device location, keyed to both the system block diagram and Equipment Rack Elevation Drawings.
  10. Contractor fabricated items, Detailed Drawings showing all components, devices and equipment, including dimensions, component values, terminal designations, types, locations, Manufacturer's name and model number.
  11. Loudspeaker cluster and monitor loudspeaker supports stamped and signed by an Engineer licensed in the Project State. Include all loads, location of attachment to building structure, complete layout of all components, devices and equipment, including dimensions, methods of assembly, and connections to supporting construction, details of hardware, locations, Manufacturer's name and model number. All design calculations, loads, etc. shall be shown. Drawings shall be ¼-inch = 1-foot-0-inch scale minimum. Permissible scales shall be ¼-inch, ⅜-inch, 1-inch, 1½-inch, and 3-inch = 1-foot-0-inch and full scale.
  12. A bound volume or volumes of Comprehensive Specifications for all material, devices, components and equipment selected for use in this Section, whether modified or not, provided as required under "Post Award Submittals" above.
  13. Control panel Layouts: Developed Drawings of all control system panel layouts.
- E. Digital Signal Processor (DSP) System Submittal for CM Review:
1. Prior to programming the Digital Signal Processing (DSP) system, the Contractor shall submit Shop Drawings per the project standards showing all screen layouts and control descriptions of all system functions to the CM for review and comment prior to actual programming of the system. Shop Drawings shall include screen layouts of the DSP software "control pages" for all "configuration-presets" and "parameter-presets". Submit electronic versions of the DSP software to the Consultant for review and approval. The Contractor shall incorporate all CM comments into the programming of the systems.
  2. Prior to delivery of the systems to the job site, the Contractor shall demonstrate fully functioning systems in the Contractor's facilities that include the DSP system programming. This demonstration shall coincide with the CM's Representatives observation of completed sub-assemblies (Refer to Part 3 paragraph entitled "System Performance Tests"). The CM will review and comment upon the remote control programming, and the Contractor shall incorporate all CM comments into the programming of the systems.
  3. After the installation of the AV systems has been deemed substantially complete, but prior to final acceptance of the system, the CM shall have a review period of 30-days to observe the operation of the DSP system. At the end of this review period, the CM may request programming changes relating to the look and feel of the operation pages or the functionality of commands. The Contractor shall make these changes prior to acceptance of the systems.

F. Control System Submittal for CM Review:

1. Prior to programming the remote control system, the Contractor shall submit Shop Drawings per the Project Standards showing all control screen layouts, graphical user interfaces (GUI) and control descriptions of all remote control system functions to the CM for review and comment prior to actual programming of the system. Submit in native file format and hard copy form. Shop Drawings shall include control screen layouts of the touch panel pages for each venue, web page layouts (as required in Part 2 below). Submit electronic versions for CM review. The Contractor shall incorporate all CM comments into the programming of the systems.
2. Prior to delivery of the systems to the job site, the Contractor shall demonstrate fully functioning systems in the Contractor's facilities that include the remote control programming. This demonstration shall coincide with the CM's Representative observation of completed sub-assemblies (Refer to Part 3 paragraph entitled "System Performance Tests"). The CM will review and comment on the remote control programming submittal, and the Contractor shall incorporate all CM comments into the programming of the systems.
3. After the installation of the AV systems has been deemed substantially complete, but prior to final acceptance of the system, the CM shall have a review period of thirty days to observe the operation of the remote control system. At the end of this review period, the CM may request programming changes relating to the look and feel of the remote control panels or the functionality of commands. The Contractor shall make these changes prior to acceptance of the systems.
4. Digital Signal Processing and control system programming files, touch panel, and other control page and Graphical User Interface layouts in native file format and hard copy form,

G. Shop Test Statement Submittals:

1. Submit electronically - photographs and state of the following prior to shipping fabricated equipment racks to Project site:
  - a. A bound volume, or volumes, of results of performance tests and adjustment data, including all test procedures specified in Part 3 paragraph Reference source not found entitled "System Performance Tests". Example shop test statement submittal templates are available from the AV consultant upon request.
  - b. Submit a written request for equipment rack observation certifying that equipment racks are completely assembled, tested and ready for inspection.
  - c. Detailed interior and exterior photos of assembly supporting claim for readiness for inspection.

H. Final Submittals: Submit the following Record Drawings developed from the final "As-Built" systems:

1. Two copies and one reproducible of each of the Block Diagrams, Plans, Risers, Patch Bay Drawings, Rack Elevations, Cable Schedules and Detail Drawings. All reproducible Drawings shall be submitted on CD-ROM.
  - a. One complete set of Functional diagrams 1/2z size Drawings.
  - b. One additional set of Rack Elevation Drawings and sheets provided in the Drawing package.

2. No more than 30-days after Acceptance Testing, submit two copies of each of the following equipment cut sheets and manuals prior to, and as a Requirement of, CM acceptance of the work of this Section:
  - a. Equipment operating instructions; complete, comprehensive instructions for the operations of all Contractor-fabricated devices and equipment items provided as part of the work of this Section.
  - b. Manufacturer's cut sheets, installation, operating and service information including schematic diagrams for each item of equipment furnished. Order the equipment manuals in the order of the Specifications. Provide tabs between each equipment manual. Provide a detailed index at the front of each manual indicating Specification reference number. Manufacturer's trade name, model number and part description. Provide two copies to the CM after they have been reviewed and approved by the AV Consultant.
  - c. Printed material within Contractor-fabricated equipment and systems operating manuals shall be bond paper copies, offset or letterpress printed. Drawings, charts and graphs shall be bond paper offset printed. The Systems Contractor-fabricated equipment instruction manuals shall be composed using a single, consistent visual format and writing style; text shall be derived from Component Equipment Manufacturer's instruction manuals and may include reproductions of artwork and other materials.
3. Submit two copies of each of the following schedules, lists, and data prior to, and as a Requirement of, CM acceptance of the work of this Section:
  - a. All source code for any Contractor provided or programmed equipment on CD-ROM.
  - b. Final bill of quantities; complete bill of quantities all material as delivered, including a separate schedule of portable equipment.
  - c. Equipment schedule; complete, final schedules of equipment and devices provided in each room, by room number and name.
  - d. Performance, test and adjustment data; comprehensive documentation of all performance verification and correction procedures and measurements, including raw and equalized house curves and equalizer settings.
  - e. Maintenance and spare parts schedules; a comprehensive tabulation of equipment, devices, miscellaneous parts and maintenance items, including Manufacturer's name, address, model number, systems use and miscellaneous information,
  - f. No more than 30-days after Acceptance Testing, provide one copy of the following:
    - 1) Certificates; any and all licenses, certificates of operation and/or compliance as required.
4. The system will not be accepted until these documents are reviewed and approved by the CM's Representative.

### **1.09 QUALITY ASSURANCE**

- A. Unless otherwise stated, all electrical, electronic and optical equipment shall be a product of firms regularly engaged in the manufacture of electrical, electronic or optical equipment. The equipment shall be the latest model or type offered which meets the applicable Specifications at the time of the submittal. Discontinued items replaced by newer models or versions are prohibited and should not be submitted for review. It shall be the Contractor's responsibility



to provide the AV Consultant with information regarding discontinued products listed as alternatives in the Specification. If an alternative listed is discontinued prior to installation, the Contractor shall submit a substitution request to provide the Manufacturer's replacement model.

- B. Quality of workmanship and fabrication of all equipment and components, which are custom fabricated shall be comparable to professional equipment produced by specialized Manufacturers of the trade involved and shall be verified by observation. Only firms having 10 years' experience in all aspects of the fabrication and installation of similar systems shall be allowed to perform the work.
- C. All materials and products shall be new and of professional quality. Unless specifically stated in the Drawings or Specifications, no existing or pre-owned materials shall be installed.
- D. The work specified herein, and in each of the allied Sections, shall be accomplished by a single Contractor experienced in the design, fabrication, installation, checkout and Warranty Contract management of systems such as those described in each Section. This Contractor shall have complete responsibility for the systems described herein and shall be the single Contract point for the Architect, the AV Consultant and/or the CM with respect to all work specified herein.

#### **1.10 WARRANTY AND SERVICE**

- A. The Contractor shall warrant the installation free of faulty workmanship.
- B. All components, including solid-state devices, warranted free of defects for a period of 1-year from date of final acceptance. This minimum warranty provision shall not diminish the terms of individual Equipment Manufacturers' warranties.
- C. Paint and exterior finishes, fuses and lamps excluded from above warranties except when damage or failure results from defective materials or workmanship covered by warranty.
- D. Provide maintenance service for a period of 1-year after acceptance of installation. Service to consist of at least two semiannual visits to the site software updates, and equipment adjustments. These visits should be coordinated with CM or Representative.
- E. Service request response time: Provide 2-hour via telephone / email, with 24-hour on-site technical response time. Provide a Technician on call from 7 a.m. to 9 p.m. 5-days a week.
- F. All repairs must be completed within 10 business work days. If repairs cannot be completed within 10 working days, a replacement/loaner must be provided. If it cannot be resolved within the 10 days, the CM or CM Representative will have the option of getting it repaired with the Contractor covering the costs.

### **PART 2 - PRODUCTS**

#### **2.01 GENERAL:**

Appendix A - Refer to the attached Major Equipment and Approved Manufacturers List.

## **PART 3 - EXECUTION**

### **3.01 INSTALLATION**

- A. The following Installation Requirements shall govern the design, fabrication and installation of the system(s) specified herein. In case of a discrepancy between these overall System Standards and the individual equipment item Specifications, the latter shall govern:
  - 1. The equipment specified shall be installed according to Standards of good human engineering practice and the conditions specified herein.
  - 2. Workmanship on the installed systems shall be of professional quality, best commercial practice and accomplished by persons experienced in the Techniques and Standards of the particular industries involved.
  - 3. The Specifications describe required performance. The Specifications with the Contract Drawings indicate a general design; it is the intention of the Specifications that the Contractor will supply from his background of experience and knowledge the necessary supporting details; for example, the implementation of specific components into functioning sub-systems.
  - 4. In general, the Drawings show dimensions, positions, and kind of construction. The Specifications describe materials, qualities and methods. Any work called for on the Drawings and not mentioned in the Specifications, or vice versa, shall be performed as though fully set forth in both. In case of differences between the Drawings and the Specifications, the decision of the CM's Representative shall govern. Work not particularly detailed, marked or specified shall be construed to be the same as similar parts or areas that are detailed, marked, or specified.
- B. Equipment markings shall present only needed information and be readable from the Operator's normal work position. These markings shall be designed to minimize ambiguous interpretation.
- C. Control panels shall be designed to reduce chances of human error and controls shall be natural and consonant with normal operator expectations.
- D. All control consoles and their panel mountings shall be provided with the necessary controls, indicators and switches, etc., as outlined in the pertinent sections of this Specification. The grouping of these facilities shall be in accordance with the Associated Drawings and shall, in all cases, be arranged to present an orderly, functional appearance. The layout of controls shall be such that priority of accessibility shall be given to those facilities which frequently require attention.
- E. The total design of the system shall simplify the Operator's task and insure maximum performance and reliability while minimizing possibilities for human error and providing a comfortable environment for the operator during operation.
- F. At the operational level (i.e., patch panels, AV equipment receptacle boxes, etc.) all receptacles shall be clearly marked by function and number. When there are multiples of the same function for example, a given microphone line may appear at several locations, the same label shall be shown at each location.

### **3.02 THE CONDUIT SYSTEM:**

- A. The AV Category Drawings indicate the number, type and location of the receptacle. Wire and Cable Requirements and Equipment Room layouts, which are the responsibility of the Contractor. The conduit diagrams indicate schematically the functions served by the conduit system. Also, the conduit diagrams may indicate the locations at which functions are served at several locations in the facility. See the general installation notes for additional Information and Requirements as shown on the AV category Drawings.
- B. The Electrical Contractor is bound to provide the conduit system shown on the AV Category Drawings as part of the Base Building Contract.
  - 1. If any portion of the conduit installation is concurrent with the AV Contract, the Contractor shall inspect the work at appropriate times during construction and report any discrepancies to the architect and CM in writing. The Contractor shall coordinate the exact location of intermediate collector boxes behind the equipment rack with the Electrical Contractor.
  - 2. The Electrical Contractor is bound to verify continuity of all conduits as described in the AV category Drawings with a yellow pull string.
- C. The Contractor shall be responsible for supplying any additional conduit that may be required to complete the system installation in accordance with the Drawings.
- D. It shall be the responsibility of the Contractor to obtain the exact location of any pull boxes, "LBs" or other intermediate locations from the Electrical Contractor.
- E. The Contractor shall also verify that conduits are adequate for the wiring and functions specified. If the Contractor substitutes the specified wiring the Contractor shall bear the sole responsibility for reengineering the conduit system,
- F. The Contractor shall field verify all back box installation conditions on site and shall size connection panels as described below. Notify the CM and AV Consultant of any discrepancies between AV Drawings and installation conditions.
  - 1. Surface Mounted Back Boxes: Connection panels shall be sized to match the outer edges of the installed back box and shall have smooth edges.
  - 2. Recessed Mounted Back Boxes: Connection panels shall be sized to overlap the outer edges of the installed back box by 1-inch in both horizontal and vertical directions and shall be installed tightly against the wall surface finish,
- G. Each conduit shall contain wires or cable of the same signal level or the same type of circuitry only. Each separate service level designation shown on the AV conduit riser shall be run in their respective, separate conduits and all conduit landings in backboxes or equipment racks shall be grouped by service level.
- H. Ground power conduits to the power system ground. Do not connect power system conduits to the racks or to the audio system ground.

### **3.03 EQUIPMENT RACK ASSEMBLIES:**

- A. General:
  - 1. Equipment rack shall be completely assembled, tested and programmed in the Contractor's shop. No rack assembly shall be performed at the Project Site. After the equipment rack is tested the Contractor shall notify the CM's Representative in writing

that the equipment rack assemblies are ready for observation and approval. Allow adequate time for any modifications necessary to satisfy the Contract Drawings and Specifications.

2. Use rear and mid rails for intermediate terminations. Maintain accessibility to the rear of the equipment.
3. Mid rails must be used to support equipment weighing more than 50 pounds.

B. Wiring Harnesses:

1. Equipment rack wiring shall be "Harness" style. "Point to Point" rack wiring is not acceptable. The individual wiring harnesses shall be located at the rear of the equipment rack on the sides and individual pairs of cable shall be broken out on to lacing bars to the back of the equipment to the connectors.
2. Electrical service levels shall not be mixed in an individual harness. It is the intent that there will be a separate harness for each electrical service level.
3. Great care shall be exercised to keep low level signal harnesses separated from the AC power lines and high level signal harnesses.

C. Equipment Labels:

1. Rack-mounted equipment shall be labeled on front and back, as to function using engraved black/white laminated plastic blocks. For example: LEFT HI- FREQ AMPLIFIER or CENTER EQUALIZER.
2. Use permanent professional quality labels such as "Gravelply" or approved equal. Stick-on strip labels such as those from Dyno or Brother are not acceptable.

D. Internal A/C Receptacles:

1. Maintain grounding as described in the herein.
2. Locate all internal AC receptacles on the left side of the rack and all harnesses on the right side of the rack. In the event that there are two equipment racks side by side locate the AC receptacles in the middle of the equipment racks and the wiring harnesses to the outer sides.

E. Installation:

1. No equipment may be installed prior to the following:
  - a. The AV Consultant has performed the AV equipment rack observation in the Contractor's shop.
  - b. Any and all punch list items described as 'minimum to enable rack delivery to site' have been addressed, proof has been submitted to AV consultant, and AV consultant has approved rack delivery to site.
  - c. Notice has been filed with the CM, the Architect, and the AV Consultant that a 'dust-free' environment has been achieved in the project in all areas where audiovisual system equipment is to be installed. Dust-free shall be defined as follows: all floor, wall, ceiling construction, millwork, finishes (including paint), carpet, hardware, electrical, and HVAC is absolutely complete (and tested and fully operational in the case of electrical and HVAC systems) before AV equipment racks may be delivered to the site.

2. All stationary equipment rack(s) shall be secured to the building structure to meet Seismic and Code Requirements.
  3. Great care shall be exercised to keep low level signal lines separated from the AC power lines and high-level signal lines.
  4. All audio field lines entering the equipment rack must be connected to equipment. Video field lines may be connected directly to the switcher or patch bays. In the event that a patch bay with an E3 or E90 connectors is used, the patch bay may serve as the terminal block. This will also facilitate the testing of the systems in the Contractor's shop.
  5. All connections of lines at terminal blocks, as well as at signal receptacles, shall be mechanically secured and then soldered. No unsoldered connections shall be permitted. Where lines approach the racks and terminal blocks they shall also be mechanically anchored at the rack, and provided with sufficient slack length to avoid strain, abrasion or wear.
- F. Wiring and Cabling:
1. Extreme care must be taken to physically segregate and separate all high level lines from lower level lines,
  2. Control cables and power distribution wiring shall not be installed adjacent to signal cables. Power distribution cabling shall be on the opposite side from signal wiring in equipment enclosures and shall be uniformly located throughout an installation.
  3. All wire and cable utilized in systems interconnection shall be of the flame- retardant type (FR-1 flame test).
- G. Penetrations of Cabling in Construction:
1. All cabling or system interconnection which passes through or into acoustically isolated areas, such as sound locks and studios, shall be suitably sealed after cable has been installed.
  2. Contractor shall provide all necessary fire stopping of openings through which cable is installed under this Specification in accordance with NFPA 70 and all Local Codes. This includes installation in conduits, raceways, or bare penetrations in fire-rated barriers. All Contractor installed "Fire Stop Systems" must be UL approved including fire stop material (Fire Barrier Caulk), which must be UL 1479 approved,
- H. Wire Labels:
1. During installation both ends of all wires or cables shall be clearly labeled with approved wire labels.
  2. The wire labels shall be numbered consecutively with respect to the patch bay with a leading service level designation. If there are no patch bays utilized in the system the wire labels shall be numbered consecutively with a leading service level designation.
  3. The wire labels shall not be more than 8 inches or less than 4 inches from the connector or termination at each end of the cable.
  4. Wire labels shall utilize plastic shrink-wrap, protecting the text and ensuring they remain affixed to the wiring. Approved: Thomas and Betts or approved equal, submit sample to the CM's Representative.

I. Documentation:

1. Maintain a careful running log of route and terminations for each cable.
2. A detailed wiring diagram shall be furnished with wire numbers shown as part of the As-Built Documentation. All spare cable shall be shown on the As-Built Documentation.

J. Cable Management:

1. Cables shall be grouped and bundled by type and routed from source to termination in a uniform manner throughout all equipment housings. Care shall be taken not to break the insulation or deform the cable by harness supports. Cables shall not change relative position in a cable group throughout a cable route.
2. Cable support bars shall be installed to support cables in areas of dense harness break-outs such as behind patch panels, distribution amplifiers and other multiple input/output devices.
3. Edge protection material ("cat track") or grommets shall be installed on the edges of holes, lips of ducts or any other point where cables or harnesses cross metallic edges.

K. Terminations:

1. The Contractor shall employ the latest termination practices and materials.
2. Signal and control cable ends shall be neatly formed, and shrinkable tubing shall be applied where necessary to secure the insulation against fraying or raveling.
3. Field terminations shall be made with terminal blocks.
4. Internal rack terminations and field terminations shall be made with terminal blocks.
5. Punch block terminations are not acceptable and shall not be allowed.
6. Coaxial connectors shall be crimp-on and then soldered. Audio and control wires shall be terminated with crimp-on lugs, and then soldered.
7. Digital media cabling — submit proof of applicable cable termination training prior to installation and terminate per Manufacturer's detailed instructions.
8. All bare wire shall be tinned prior to termination unless the Connector Manufacturer recommends otherwise.
9. Unused line level shields shall be individually insulated using shrinkable tubing and attached to the cable using an additional piece of shrinkable tubing.

L. System Grounding:

1. The "spider" concept is designed to avoid ground loops and inductive coupling.
2. The systems shall be hum free, stable and free of oscillation with the earth ground temporarily disconnected.
3. The earth ground shall be made at only one point in the system as indicated and shall be in accordance with National Electric Code 2002 paragraphs 250.146(D), 406.2(D) and 408.20 Exception.
4. The grounding method shall insure that the system is free of the following problems under any mode of operation:
  - a. RF oscillation, pickup and interference.
  - b. Distortion.
  - c. Crosstalk.

## f. Audio Hum.

5. Major wiring ducts or trays shall be grounded to the conduit system.
6. The equipment racks shall be isolated from, and not electrically bonded to, the building conduit system. This means that the conduit system shall not be electrically connected to the equipment racks and that the equipment racks shall be installed so that they are electrically isolated from the building structural steel. The racks shall be electrically bonded at only one point to the isolated grounding system as shown on the AV Category Drawings.

## M. Seismic Restraints:

1. All hanging or free-standing equipment and cabinets furnished including but not limited to racks, loudspeakers, projection screens, and TV monitors shall be secured to substantial building structures. The equipment described shall resist seismic acceleration in any direction up to a limit of the greater of 1.0 G or the limit prescribed by the Local Governing Codes.
2. Maintain electrical isolation between the equipment racks and building steel.
3. Loudspeaker hanging details, rack bracing, and other seismic restraints are not shown on the Contract Drawings; it shall be the Contractor responsibility to develop these Drawings.
4. Submit loudspeaker mounting (rigging) Drawings to the Architect for review after they have been stamped and signed by a licensed structural engineer engaged in regular practice in the Project's State.

## N. Audio System Processing Adjustments:

1. The Contractor shall program the Digital Signal Processing system to include filters adjusted such that the loudspeaker zone(s) effected by same are measured to exhibit uniform (flat) frequency response (less than  $\pm 3$  dB) at the listening location for the frequencies the transducer is designed/intended to address. Measurements utilized for determining filter adjustments shall be made on axis with respect to a single transducer (representative of the zone) in its intended field of coverage. Loudspeaker cross-over filters shall be provided first for all actively crossed transducers per Loudspeaker Manufacturer's instructions. Additional filters will still be required to achieve uniform frequency response measured at the various listening locations. For loudspeaker zones of small transducers, utilize high-pass filters first and foremost and then utilize parametric EQ filters to flatten the measured response. For loudspeaker zones of large transducers, where other transducers in the system will address higher frequencies, utilize low-pass filters first and foremost and then utilize parametric EQ filters to flatten the measured response.
2. The Contractor shall program the Digital Signal Processing system to include delay settings adjusted so that the direct sound from the main loudspeaker clusters and the delay zone transducers in question arrives simultaneously at the listening plane served by the delay zone transducers. The AV Consultant may add additional delay to address 'imaging / Haas affect preferences' as appropriate.
3. The AV Consultant may add additional filters and delay (as required) to address 'tuning preferences', but such 'tuning preferences' shall not be considered as part of the Base Line Requirements for determining substantial completion of the audio system. Flat

frequency response and time alignment of the direct sound from the loudspeakers will be considered a Base Line Requirement for determining substantial completion of the audio system.

O. Loudspeaker Installation:

1. Verify all loudspeakers aiming and positioning with CM's Representative.
2. Submit Loudspeaker Mounting (Rigging) Drawings to the Architect for review after they have been approved and signed by a certified Structural Engineer engaged in regular practice in the Project's State.

P. Video Projector Installation:

1. The video projector shall be converged, registered and color balanced, Obtain from the CM all scan rates and resolutions that are to be used and properly converge the projector for all possible inputs. In addition, the Contractor shall optimize the projector for the following standard scan rates and resolutions:
  - a. HDTV, 720p, 1080i and 1080p
  - b. 1280 x 800, 60Hz, 70Hz, and 75Hz
  - c. 1440 x 900, 60Hz, 70Hz and 75Hz.
  - d. 1600 x 1200, 60Hz, 70Hz and 75Hz.
  - e. 1920 x 1080, 60Hz, 70Hz and 75Hz
  - f. 1920 x 1200, 60Hz, 70Hz, and 75Hz

**3.04 SYSTEM PERFORMANCE TESTS:**

- A. The Contractor shall pre-assemble and test all systems and sub-systems in his own facility before completed assemblies are delivery to the Project Site.
- B. Tests shall include but are not limited to those listed below in order to verify that the system meets all Design Requirements.
- C. The Contractor shall perform the initial system testing and adjustment prior to scheduling the final system acceptance tests.
- D. All tests shall be fully documented and a neat copy presented for review by the CM's Representative and inclusion in the system manual.
  1. Performance Tests on Individual Components:
  2. Perform in Contractor's facility.
  3. Verify that the Manufacturer's Specifications are met.
  4. Measure and record the impedance on each driver, and verify the acoustical output and freedom from rattles and distortion of all loudspeakers.
- E. Performance Tests on Completed Component Sub-assemblies:
  1. Perform in Contractor's facilities.
  2. Before delivery of the equipment to the project site, the specialty Contractor shall demonstrate to CM's Representatives at the Contractor's facilities that all sub-assemblies are operating as specified.
  3. Verify the achievement of the Specifications for each electronic component in situ, i.e., as assembled in its console, rack or other enclosure, powered by the system power supply and with all other components also activated, i.e., powered and interconnected.



The magnitude and character of the threshold noise shall be observed for appearance of hum in excess of that present with individual activation, or the appearance of high frequency oscillation.

4. Projection equipment shall be tested to verify that the Manufacturer's Specifications are met after it has been incorporated into a complete subassembly.
  5. Video equipment shall be tested to verify that its operation meets the Manufacturer's Specifications and EIA RS-170A after assembly into complete subsystems.
- F. Performance Tests on the Complete System:
1. Verify that all wiring is correctly and completely installed. Verify that there are no short circuits between conductors within any cable, or from cable to cable. Verify the integrity of each conductor, i.e., that the conductor is not open circuited. In addition, the correct polarity of each connector, including those in patch panels, shall be verified and the color-coding scheme shall be recorded and included in the documentation provided to the CM's Representative.
  2. Verify that the entire system performance is in accordance with the Design Requirements. Specific attention is directed to the following for each system:
    - a. Projection Equipment.
    - b. Source Equipment Transports
    - c. Video Matrix Switchers.
    - d. Remote Control Components.
    - e. Video Distribution Amplifiers.
    - f. Audio Amplifiers.
    - g. Consoles.
    - h. Networking Equipment.
- G. The threshold noise output of the system, measured at the output of the power amplifier, must equal the input when its gain control is full on, and of the line or booster amplifier input when all channel controls are off. No hum shall be audible in the system within the noise signal, or with the inputs terminated in microphone impedance and all controls full on. No high frequency oscillation shall be observed at the system output. No audible radio signal shall be detectable in the system at any control setting. Depending upon the proximity of a local radio station or upon the cable configuration of the system, RF oscillation or leakage may be a problem and the Contractor shall be prepared to install a RF low pass filter appropriately in the system as a final remedy.
- H. Cross talk between channels shall be measured with signal equivalent to 1.0 Volts output into one channel with its gain off and the gain of each other channel varied over their full range. Maximum signal leakage at the system output must be equivalent to -70 dB re 1.0 Volt at the pre-amp output at 1 kHz, increasing to -52 dB at 8 kHz.
- I. The general performance of each loudspeaker unit in situ shall be verified by applying pink noise signal at 10.0 Volt level and verifying the specified output SPL at a distance of 1 foot. Normal undistorted sound quality shall be verified by headphone listening at the output of the calibrated system. Each loudspeaker shall also be fed with an oscillator signal at 10.0 Volt level within its intended frequency range, verifying absence or abnormal distortion of rattles due to installation.

- J. The audio system shall be adjusted as specified above in paragraph entitled "Audio System Processing Adjustments" where Minimum Requirements for establishing readiness for the substantial completion observation of an audio system are specified.
- K. The complete video system shall be tested in the following manner: All video outputs of the system shall conform to EIA RS-170A when typical inputs to the system are fed with a "known good signal" from a video signal generator.
- L. Provide installation functionality test results report prior to substantial completion punch walk.
- M. Test procedures for video systems shall conform to the following Basic Guidelines:
  - 1. All equipment and video signal chains shall operate according to Manufacturer's Specifications and/or to the EIA RS-170A Standard.
    - a. Black level (using the brightness control).
    - b. White level (using the contrast control).
    - c. Correct Hue.
  - 2. All video cameras shall be setup and adjusted for the following:
    - a. Black balance.
    - b. White balance.
    - c. Range of zoom and iris function.
- N. All these tests, and any others that the Contractor may wish for his own satisfaction, shall have been performed and successfully achieved before observation requested. The CM's Representative may request repetition and demonstration during observation of certain of these tests or other critical tests if problems become apparent. If Specifications are not met, further observations will be at the Contractor's expense.

### **3.05 DEMONSTRATION AND ACCEPTANCE TESTING**

- A. Substantial Completion Observation:
  - 1. The Contractor shall file a written notice with the CM when all of the aids to use describe in "Submittals", above, have been submitted for approval, all tests described in above in "System Performance Tests", are complete and the test reports have been submitted for review and approval and the systems and sub-systems are ready for the Substantial Completion Observation.
  - 2. The Contractor shall be prepared to demonstrate the overall system performance including but not limited to functionality, control system programming, operation, optics performance and Digital Signal Processing software control (where applicable). The Contractor shall be prepared to demonstrate proper gain structure and that base line EQ (equalization of uniform frequency response) settings and delay filters (time alignment) have been set. In addition the Substantial Completion Observation of the systems may include repetition or demonstration of any or all of the tests described in "System Performance Tests" above or other critical tests if problems become apparent and the Specifications are not met. After the Substantial Completion Observation, written notice noting whether the systems meet the criteria set forth in the General Conditions for Substantial Completion, along with a list of items for the Contractor to correct shall be provided to the Contractor.

3. In the event that the systems are found not to be Substantially Complete, all of the costs including fees, travel and living expenses in connection with subsequent observations or corrective work shall be borne solely by the Contractor. This includes new problems that arise during the course of the subsequent observations.
- B. Acceptance Observation:
1. After the systems have been certified as Substantially Complete, and the Contractor has filed written notice with the CM that the corrections ordered, have been completed, a Final Acceptance Observation shall be scheduled.
  2. During the Final Acceptance Observation of the systems repetition or demonstration of any of the tests described in "System Performance Tests", above, or other critical tests if problems become apparent and the Specifications are not met, may be requested.
  3. Assist in performing final system adjustments and acceptance tests. Provide all labor, materials and tools necessary for these tests and adjustments. Provide all necessary test equipment to complete the tests.
  4. Budget 24 working hours for the performance of these tests and adjustments with the CM's Representative. If final acceptance is delayed beyond this period because the installation is not in proper working order or is incomplete, the Contractor shall pay for all additional time and expenses for any resultant extension or re-scheduling of the acceptance testing period.
  5. Any measurements of frequency response, distortion, noise or other characteristics and any adjustments deemed necessary may be performed on any item or group of items, including re-orientation of loudspeakers, to insure optimum performance of the system.
  6. In the event that the corrections have not been completed to the satisfaction of the CM's Representative, or new problems arise at the time of the Acceptance Observation, all costs including consulting fees, travel and living expenses in connection with subsequent observations or corrective work shall be borne solely by the Contractor.
- C. Acceptance:
1. After observations and tests indicate that the entire AV system and sub systems as specified herein and indicated on the Drawings are in total compliance with the Drawings and Specifications, a letter indicating said compliance shall be issued.
  2. Acceptance of the system shall be accomplished as described in the General Conditions.
  3. Final acceptance of the installation will be granted when it is clear to the CM's Representative and the architect that the following conditions have been met:
    - a. All fixed equipment has been furnished and installed according to the Drawings and Specifications.
    - b. All portable equipment has been turned over to the CM.
    - c. All equipment and installation have been tested and shown to perform as specified.
    - d. All instruction manuals, software source Code and As-Built Documentation have been completed and delivered to the CM's Representative.
  4. The Warranty period will begin only when all of the above listed items have been performed to the satisfaction of the Architect, CM and CM's Representative.

D. TRAINING

1. Submit all training materials to the CM's Representative for approval prior to scheduling training sessions.
2. Provide 24 hours of hands on training practical operation of the system to the CM's Representative. Address in the training, the general configuration of the system, basic functionality, correct operation procedures, routine maintenance and upkeep.
3. Provide 4 hours of follow-up training within 3 months of the initial training to review aspects of the original training and provide instruction on specific troubleshooting issues the CM's Representative raises during the training,
4. Record via video and audio all training sessions and provide three copies to the CM on DVD- R format.

END OF SECTION 27 41 16  
022219/212220

This page is blank.

**SECTION 27 51 26**  
**ASSISTIVE LISTENING SYSTEM**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances tools, equipment, facilities transportation and services necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
1. Examine all other Sections for work related to those other Sections and required to be included as work under this Section.
  2. General Provisions and Requirements for electrical work.

**1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

Submit block wiring diagrams and catalog data showing component interconnection and descriptive literature for all component parts and cabinets.

**1.03 EQUIPMENT QUALIFICATION**

- A. All Equipment shall conform to Federal, State and Local applicable Codes, Ordinances and AHJ, and shall be listed and labeled by Underwriters Laboratories.
- B. Assistive-Listening Systems
1. Assistive-listening systems shall be provided in accordance with CBC Section 11B-219 and shall comply with CBC Section 11B-706.
  2. The minimum number of receivers to be provided shall be equal to 4% of the total number of seats, but in no case less than two. 25% minimum of the receivers provided, but no less than two shall be hearing-aid compatible in accordance with CBC Section 11B-706.3.
  3. If the system provided is limited to specific areas or seats, then such areas or seats shall be within a 50-foot viewing distance of, and have a complete view of, the stage or playing area. CBC Section 11B-219.4.

**PART 2 - PRODUCTS**

**2.01 GENERAL**

- A. The Assistive Listening System shall include the following items
1. Instructor (program source) wireless transmitter units.
  2. Student (audience) portable wireless receiver units.
  3. Plug-in microphones and earphones, for each unit.
  4. Multiple program source inputs for, Instructor's microphone, respective room audio/ video A/V system input/output and Instructor's computer audio input/ output.

5. System accessories.

B. Function

1. The Assistive Listening System shall provide amplified available audio programs for hearing impaired students/audience, originating from classroom/stage/room instructors and audio/video instructional program source materials, and equipment in respective building spaces, rooms, classrooms and outdoor areas.
2. The audible program shall be transmitted wireless from the program source to the student/audience, with reception coverage throughout not less than approximately 80% of the respective floor space/area space.
3. Shall provide automatic stereo or mono audio full system operation, depending on program source input.
4. The system in each space shall comply with Federal ADA, State and Local AHJ Requirements for the hearing impaired.

## 2.02 MATERIALS (RF WIRELESS)

A. General

1. Power for each portable unit operation shall be supplied by internal, changeable rechargeable NiCad batteries and alternately by alkaline disposable batteries. Rechargeable batteries shall be recharged without removal from the unit. Each unit shall have a charging indicator light. The batteries shall be recharged from either a portable charger/organizer and with wall transformer/two unit chargers. The units shall operate for up to 40-hours with alkaline batteries, and up to 10-hours with NiCad (NiMH) batteries. The batteries shall be rechargeable without removal from unit.
2. Provide power on-off control on each unit, to extend battery duration.
3. A protection circuit shall prevent battery “back-drain” if the power to the charger is turned off while the unit is being recharged.
4. The receivers and transmitters shall be US Government FCC and Industry Canada-approved, for FM-RF (radio frequency) wireless operation.
5. All components shall be the product of the same Manufacturer.
6. As manufactured by Williams Sound; or PhonicEar; or Listen Technologies; or Centrum Sound.

B. Instructors Portable (Program Source) RF Transmitter Units

1. The transmitter, shall be compact, easily portable units, self-contained ABS, plastic housing/enclosure shall clip to a pocket or belt.
2. Each portable transmitter shall provide RF transmitting on one of the US Government 40 different FCC – and Industry Canada-approved narrow-band channels in the 72-86MHz RF band.
  - a. Line-of-sight transmit-distance range of not less than 100-feet up to 150-feet from transmitter to receiver.
3. Easy-to-read channel label and volume adjustment on the front unit face. Stereo and mono audio processing.

4. 3.5mm auxiliary input jack that allows transmission of audio from an auxiliary source such as a cassette recorder, computer, CD/DVD player or television audio source. The transmitter shall also provide a second 3.5mm microphone input source jack. The two input sources shall be simultaneously operational to provide a mixed signal output RF transmission of the two sources.
5. Select the separate independent RF transmission frequency for each transmitter to prevent transmission interference between units and to provide for at least two student receiver units to selectively overlap reception of the transmitter.
6. Quantity of Instructor's portable RF transmitters
  - a. Provide quantity of nine instructor portable transmitters, 3-on low band; 3-on mid band and 3-on high band RF frequencies.
  - b. Provide a quantity of one portable transmitter at the respective room audio/video (A/V) equipment, program output source. Provide 120 volt AC-to-DC power-supply for portable transmitter at the A/V equipment location.
7. Extended range fixed base non-portable RF transmitter.
  - a. Provide fixed location non-portable base unit RF transmitter for spaces larger than 9,000 square foot indoor or outdoor spaces.
  - b. Shall have the same RF characteristics and performance as the portable transmitter except as follows:
    - 1) Line-of-sight transmit-distance range of not less than 800-feet from transmitter to receiver.
    - 2) Fixed install location non-portable, with NEMA-1 metal housing.
    - 3) Radiated RF energy intensity shall provide manual attenuation adjustments to prevent multiple adjacency RF interferences.
  - c. Provide a student/audience portable RF receiver unit at the RF base unit to receive RF signals from an instructors RF transmitter. Connect to the base unit to rebroadcast. Provide a self-contained 120-volt AC-to-DC power-supply for the portable receiver at the base unit transmitter.
  - d. Shall operate on 120 volt 60Hz AC branch circuit. Provide remote system master on-off control.
  - e. Provide remote RF antenna (outdoor/indoor) rated, for fixed base RF transmitter. Antenna shall extend the transmitter range for large spaces. Provide two RG-6 coaxial cable connects from antenna to base transmitter.

C. Student/Audience Receiver Units

1. The multi-channel narrow-band FM receivers shall be compact easily portable units, self-contained ABS/plastic housing/enclosure and shall clip to a pocket or belt.
2. The receiver shall provide an on/off switch and volume control which adjusts the output level as required by the listener.
3. The receiver shall have a 3.5mm output jack which accepts one of any of the plug-in listening accessories. Headsets shall provide magnetic induction pick-up for hearing impaired, hearing aid interface operation.
4. The receiver shall have an easy-to-read channel label on the front face. The receiver shall incorporate an automatic squelch circuit which eliminates white noise when the receiver is out of transmission range. Stereo and mono audio reception and processing.



5. The multi-channel receiver shall receive any six of the US Government forty different FCC- approved narrow-band FM frequencies within the 72-76MHz band from the respective transmitter units. The user shall be able to change to any one of these six frequencies by using a slide or rotary switch on the receiver. Label on the front face shall indicate the receiver is a multi-channel unit. A label inside the battery compartment shall indicate the six channels that are available to the user.
  6. Quantity of portable RF receivers
    - a. Provide a quantity of two receivers with matching frequencies for each transmitter, not less than eighteen total quantities of receivers.
    - b. Provide a quantity of one receiver with matching RF frequency of the transmitter at the respective room audio/video (A/V) equipment, program input source. Provide 120 volt AC-to-DC power-supply for portable receiver at the A/V equipment location.
    - c. Provide hearing aid compatible units at a ratio of one per four receivers in accordance with ADA 219.3.
- D. RF System Accessories
1. Battery recharger portable charger/organizer pack.  
Locking, portable case with cover, shall accept a group of not less than twelve plug-in portable transmitter and receiver units in each pack for simultaneous multi-unit battery recharging. Provide a quantity of one organizer for each quantity group of twelve (or fraction thereof) transmitters receivers provided as part of the Contract.
  2. Stereo audio headset style automatic noise canceling microphone, integral on-off-volume control and with behind the neck support style each with cable and outlet plug-jacks to match transmitter jacks. Provide two cables for each transmitter.
  3. Equipment wall mount support brackets.
  4. Auxiliary audio program source 15-feet long cables with plug-in at both ends to match transmitter jacks. Provide two for each transmitter.
  5. Stereo audio headset style ear phones with cable and plug to match receiver jacks. Headsets shall provide magnetic induction pick-up for hearing impaired, hearing aid interface operation. Provide one headset for each receiver.
  6. Rechargeable Ni-Cad (NiMH) batteries, one complete set for each transmitter and receiver unit.
  7. Locking auxiliary equipment storage cases for cables, microphones and headsets, with quantity and capacity for all auxiliary accessories furnished as part of the Contract.

## **2.03 MATERIAL (INFRARED WIRELESS)**

- A. General
1. All equipment shall be the product of the same Manufacturer.
  2. The receivers and transmitters shall be US Government FCC and Industry Canada-approved.
  3. Provide power on-off control on each unit, to extend battery duration.
  4. As manufactured by Williams Sound; or PhonicEar; or Listen Technologies; or Centrum Sound.

B. Master (Program Source) Transmitter (Infrared Emitter) Units

1. The infrared emitter/transmitter shall be compact, portable units, self-contained ABS/ plastic housing/enclosure.
2. The emitter panel shall be a dual-channel system operating on both 2.3 and 2.8MHz invisible infrared light waves' frequencies. The channels shall be designated "CHANNEL A" for the left and "CHANNEL B" for the right.
3. The emitter shall provide left and right AUDIO IN jacks to accept an input signal from a sound system, left and right "SYNC IN/SYNC OUT" jacks for master/slave daisy-chaining with other emitters if desired, and left and right "MIC-IN" jacks to accept an audio signal from a microphone or Audio/ Video preamplifier.
4. The emitter shall provide separate LED input level detectors for each channel which illuminate when the audio signal peaks. Stereo and mono audio processing.
5. The emitter shall be mounted by the following methods:
  - a. Fixed to a wall with an adjustable, wall-mounting support bracket accessory.
  - b. Portable mounted to a table-top-or floor-stand, using accessory support-stand adapter.
6. Each emitter shall provide an array of not less than 130-infrared LEDs covered by an infrared transparent acrylic lens. The infrared signal from each emitter shall cover not less than 3,000 square feet (32,000 cubic feet) enclosed space. Note: For room sizes smaller than 3000 square feet, the infrared transmitter/emitter infrared output shall be reduced to accommodate the actual smaller room square feet size and height.
7. 120 volt 60Hz AC input to nominal 24-volt DC output (plug-in "power-brick") power supply external transformer shall be UL approved, with cable "plug-in" connection to emitter/transmitter. Provide remote system master on-off control.
8. Slave emitter/transmitter for rooms exceeding 30,000 cubic feet. Provide one additional infrared emitter/transmitter repeater slave unit, for each additional 30,000 cubic feet room volume, or fraction thereof. The slave repeater shall receive and retransmit the program signals from the master unit. Provide one 100-foot long "master-to-slave" auxiliary portable extension wire cable for each slave unit.
9. Provide wall mount plug-in outlets for instructors' microphone outlet connect ports to emitter/transmitter.
  - a. Provide 1.0-inch conduit and wire, homerun connect from microphone outlet to each room respective emitter/transmitter and slaves. Provide conductors as recommended by Manufacturer.
  - b. Provide 1.0-inch conduit and wire homerun connect from microphone outlet to respective room Audio/Video (A/V) equipment, microphone program source input. Provide conductors as recommended by Manufacturer.
10. Provide a quantity of nine emitter/transmitter "master" units, plus additional "slave" units for adjusted room sizes.

C. Student/Audience Receiver Units

1. Battery Power
  - a. Power for each unit operation shall be supplied by internal, changeable rechargeable NiCad batteries and alternately by alkaline disposable batteries. Rechargeable

batteries shall be recharged without removal from the unit. Each unit shall have a charging indicator light. The batteries shall be recharged from either a portable charger/organizer and with wall transformer / two unit chargers. The units shall operate for up to 40-hours with alkaline batteries, and up to 15-hours with NiCad (NiMH) batteries.

- b. Provide power on-off control on each unit, to extend battery duration.
  - c. A protection circuit shall prevent battery "back-drain" if the power to the charger is turned off while the unit is being recharged.
2. The receiver shall be a dual-channel unit for wearing around the neck with an adjustable strap. Stereo and mono audio reception and processing.
  3. Compatible with the transmitter (emitter) and operate on 2.3MHz and 2.8MHz frequencies invisible infrared light waves. Self-contained and switchable from "CHANNEL A" to "CHANNEL B" through a switch located on the back of the unit.
  4. The receiver shall provide an infrared light-gathering lens on the front of the unit to focus the light signal from the emitter onto the infrared detector element. The receiver shall detect and decode the infrared emitter/transmitter light source within a 160° acceptance angle.
  5. Audio squelch circuit which turns the output circuit off when the infrared signal is reduced or not received, with on/off and volume control.
  6. Output jack, which accepts any of the listening accessories. Headsets shall provide magnetic induction pick-up for hearing impaired, hearing aid interface operation.
  7. Shall be compact easily portable units, self-contained ABS/plastic housing/enclosure with red infrared receiver lens. Shall clip to pocket or belt.
  8. Provide quantity of two infrared receivers for each master transmitter, not less than eighteen total quantities of receivers.
- D. Infrared System Accessories
1. Battery recharger portable charger/organizer pack.  
Locking, portable case with cover, shall accept a group of not less than twelve plug-in portable transmitters and receivers units in each pack for simultaneous multi-unit battery recharging. Provide a quantity of one organizer for each quantity group of twelve (or fraction thereof) receivers provided as part of the contract.
  2. Stereo audio headset style automatic noise canceling microphones, integral on-off-volume control and with behind the neck support style. Each with 25-feet long extension cables and outlet plug-jacks to match transmitter outlet jacks. Provide two cables for each emitter/transmitter.
  3. Equipment wall mount support brackets.
  4. Auxiliary audio program source 15-feet long cables with plug-in at both ends to match transmitter jacks. Provide two for each transmitter.
  5. Headset style ear phones with cable and plug to match receiver jacks. Headsets shall provide magnetic induction pick-up for hearing impaired, hearing aid interface operation. Provide one headset for each receiver.
  6. Rechargeable Ni-Cad (NiMH) batteries, one complete set for each unit.

7. Locking auxiliary equipment storage cases for cables, microphones and headsets. Quantity and capacity as required to store all accessories.
8. Portable floor stand, for infrared emitter/transmitter units mounting and support, with variable height adjustment and tip-resistant weighted base. Provide one floor stand for each infrared emitter/transmitter.
9. Locking, portable case for infrared emitter/transmitter. One for each emitter/transmitter unit.
10. Provide microphone extension cable with plug to match microphone and infrared emitter/transmitter microphone input jack, 25-foot length. One for each microphone.

## **PART 3 - EXECUTION**

### **3.01 GENERAL**

#### **A. Each System General**

1. Assemble, set up, and test each transmitter, receiver, and accessories units.
2. Install and fully charge all batteries prior to and after testing/set-up is complete.

#### **B. Wireless RF Units**

1. Perform an onsite RF frequency survey to determine available unused RF channels, prior to selecting unit operating channels and prior to ordering the equipment.
2. Select operational RF frequency to prevent system RF interference's with other equipment.
3. Provide - one 0.75-inch conduit with two Category-6A, ANSI/EIA/TIA-568C 4-pair, UTP cables connecting from each emitter/transmitter master outlet box location to respective room instructors microphone outlet box location. Provide matching RJ-45 Category-6A female jacks at each outlet box for each cable. Provide an audio circuit matching Balun at each outlet RJ-45 jack location, for RJ-45-to-portable cable plug-in transition and circuit impedance matching audio/transformer, into respective equipment. Additionally provide four portable Category-6A patch cables with RJ-45 jacks on each end of 7-foot long patch cable. Typical for each outlet location.

#### **C. Wireless Infrared Units**

1. Provide aiming and intensity adjustments of emitter/transmitter units to insure complete room coverage.
2. Provide - one 0.75-inch conduit with two Category-6A, ANSI/EIA/TIA-568C 4-pair, UTP cables connecting from each emitter/transmitter master outlet box location to respective room instructors microphone outlet box location. Provide matching RJ-45 Category-6A female jacks at each outlet box for each cable. Provide an audio circuit matching Balun at each outlet RJ-45 jack location, for RJ-45-to-portable cable plug-in transition and circuit impedance matching audio/transformer, into respective equipment. Additionally provide four Portable Category-6A patch cables with RJ-45 jacks on each end of 7-foot long patch cable. Typical for each outlet location.
3. Provide - one 0.75-inch conduit with two Category-6A, ANSI/EIA/TIA – 568C, 4-pair UTP cables connecting from each emitter/transmitter master outlet box location to respective room audio amplifier / preamplifier location. Provide matching RJ-45

Category-6A female jacks at each outlet box location for each UTP cable. Provide an audio circuit matching Balun at each outlet RJ-45 jack location, for RJ-45-to-portable cable plug-in transition and circuit impedance matching audio/transformer, into respective equipment. Additionally provide four portable Category-6A patch cables with RJ-45 jacks on each end of 7-foot long patch cable. Typical for each outlet location.

END OF SECTION 27 51 26  
022219/212220

**SECTION 27 53 13**  
**CLOCK SYSTEM**

**PART 1 - GENERAL**

**1.01 SCOPE**

- A. Work Included: All labor, materials, appliances tools, equipment, facilities transportation and services necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other Sections for work related to those other Sections and required to be included as work under this Section.
  - 2. General Provisions and Requirements for electrical work.

**1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)**

- A. Submit product data sheets and descriptive literature for all component parts.
- B. Submit block wiring diagram of the clock and paging systems, showing headend equipment, terminal cabinets, remote power supplies, and typical clock for each zone.

**1.03 EQUIPMENT QUALIFICATION**

- A. The Specification is based on the equipment of Manufacturers who have been approved by the District and the Manufacturers herein named shall be considered as meeting the Requirements of this Specification. For all items which are identified by part number and Manufacturer the Performance Specifications which are published in the most recent Manufacturer's data sheets available at the time of bidding this Project shall be applicable to the present work as though fully written out herein.
- B. All equipment shall conform to all local applicable Codes and Ordinances, and shall be listed by Underwriters Laboratories.

**1.04 QUALIFICATIONS**

To qualify as an acceptable Bidder, whether the bid is submitted to the District, his Agent, a General Contractor or a Sub-Contractor, the System Bidder or Contractor shall be qualified Sound Contractor and shall hold a valid C61 License issued by the Contractors State License Board of California. The System Bidder or Contractor shall hereinafter be referred to as the Contractor. The Contractor shall hold all other licenses required by the legally constituted Authorities Having Jurisdiction (AHJ) over the work. The Contractor shall be the Factory Authorized Distributor for the brand of equipment offered and shall have been engaged in the business of supplying and installing the specified type of system for at least 5-years. The Contractor shall maintain a fully equipped service organization capable of furnishing adequate repair service to the equipment.

**1.05 GENERAL REQUIREMENTS AND SCOPE**

- A. Furnish and Install a complete new GPS wireless clock system using Primex Wireless Inc. GPS wireless system or equal by American Time and Signal, Sapling. All bids shall be based on the equipment as specified herein.

- B. Section includes Transmission Systems GPS Receiver, Primary Transmitter, and Satellite Transmitter.
  - 1. Clocks:
    - a. Analog
    - b. Digital

#### **1.06 RELATED SECTIONS**

Division 26 – Electrical (120 volt grounded outlet required for transmitter).

#### **1.07 REFERENCES**

This Technical Specification and Associated Drawings, Primex Wireless GPS Satellite Time System User Manual.

#### **1.08 DEFINITIONS**

GPS: Global Positioning System, a worldwide system that employs 24-satellites in an integrated network to determine geographic location anywhere in the world, and which employs and transmits Universal Coordinated Time, the world’s most accurate and reliable time.

#### **1.09 SYSTEM DESCRIPTION**

- A. GPS wireless clock system shall continually synchronize clocks throughout the facility, and shall be capable of clock readouts in multiple time zones where desired.
- B. The system shall provide wireless time using GPS and be synchronized to UTC. The system shall not require hard wiring. Clocks shall automatically adjust for Daylight Saving Time
- C. Analog Clocks shall be synchronized to within 10-milliseconds 6-times per day, and the system shall have an internal oscillator that maintains plus or minus 1-second per day between synchronizations, so that clock accuracy shall not exceed plus or minus 0.2 seconds.
- D. The system shall include an internal clock reference so that failure of the GPS signal shall not cause the clocks to fail in indicating time.
- E. The system shall incorporate a “fail-safe” design so that failure of any component shall not cause failure of the system. Upon restoration of power or repair of failed component, the system shall resume normal operation without the need to reset the system or any component thereof.
- F. Clock locations shall be as indicated, and clocks shall be fully portable, capable of being relocated at any time.
- G. The system must operate in accordance with a “Radio Station Authorization”, Form FCC 601 – LM, granted by the Federal Communications Commission (FCC). This license will be issued to and held by the end user.

#### **1.10 REGULATORY REQUIREMENTS**

- A. Equipment and components furnished shall be of Manufacturer’s latest model.
- B. The end user will hold a License, known as a “Radio Station Authorization” granted by the FCC.
  - 1. This License grants the end user protected use for wireless transmission at the designated frequency.
  - 2. This License will designate a unique “call sign” for each end user.

- C. Transmitter and Receiver shall comply with Part 90 of FCC rules as follows:
  - 1. This device may not cause harmful interference, and
  - 2. This device must accept interference received, including interference that may cause undesired operation.
  - 3. Transmitter frequency shall be governed by FCC Part 90.35.
  - 4. Transmitter output power shall be governed by FCC Part 90 257 (b)
- D. System shall be installed in compliance with Local and State Authorities Having Jurisdiction.
- E. Operating License: Submit evidence of application for FCC Radio Station Authorization prior to installing equipment. Furnish the license or a copy of the application for the license, to the District/End User prior to operating the equipment. The original license must be delivered to the District/End User.
- F. Samples: Submit one clock for approval. Approved sample shall be tagged and shall be installed in the work at location directed.
- G. Manufacturer's Instructions: Submit complete installation, set-up and maintenance instructions.
- H. Floor Plans indicating the location of system transmitter(s), approved by Manufacturer, will be submitted to District prior to installation.

#### **1.11 QUALITY ASSURANCE**

- A. Permits: Obtain Operating License for the transmitter from the FCC.
  - 1. Qualifications:
    - a. Manufacturer: Company specializing in manufacturing commercial time system products with a minimum of 30 continuous years of documented experience including 4 years' experience producing GPS wireless time systems.
    - b. Installer: Company with documented experience in the installation of commercial time systems.
  - 2. Prior to installation, a site survey must be performed to determine proper transmitter placement.

#### **1.12 DELIVERY STORAGE AND HANDLING**

- A. Deliver all components to the site in the Manufacturer's original packaging. Packaging shall contain Manufacturer's name and address, product identification number, and other related information.
- B. Store equipment in finished building, unopened containers until ready for installation.

#### **1.13 PROJECT SITE CONDITIONS**

- A. Clocks shall not be installed until painting and other finish work in each room is complete.
- B. Coordinate installation of GPS receiver for access to the roof or exterior side wall so that the bracket and related fasteners are watertight.

#### **1.14 SYSTEM STARTUP**

At completion of installation and prior to final acceptance, turn on the equipment; ensure that all equipment is operating properly, and that all clocks are functioning.



### 1.15 WARRANTY

Manufacturer will provide a 1-year warranty on GPS receiver, transmitter, and satellite transmitter. All other components will have a 1-year warranty.

## PART 2 - PRODUCTS

### 2.01 MANUFACTURER

GPS wireless clock system shall be manufactured by Primex Wireless, Inc., N3211 County Road H, Lake Geneva WI 53147, telephone (800) 537-0464, Fax (262) 248-0061, [www.primexwireless.com](http://www.primexwireless.com) or equal by American Time and Signal, Sapling.

### 2.02 SEQUENCE OF OPERATION

- A. Transmitter Operation: When power is first applied to the transmitter, it checks for and displays the software version. It then checks the position of the switches and stores their position in memory. The transmitter looks for the GPS time signal. Once the transmitter has received the GPS time, it sets its internal clock to that time. The transmitter then starts to transmit its internal time once every second. The transmitter updates its internal clock every time it receives valid time data from the GPS.
- B. Analog Clock Operation:
  - 1. Apply power or insert batteries. Follow set up procedures detailed in Manufacturer's instructions.
  - 2. After initial setup, the clock will shut off the receiver. Six times each day, the micro-processor will activate the receiver and starting with the stored channel, it will again look for a valid time signal. If necessary, the clocks will resynchronize to the correct time.
  - 3. If the clock has not decoded a valid time signal for a pre-determined number of days, it will go to a step mode. Non signal reception can be caused by low battery voltage. If this occurs, replace the batteries.

### 2.03 EQUIPMENT

- A. General: The clock system shall include a transmitter, a roof or window mounted GPS receiver, indicating clocks, and all accessories for complete operation.
- B. The GPS Receiver shall be a complete GPS receiver including antenna in a waterproof case, designed for roof or outdoor mounting. Provide mounting bracket for attachment to roof structure.
- C. The GPS Receiver cable must be plenum rated where required by local Code.
- D. Transmitter: Primex Wireless Model 14400, consisting of wireless transmitter with GPS receiver, a surge suppressor/battery backup, and a mounting shelf. Unit shall obtain current atomic time from satellite. The clock system shall transmit time continuously to all clocks in the system.
  - 1. Transmission:
    - a. Frequency Range: 72.100 to 72.400 MHz.
    - b. Transmission Power: 1 watt (30dBm) maximum
    - c. Radio technology: narrow band FM

- d. Number of channels: 16
  - e. Channel bandwidth: 20kHz maximum
  - f. Transition mode: one-way communication
  - g. Data rate: 2 Kbps
  - h. Operating range: 32 degree F to 158 degrees F (0 degrees C. to 70 degrees C).
2. Transmitter:
    - a. Transmitter output power: +26 to +30 dBm
    - b. Frequency deviation: +/- 4 kHz
    - c. Transmitter Power Requirements: 120 VAC 60 Hz
    - d. Internal Power Requirements: 5 VDC
    - e. Carrier frequency stability: +/- 20 ppm
  3. Transmitter shall have 16 selectable channels to assure interference-free reception.
  4. Transmitter shall have the following switches:
    - a. Time zone adjustment switches for all time zones in the World. Includes Eastern, Central, Mountain, Pacific, Alaska, and Hawaii.
    - b. Daylight Saving Time bypass switch.
    - c. 12-hours or 24-hours display.
  5. Transmitter housing shall be black metal case, 16¼-inches (424.4mm) by 12 inches (304.8mm) by 1-7/8 inches (46.4mm) in size.
  6. Antenna shall be 46-inches (1168mm) high, commercial type, mounted on top center of transmitter housing. Antenna gain shall be < 2.2 dB. Antenna polarization shall be vertical.
  7. Transmitter housing shall incorporate a display which shall include the following:
    - a. Time readout
    - b. AM and PM indicator if 12-hour time display is set
    - c. Day and date readout
    - d. Indicator for daylight savings or standard time
    - e. LED which shall flash red in event of reception problem
    - f. GPS reception indicator
  8. Transmitter shall contain an internal clock such that failure of reception from the GPS will not disable the operation of the clocks.
  9. Power supply (included):
    - a. Input: 120 volt AC 50/60 Hz, 0.4 amps.
    - b. Output: 9 volt DC, 1.5 amps.
- E. Surge Protector/Battery Backup (included).
1. Input: 120 volt AC 60 Hz +/- 1 Hz.
  2. Output: 120 volt AC, 500VA, 300 watts
  3. Surge Energy Rating: 365 joules

F. Additional Equipment

1. Wireless Receiver Switches: Switches shall receive time packets from the Primary Transmitter and relay the synchronized time to the Satellite Transmitter connected to it. The unit shall include the following:
  - a. Antenna mounted on top of the switch housing, 11½-inches (292mm) long. Power Supply:
    - 1) Input 120 VAC 50/60Hz, 0.4 amps
    - 2) Output: 9 volt DC, 1.5 amps RS 232 data cable, 5 feet (1.5mm) long
  - b. Daylight Savings Time bypass switch
  - c. Dimensions: 4¼-inches (108mm) long, 5¾-inches (146mm) wide, 1¼-inches (31.75mm) deep.
  - d. Weight: 12 ounces (.34kg)
  - e. Operating Range: 32 degrees F to 158 degrees F (0 to 70 degrees C)
2. Satellite Transmitters Primex Wireless Model 14401: Satellite Transmitters shall receive the signal from the Wireless Receiver Switches and transmit the signal to the devices in its vicinity, which are out of the range from the Master Transmitter. The unit shall include the following:
  - a. Antenna mounted on top of the housing, 46 inches (1168mm) long.
  - b. Wireless Receiver Switch.
  - c. Power Supply Input: 120
  - d. VAC, 50/60Hz, 0.4-amps
  - e. Output: 9 volt DC, 1.5-amps.
  - f. 6 foot (1.83m) cord
  - g. Surge Suppressor/Battery Backup
  - h. Mounting Shelf.
  - i. Transmission Power: 1 watt maximum
  - j. 72 MHz frequency.
3. Traditional analog clocks (battery): Analog clocks shall be wall mounted. Clocks shall have polycarbonate frame and polycarbonate lens. Face shall be white. Hour and minute hands shall be black.
  - a. 9 inches (228.6mm) diameter analog clock: Primex Wireless Model 14280
  - b. 12½-inch (317.5mm) diameter analog clock: Primex Wireless Model 14155
  - c. 16 inches (406.4mm) diameter analog clock: Primex Wireless Model 14163
  - d. 24 inches (610mm) diameter analog clock: Primex Wireless Model 14346
4. Additional colors, finishes, and dial faces are available from Manufacturer.
  - a. Analog clocks shall be battery-operated,
  - b. Analog clocks shall be capable of automatically adjusting for Daylight Saving Time. An on-off switch located on the transmitter shall disable this function if desired.
  - c. Time shall be automatically updated from the transmitter 6 times per day.
  - d. Analog clocks shall remember the time during changing of batteries.
  - e. 9 inches (228.6mm) and 12.5 inches (317.5mm) analog clocks shall have a tamper proof/ theft resistant clock lock mounting slots.

5. Analog clock receivers shall be as follows:
  - a. Receiver sensitivity: >-110 dBm
  - b. Receiver power: 24 VAC or 120 VAC (see model #)
  - c. Antenna type: internal
  - d. Antenna gain: -7 dBd

If transmitter stops transmitting valid time signals due to power failure, the clocks will continue to function as accurate quartz clocks until a valid time signal is decoded. If signal transmission is not restored after 96 hours, the second-hand will “five-step” as a visual indicator that the signal has been lost. Should the clocks lose power and signal, the clocks will not function.

6. Wire guards: Provide one for each analog clock as follows:
  - a. Analog clock wire guard Primex Wireless Model 14131, 14-inches by 14-inches (355.6 by 355.6 mm) size, for nominal 12½-inch (317.5 mm) diameter analog clocks.
  - b. Analog clock wire guard Primex Wireless Model 14123, 18-inches by 18-inches (457.2 by 457.2mm) size, for 16 inches (406.4mm) diameter analog clocks.
7. Cable Connection Sealant: Radio Shack Coaxial Cable Connector Sealant 278-1645, or approved electrical grade silicone sealant.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that construction is complete in spaces to receive equipment and that rooms are clean and dry.
- B. Verify that 120-volt electrical outlet is located within 6 feet (1.83m) of location of transmitter and the outlet is operational and properly grounded.

### **3.02 INSTALLATION**

- A. Provide all equipment necessary for a complete and operable system.
- B. Transmitter: Locate transmitter where indicated, a minimum of 2 to 3 feet (.6 to 1 meter) above the floor, away from large metal objects such as filing cabinets, lockers or metal framed walls. Transmitter(s) will be placed at locations indicated below:
  1. Attach receiver to transmitter using cable.
  2. Connect antenna to transmitter, using care not to strip threads.
  3. Connect power supply to the transmitter. Set the channel number on the display to correspond to the FCC license.
  4. Plug power supply into electrical outlet.
- C. Analog clocks shall perform the following operations with each clock:
  1. Set clock to correct time in accordance with Manufacturer's instructions.
  2. Observe analog clock until valid signals are received and analog clock adjusts itself to correct time.

3. Install the analog clock on the wall in the indicated location, plumb, level and tight against the wall. If using 12½-inch (317.5mm) clock, attach using clock-lock hanging method and suitable fasteners as approved by Clock Manufacturer.
4. Wire guards: Secure to wall, using approved theft-resistant fasteners.

### **3.03 ADJUSTING**

Prior to final acceptance, inspect each clock, adjust as required, and replace parts which are found defective.

### **3.04 CLEANING**

Prior to final acceptance, clean exposed surfaces of clocks, using cleaning methods recommended by Clock Manufacturer. Remove temporary labels from clock faces. Do not remove labels from backs of clocks.

### **3.05 DEMONSTRATION**

Provide training to District's Representative on setting and adjusting clocks, replacing batteries and routine maintenance.

### **3.06 PROTECTION**

Protect finished installation until final acceptance of the Project.

### **3.07 TESTING**

All devices must be tested at their operational location under normal operational conditions to assure reception of signal.

END OF SECTION 27 53 13  
022219/212220

## **SECTION 28 10 00 ACCESS CONTROL**

### **PART 1 - GENERAL**

#### **1.01 SUMMARY**

- A. This Section includes access control door hardware for the following:
  - 1. Swinging doors.
  - 2. Sliding doors.
  - 3. Other doors to the extent indicated.
- B. Section includes, but is not necessarily limited to, the following for the integrated access control security and site management system:
  - 1. IP-enabled integrated access control door hardware.
  - 2. Monitoring and signaling equipment.
  - 3. System network control processors.
  - 4. Reader controller interfaces and modules.
  - 5. Input monitor and output control interfaces and modules.
  - 6. Remote card readers and display terminals.
  - 7. Power sourcing equipment, network switches and wireless access points.
  - 8. Access control cards and credentials.
  - 9. Access control system application software.
  - 10. Access control system power supplies, back-ups and surge protection.

#### **1.02 REFERENCE STANDARDS**

- A. BHMA A156.13 - American National Standard for Mortise Locks and Latches Series 1000.
- B. BHMA A156.18 - American National Standard for Materials and Finishes.
- C. DHI (LOCS) - Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames.
- D. DHI WDHS.3 - Recommended Locations for Architectural Hardware for Flush Wood Doors; also in WDHS-1/WDHS-5 Series.
- E. IEEE 802.3 - IEEE Standard for Ethernet; with Amendments.
- F. NFPA 101 - Life Safety Code.
- G. NFPA 80 - Standard for Fire Doors and Other Opening Protectives.
- H. TIA/EIA-568 - Commercial Building Telecommunications Cabling Standard; Rev C and latest addenda.
- I. Codes and References: Comply with the current version adopted by the Authority Having Jurisdiction.
  - 1. See Section 01 41 00 - Regulatory Requirements.

### 1.03 SUBMITTALS

- A. Product Data: Manufacturer's product data sheets including installation details, material descriptions, dimensions of individual components and profiles, operational descriptions and finishes.
- B. System Operational Descriptions: Complete system operational narratives for the integrated access controlled openings defining the Owner's Prescribed Requirements for the opening functionality. Narratives include, but are not limited to, the following situations: normal secured/unsecured state of door; authorized access; authorized egress; unauthorized access; unauthorized egress; fire alarm and loss of power conditions, and interfaces with other building control systems.
- C. Shop Drawings: Details of electrified integrated locking hardware and access control firmware, indicating the following:
  - 1. Wiring Diagrams: Upon receipt of approved schedules, submit detailed system wiring diagrams for power, signaling, monitoring, communication and control of the access control system electrified hardware and firmware. Differentiate between Manufacturer-installed and field-installed wiring. Include the following:
    - a. Elevation diagram of each unique access controlled opening showing location and interconnection of major system components with respect to their placement in the respective door openings.
    - b. Complete (risers, point-to-point) access control system block wiring diagrams.
  - 2. Electrical Coordination: Coordinate with related Division 26 Electrical Sections the voltages and wiring details required at electrically controlled and operated hardware openings.
- D. Proof of Certification: Provide copy of Manufacturer(s) official certification or accreditation document indicating proof of status as a qualified and authorized Provider of the primary access control components.
- E. Keying Schedule: Reference Division 08 Section "Door Hardware".
- F. Product Test Reports: Indicating compliance with Cycle Testing Requirements, based on evaluation of comprehensive tests performed by Manufacturer and witnessed by a qualified Independent Testing Agency.
- G. Operating and Maintenance Manuals: Provide Manufacturers operating and maintenance manuals for each item comprising the complete access control and site management installation in quantity as required in Division 01, Closeout Submittals. The manual to include the name, address, and telephone number of the Supplier/Integrator providing the installation and the nearest Service Representatives for each item of equipment included in the system. The final copies delivered after completion of the installation test to include "As Built" modifications made during installation, checkout, and acceptance.
  - 1. Record Drawings: During system installation, the Contractor to maintain a separate hard copy set of Drawings, Elevation Diagrams and Wiring Diagrams of the access control system to be used for Record Drawings. This set to be kept up to date by the Contractor with all changes and additions to the access control system accurately recorded.
- H. Warranties and Maintenance: Special Warranties and Maintenance Agreements specified in this Section.

#### 1.04 QUALITY ASSURANCE

- A. **Manufacturers Qualifications:** Engage Qualified Manufacturers with a minimum of 5-years of documented experience in providing access control and security systems equipment and software similar to that indicated for this Project and that have a proven record of successful in-service performance.
  - 1. Software and access control systems components to have been previously and thoroughly tested together with proven installations similar in size and functionality to the Design Requirements indicated for this Project.
- B. **Integrator Qualifications:** Systems Integrators, verifiably factory trained and certified by the Primary Product Manufacturers, with a minimum 3 years documented experience installing complete integrated access control systems similar in material, design, and scope to that indicated for this Project and whose work has resulted in construction with a proven record of successful in-service performance. Qualifications include, but are not necessarily limited, to the following:
  - 1. **References:** Provide a list of references for similar projects including contact name, phone number, name and type of Project.
  - 2. **Professional Staffing:** Firms to have a dedicated access control systems integration department with full time, experienced professionals on staff experienced in providing on site consulting services for both electrified door hardware and integrated access control systems installations.
  - 3. **Factory Training:** Installation and Service Technicians are to be competent factory trained and certified Personnel capable of maintaining the system.
  - 4. **Service Center:** Firms to have a service center capable of providing training, in-stock parts, and emergency maintenance and repairs at the Project site with 24-hour/7-days a week maximum response time.
- C. **Supplier/Dealer Qualifications:** Supplier/Dealers verifiably authorized and in good standing with the Primary Product Manufacturers, with a minimum 3 years' experience supplying integrated access control systems similar in material, design, and scope to that indicated for this Project and whose work has resulted in construction with a proven record of successful in-service performance.
- D. **Integrated Wiegand Output, Wireless, and IP-Enabled access control products** are required to be supplied and installed only through designated ASSA ABLOY "Authorized Channel Partner" (ACP) and "Certified Integrator" (CI) accounts.
- E. **Source Limitations:** Obtain the access control door hardware, system firmware and application software specified in this Section from a single source, qualified Supplier/Integrator unless otherwise indicated.
  - 1. Electrified modifications or enhancements made to a Source Manufacturer's product line by a secondary or third party source will not be accepted.
  - 2. Provide integrated access control door hardware from the same Manufacturer as mechanical door hardware, unless otherwise indicated.



- F. Regulatory Requirements: Comply with Section 01 41 00 - Regulatory Requirements and Guidelines as directed in the Building Code including, but not limited to, the following:
1. Comply with California Electrical Code, including electrical components, devices and accessories listed and labeled as defined in Article 100 by a Testing Agency acceptable to authorities having jurisdiction, and marked for intended use.
  2. Where indicated to comply with Accessibility Requirements, comply with Americans with Disabilities Act (ADA), "Accessibility Guidelines for Buildings and Facilities (ADAAG)," CBC Chapter 11B as follows:
    - a. Handles, Pulls, Latches, Locks, and other Operating Devices: Shape that is easy to grasp with one hand and does not require tight grasping, tight pinching, or twisting of the wrist.
    - b. Door Closers: Comply with the following maximum Opening-Force Requirements indicated:
      - 1) Interior Hinged Doors: 5 lbf applied perpendicular to door.
      - 2) Fire Doors: Minimum opening force allowable by authorities having jurisdiction.
  3. Comply with NFPA 101 for doors in a means of egress.
  4. Comply with NFPA 80 for fire labeled opening assemblies.
  5. The installed access control system shall conform to all Local Jurisdiction Requirements.
- G. Keying Conference: Reference Section 087100 - Door Hardware.
- H. Pre-Submittal Conference: Conduct coordination conference in compliance with Requirements in Section 01 30 00 - Administrative Requirements with attendance by Representatives of Supplier(s), Installer(s), Systems Integrator(s), and Contractor(s) to review proper methods and procedures for receiving, handling, and installing door and access control hardware to Manufacturer's recommendations and according to Specifications.
1. Prior to installation of door hardware, arrange for Manufacturers' Representatives to hold a Project specific training meeting on the proper installation and adjustment of their respective products. Product training to be attended by the Installers of access control hardware for the aluminum, hollow metal and wood door sections. Training will include the use of installation manuals, hardware schedules, templates and physical product samples as required.
  2. Inspect and discuss electrical roughing-in, power supply connections, and other preparatory work performed by other trades.
  3. Review sequence of operation narratives for each unique access controlled opening.
  4. Review and finalize construction schedule and verify availability of materials.
  5. Review the required Inspecting, Testing, Commissioning, and Demonstration Procedures.

## **1.05 DELIVERY, STORAGE, AND HANDLING**

- A. Inventory door hardware on receipt and provide secure lock-up and shelving for door hardware delivered to Project site. Do not store electronic access control hardware, software or accessories at Project site without prior authorization.
1. Access control firmware and software: Where approved and directed, inventory upon receipt and store electronic access control equipment in a secure, temperature and humidity controlled environment in original Manufacturer's sealed containers.

- B. Tag each item or package separately with identification related to the final Access Control Door Schedule, and include basic installation instructions with each item or package.
- C. Deliver permanent keys, cores, access control credentials, software and related accessories directly to Owner via registered mail or overnight package service. Instructions for delivery to the Owner established at the "Pre-Submittal Conference".

#### **1.06 COORDINATION**

- A. Coordinate quantity and arrangement of assemblies with ceiling space configuration and with components occupying ceiling space, including structural members, pipes, air-distribution components, raceways, cable trays, recessed lighting fixtures, and other items.
- B. Integrated Access Control Door Hardware and Electrical Coordination: Coordinate the layout and installation of scheduled integrated access control door hardware, and related access control equipment, with required connections to source power junction boxes, power supplies, detection and monitoring hardware and fire alarm system.
  - 1. Door Hardware Interface: The access control system to interface and be connected to electrified and integrated access control door hardware as described under Division 08 Sections "Door Hardware" or "Access Control Door Hardware". Coordinate the installation and configuration of electrified door hardware being monitored or controlled with the controls, software and access control hardware specified in this Section.
- C. Templates: Obtain and distribute to the parties involved templates for doors, frames, and other work specified to be factory prepared for installing electrified door hardware and access control system components. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing access control system hardware to comply with Indicated Requirements.
- D. Door and Frame Preparation: Related Division 08 Sections (Steel, Aluminum and Wood) doors and corresponding frames are to be prepared, reinforced and pre-wired (if applicable) to receive the installation of the specified electrified, monitoring, signaling and access control system hardware without additional in-field modifications.

#### **1.07 WARRANTY**

- A. General Warranty: Reference Division 01, General Requirements. Special warranties specified in this Article will not deprive Owner of other rights Owner may have under other provisions of the Contract Documents and are in addition to, and run concurrent with, other warranties made by Contractor under Requirements of the Contract Documents.
- B. Warranty Period: Written Warranty, executed by Manufacturer(s), agreeing to repair or replace components of the installed access control system hardware and software that fails in materials or workmanship, including all related parts and labor, within specified Warranty period after final testing and acceptance by the Owner. Failures include, but are not limited to, the following:
  - 1. Structural failures including excessive deflection, cracking, or breakage.
  - 2. Faulty operation of the hardware.
  - 3. Deterioration of metals, metal finishes, and other materials beyond normal weathering.
  - 4. Electrical component defects and failures within the systems operation.

- C. Standard Warranty Period: One year from date of Substantial Completion, unless otherwise indicated.
- D. Special Warranty Periods:
  - Two years for Integrated Access Control Door Hardware.

#### **1.08 MAINTENANCE SERVICE**

- A. Maintenance Tools and Instructions: Furnish a complete set of specialized tools and maintenance instructions as needed for Owner's continued adjustment, maintenance, and removal and replacement of standard and access control door hardware.
- B. Maintenance Service: Beginning at Substantial Completion, and running concurrent with the specified Warranty period, provides continuous 6-months full maintenance including repair and replacement of worn or defective components, lubrication, cleaning, and adjusting as required for proper door opening operation. Provide parts and supplies as used in the manufacture and installation of original products.
- C. Maintenance Support and Extended Service Agreement: Submit for Owner's consideration an optional extended Service Agreement for the installed access control system, including support for software related issues. The extended Service Agreement is considered elective and is without Manufacturer's Requirement stipulating mandatory coverage for Owner and/or Vendor system support.
  - 1. A published copy of this Agreement to be included with the submittal package
  - 2. Support for the installed access control system components is provided through the Vendor under a 24 hour Technical Assistance Program.
  - 3. Access control and management system components are to be available on a 1-day turn-around time frame from the Manufacturer.
  - 4. Primary Systems Manufacturer to offer and provide remote modem or internet access for direct factory support to the Vendor. The factory level support to include diagnostics and troubleshooting support on systems related issues at no additional cost to the Owner.
- D. Access Control Software Upgrades: Version upgrades and "fix" releases to the access control system software are available at no extra charge as long as the version of software provided in this Specification remains the current Manufacturer's version or for up to 2-years after a new version release.
  - 1. Major access control software revisions that provide new functionality to the product provided free of charge for up to 1-year from the date of substantial completion.
  - 2. Access control system software is to be upgradeable as may be required or as necessary, to expand and manage the Owner's site or sites. Upgrades are to be offered at a published flat fee for the primary system software, with single license modules included in the primary fee structure. System upgrades offered at a costing structure based upon the original number of licensed modules issued, or on those to be purchased at a future date, are not allowed.
  - 3. As part of the submittal package, provide a list of available software upgrades and/or expansions modules. List to identify related costs for upgrades, or expansions to the original system, up to the next qualifying operational level.

## 1.09 SCOPE OF WORK

- A. Access Control Site Management System: Furnish and install at the indicated locations the specified integrated access control door hardware and access control system firmware and software for a completely operational access control and security site management system. System includes, but is not necessarily limited, to the following:
1. Electrified integrated access control locks and exit hardware, network control processors, reader controller panels, I/O monitor/control interfaces, door position switches, remote card readers, keypads, and display terminals, access cards and credentials, system application software, special tools, operating manuals, and required cabling and accessories as detailed below and listed in the Access Control Hardware Sets at the end of Part 3.
    - a. Provide the appropriate number of reader controller panels and I/O monitoring / control expansion interfaces as needed to handle the number of card readers, locking devices, door status devices, and identified alarm inputs specified in this section, and as shown on the Security Drawings.
    - b. Provide Manufacturer approved integrated access control locks, exit hardware, and remote mounted card readers, keypads, and display terminals that are functionally compatible with the specified access control equipment interfaces.
  2. Access control system equipment to be installed in an enclosure box compatible with the specified components. This enclosure to include, but is not necessarily limited to, the network control processor, I/O monitor/control interface panels, power supplies, terminal strips, wire ducts, keyed lock cylinder, integrated outlet for A/C power, and standoffs.
    - a. Enclosure box to be located in the designated IT/Telecom room(s) with connection to the owner designated local area network for communication back to the central server host.
  3. Owner to provide the following:
    - a. Computer hardware and peripherals to be from an approved, Major Line Computer Manufacturer. The following Manufacturers will be considered "pre-approved", however, specific information detailing compliance with the Manufacturer's Requirements must be included within the Project submittal package as specified.
      - 1) Compaq
      - 2) Dell
      - 3) Hewlett-Packard
      - 4) IBM
    - b. Central Server Host Computer:
      - 1) System Server to include the following Minimal Requirements: Windows Server 2003 (Service Pack 1 or higher) or later Operating System, Intel Pentium IV 1 GHz (equivalent or greater), SQL Server 2005 Express Edition or SQL 2005, 1GB Ram or larger, 120GB hard disk space available or more as needed, CRT or LCD minimum 15-inch display Monitor, CD/RW Drive. Single serial port, or multiple USB ports, and one parallel port, keyboard and mouse.
    - c. Client Workstations:
      - 1) Client Workstation to include the following minimal Requirements: Windows XP Professional (Service Pack 2 or higher) or Windows Vista Business, Intel

Pentium III 500 MHz (equivalent or greater), SQL Server 2000 Client Access License, 1GB Ram or larger, 30GB hard disk space available or more as needed, CRT or LCD minimum 15-inch display Monitor, CD/RW Drive. Single serial port, or multiple USB ports, and one parallel port, keyboard and mouse.

- d. Owner will be responsible for ensuring that each computer hardware component includes the required interfaces, expansion boards, and peripherals that will be necessary to allow the system to operate as described within this Specification and as indicated on the Drawings.
- e. Power Sourcing, Network Switches and Wireless Access Points: Quantity as required to accommodate installed access control (and video surveillance) devices.
- f. Network Control Processor Connections:
  - 1) LAN/Ethernet communication ports (jacks) and network interface cards as needed, CAT5e (CAT6) cabling from network router/switch to network control processor, outlet and cover plates and/or patch cables required for network connection within each designated IT/Telecom room.
  - 2) Required static IP addresses.
- 4. Power Supplies, including battery or uninterruptible backup powers supply (UPS) and separately fused surge protection, required for the electrified door hardware, access control equipment, and PoE switches or wireless routers driving the integrated card reader locking devices.
- 5. Installation, final configuration and commissioning of electrified door and access control system hard-ware, communication firmware, power supplies and related accessories.
- 6. System application software including installation, programming, and end user training of the access control system demonstrating operating, repair, and maintenance procedures. Include on-site central server training for designated Personnel (facilities maintenance, security, IT, administration) by a Factory Certified Representative.
  - a. Include Client Software Application (client workstation) training at each of the remote installed facilities for local Administrative Staff.
- 7. Provide Manufacturer required power controllers, interface boards, and programming that may be required for approved electric latch retraction exit devices supplied under Division 08 Section "Door Hardware."
- 8. Electrical Contractor, Division 26, to provide the following:
  - a. Source power wiring (120VAC) as required for the integrated locking and access control hard-ware, equipment, accessories and power supplies. This includes quad outlets as required on a dedicated circuit in the designated IT/Telecom room(s) and the related conduit, stub-in, junction boxes and connectors required for the source power delivery and connections.
  - b. Provide required conduit, stub-in, junction and back boxes for both the electrified locking hardware and access control equipment at each of the access controlled or monitored openings per Plan Drawings and Specifications. Supply and install conduit between each of the aforementioned devices and between the electrical junction boxes, power supplies and access control equipment located on or above the door opening.

- 1) At wall mounted remote readers, provide conduit on the secured side of the door, 36-inches from the finish floor and 6-inches from the edge of the frame, to the related power supplies and access control equipment.
- 2) At electrical hardware power transfers provide conduit on the secured side of the opening from the power transfer, thru-wire hinge, or serviceable panel location on the frame jamb to the related power supplies and access control equipment.
- c. Electrical Contractor to provide all 120VAC cabling connections and terminations from the electrical junction boxes to these electrical devices.
9. Access Control System Integrator to provide the following:
  - a. Low voltage wiring (12/24VDC) and communication cabling (RS-232/RS-485) from network control processors to reader controllers, I/O monitor/control interface panels, electrified and integrated locking hardware, remote card readers, keypads, or display terminals, monitoring and signaling switches, and power supplies. Work includes related connectors, final terminations, and hook-ups required for a complete and functional access controlled opening in accordance with applicable Codes and specified system operational narratives.
10. Elevator Contractor to provide the following:
  - a. Interface or landing of interface cable onto the elevator call button will be performed by a Certified Elevator Contractor.
  - b. Coordinate with access control systems integrator provisions for a card reader with output allowing the elevator call button to be activated. A validated card read will be required for activation.
11. Full and seamless integration of the analog, digital or IP-enabled CCTV video surveillance system (Division 28) if applicable, with the installed site access control system software.
12. Full and seamless integration of the site intrusion alarm service and motion detector systems, (Division 28) if applicable, with the installed site access control system software.
13. Final connections to fire alarm system, if required, by Electrical and Fire Alarm System Contractors.
14. Provide permits, submittals and approvals required by the authority having jurisdiction, prior to commencing with work.

## **PART 2 - PRODUCTS**

### **2.01 SYSTEM ARCHITECTURE - ACCESS CONTROL SITE MANAGEMENT SYSTEM (ACSMS)**

- A. General: The ACSMS is a modular and networked based system providing physical access control security to a Wide Area District, campus or educational enterprise. The system to be capable of controlling and integrating multiple security functions including the configuration, management and monitoring of cardholder access, locking hardware units, events, alarms, visitors, and real-time tracking and reporting. The ACSMS is to be alterable at any time depending on the Facility Requirements and will allow for easy upgradeability or modification of network processors, controller, interface modules, card data, inputs, outputs, and remote workstations. The ACSMS to include, but is not be limited to, the following features and functions:

1. An "Enterprise" class access control software application.
2. Client/Server model operating central server host software modules and client workstation software applications in a multi-user and a multi-tasking environment.
  - a. The ACSMS to permit multiple instances of client software applications to run simultaneously on the network. The base system to include software application licenses with an unlimited number of licenses available subject to connection fees.
3. Partitioning: The system to support security partitioning enabling system administrator to segment the configuration database and group multiple entities within the security partition.
  - a. Security partitions limit what users can view in the configuration database. Administrators, who have all rights and privileges, can segment a database into multiple security partitions. A user who is given access to a specific partition will only be able to view entities (components) within the partition they have been assigned.
4. Encryption: The system to support encrypted communication between the central server software and client software applications (server-to-server and client-to-server) using a 128-bit AES encryption algorithm (at a minimum).
  - a. Communication between the central server host software module and system controllers to be encrypted if supported by the controllers.
  - b. The ACSMS client software applications to be password protected with passwords stored in the central server database in an encrypted manner.
5. Distributed Processing: The system is a fully distributed processing application allowing information, including time, date, zones, valid codes, tasks, access levels, and similar data, to be downloaded from the central host station to controller interface devices allowing access-control decisions with or without central host station communication. If communications to a central host station are lost, the controllers will automatically buffer event transactions until communications are restored and events are automatically uploaded to the central host station.
  - a. Provide for a higher level of distributed database management at defined perimeter access points such that no single point of failure will allow more than two access points to fail, or affect more than two access points at perimeter points system wide.
6. Single Data Base: The system to support a single database for access control site setup, credential and identity file creation, alarm and control setup, and system user operation and command functions.
7. System Access Management: The system to allow operators through password authentication the ability to make access granted or denied decisions, define access levels, time zones, holidays, assign cardholders, access groups, develop tasks, and generally manage access control, alarm monitoring and response activities system wide from a single login. Operator and user privileges are managed by a system administrator allowing for different levels of system access and system control. Authorization management is fully Owner definable.

8. Cardholder Management: The system to include a cardholder management system integrated within the access control system. This cardholder management functionality allows the enrollment of card-holders into the database, and import/export of employee data.
  9. Access Groups and Access Levels: The system to provide adequate access groups and access level assignment capability to meet Owner Requirements for the specified project. If required, software application can be expandable to support unlimited access groups and access levels.
  10. Alarm Monitoring: The system is able to monitor, report, and provide information about the time and location of alarms, along with their priority.
  11. Event Monitoring: The system is able to monitor, report, and archive network access control activity.
  12. Transaction Logs: The system to support an unlimited number of logs and historical transactions (events and alarms) with the maximum allowed being limited by the amount of hard disk space available.
  13. System Monitoring: The system to have ability to report on the integrity of all network assigned devices, circuits and communications and provide a diagnostics screen showing field level communications system wide
  14. Lock/Unlock Commands: The system to allow an operator to manually lock and unlock doors over-riding scheduled access control restrictions and configurations if necessary.
  15. Hardware Interface: The system to integrate with and control specified electrified hardware, signaling and monitoring devices.
  16. Report Generator: The system to have the ability to generate and output reports with any and all combinations of system fields and data including, but not limited to: by cardholder, by door, by site, by time, by groups of doors and by cardholder field. Any and all combinations of fields must be available for reporting. The report feature to allow exporting of generated reports over a network connection or by remote printing.
  17. Multi-User/Web Based Network Capabilities: The system to support multiple operator workstations via Local Area Network/Wide Area Network (LAN/WAN), the Internet, or VPN. The system to be capable of supporting minimum number concurrent Users/ Clients with software expansions to an unlimited number of workstations based on the Owners Network Requirements.
  18. Systems Integration: The system to have the ability to be fully and seamlessly integrated with existing or specified intrusion detection alarm and video surveillance (CCTV) systems.
- B. Open Architecture: The access control system infrastructure will be based on an open Architecture Design capable of supporting multiple Access Control Hardware Manufacturers and integrate with multiple non-proprietary network processors, controllers, interface modules, integrated locking hardware, remote card readers, keypads and display terminals, and other third party applications.



- C. Network Support: Communication network connecting the central server host software modules, Client work-station software applications, and hardware controllers to be designed to support all of the following:
  - 1. LAN/Ethernet enterprise ring topology and localized star topology based on TCP/IP.
  - 2. Direct-connected RS-232 and RS-485 communication cabling.
  - 3. Dial-up modem connection using a standard dial-up telephone line.

## 2.02 MANUFACTURERS

- A. Approved Access Control and Site Management System Manufacturers:
  - 1. Corbin Russwin (Integrated Access Control Locking Devices and Accessories).
  - 2. HID Global (Access Cards and Credentials, Remote Readers).
  - 3. Sargent Manufacturing (Integrated Access Control Locking Devices and Accessories).
  - 4. Securitron Corporation (Power Supplies).
  - 5. Substitutions: See Section 01 60 00 - Product Requirements.
- B. General: Provide integrated access control door hardware and access control system equipment and accessories for each designated opening to comply with Requirements in this Section and with the Access Control Hardware Sets listed at the end of Part 3.
  - 1. Access Control Hardware Sets: Requirements for quantity, item, model, design, grade, finish, size, and other distinctive qualities of each type of integrated door and access control hardware are indicated in the Access Control Hardware Sets at the end of Part 3.
  - 2. Named Manufacturer's Products: Product designation and Manufacturer are listed for each door hardware type required for the purpose of establishing Minimum Requirements. Manufacturers' names are abbreviated in the Door Hardware Schedule.
- C. System Design: The equipment and materials supplied are to be standardized components regularly manufactured and utilized within the Source Manufacturer's access control systems.
  - 1. System components to be non-proprietary in design and implementations, providing for an open protocol platform with multiple Manufacturers having functional software capable of integrating with the hardware specified. The installed integrated product is to be part of a single, cohesive management and access control system.
- D. Substitutions: Requests for substitution and product approval for inclusive integrated access control door and access control systems hardware in compliance with the specifications must be submitted in writing and in accordance with the procedures and time frames outlined in Section 01 25 00 - Substitution Procedures. Approval of requests is at the discretion of the Architect, Owner, and their Designated Consultants.
  - 1. The access control system described in this Specification represents a complete engineered system. If alternate products are submitted, it is the responsibility of the Supplier/Dealer/Integrator to provide an acceptable complete and working system layout, including re-engineering of elevation and wiring diagrams, as applicable. Complete systems to include at a minimum required power supplies, power transfers, and integrated access control locking hardware and accessories.

### **2.03 ACCESS CONTROL AND SITE MANAGEMENT SYSTEM HARDWARE**

- A. General: Provide all necessary access control field hardware devices required to receive alarms and administer all access granted/denied decisions. Field hardware devices must be designed and installed in accordance with applicable Electrical Codes.
- B. Central Computer Host Server (Owner Provided): The central host server is interconnected to all system components, including client workstations and field installed controllers, providing operator interface, inter-action, display, control, and real-time monitoring.

### **2.04 INTEGRATED IP-ENABLED ACCESS CONTROL DEVICES**

- A. IP Enabled Power-over-Ethernet (PoE) Integrated Card Reader Mortise Lock: IP enabled ANSI/BHMA A156.13 Grade 1 mortise lockset with integrated credential reader, request-to-exit, and door position signaling in one complete unit. Motor driven locking/unlocking control of the lever handle trim, ¾-inch projection latch bolt, and optional 1 inch steel deadbolt. Lock is UL listed and labeled for use on up to 3 hour fire rated openings. Available with or without keyed high security cylinder override.
  - 1. Acceptable Manufacturers:
    - a. Corbin Russwin Hardware (RU) - IN220 Series.
    - b. Mortise locks - IN220-ML20234 B OA BIP PSA M17 CT6R 626
    - c. Exit Devices - ED5200N IN220 PR9134 B OA BIP 5CH M110 CT6R 630 - Special App request for 5CH
    - d. Fire-Rated Exit Devices - ED5200AN IN220 PR9134 B OA BIP 5CH M110 CT6R 630 - Special App request for 5CH
    - e. Substitutions: See Section 01 60 00 - Product Requirements.
  - 2. Operational Narratives required at ALL Card Access openings.
  - 3. Completely intelligent and integrated locking unit with Ethernet power and communication connection capability directly from the locking unit back to the central system host server without additional access control interfaces or components (excluding PoE Endspan and Midspan devices) via an existing or newly installed IEEE 802.3af PoE enabled network.
  - 4. Open architecture design supports wired integration with third party access control systems applications via software development kit (SDK). Real-time software accessible alarms for forced door, unknown card and door held open, with inside lever handle (request-to-exit), battery status, tampering, and door position (open/closed status) monitoring.
  - 5. 2,400 users and 10,000 event transaction history (audit trail). Distributed intelligence allows stand-alone operation in absence of network communication allowing for system operational redundancy.
  - 6. Provide a network and lock configuration CD tool kit for initial lock setup and programming via a USB connection.
  - 7. Energy Efficient Design: Provide lock bodies which have a holding current draw of 15mA maximum, and can operate on either 12 or 24 volts. Locks are to be field configurable for fail safe or fail secure operation.

8. Integrated reader supports the following Credentials:
  - a. 125kHz proximity credentials: HID, AWID, Indala, and EM4102.
  - b. 13.56 MHz contactless credentials: HID iClass, HID iClass SE, HID iClass Seos, SIO on MIFARE Classic, SIO on MIFARE DESFire EV1, MIFARE Classic, DESfire EV1, NFC-enabled mobile phones, Bluetooth Smart-enabled mobile phones.
9. Communication between access control system and device is protected by AES 128 bit encryption via the SDK. Programmable for time zones, holidays, and automatic unlocking.
10. Power and communication from one Ethernet (CAT5e or higher) cable. Compliant with IEEE 802.3af Class 1 device specifications requiring 3.84 watts for Power over Ethernet.
11. Supports real-time system lockdown capabilities. Inside lever retracts latch bolt and deadbolt simultaneously.
12. High security mechanical key provides emergency override retraction of latch-bolt without need for electronic activation.
13. Ethernet system framework, network cabling, mounting boxes, PoE end-span/mid-span, electrical hard wiring, grounding, and connections are required for complete system functionality. All system components are by others and are specified elsewhere.
  - a. Power Requirement: PoE Class 2, maximum 7 watts.
  - b. Network Cabling Requirements: Cat5e or higher meeting or exceeding ANSI/TIA/EIA-568-C. 24 AWG Plenum rated.
  - c. Bonding and Grounding: Meet or exceed TIA-607-B Requirements. Connect device ground cable to building electrical earth ground.
  - d. Network Surface Mount Box: Meet or exceed ANSI/TIA/EIA-568-C Requirements. CAT5e or higher (RJ45).

## **2.05 CABLES AND WIRING**

- A. Comply with Division 26 and 27
- B. Data Line Supervision: System to include alarm initiation capability in response to opening, closing, shorting, or grounding of data transmission lines.
- C. Install appropriate number of conductor pairs, in the wire gage (AWG) recommended by Manufacturer, corresponding to the electronic locking functions specified, amperage drawn and distances covered between the power supplies, power transfer devices, electrified hardware and access control equipment.

## **2.06 FABRICATION**

Fasteners: Provide door hardware manufactured to comply with published templates generally prepared for machine, wood, and sheet metal screws. Provide screws according to Manufacturers recognized installation standards for application intended.

## **2.07 ACCESS CONTROL HARDWARE FINISHES**

- A. Standard: Designations used in the Hardware Sets and elsewhere indicate hardware finishes complying with ANSI/BHMA A156.18, including coordination with traditional U.S. finishes indicated by certain Manufacturers for their products.

- B. Protect mechanical finishes on exposed surfaces from damage by applying temporary protective coverings before shipping.
- C. Where specified, finishes on integrated card key locksets or exit hardware to incorporate an FDA recognized antimicrobial coating (i.e., MicroShield™) listed for use on equipment as a suppressant to the growth and spread of a broad range of bacteria, algae, fungus, mold and mildew.

## **PART 3 - EXECUTION**

### **3.01 EXAMINATION**

- A. Examine scheduled openings, with Installer present, for compliance with Requirements for installation tolerances, labeled fire door assembly construction, wall and floor construction, and other conditions affecting performance of the installed access control system.
- B. Examine roughing-in for electrical source power to verify actual locations of wiring connections before electrified and integrated access control door hardware installation.
- C. Examine roughing-in for LAN and control cable conduit systems to PCs, controllers, card readers, and other cable-connected devices to verify actual locations of conduit and back boxes before device installation.
- D. Notify Architect of any discrepancies or conflicts between the Specifications, Drawings and Scheduled access controlled hardware. Proceed only after such discrepancies or conflicts have been resolved in writing.

### **3.02 PREPARATION**

Doors and frames at scheduled access controlled openings to be properly prepared to receive specified electrified and access control hardware and connections without additional in-field modifications.

### **3.03 INSTALLATION**

- A. Install each item of integrated access control door hardware and access control equipment to comply with Manufacturer's written instructions and according to Specifications.
- B. Mounting Heights: Mount integrated access control door hardware units at heights indicated in following applicable publications, unless specifically indicated or required to comply with Governing Regulations:
  - 1. Standard Steel Doors and Frames: DHI (LOCS).
  - 2. Wood Doors: DHI WDHS.3.
  - 3. Where indicated to comply with Accessibility Requirements, comply with CBC Chapter 11B.
- C. Boxed Power Supplies: Verify locations.
  - 1. Configuration: Provide the least number of power supplies required to adequately serve doors with access control hardware and equipment.
- D. Integrated Wiegand access control products, campus locks, and IP enabled products are required to be installed through current members of the ASSA ABLOY "Certified Integrator" (CI) program.

- E. Final connect the system control switches (integrated access control door hardware, remote readers, keypads, display terminals, biometrics), and monitoring, and signaling equipment to the related controller devices at each opening to properly operate the electrified door and access control hardware according to system operational narratives.
- F. Retrofitting: Install each door hardware and access control item to comply with Manufacturer's published templates and written instructions. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation of surface protective trim units with finishing work specified in Division 9 Sections. Do not install surface-mounted items until finishes have been completed on substrates involved.
- G. Networked System Application Software: Install, and test application(s) software and data-bases for the complete and proper operation of systems involved. Assign software license(s) to Owner.

### **3.04 FIELD QUALITY CONTROL**

- A. Field Inspection: Perform a final inspection of the installed integrated access control door hardware and access control system and state in report whether installed work complies with or deviates from Requirements, including whether each component representing the opening assembly is properly installed, adjusted, operating and performing to system operational narratives.
- B. Commissioning and Testing Schedule: Prior to final acceptance of the access control system installation, the following testing and documentation to be performed and provided to the Owner.
  - 1. Inspection: Verify that units and controls are properly installed, connected, and labeled and that interconnecting wires and terminals are identified.
  - 2. Pre-testing: Program and adjust the system and pretest all components, wiring, and functions to verify they conform to Specified Requirements. Provide testing reports indicating devices tested, pass/fail status, and actions taken to resolve problem(s) on failed tests.
  - 3. Acceptance Test Schedule: Correct deficiencies identified by tests and observations and retest until Specified Requirements are met.
  - 4. Provide "As Designed" Drawings showing each device and wiring connection and electronic enclosure legends indicating cabling in and out.
  - 5. Provide a complete set of operating instructions for access control hardware devices and a complete software user manual. The documentation includes module reference guides for each electronic enclosure.

### **3.05 ADJUSTING**

Adjust and check each operating item of integrated access control door hardware, and each door opening to ensure proper secured operation and function of every unit. Replace units that cannot be adjusted to operate as intended.

### **3.06 CLEANING AND PROTECTION**

- A. Protect all hardware stored on construction site in a covered and dry place. Protect exposed hardware installed on doors during the construction phase. Install any and all integrated access control door hardware at the latest possible time frame.
- B. Clean adjacent surfaces soiled by access control system installation.
- C. Clean operating items as necessary to restore proper finish and provide final protection and maintain conditions that ensure access control door hardware is without damage or deterioration at time of Owner occupancy.

### **3.07 DEMONSTRATION**

Instruct Owner's Maintenance Personnel to adjust, operate, and maintain electronic integrated door hardware and the access control system.

### **3.08 ACCESS CONTROL HARDWARE SETS**

- A. The hardware sets listed represent the design intent and direction of the Owner and Architect. They are a guideline only and should not be considered a detailed hardware schedule. Discrepancies, conflicting hardware and missing items should be brought to the attention of the Architect with corrections made prior to the bidding process. Omitted items not included in a hardware set should be scheduled with the appropriate additional hardware required for proper application and functionality.
- B. Refer to Section 08 06 71 - Door Hardware Schedule for hardware sets.

END OF SECTION 28 10 00  
022219/212220

This page is blank.

## SECTION 28 46 20

### FIRE ALARM

#### PART 1 - GENERAL

##### 1.01 SCOPE

- A. Work Included: All labor, materials, appliances, tools, equipment necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete, as shown on the Drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other Specifications Sections and Drawings for related work required to be included as work under Division 26, 27 and 28.
  - 2. General Provisions and Requirements for electrical work.
- B. This Specification provides the Minimum Requirements for the Fire Alarm and Detection System. The system shall include, but not limited to all equipment, materials, labor, documentation and services necessary to furnish and install a complete, operational system to include but not limited to the following functions:
  - 1. Smoke and Fire Detection.
  - 2. Off-Premise Notification.
  - 3. Mass Notification System.
  - 4. One-Way Voice Communication Notification System.
  - 5. Two-Way Voice Communication System.

##### 1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)

- A. Submit eight copies of the following to the Architect for approval.
  - 1. A listing of all fire alarm components and equipment including the California State Fire Marshal (CSFM) listing numbers.
  - 2. CSFM listing sheets of all devices being used.
  - 3. Manufacturers' standard catalog data for fire alarm components.
    - a. The submittal shall be arranged in the order of the Specification and shall list the Specification paragraph number, the name, the proposed Model and Manufacturer for each item as well as a reference indicating the specific piece of data which can be easily located in the brochure.
    - b. The Manufacturers' data sheets shall be marked to indicate the specific item being proposed in cases where the sheet covers several types or sizes of item. The data sheet shall completely describe the proposed item.
    - c. Where modification to the equipment is necessary to meet the Operational Requirements of the Contract Documents and the data sheets shall include complete Mechanical and Electrical Shop Drawings detailing the modification.
  - 4. A listing of the outlet rough-in needed for every device and equipment item. The applicable symbol which illustrates that rough-in item on the Job Plans shall be drawn on



the proposal, opposite the description of the rough-in to facilitate locating the data by Field Personnel.

5. Elevation and dimensional information.

### **1.03 APPLICABLE STANDARDS**

- A. The Equipment shall be listed, labeled, and approved for the application shown in Contract Documents, as fire alarm equipment complying with the following Requirements:
  1. List of applicable Codes:
    - a. Building Standards Administrative Code, Part 1, Title 24 C.C.R.
    - b. California Building Code (CBC), Part 2, Title 24 C.C.R.
    - c. California Electrical Code (CEC), Part 3, Title 24 C.C.R.
    - d. California Mechanical Code (CMC), Part 4, Title 24 C.C.R.
    - e. California Plumbing Code (CPC), Part 5, Title 24 C.C.R.
    - f. California Fire Code (CFC), Part 9, Title 24, C.C.R.
    - g. California Referenced Standards Code, Part 12, Title 24, C.C.R.
    - h. Title 19, C.C.R., Public Safety, State Fire Marshal Regulations.
    - i. California Energy Code (CEC, Part 6, Title 24 C.C.R.
  2. NFPA Standards and Guides:
    - a. NFPA 13, Standard for the Installation of Sprinkler Systems
    - b. NFPA 14, Standard for the Installation of Standpipe and Hose Systems
    - c. NFPA 17, Standard for Dry Chemical Extinguishing Systems
    - d. NFPA 17A, Standard for Wet Chemical Extinguishing Systems
    - e. NFPA 24, Standard for the Installation of Private Fire Service Mains and Their Appurtenances.
    - f. NFPA 72, National Fire Alarm and Signaling Code®, (California Amended).
    - g. NFPA 253 Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source
    - h. NFPA 2001, Standard on Clean Agent Fire Extinguishing Systems
  3. The Fire Alarm System shall conform to the applicable Standards and Guides referenced in CBC, California Code of Regulations, Title 24, Part 9
- B. Written Certification by the Fire Alarm Equipment Manufacturer shall be submitted to the Architect, stating that the system and its component parts are listed and approved by the California State Fire Marshal and the Installation has been Tested, is Operational and Conforms to the Requirements as set forth in Part 3, Article 24, Title 19, California Code of Regulations.

### **1.04 EQUIPMENT AND INSTALLING QUALIFICATIONS**

- A. The Equipment shall be manufactured by Simplex to match existing fire alarm equipment on the Campus.
- B. The Specification is based on the equipment of Manufacturers who have been approved by the District and the Manufacturers herein named shall be considered as meeting the Requirements of this Specification. For all items which are identified by part number and Manufacturer the Performance Specifications which are published in the most recent

Manufacturer's data sheets available at the time of bidding this Project shall be applicable to the present work as though fully written out herein.

- C. All equipment shall conform to all local applicable Codes and Ordinances, and shall be listed by Underwriters Laboratories.
- D. To Qualify as an acceptable Bidder, whether the bid is submitted to the District, his Agent, a General Contractor or a Sub-Contractor, the System Bidder or Contractor shall be qualified Fire Alarm Contractor and shall hold a valid C10 License issued by the Contractors State License Board of California. The System Bidder or Contractor shall hereinafter be referred to as the Contractor. The Contractor shall hold all other licenses required by the legally constituted Authorities Having Jurisdiction over the work. The Contractor shall be the Factory Authorized Distributor for the branch of equipment offered and shall have been engaged in the business of supplying and installing the specified type of system for at least 5-years. The Contractor shall maintain a fully equipped service organization capable of furnishing adequate repair service to the equipment. The Contractor shall be financially able to provide a performance bond covering the work and the guarantee described. The Contractor shall provide that bond if requested.
- E. Installation Certification
  - 1. Work and material for cables, cable terminations and related components shall be performed by Certified Installers. The Installer shall be certified by the respective Product Manufacturers.
  - 2. The Manufacturers of the indicated work and material shall provide an Installer Education/Training and Certification Program for the supplied products.
  - 3. The Installers performing the Contract work for the indicated products shall have attended and successfully completed each of the respective Manufacturer's installation training education programs for the specified products.
  - 4. Submit six copies of the Manufacturer's Certifications for each Installer performing the work. The submittal shall be approved prior to initiating any related Contract Work.
  - 5. Contract material installed and work performed by Installers not complying with these Requirements shall be removed. Removal of work and material not in compliance with these Requirements shall done at the Contractors' expense, without any additional cost to the Contract and without any Additional Contract completion due date extensions. New material and work required to replace the non-complying removed work and material shall be provided at the Contractors' expense, without any additional cost to the Contract and without any additional Contract completion due date extensions.

## **PART 2 - PRODUCTS**

### **2.01 GENERAL SYSTEM OPERATION**

- A. System shall be microprocessor-based, addressable, and power-limited with Class B supervised circuits, one-way and two-way emergency audio communications.
  - 1. The microprocessor shall execute all supervisory and control programming to detect, report the failure or disconnection of any system module or peripheral device and initiate programmed control sequences. An isolated supervision "watchdog" circuit shall monitor the microprocessor and, upon failure, shall activate the system trouble circuits.

2. The automatic fire detection and alarm system shall consist of main control panel, transponder panel(s), notification alarm devices, remote annunciator, automatic detection devices, manual stations, printer, and CRT/keyboard, installed and wired in accordance with the Drawings and shall function as specified herein.
3. The system shall be programmable in the field, by a non-computer trained person. All programmed information shall be stored in non-volatile memory.
4. The system shall operate both addressable and non-addressable ionization, thermal and photoelectric detecting devices, manual stations, water-flow switches, and external control modules.
5. The control panel shall provide power, annunciation, supervision and control for the fire detection and alarm system. The system shall be designed such that alarm indications override trouble and control conditions.
6. External Circuit Supervision shall not require additional wires other than the pair used for detection or alarm (only two wires shall be used from the control panel to each loop of initiating devices and two wires for the notification alarm devices). These two wires shall provide both supervision and notification alarm signals. There shall be no loss of Supervision for Class "B" wired addressable devices. Class "A" Supervision may be provided by adding an additional pair of wires.

**B. Alarm Conditions**

1. Actuation of any manual or automatic alarm initiating device, connected to the system shall cause the following automatic functions.
  - a. All notification alarm signaling units shall activate continuously. Audible notification alarms shall sound the California State Coded Signal.
  - b. The respective zone alarm lamp or annunciator alphanumeric readout on the central control panel, and remote annunciator panel, shall be activated.
  - c. Activate the Digital Alarm Communicator system.
2. Actuation of HVAC air duct smoke detectors shall stop the designated fans and motors in the building's air distribution system.
3. Actuation of smoke detectors on either side of smoke doors shall energize the release mechanism on the smoke door causing the door to close.
4. Notification alarm signal duration shall be capable of continuous sounding or adjustable from 3 to 10-minutes.
5. Perform any additional functions as specified herein or shown on the Drawings.

**C. Trouble Condition**

1. A single open or single trouble condition in a manual or automatic fire initiating wiring circuit shall activate the respective zone trouble lamp or annunciator readout on the fire alarm control panel and sound a trouble signal at the control panel.
2. A single open or single trouble condition in the notification alarm signaling wiring circuit shall activate the trouble lamp or annunciator readout in the control panel and sound a trouble signal at the control panel.
3. 120 volt AC normal power shall be monitored with indication by a "power on" lamp. Upon normal power outage, the system shall activate power trouble condition lamp or annunciator readout, and indicate a trouble condition.

4. The control panel shall monitor the standby batteries and, upon a low battery condition, activate the low battery lamp or annunciator readout and indicate a trouble condition.
  5. System ground detection shall be provided for the entire system. Upon ground detection, activate the ground detection lamp or annunciator readout and indicate a trouble condition.
- D. Control panels employing alphanumeric readouts shall display the trouble condition along with a prompt to review the list chronologically. The end of the list shall be indicated.

## **2.02 FIRE ALARM CONTROL PANEL**

### **A. General**

1. The fire alarm control panel shall be software programmable, microprocessor controlled, solid state, electronic integrated system. The panel shall be the product of one Manufacturer. The control panel shall provide power, annunciation, supervision and control for the detection and alarm system. The detection system shall remain 100% operational, responding to an alarm condition while in the routine maintenance mode.
2. Addressable detection and control devices shall be individually identified by the system, and any quantity of addressable detection devices shall be in alarm and any quantity of addressable control units shall be operable at any time up to the total number connected to the system.
3. The microprocessor shall access the system program, which is stored in non-volatile programmable memory, for all Control-By-Event (CBE) functions. The system program shall not be lost upon failure of both primary and secondary power. Volatile memory shall not be acceptable.
4. A means shall be provided for acknowledging each abnormal condition. Each activation of the appropriate acknowledges button shall sequentially acknowledge every point in the system. After all the points have been acknowledged, the LEDs shall glow steady and the panel audible signal will be silenced. The total number of alarms, supervisory, and trouble conditions shall be displayed along with a prompt to review each list chronologically. The end of the list shall be so indicated.
5. An alphanumeric annunciator readout shall indicate on the control panel the activation by type, loop, and address of the specific device, sub-loop or alarm/monitor/control point via an alphanumeric display. An audible alert shall sound at the control panel and an alarm light shall flash.
6. If the microprocessor fails, the system shall executive a default signaling program. This program shall enable the control panel to sound the audible signals and summon the Fire Department. In addition, a red LED shall light to indicate the communication loop wherein the alarm originated. Inability of the system to sound signals or summon the fire department during microprocessor failure shall not be acceptable.
7. Protected access to the system controls shall be provided to allow the user/operator access to the following system functions:
  - a. Status of all addressable points.
  - b. Status of all events logged.
  - c. Set/change the real-time clock and date.

- d. Perform an operational manual test of the system from the control panel, including actuation of any initiating device and trouble circuit without alarming the remote central station. The panel shall automatically return to normal mode in the event the panel remains unattended in the service mode.
  - e. Retrieve from event log the last 300 alarms, or control points and 300 trouble conditions.
8. Individual input (monitor) and output (control) device addressability shall all be performed on the same pair of wires. Wiring shall be Class "A" or "B". When Class "B" wiring is used, no special wiring sequence shall be required on addressable device circuits. An unlimited number of wiring branches shall be permitted with no loss of supervision.
9. A minimum of 25% addressable monitor, trouble and control points shall be provided.
- B. Cabinet
- 1. A metal tamper resistant cabinet shall contain the control panel components. Panel shall be surface or flush mounting as indicated on the Drawings. Provide a full height tamper resistant hinged locking cabinet door. The door shall have transparent, high impact windows to allow visual observation of all indicators and switches without opening the panel door.
  - 2. "In-out" circuit conductors shall terminate on numbered screw-type terminals.
  - 3. All groups of circuits or common equipment shall be clearly marked and shall be expandable by inserting interchangeable units.
- C. The Control Panel shall provide positive protection against the fire alarm system inadvertently being left in a non-operating status. The alarm system shall automatically restore and resound alarms and trouble signals, if subsequent alarm initiating or trouble signals are received under any of the following conditions:
- 1. After the alarm or trouble silence switch have been activated.
  - 2. Prior to resetting system after previous alarm or trouble conditions.
- D. The System Indicating and Operational Control Devices shall be mounted on the control panel face behind the panel door and shall provide the following minimum functions:
- 1. Individual visual indicating pilot lights annunciator or alphanumeric readout to monitor the following alarm system conditions:
    - a. Input power.
    - b. System common alarm.
    - c. System common trouble.
    - d. Alarm or trouble signal silenced.
    - e. Ground fault.
    - f. Battery condition.
    - g. Each individual alarm, control or initiating zone-activation.
    - h. Each individual alarm, control or notification zone-trouble.
    - i. Report, by specific device number, any device removed from an addressable initiating circuit, all other devices shall continue to function.

2. Manual control switches to allow the following system controls:
    - a. Alarm silence.
    - b. Trouble silence.
    - c. Test all indicating pilot lights and readouts.
    - d. System reset, including remote devices connected to the alarm panel.
    - e. Alarm test to initiate an alarm condition from the control panel.
    - f. Alarm disconnect for system testing without activating the Digital Alarm Communicator system.
    - g. Changing the status of configured circuits (arming or disarming and changing status of relays). If any change in status degrades system operation as configured, a trouble condition shall be reported and remain until system operation again meets configured status.
    - h. Perform multiple operations at the same time. These operations shall include but not be limited to timed functions and multiple configured sequences.
- E. Alarm Initiating Zone Modules.
1. Shall supervise and accept remote alarm actuating device input signals. An alphanumeric readout shall indicate separate zone alarm and trouble indicators for each zone.
  2. Zones shall be compatible, and designed to operate with the connected initiating devices either addressable or non-addressable type.
  3. A spare double throw set of software programmable auxiliary alarm relay contacts shall be provided for control of remote devices for each zone. Contacts shall be rated 120-volt 60Hz 3-amp.
  4. Each device on the system shall report as its own unique address.
- F. Notification Alarm Signal Control.
1. Shall supervise and activate remote notification alarm devices.
  2. Notification alarm shall be compatible and designed to properly operate with the connected audio and visual notification alarm devices, with no signal degradation.
  3. The notification alarm shall provide group notification signal control of all notification zones.
  4. The alarm modules shall be field resettable to provide either continuous or coded notification alarm signals. The coded alarm signal shall provide an intermittent "on-off" pulsed sound activation of audible notification alarm devices.
  5. A notification alarm circuit trouble indicating readout shall be provided for each notification zone.
- G. Audio
1. The system shall be capable of delivering multi-channel audio messages simultaneously over copper and/or fiber media. All audio messages and live pages shall originate at the one-way audio control unit. The one-way audio control unit shall store pre-recorded audio messages digitally. These messages shall be automatically directed to various areas in a facility under program control. The system shall support remote cabinets with zoned amplifiers to receive, amplify and send messages through speakers over

supervised circuits. The one-way emergency audio control shall provide control switches to direct paging messages as follows:

- a. "All Call" to direct the page messages to all areas in the facility, overriding all other messages and tones.
  - b. "Page to Evacuation Area" to direct the message to the evacuation area(s), overriding all other messages and tones.
  - c. "Page to Alert Area" to direct page messages to the area(s) receiving the alert message and tones, overriding all other messages and tones.
  - d. "Page to Balance Building" to direct page messages to the areas) in the facility NOT receiving either the evacuation area or alert area messages.
  - e. "Page by Phone" switch to select the Firefighters telephone system as the source for paging.
2. The system shall be capable of delivering multiple audio messages simultaneously over copper and/or fiber media. All audio messages and live pages shall originate at the one-way emergency audio control unit. The one-way emergency audio control unit shall store pre-recorded audio messages digitally. These messages shall automatically directed to various areas in a facility under program control. The system shall support remote panels with zoned amplifiers to receive, amplify, and distribute messages through speakers over supervised circuits.
  3. The two-way voice communications control unit shall provide two-way communications between remotely located phones and the command center. The control unit shall provide the ability to individually select and display each two-way voice communication circuit support up to five remote telephones in simultaneous two-way voice communications.
  4. Audio Amplifiers (Multi-Channel)
  5. Provide one 20-watt audio amplifier per paging zone. There will be a total of two 20-watt amplifiers (one per floor). The system software shall be capable of selecting the required audio source signal for amplification. To enhance system survivability, each audio amplifier shall automatically provide a local 3-3-3 1000Hz temporal pattern output upon loss of the audio communications with the one-way audio control unit, during an alarm condition. Audio amplifiers shall be power limited and protected from short circuits conditions on the audio circuit wiring. Each amplifier output shall include a dedicated, selectable 25/70 Vrms output. Provide a standby audio amplifier that will automatically sense the failure of a primary amplifier, and replace the function of the failed amplifier.
- H. Automatic ground detection shall detect either positive or negative voltages when earth connections of 50,000 OHMS or less occur, and activate the ground trouble signal.
1. A ground fault Code shall provide indication of either a positive or negative ground fault and shall operate the general trouble devices as specified herein but shall not cause an alarm to be sounded.
  2. A short circuit error message shall be a standard feature of the fire alarm control panel. Each communication loop shall be monitored for short circuits and shall have a distinctive error message for visual indication of circuits and operating trouble devices as specified herein but shall not cause an alarm to be sounded.

I. Power Supply

1. The dedicated power supply shall be adequately sized to properly operate the equipment, including remotely connected, spare and future indicated equipment with all alarm devices in alarm condition. Provide 20% spare power supply capacity for future expansion. Provide transfer modules and multiple power supplies as required for proper operation.
2. Input voltage 120/240 volt or 120/208 volt 60Hz AC.
3. Surge protection device on the input and output phases of the power supply shall be provided.
4. Supervised voltage types (i.e., 120-volt, 60Hz AC, 24 volt, AC, 24 Volt D.C., etc.) required by special connected equipment shall be supplied, including but not limited to:
  - a. Alarm initiating devices.
  - b. Notification alarm devices.
  - c. Control and annunciator panels.
  - d. Fire and smoke dampers.
5. A solid-state power transfer circuit shall provide (UPS) Uninterrupted Power Supply between internal standby power and line power automatically and instantaneously if normal power fails or falls below 15% of normal ("brown out" conditions).
6. Individual circuit fuses shall be provided for smoke alarm detector power, main power supply notification circuits, battery standby power, and auxiliary output.
7. Provide lock-on device on each power supply dedicated branch circuit breaker at panel.

J. Battery Back-Up Operation

1. Internal batteries and battery power supplies shall be provided to allow 60-hours continuous automatic normal operation of the entire control panel and fire alarm system after the failure of the incoming utility power. Sufficient battery capacity shall remain at the end of 60-hour period to provide 10-minutes of continuous operation of all connected notification alarm devices.
2. Batteries shall be maintenance free, sealed, lead-acid or lead calcium or gelled electrolyte type rated 25% larger than required to provide power for the entire system upon loss of normal 120 VAC power for a period of 60-hours with 15-minutes of alarm signaling at the end of this 60-hour period.
3. The battery charger shall be automatic, dual rate with capacity to recharge completely discharged batteries in 18-hours. Charger shall be temperature compensated.

K. Lightning and surge protection device shall be a standard feature of the fire alarm control panel and shall be incorporated in the power supply circuit, common control circuits, signal circuits, and telephone line circuit.

L. Circuitry shall be provided in the control panel to permit transmission of trouble and alarm signals over leased or privately owned telephone cables to a remote receiving panel. A reverse polarity or a master box circuit as required shall be provided in the control panel. There shall be a supervised disconnect switch to allow testing of the fire alarm signal without transmitting an alarm signal to the central station.



- M. The Alphanumeric Annunciator (printer and CRT/keyboard) shall list upon request:
1. Alarms with time, date and location.
  2. Troubles with time, date and location.
  3. Status of output functions, "on" or "off".
  4. Sensitivity of addressable smoke detectors.
  5. Detection device number, type and location.
  6. Status of remote relays, "on" or "off".
  7. Acknowledgment time and date.
  8. Signal silence time and date.
  9. Reset time and date.
- N. The System shall also provide the following:
1. Counting the number of addressable detectors within a "Zone".
  2. Which are in the alarm.
  3. Counting "Zones" which are in alarm.
  4. Counting the number of addressable detectors which are in alarm.
  5. Alarm on the system.
  6. Differentiating among types of addressable detectors such as smoke detectors, manual stations, water-flow switches, thermal detectors.
  7. Assigning priorities to types of detectors, zones or groups of detectors.
  8. Cross-zoning.
- O. Control Functions
1. Control functions shall be assigned on the basis of multi-relational system initiation patterns of detection devices including full logic element equations using as "anding" zones, counting zones, counting devices, "anding" groups, conditional "if", "then", "or" programming and "anding" types of detection devices.
  2. Control functions shall be assigned on the basis of, cycle, delay, count, time of day, day of week, day of month and with a holiday schedule of up to 30-holidays per year. Each addressable detection device shall report its condition to the system control unit not less than every 4-seconds in a manner such that failure of the connections to the internal electronics of the device will result in a trouble signal which identifies the specific device involved.
  3. The system shall be field programmable for the response of control points to monitored devices.
  4. The operating software program shall provide programmable control for the Event-Initiated-Programs (E.I.P.) which shall allow automatic operation of system control points in the event of an alarm condition. To program the E.I.P.s, the system shall use a specifically designed user friendly programming language, which shall not require knowledge of the computer programming to learn and understand.
  5. The operating software shall support the following additional capabilities:
    - a. Three levels of designated and unique Priority Alarms for each point.

- b. Designated "Sense Mode" for status interpretation for each point.
  - c. Designated Print/No Print/Vectoring Mode for each point.
6. The input statement defines the conditions required to activate the associated output statement. The input statement shall consist of single or multiple monitor point status, subroutine status, time comparison and the utilization of AND, OR, NOT, COUNT, and DELAY logic functions.
  7. The output statement defines the action to be taken by the control panel. The output statement shall consist of activation/deactivation of single or multiple control functions, subroutines, and remote annunciator status LED's. Output statements shall also include the "Alert" messages.
  8. The software shall provide an "Alert" message, unique to each point in the system, which will provide specific instructions for the operator on duty. These messages shall be up to five lines with up to 70-characters in each line. Each system monitor point shall have five specific alert messages when in alarm. Control points shall also be assigned alert messages.
  9. The hardware and software shall have the capacity to accept up to 64-independent programs. Each program shall have "Edit" or "No Edit" capability. Each program shall be written in an equation format comparable to ladder-logic equations. The Equations shall consist of an input and an output statement.
  10. Provide initial programming services for Coding, Loading and Debugging the initial District specified programs, as part of the Contract.
  11. Programming Command Definition
    - a. Timing command shall provide time delay and time control functions based on internal clock/calendar by time of day; day of week; day of month; month in year.
    - b. Count command shall provide a specific number of events to occur before a control action is initiated.
    - c. Pulse command shall provide on control for a specific period of time.
    - d. Cycle command shall provide on-off control for preset periods of time.
    - e. Print command shall provide printing of specified information after an event occurs.

### **2.03 FIRE ALARM DIGITAL ALARM COMMUNICATOR TRANSMITTER**

- A. Enclosure shall be red.
- B. Panel shall be solid state with eight zones for off premise monitoring of the fire alarm control panel.
- C. System shall monitor alarm and trouble conditions. System shall be power limited.
- D. System shall include dual telephone line switcher for central station reporting. Telephone lines shall be supervised.
- E. System shall include dual battery harness, batteries, and battery charger.
- F. System shall be UL listed for central station fire signaling systems (NFPA 71).
- G. System shall be California State Fire Marshal approved for central station reporting.
- H. System shall be Radionics D8112FA Series or Simplex 5071 Series. System shall be approved for connection to the fire alarm control panel.

- I. Verify Specific Requirements with District and Central Station prior to submittals.

#### **2.04 MANUALLY ACTIVATED ALARM INITIATING DEVICES**

Manual Fire Alarm Boxes shall comply with CBC Sections 11B-309 and 11B-403.

- A. An electronic, digital multiplex, addressable module shall be incorporated into each device. The module shall communicate the status and trouble condition of each device with a unique address code. The module shall communicate with and be supervised and monitored by the fire alarm control panel.
- B. Devices shall be suitable for use on a Class "B", 2-wire supervised alarm initiating circuit.
- C. Numbered screw type terminals shall be provided for "in-out" connections of the alarm circuit wiring.
- D. The face of the station shall have lettering indicating "FIRE" and operational instructions. Stations shall be tamper resistant, semi-flush mounting.
- E. Auxiliary spare switch contact shall be provided for control of remote devices rated 120 volts - 60Hz, AC, 3-amp minimum.
- F. Stations shall provide visual indication the station has been activated. A key (and/or special tool) shall be required to gain access into the station to reset the station after being activated.
- G. Stations shall be "nonbreak-glass" type.
- H. RF and transient filtering shall be provided in the device electronics.
- I. Pull stations shall be non-coded double action, requiring a two District manual "pulling" actions to initiate the fire alarm system.
- J. Stations installed outdoors shall be weather resistant construction, double action to activate the pull station.

#### **2.05 AUTOMATIC ALARM INITIATING DEVICES**

- A. General
  - 1. An electronic digital, multiplex, addressable module shall be incorporated into each device. The module shall communicate the status and trouble condition of each device with a unique address code. The module shall communicate with and be supervised and monitored by the fire alarm control panel.
  - 2. Devices shall be suitable for use on a Class "B", 2-wire supervised alarm initiating circuit. Where initiating devices are shown connected to an existing system, devices shall operate on 2 or 4-wire circuits plus, 2-wire power circuit as required by the existing equipment.
  - 3. Numbered screw type terminals shall be provided for "in-out" connectors of the alarm circuit wiring.
  - 4. Auxiliary double throw spare relay contact shall be provided for activation of remote rated devices 120-volt 60Hz, AC, 1-amp minimum.
  - 5. RF and transient filtering shall be provided in the initiating device electronics.
  - 6. Initiating devices shall be reset from the control panel and shall not require individual resetting.

B. Smoke Detector

1. Detectors shall comply with UL Standard 268, 167 and 168, and shall use solid state electronic circuits throughout.
2. The smoke detector shall operate on a total of two circuit wires. Alarm signaling and detector power shall use the same conductors. Detector sensitivity shall be factory set at 1.5%. Provide testing provisions in accordance with CFC 904(a) – 904.2(f), NFPA72.
3. A fine mesh insect screen shall be provided on all detector openings.
4. The detector shall lock-in on alarm and shall provide a visual alarm/trouble indicator light. An electromechanical test feature shall provide functional testing of the unit without smoke.
5. The detector shall also incorporate a fixed temperature heat detector rated at 135 degrees F. The heat detector shall operate the alarm circuit and alarm/trouble light.
  - a. Photo electric type smoke detectors shall employ a Light Emitting Diode (LED) as the detector light source, activated by the presence of combustion smoke products. Failure of the LED shall activate the alarm/trouble light on the detector.
  - b. Ionization type smoke detector shall employ the triple chamber (dual chamber) ionization principle, activated by the presence of combustion products. The ionization chamber shall be RF shielded.
  - c. Air duct smoke detector photo electric or ionization type for installation on a mechanical air ducts. Two air tubes shall extend into the air duct. The sampling tube shall extend across the entire width of the air duct. The second tube shall allow air to escape back into the duct.

C. Fire Detector - Heat

1. Heat detectors shall be dual action electro-thermostatic combination rate of temperature rise and fixed temperature operation. An indicator shall be visible when detector has activated.
2. The rate of rise element shall be self-restoring, after activation.
3. The fixed temperature unit shall be set at 136 degrees F (190 degrees F for high temperature areas i.e. over 110 degrees F).
4. Provide a wire guard cover for the detector.

**2.06 NOTIFICATION ALARM DEVICES**

A. General

1. Notification alarm devices shall activate automatically from the control panel. Devices shall operate on a Class "B" (Style Y), 2-wire supervised alarm notification circuit. Series wired alarm devices shall not be used.
2. Numbered screw type terminals shall be provided for "in-out" connections of the alarm circuit wiring.
3. Devices shall be installed in a box, 3½-inches deep maximum, flush mounting unless indicated other-wise on the Drawings. Size as required for the alarm indicating device and wiring connections. Provide a trim ring and metal grill cover assembly. Cover assembly shall be a minimum of 1/16-inch minimum thick flat stainless steel or

aluminum. Finish color as selected by Architect. The word "fire" shall appear on the grill minimum ½-inch letters. The grill shall be attached with screws to the box.

4. Each audible notification visual devices shall incorporate a visual alarm indicator. The visual alarm indicating device shall be an integral part of the audible alarm box assembly.
5. Audible notification device and visual notification devices shall be connected to separate notification alarm signal circuits. Do not connect these devices to the same circuit conductors.

B. Notification Appliances

1. Speakers

Low Profile Speaker

Provide low profile wall mount speakers at the locations shown on the Drawings. The low profile speaker shall not extend more than 1-inch (2.5cm) past the finished wall surface and provide a switch selectable audible output of 2w (90dBA), 1w (87dBA), ½w (84dBA), or ¼w (81dBA) at 10 feet when measured in reverberation room per UL-464.

Wattage setting shall be visible with the cover installed. When the cover is installed, no mounting hardware shall be visible. In and out screw terminals shall be provided for all wiring. The low profile speaker shall mount in a North American 4-inches x 2½-inches square electrical box, without trims or extension rings.

2. Speaker-Ceiling Mount-8-inch

Provide 8-inches ceiling mounted speakers at the locations shown on the Drawings. In and out screw terminals shall be provided for wiring. Speaker baffles shall be round or square steel with white finish as required. Provide square surface mount boxes with matching finish where required. Speakers shall provide ½w, 1w, 2w, and 4w power taps for use with 25V or 70V systems. At the 4 watt setting, the speaker shall provide a 94-dBA sound output a frequency of 1000Hz when measured in an anechoic chamber at 10 feet.

3. Speaker-Cone-4-inch

Provide 4-inches white speakers at the locations shown on the Drawings. Speakers shall have a 4-inch Mylar cone, paper cones are not acceptable. The rear of the speakers shall be completely sealed protecting the cone during and after installation. In and out screw terminals shall be provided for wiring. Speakers shall provide ¼w, ½w, 1w, and 2w power taps for use with 25V or 70V systems. At the 2-watt setting, the speaker shall provide a 90-dBA sound output over a frequency range of 400-4000Hz when measured in reverberation room per UL-1480.

4. Speaker-Reentrant Surface

Provide 4-inch surface re-entrant speakers at the locations shown on the Drawings. Speakers shall provide 2w, 4w, 8w, and 15w power taps for use with 25V or 70V systems. The re-entrant speakers shall utilize a high efficiency compression drivers. Cone type drivers are not acceptable. At the 15 watt setting, the speaker shall provide a 102 dBA sound output over a frequency range of 400-4000Hz when measured in reverberation room per UL-1480. Weatherproof boxes shall be provided for out-door mounting.

5. Speaker-Strobes

Low Profile Speaker-Strobe

Provide low profile wall mount speaker/strobes at the locations shown on the Drawings. The low profile speaker/strobe shall not extend more than 1-inch (2.5cm) past the finished wall surface, and provide a switch selectable audible output of 2W (90dBA), 1w (87dBA), ½w (84dBA), or ¼w (81dBA) at 10 feet when measured in reverberation room per UL-464.

Strobes shall provide synchronized flash output that shall be switch selectable for output values of 15cd, 30cd, 75cd and 110cd. Wattage and candela settings shall be visible with the cover installed. When the cover is installed, no mounting hardware shall be visible. In and out screw terminals shall be provided for all wiring. The low profile speaker/strobes shall mount in a North American 4-inches x 2½-inches square electrical box, without trims or extension rings.

6. Speaker-Strobe 4-inch

Provide 4-inches red speakers/strobes at the locations shown on the Drawings. Speakers shall have a 4-inches Mylar cone, paper cones are not acceptable. The rear of the speakers shall be completely sealed protecting the cone during and after installation. In and out screw terminals shall be provided for wiring. Speakers shall provide ¼w, ½w, 1w, and 2w power taps for use with 25V or 70V systems. At the 2 watt setting, the speaker shall provide an 87 dBA sound output over a frequency range of 400-4000Hz when measured in reverberation room per UL-1480. Strobes shall provide synchronized flash. Strobe output shall be determined as required by its specific location and application from a family of 15/75cd, 30cd, and 110cd devices.

7. Speaker-Strobe Ceiling 8-inch

Provide 8-inches ceiling mounted speaker/strobes at the locations shown on the Drawings. In and out screw terminals shall be provided for wiring. Speaker baffles shall be round or square, steel with white finish as required. Provide square surface mount boxes with matching white finish as required. Speakers shall provide ½w, 1w, 2w, and 4w power taps for use with 25V or 70V systems. At the 4 watt setting, the speaker shall provide a 94 dBA sound output a frequency of 1000Hz when measured in an anechoic chamber at 10 feet. Strobes shall provide synchronized flash outputs. Strobe output shall be determined as required by its specific location and application from a family of 15cd, 30cd, 75cd, and 110cd devices.

8. Speaker-Strobe Re-entrant

Provide 4-inch red re-entrant speaker/strobes at the locations shown on the Drawings. Weatherproof boxes shall be provided for outdoor mounting. Speakers shall provide 2w, 4w, 8w, and 15w power taps for use with 25V or 70V systems. The re-entrant speakers shall utilize a high efficiency compression drivers. Cone type drivers are not acceptable. At the 15-watt setting, the speaker shall provide a 102 dBA sound output over a frequency range of 400-4000Hz when measured in reverberation room per UL-1480. Strobes shall provide synchronized flash. Strobe output shall be determined as required by its specific location and application from a family of 15cd, 30cd, 75cd, and 110cd devices.

C. Visual Alarm Indicator

1. Lamp/Strobe internally illuminated projecting lens assembly, with flasher system. Unit shall flash on and off to provide visual indicating of fire alarm.
2. The word "fire" shall appear on the lens or lens plate.
3. Flash rate, one flash per second, with a flash duration of approximately 0.001 second, flash rate independent of audible device.
4. Light source, Xenon high intensity flash strobe tube white/clear color.
5. Strobe shall have a minimum output of 75 candelas with a maximum flash intensity of 120 candelas.
6. Strobe shall comply with NFPA Requirements.

## 2.07 REMOTE FIRE ALARM ANNUNCIATOR

A. General

1. The annunciator panel shall be powered and operated from the fire alarm control panel. "In-out" circuit conductors shall terminate on numbered screw-type terminals.
  2. A metal tamper resistant weatherproof cabinet shall contain the annunciator components. The panel shall be surface or flush mounted as indicated on the Drawings. Provide a full height tamper resistant, hinged locking cabinet door. Door shall have transparent high impact windows to allow visual observation of all indicators and switches.
  3. An electronic digital, multiplex, addressable module shall be incorporated into the annunciator. The module shall communicate the status and trouble condition of each device with a unique address code. The module shall communicate with and be supervised and monitored by the fire alarm control panel.
- B. Each Alarm Initiating Zone (including spares) shall be individually annunciated in the annunciator panel.
- C. A Common Fire Trouble Alarm shall be annunciated in the annunciator panel from the fire alarm control panel.
- D. Annunciator Lamp Circuits shall be automatically supervised. Provide lamp test switch in the annunciator panel.
- E. An Audible Alarm/Trouble Buzzer with silence switch and automatic resound for subsequent alarm/trouble signals shall be provided. The annunciator panel shall be automatically reset when the control panel is reset.
- F. A Keyed Switch shall be provided for remote reset of the system. The annunciation panel shall also be automatically reset when the control panel is reset.
- G. Provide a Floor Plan of the facility framed under acrylic and mounted adjacent to the fire alarm annunciator. The Floor Plan shall be to scale and shall have room numbers clearly displayed on all rooms corresponding to the annunciator for the purpose of easily identifying the fire zones.

## **2.08 REMOTE EQUIPMENT MONITORING AND CONTROL**

- A. An Electronic Digital Multiplex addressable module shall be provided at each device or equipment indicated to be controlled by the multiplex system. Multiple addressable control ports shall be provided in each module quantity as required for each point controlled or monitored. The module shall communicate the monitor status control action and trouble condition of each device with a unique address code. The module shall communicate with and be supervised and monitored by the fire alarm control panel.
- B. Where multiple points are monitored or controlled, provide digital, multiplex, Multi-points, Monitor, Control Panel (MMCP). The panel cabinet shall be self-contained NEMA 1 construction and hinged locking door. Provide tamper switch detection zone on the cabinet door; provide 60 hour battery UPS backup and power supply, the same as required for the fire alarm control panel. Panel shall be expandable using plug-in circuit monitor/control printed circuit cards. Provide barriered numbered terminal strips.
- C. Each Control Point shall provide a supervised "dry" relay contact single pole double throw maintained contact rated 10-amp, 227 volt, 60Hz AC.
- D. Each monitor point shall provide not less than one of the following supervised methods of monitoring a remote device or equipment action or status.
  - 1. Remote "dry" contact operation normal open, normally closed or momentary contact operation.

## **PART 3 - EXECUTION**

### **3.01 IDENTIFICATION**

- A. The inside cover of alarm initiating devices shall be marked with the zone initiating number corresponding to the zone number in the control panel. Marking shall be with a felt-tip pen.
- B. Each fire alarm terminal cabinet shall be painted red.
- C. Provide nameplate: "Power to Main Fire Alarm Control Panel" screwed onto the branch circuit overcurrent device supplying power to the main fire alarm control panel.

### **3.02 WIRING**

- A. Review the total system point-to-point wiring layout to assure that the correct number and type of wires and conduit sizes are installed.
- B. Final connections, testing, adjusting and calibration shall be made under the direct supervision of a Factory-Trained Technician of the System Supplier.
- C. All wiring shall be in conduit.
- D. All wiring in cabinets shall be neatly formed, laced and made up on bolt and nut terminal blocks. Tag all spare conductors. All conductors shall terminate on terminal strips with spade lugs, of adequate size for all incoming and outgoing conductors. The strips shall be labeled as to their use and wiring diagram shall be placed on the cabinet door showing connections of all related equipment to these strips.
- E. Wiring Requirements for shielding certain conductors shall be as recommended by the Manufacturer. Provide all conduit, raceways and conductors per Manufacturers recommendations and include all material and labor costs in the Contract price.



- F. The conductors used for digital, multiplex communication between the fire alarm control panel and external remote initiation devices, control points and annunciators, shall be twisted, shielded, multi-conductor cable, #16AWG copper minimum with a separate internal ground/drain conductor, UL listed for fire alarm system use. One spare pair of multiplex conductors shall be provided in all main and branch device/equipment connections for future system use. "Tees" and taps at any junction box location in the communication lines, shall be permitted by the system to additional devices without affecting proper system operation.
- G. Wire Size: Wire shall be sized to insure installed circuit voltage drop does not exceed 10% to all devices.

### **3.03 OUTLET BOXES**

Device outlet boxes shall be flush mounted unless indicated otherwise on the Drawings. Provide extension rings to finish flush with finish surface. Where the Drawings indicate surface mounted devices, outlet boxes shall be cast metal with threaded hubs. Where the conduit entrances are not exposed for surface mounted devices, provide flush outlet box behind the device box, and omit the conduit hubs on the device box. Size device boxes and outlet boxes per Manufacturer's recommendation and as required by Code for wire fills.

### **3.04 SPECIAL INSTALLATION REQUIREMENTS**

- A. Air duct smoke detectors shall be installed in the supply air ducts and return air ducts with an air flow of 2000 CFM or greater, coordinate with Mechanical Contractor. Sampling tube shall extend across entire duct width. Provide ¾-inch conduit with 2#12 to respective motor control device to automatically shut down the respective fan motor upon detection of smoke in the air duct. Installation shall be in compliance with CMC 606.8.
- B. Water flow switches shall be installed on each main fire sprinkler rise pipe, coordinate with the Fire Sprinkler Contractor.
- C. Tamper switches shall be installed on each main fire sprinkler shut-off valve, coordinate with the Fire Sprinkler Contractor.
- D. Equipment shall be weatherproof gasketed where installed in locations exterior to the building, or where indicated on the Drawings. Weatherproof equipment shall be tamper resistant.
- E. Provide clear vandal resistant protective cover for all audio-visual devices located in student restrooms and public hallways.
- F. Provide wire guard for ceiling mounted smoke and heat detectors located in student restrooms.
- G. Connect fire alarm control panel with security/intrusion control panel for monitoring by remote monitoring company.
- H. Connect fire alarm control panel with master clock system to turn off class passing schedule, with paging system to turn off system when fire alarm system in alarm condition.
- I. Conduit with fire alarm wiring shall be painted red.
- J. Fire alarm system shall be programmed per actual building and room designation. Submit printout for review.

### 3.05 TESTING

- A. The Entire Fire Alarm System shall be tested in the presence of the Local DSA Inspector and a Representative of the Manufacturer after the installation is complete.
  - 1. Individually activate each manual initiating station and verify correct alarm operation and control panel response.
  - 2. Individually test each automatic initiating device and verify correct alarm operation, control panel response and remote equipment operation.
  - 3. The communication loops and the notification alarm circuits shall be opened in at least two locations per building to check for the presence of correct supervisory circuitry.
- B. Test the battery back-up system by disconnecting the incoming normal power and allowing this alarm system to operate 24 hours on battery power. Sound the alarm system for 5-minutes at the end of 24 hours on battery power.
- C. Perform all electrical and mechanical tests required by the Equipment Manufacturer's certification form. Measure and adjust each automatic detection detector to the maximum stable sensitivity setting. Detector tests shall be performed with the detector at its operational location and under normal operational environmental conditions in the area. Bench settings are not acceptable. An operational check-out test and report shall be performed. Submit six copies of test report results. The tests and report shall include, but not be limited to:
  - 1. A complete list of equipment installed and wired.
  - 2. Indication that all equipment is properly installed and functions and conforms with these Specifications.
  - 3. Test of individual zones as applicable.
  - 4. Serial numbers locations by zone and model number for each installed detector.
  - 5. Voltage (sensitivity) settings for each ionization and photoelectric detector as measured in place with the HVAC system operating.
  - 6. Technician's name, certificate number and date.
  - 7. The completed manual and automatic monitoring and control system shall be tested to insure that it is operating properly. This test will consist of exposing the installed units to a standard fire test.
  - 8. Acceptance of the system shall also require a demonstration of the stability of the system. This shall be adequately demonstrated if the system operates for a 90-day test period without any unwarranted alarms. Should an unwarranted alarm(s) occur, the Contractor shall readjust or replace the equipment and detector(s) and begin another 90-day test period. As required by the Architect, the Contractor shall recheck the detectors using the fire test after each readjustment or replacement of detectors. This test shall not start until the District has obtained beneficial use of the building under tests.
- D. After the testing has been completed to the satisfaction of CFC 904(a) – 904.2(f) the Inspectors, provide the NFPA certificate of compliance to the District, the Local Fire Official, the Architect and DSA.

- E. Upon the receipt of Certificate of Compliance, the Installer/Supplier shall supply the District with a written Operating, Testing and Maintenance Instructions, Point-To-Point As-Built Drawings and Equipment Specifications. Maintenance provisions, CFC 904(a) – 904.2(f).

**3.06 instructional sessions**

Provide a 2-hour instructional sessions conducted by a Factory-Authorized Technician at the job site after completion of all tests to instruct District Personnel on the use of the system. The first session shall be videotaped and conducted prior to final acceptance of the Project. The second session shall be held within eleven months of final acceptance of the Project, when requested by the District.

END OF SECTION 28 46 20  
022019/212220

## SECTION 31 23 16.13

### TRENCHING

#### PART 1 GENERAL

##### 1.01 SECTION INCLUDES

- A. Backfilling and compacting for utilities outside the building to existing.

##### 1.02 DEFINITIONS

- A. Finish Grade Elevations: Indicated on drawings.
- B. Subgrade Elevations: Indicated on drawings.

##### 1.03 REFERENCES

- A. AASHTO T 180 - Standard Specification for Moisture-Density Relations of Soils Using a 4.54-kg (10-lb) Rammer and a 457-mm (18 in.) Drop; 2018.
- B. ASTM C136/C136M - Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates; 2014.
- C. ASTM D698 - Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft<sup>3</sup> (600 kN-m/m<sup>3</sup>)); 2012, with Editorial Revision (2015).
- D. ASTM D1556/D1556M - Standard Test Method for Density and Unit Weight of Soil in Place by Sand-Cone Method; 2015, with Editorial Revision (2016).
- E. ASTM D1557 - Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft<sup>3</sup> (2,700 kN m/m<sup>3</sup>)); 2012, with Editorial Revision (2015).
- F. ASTM D2487 - Standard Practice for Classification of Soils for Engineering Purposes (Unified Soil Classification System); 2011.
- G. ASTM D6938 - Standard Test Methods for In-Place Density and Water Content of Soil and Soil-Aggregate by Nuclear Methods (Shallow Depth); 2017.

##### 1.04 SUBMITTALS

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Comply with the requirements listed in Section 31 23 23 - Fill.
- C. Fill Composition Test Reports: Results of laboratory tests on proposed and actual materials used.
- D. Compaction Density Test Reports.

##### 1.05 COORDINATION OF SPECIFICATION REQUIREMENTS

- A. Coordinate these Specification Section requirements with specifications included on Drawings. Comply with more stringent requirements and with those requirements of the authorities having jurisdiction.

##### 1.06 DELIVERY, STORAGE, AND HANDLING

- A. When necessary, store materials on site in advance of need.
- B. When fill materials need to be stored on site, locate stockpiles where designated.

1. Separate differing materials with dividers or stockpile separately to prevent intermixing.
2. Prevent contamination.
3. Protect stockpiles from erosion and deterioration of materials.

## **PART 2 PRODUCTS**

### **2.01 FILL MATERIALS**

- A. General Fill: Subsoil excavated on-site.
- B. Structural Fill: Subsoil excavated on-site.
  1. Free of lumps larger than 3 inches, rocks larger than 2 inches, and debris.
- C. Concrete for Fill: Lean concrete.
- D. Granular Fill - Gravel: Pit run washed stone; free of shale, clay, friable material and debris.
  1. Graded in accordance with ASTM C136/C136M, within the following limits:
    - a. 3/4 inch sieve: 95 to 100 percent passing.
- E. Granular Fill - Pea Gravel: Natural stone; washed, free of clay, shale, organic matter.
  1. Grade in accordance with ASTM D2487 Group Symbol GM.
- F. Sand: Natural river or bank sand; washed; free of silt, clay, loam, friable or soluble materials, and organic matter.
  1. Grade in accordance with ASTM D2487 Group Symbol SW.
- G. Topsoil: Topsoil excavated on-site.
  1. Select.
  2. Graded.
  3. Free of roots, rocks larger than 1/2 inch, subsoil, debris, large weeds and foreign matter.
  4. Acidity range (pH) of 5.5 to 7.5.
  5. Containing a minimum of 4 percent and a maximum of 25 percent inorganic matter.
  6. Complying with ASTM D2487 Group Symbol OH.

### **2.02 SOURCE QUALITY CONTROL**

- A. See Section 01 45 00 - Quality Control, for general requirements for testing and analysis of soil material.
- B. Where fill materials are specified by reference to a specific standard, test and analyze samples for compliance before delivery to site.
- C. If tests indicate materials do not meet specified requirements, change material and retest.
- D. Provide materials of each type from same source throughout the Work.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that survey bench marks and intended elevations for the work are as indicated.

### **3.02 PREPARATION**

- A. Identify required lines, levels, contours, and datum locations.
- B. Locate, identify, and protect utilities that remain and protect from damage.
- C. Protect bench marks, survey control points, existing structures, fences, sidewalks, paving, and curbs from excavating equipment and vehicular traffic.
- D. Protect plants, lawns, rock outcroppings, and other features to remain.
- E. Grade top perimeter of trenching area to prevent surface water from draining into trench. Provide temporary means and methods, as required, to maintain surface water diversion until no longer needed, or as directed by the Architect.

### **3.03 TRENCHING**

- A. Excavate subsoil required for conduits, storm drain, sanitary sewer, water and gas piping to municipal utilities.
- B. Notify Architect of unexpected subsurface conditions and discontinue affected Work in area until notified to resume work.
- C. Slope banks of excavations deeper than 4 feet to angle of repose or less until shored.
- D. Trenches Parallel to Footings: Do not place the trench below a 1 vertical to 2 horizontal from 9 inches above the bottom edge of the footing and no closer than 18 inches from the face of footing. CBC Section 1809A.14.
- E. Do not interfere with 45 degree bearing splay of foundations.
- F. Cut trenches wide enough to allow inspection of installed utilities.
- G. Hand trim excavations. Remove loose matter.
  - 1. Hand trim for bell and spigot pipe joints.
- H. Remove large stones and other hard matter that could damage piping or impede consistent backfilling or compaction.
- I. Remove lumped subsoil, boulders, and rock up to 1/3 cubic yard measured by volume.
- J. Remove excavated material that is unsuitable for re-use from site.
- K. Stockpile excavated material to be re-used in area designated on site.
- L. Remove excess excavated material from site.
- M. Provide temporary means and methods, as required, to remove all water from trenching until directed by the Architect. Remove and replace soils deemed unsuitable by classification and which are excessively moist due to lack of dewatering or surface water control.
- N. Determine the prevailing groundwater level prior to trenching. If the proposed trench extends less than 1 foot into the prevailing groundwater, control groundwater intrusion with perimeter drains routed to sump pumps, or as directed by the Architect.

### **3.04 PREPARATION FOR UTILITY PLACEMENT**

- A. Cut out soft areas of subgrade not capable of compaction in place. Backfill with general fill.
- B. Compact subgrade to density equal to or greater than requirements for subsequent fill material.

- C. Until ready to backfill, maintain excavations and prevent loose soil from falling into excavation.
- D. Support pipe and conduit during placement and compaction of bedding fill.

### **3.05 BACKFILLING**

- A. Backfill to contours and elevations indicated using unfrozen materials.
- B. Fill up to subgrade elevations unless otherwise indicated.
- C. Employ a placement method that does not disturb or damage installed piping and conduits, or other work.
- D. Systematically fill and compact as as to achieve 90 percent relative compaction without damaging conduit or pipe. Do not fill over porous, wet, frozen or spongy subgrade surfaces.
- E. Maintain optimum moisture content of fill materials to attain required compaction density.
- F. Granular Fill: Place and compact materials in equal continuous layers not exceeding 6 inches compacted depth.
- G. Soil Fill: Place and compact material in equal continuous layers not exceeding 8 inches compacted depth or as directed by the Geotechnical Report.
- H. Slope grade away from building minimum 2 inches in 10 feet, unless noted otherwise. Make gradual grade changes. Blend slope into level areas.
- I. Correct areas that are over-excavated.
  - 1. Thrust bearing surfaces: Fill with concrete.
  - 2. Other areas: Use general fill, flush to required elevation, compacted to minimum 90 or 95 percent of maximum dry density as applicable for the fill area.
- J. Compaction Density Unless Otherwise Specified or Indicated:
  - 1. Under paving and similar construction: 95 percent of maximum dry density.
  - 2. At other locations: 90 percent of maximum dry density.
- K. Reshape and re-compact fills subjected to vehicular traffic.

### **3.06 BEDDING AND FILL AT SPECIFIC LOCATIONS**

- A. Use general fill unless otherwise specified or indicated.
- B. Utility Piping, Conduits, and Duct Bank:
  - 1. Bedding: Use Fill Type SP or SW (ASTM D2487) or SM with sand equivalent of 30 or greater per ASTM D2419, 3 inches thick, compacted to 90 percent..
  - 2. Cover with Fill Type SP, SW, SM, GM per ASTM D2487.
  - 3. Fill up to subgrade elevation.
  - 4. Compact in maximum 8 inch lifts to 95 percent of maximum dry density.
  - 5. Gas Piping: As required by the Gas Company.

### **3.07 TOLERANCES**

- A. Top Surface of General Backfilling: Plus or minus 1.2 inch from required elevations.

- B. Top Surface of Backfilling Under Paved Areas: Plus or minus 1.2 inch from required elevations.

### **3.08 FIELD QUALITY CONTROL**

- A. Perform compaction density testing on compacted fill in accordance with ASTM D1556 or ASTM D6938.
- B. Correct unauthorized excavation at no cost to District.
- C. Evaluate results in relation to compaction curve determined by testing uncompacted material in accordance with ASTM D1557 ("modified Proctor"), AASHTO T 180, or ASTM D698 ("standard Proctor").
- D. If tests indicate work does not meet specified requirements, remove work, replace and retest at no additional cost to District.

### **3.09 CLEANING**

- A. Leave unused materials in a neat, compact stockpile.
- B. Remove unused stockpiled materials, leave area in a clean and neat condition. Grade stockpile area to prevent standing surface water.
- C. Leave borrow areas in a clean and neat condition. Grade to prevent standing surface water.

### **3.10 PROTECTION OF FINISHED WORK**

- A. Protect finished Work under provisions of Section 01 50 00 - Temporary Construction Facilities and Controls.
- B. Recompact fills subjected to vehicular traffic.

**END OF SECTION**





**SECTION 32 01 17**  
**ASPHALT PAVEMENT REPAIR**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Bituminous Surfacing Repair: Areas removed for utility trenches, heaved by tree roots, cracked areas, protruding areas where pavement meets hard surfaces, depressed areas, and raveled bituminous pavement.
- B. Areas heaved by tree roots, cracked areas, holes, trenches, and areas around new structures.

**1.02 RELATED REQUIREMENTS**

- A. Section 02 41 00 - Demolition: Selective demolition, site demolition, structure removal.
- B. Section 31 23 16.13 - Trenching: Excavation and Fill for Utilities.
- C. Section 31 23 23 - Fill.
- D. Section 32 13 13 - Concrete Paving.

**1.03 REFERENCE STANDARDS**

- A. SSPWC - Greenbook: Standard Specifications for Public Works Construction; latest adopted edition.

**1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by all affected installers.
- B. Sequencing: Ensure that maintenance of temporary pedestrian and vehicular traffic flow is achieved in an orderly and expeditious manner.

**1.05 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Provide manufacturer's product literature, technical data, materials, and products, .
- C. Shop Drawings: Indicate areas to be repaired.
- D. Certificate: Certify that products of this section meet or exceed specified requirements.
- E. Field Reports: Indicate procedures followed, ambient temperatures, humidity, wind velocity during application, and supplementary instructions given.

**1.06 QUALITY ASSURANCE**

- A. Single Source Responsibility: Provide products by the same manufacturer.
- B. Comply with Standard Specifications for Public Works Construction, current edition.
- C. Installer Qualifications: Company specializing in performing the work of this section with minimum three years of experience.

## **PART 2 PRODUCTS**

### **2.01 MATERIALS**

- A. Bituminous Materials:
  - 1. Provide materials and products of the class, grade or type indicated, conforming to relevant provisions of SSPWC Section 203 - Bituminous Materials of the latest SSPWC (Greenbook).

## **PART 3 EXECUTION**

### **3.01 PAVEMENT REMOVAL**

- A. Remove bituminous and concrete pavement in accordance with applicable provisions of Section 300 - Earthwork of the SSPWC (Greenbook).
- B. Pavement Heaved By Roots:
  - 1. Remove pavement to limits of distortion and expose roots.
  - 2. Trim roots to provide at least 12 inch clearance to pavement.
- C. Remove protruding bituminous surfaces flush with the surrounding grade using a suitable tool or equipment so that adjacent finishes are not blackened.
- D. Remove raveled and depressed bituminous pavement to limits indicated or required.
- E. Saw cut existing improvements, trim holes and trenches in bituminous and concrete pavement to permit mechanical hand tampers to compact the fill.
- F. Remove broken concrete by saw cutting. If the required cut line is within 30 inches of a score or joint line or edge, cut and remove to the score, joint line, or edge.

### **3.02 EXCAVATING, BACKFILLING AND COMPACTING**

- A. Conform to requirements in Section 31 23 16.13 - Trenching, as required.
- B. Where subgrade or base is deemed to be unstable or otherwise unsuitable, excavate such materials to firm earth, and replace with a required material. Install and compact fill materials in accordance with the requirements of related Specification sections.

### **3.03 HEADERS**

- A. Install headers along edge of bituminous surfacing abutting turf, earth, or planting area, unless indicated otherwise.
- B. Install headers so the bottom surface has continuous bearing on solid grade.
  - 1. Where excavation for headers is undercut, thoroughly tamp soil under the header.
  - 2. Compact backfill on both sides of header to the density of the adjacent undisturbed grade.
- C. Fasten headers in place with redwood or Douglas fir stakes of length necessary to extend into solid earth a minimum of 12 inches.
  - 1. Stakes shall be of sound material, neatly pointed, driven vertically, and securely nailed to headers.

2. Space stakes, not to exceed 4 feet on centers with top of stakes set one inch below top of header.
  3. Provide a minimum of two 12d galvanized common nails through each stake.
- D. Remove existing headers where new surfacing is installed adjacent to existing surfacing.
- E. Install temporary headers at transverse joints of paving where continuous paving operations are not maintained.
- F. Provide additional stakes and devices as required to fasten headers.

### **3.04 BASE COURSE**

- A. Unless otherwise indicated, base course shall be crushed aggregate base, fine grade, 3 inches thick or equal to thickness of the existing base, whichever is greater.
- B. Fill grade and compact as specified in Section 31 22 00 - Grading.

### **3.05 RESURFACING**

- A. Holes and Trenches:
1. Remove loose dirt and backfill with cement-sand slurry allowing for surfacing one inch thicker than existing.
  2. Resurface flush with existing adjoining pavement installing the same type of materials and section provided in existing improvements.
- B. Other Areas:
1. Other surface improvements damaged or removed shall be cut to a neat even line and excavated one inch below the bottom of the existing pavement.
  2. Resurface by following the original grades and installing the same type of materials provided in existing improvements.
- C. Where bituminous surfacing abuts concrete, masonry, walks or paving, tamp joint smooth, if necessary, as described above to obtain a uniformly even joint, true to line and grade. Tamp and smooth materials before asphalt cools.

### **3.06 REPAIRING AND RESEALING EXISTING SURFACES**

- A. Preparation of Surfaces: Prior to filling cracks, clean existing bituminous surfacing of loose and foreign materials and coat with a film of asphalt emulsion.
- B. Repair of Existing Surfacing:
1. Fill cracks 1/2 inch wide and less with RS-1 emulsion and silica sand or other required material.
  2. Cracks larger than 1/2 inch wide shall be filled with Type C2 Asphalt Concrete as specified.
    - a. Cracks shall be filled to the level of adjacent surfacing.
  3. Where low areas, holes, or depressions occur in existing surfacing, repair with emulsified asphalt.
    - a. Install material, strike off the emulsified asphalt with a straightedge flush with adjoining surfacing.
    - b. Finish with a steel trowel, and after dehydration, compact by rolling or tamping.

- C. Testing:
  - 1. Flood test entire area in presence of the Project Inspector.
  - 2. Entire area tested shall be free of standing water or puddles.
- D. Surface Seal:
  - 1. After surface has been repaired and tested, install seal coat over entire area indicated.
  - 2. Surface seal shall be as specified in Section .

### **3.07 CLEANING**

- A. Remove all stains on the Project site and adjacent properties caused by or attributed to the Work of this section.
- B. Remove rubbish, debris, and waste materials and legally dispose of off the Project site.

### **3.08 PROTECTION**

- A. Protect installed Work from subsequent construction operations.

**END OF SECTION**

## **SECTION 32 13 13**

### **CONCRETE PAVING**

#### **PART 1 GENERAL**

##### **1.01 SECTION INCLUDES**

- A. Concrete sidewalks.

##### **1.02 RELATED REQUIREMENTS**

- A. Section 32 17 26 - Tactile Warning Surfacing: Plastic tactile and detectable warning tiles for pedestrian walking surfaces.
- B. Section 32 17 23.13 - Painted Pavement Markings: Pavement markings.

##### **1.03 REFERENCE STANDARDS**

- A. 28 CFR 35 - Specifications for Structural Concrete; 2016.
- B. ACI 304R - Guide for Measuring, Mixing, Transporting, and Placing Concrete; 2000 (Reapproved 2009).
- C. ACI 305R - Guide to Hot Weather Concreting; 2010.
- D. ACI 306R - Guide to Cold Weather Concreting; 2016.
- E. ACI 318 - Building Code Requirements for Structural Concrete and Commentary; 2014 (Errata 2018).
- F. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- G. ASTM A615/A615M - Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement; 2018.
  - 1. Use 2012 as indicated in 2016 CBC Referenced Standards.
- H. ASTM C33/C33M - Standard Specification for Concrete Aggregates; 2016, with Editorial Revision (2016).
  - 1. Use 2013 as indicated in 2016 CBC Referenced Standards.
- I. ASTM D2047 - Standard Test Method for Static Coefficient of Friction of Polish-Coated Flooring Surfaces as Measured by the James Machine; 2011.
- J. ASTM C39/C39M - Standard Test Method for Compressive Strength of Cylindrical Concrete Specimens; 2018.
- K. ASTM C920 - Standard Specification for Elastomeric Joint Sealants; 2018.
- L. ASTM C94/C94M - Standard Specification for Ready-Mixed Concrete; 2018.
  - 1. Use 2014a as indicated in 2016 CBC Referenced Standards.
- M. ASTM C150/C150M - Standard Specification for Portland Cement; 2018.
  - 1. Use 2012 as indicated in 2016 CBC Referenced Standards.
- N. ASTM C309 - Standard Specification for Liquid Membrane-Forming Compounds for Curing Concrete; 2011.
- O. ASTM C494/C494M - Standard Specification for Chemical Admixtures for Concrete; 2017.

- P. ASTM D1751 - Standard Specification for Preformed Expansion Joint Filler for Concrete Paving and Structural Construction (Nonextruding and Resilient Bituminous Types); 2018.
- Q. ASTM D1752 - Standard Specification for Preformed Sponge Rubber Cork and Recycled PVC Expansion Joint Fillers for Concrete Paving and Structural Construction; 2018.
- R. SSPWC - Greenbook: Standard Specifications for Public Works Construction; latest adopted edition.

#### **1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Mix Design: Design mixes for each concrete mix.
- C. Product Data: Provide data on joint filler, admixtures, and curing compound.
  - 1. Material Certificates signed by manufacturers for each of the following:
    - a. Cementitious materials and aggregates.
    - b. Steel reinforcement and reinforcement accessories.
    - c. Admixtures.
    - d. Curing compounds.
    - e. Joint fillers.
- D. Shop drawings: For pattern layout and verification.

#### **1.05 QUALITY ASSURANCE**

- A. Industry Standard: Perform concrete paving Work in accordance with 28 CFR 35.
- B. Regulatory Requirements: Where reference is made to Standard Specifications, the following shall apply.
  - 1. Where reference is made to Standard Specifications, the following shall apply:
    - a. Perform off-site Work in public rights-of-way as indicated on the Contract Drawings and in accordance with requirements of authorities having jurisdiction, including SSPWC.
      - 1) For conditions not indicated otherwise on Contract Drawings, conform to Standard Details adopted by authorities having jurisdiction, including SSPWC.
    - b. Perform on-site Work as indicated and referenced on the Contract Drawings and as specified herein.
  - 2. Conform to California Code of Regulations (CCR), Volume 2, Part 2, Chapters 18A and 19A.
  - 3. Conform to California Building Code (CBC), Chapter 11B and ADA Standards for accessibility requirements.
    - a. Portland cement concrete paving shall be stable, firm, and slip resistant and shall comply with CBC Sections 11B-302 and 11B-403.
    - b. Concrete paving and concrete finishes along accessible routes of travel shall be at least as slip-resistant as that described as a medium salted finish for slopes of less than 6%, and slip resistant at slopes of 6% or greater; CBC 11B-403.2.
    - c. Continuous surfaces, including walks and sidewalks, shall have a continuous common surface, not interrupted by steps or by abrupt changes in level exceeding

1/4 inch vertical (CBC 11B-303.2), or beveled at 1:2 slope to a maximum height of 1/2 inch (CBC 11B-303.3) and shall have a minimum width of 48 inches; CBC 11B-403.5.1.

4. Comply with OSHA and Cal-OSHA requirements.
  5. Surface cross slopes shall not exceed 2 percent on any accessible path of travel.
- C. Source Quality Control: Obtain like materials from one source throughout.
- D. Lines and Levels: Established by State of California licensed Surveyor or registered Civil Engineer. Costs of surveying services shall be included in the Contract Sum.
- E. Installer Qualifications: Company specializing in performing work of the type specified and with minimum three years of documented experience.
1. The Installer shall provide a qualified foreman or supervisor who has a minimum of three years experience with imprinted and textured concrete, and who has successfully completed at least five similar installations of high quality and similar in scope to that required.

## **PART 2 PRODUCTS**

### **2.01 PAVING ASSEMBLIES**

- A. Comply with applicable requirements of ACI 301.
- B. Concrete Sidewalks: 3,250 psi 28 day concrete, thickness as indicated on Drawings, minimum 4 inches, natural grey color Portland cement.

### **2.02 FORM MATERIALS**

- A. Wood form material, profiled to suit conditions.
- B. Joint Filler: Preformed; non-extruding bituminous type (ASTM D1751) or sponge rubber or cork (ASTM D1752).
  1. Thickness: 1/2 inch.

### **2.03 REINFORCEMENT**

- A. General: As indicated on Drawings and specified following. Reinforcement for portland cement concrete paving in public rights-of-way shall comply with all applicable requirements in the Standard Specifications for Public Works Construction and Standard Details, as adopted by local authorities having jurisdiction.
- B. Reinforcing Steel: ASTM A615/A615M, Grade 60 (60,000 psi) yield strength; deformed billet steel bars; unfinished.
  1. Unless detailed otherwise on Drawings, provide number 4 reinforcing bars at 24 inches on center, each way.
- C. Tie Wires: 18 gage minimum, black annealed steel.
- D. Construction Joint Reinforcing:
  1. Dowels: ASTM A615/A615M, Grade 60 - 60,000 psi yield strength; deformed billet steel bars; unfinished finish.



## **2.04 PERFORMANCE REQUIREMENTS**

- A. Albedo reflectance of finish concrete shall be minimum 0.30.

## **2.05 CONCRETE MATERIALS**

- A. Obtain cementitious materials from same source throughout.
- B. Cement: ASTM C150/C150M, Normal - Type I Portland cement, gray color.
- C. Fine and Coarse Mix Aggregates: ASTM C33/C33M Table 3 Class 4M, Non-reactive.
  - 1. Class C per SSPWC Section 201-1.3.2 // Section 73 and 90.
- D. Water: Clean, and not detrimental to concrete.
- E. Chemical Admixtures: ASTM C494/C494M, Type A - Water Reducing, Type B - Retarding, Type D - Water Reducing and Retarding, Type F - Water Reducing, High Range, and Type G - Water Reducing, High Range and Retarding.
  - 1. Do not use chemicals that will result in soluble chloride ions in excess of 0.1 percent by weight of cement.

## **2.06 ACCESSORIES**

- A. Curing Compound: ASTM C309, Type 1, Class A.
  - 1. Comply with all applicable air pollution requirements.
- B. Tactile Warning Surfaces: See Section 32 17 26.
- C. Concrete Paving Joint Sealant: Polyurethane, self-leveling; ASTM C920, Class 25, Uses T, I, M and A; single component.
  - 1. Color: Gray.
  - 2. Applications: Use for:
    - a. Joints in sidewalks and vehicular paving.
  - 3. Products:
    - a. Pecora Corporation; NR-201 Self-Leveling Traffic and Loop Sealant: [www.pecora.com](http://www.pecora.com).
    - b. Sherwin-Williams Company; Stampede 1SL Polyurethane Sealant: [www.sherwin-williams.com](http://www.sherwin-williams.com).
- D. Soil Sterilant: As specified in Standard Specifications for Public Works Construction. Soil sterilant shall comply with all applicable environmental protection and hazardous materials laws and regulations.
- E. Expansion Joint Filler: ASTM D1751, premolded, compressible 1/2 inch thick non-extruding bituminous type resilient filler, compatible with joint backing and sealing products.

## **2.07 CONCRETE MIX DESIGN**

- A. Proportioning Normal Weight Concrete: Comply with ACI 211.1 recommendations.
- B. Concrete Mix for Pedestrian (Sidewalk) Pavements, Natural Color, unless indicated otherwise: SSPWC, Section 201-1.1.2 - Class 520-B-3000, with minimum slump of 4 inches.

- C. Concrete Mix for Trash Enclosure and other Exterior Slabs on Grade: ASTM C94/C94M - Ready-Mixed Concrete, Alternative No. 2, minimum 28 day compressive strength as indicated on Drawings or, if not indicated; 3000 psi.
- D. Concrete Strength: Establish required average strength for each type of concrete on the basis of field experience or trial mixtures, as specified in 28 CFR 35.
  - 1. For trial mixtures method, employ independent testing agency acceptable to Architect for preparing and reporting proposed mix designs.
- E. Admixtures: Add acceptable admixtures as recommended in ACI 211.1 and at rates recommended by manufacturer.
  - 1. Use accelerating admixtures in cold weather or set retarding admixtures in hot weather only when approved by Architect. Do not use calcium chloride.
- F. Concrete Properties:
  - 1. Compressive strength, when tested in accordance with ASTM C39/C39M at 28 days; 3,250 psi.
  - 2. Water-Cement Ratio: Maximum 50-60 percent at point of placement, or according to indicated concrete strength.
  - 3. Maximum Slump: 4 inches.

## **2.08 MIXING**

- A. Transit Mixers: Comply with ASTM C94/C94M.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify compacted stabilized soil is acceptable and ready to support paving and imposed loads.
- B. Fine grading, checking, shaping, and compacting of subgrade shall be complete before start of concrete paving Work.
- C. Verify gradients and elevations of base are correct.

### **3.02 SUBBASE**

- A. Prepare subbase in accordance with local community adopted version of SSPWC standards.
- B. For pavement subject to vehicular traffic, provide sub-base and aggregate base material specified in Section 32 11 23 - Aggregate Base Courses and as indicated on the Drawings.
- C. Aggregate base is not required under Portland cement concrete paving subject only to pedestrian traffic in normal use.

### **3.03 PREPARATION**

- A. Project Conditions:
  - 1. Water and Dust Control: Maintain control of concrete dust and water at all times. Do not allow adjacent planting areas to be contaminated.
  - 2. Do not place pavement when base surface or ambient temperature is less than 40 degrees F or if base surface is wet or frozen.

3. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.
- B. Moisten base to minimize absorption of water from fresh concrete. Do not place concrete on standing water.
- C. Notify Architect minimum 24 hours prior to commencement of concreting operations.
- D. Curbs and Gutters: Schedule portland cement concrete curbs and gutters to be in place and cured prior to start of adjoining asphaltic concrete and portland cement concrete paving Work.

### **3.04 COORDINATION WITH EXISTING CONSTRUCTION**

- A. Connection to Existing Construction: Where new concrete is doweled to existing construction, drill holes in existing concrete, insert steel dowels and pack with non-shrinking grout.
- B. Preparation of Existing Concrete: Prepare previously placed concrete by cleaning with steel brush and apply bonding agent in accordance with manufacturer's instructions.

### **3.05 FORMING**

- A. Place and secure forms to correct location, dimension, profile, and gradient.
  1. Surfaces and Edges: Except where special finishes and tooled edges are indicated, provide all exposed finish surfaces of dense concrete with sharp arises and outside corners.
- B. Assemble formwork to permit easy stripping and dismantling without damaging concrete.
- C. Place joint filler vertical in position, in straight lines. Secure to formwork during concrete placement.

### **3.06 REINFORCEMENT**

- A. Place reinforcement at midheight of slabs-on-grade.
- B. Reinforcement Placement, General: Locate reinforcement as indicated on Drawings or in Standard Specifications, whichever is more stringent.
  1. Locate reinforcement to provide required cover by concrete. If not otherwise indicated on Drawings or in Standard Specifications, provide concrete cover in compliance with ACI 318, Article 20.6.1.3.
  2. Place, support and secure reinforcement against displacement.
- C. Reinforcement Spacing: Space reinforcement as indicated on Drawings or in Standard Specifications, whichever is more stringent. If not indicated, maintain clear spacing of two times bar diameter but not less than 1-1/2 inch nor less than 1-1/3 times maximum size aggregate.
- D. Coordination: Locate reinforcement to accommodate embedded products and formed openings and recesses.
- E. Reinforcement Supports: Provide load bearing pads under supports or provide precast concrete block bar supports.
- F. Interrupt reinforcement at contraction and expansion joints.

- G. Place dowels to achieve pavement and curb alignment as detailed.
  - 1. Secure tie dowels in place before depositing concrete. Provide No. 3 bars, 18 inch long at 24 inches O.C. for securing dowels where no other reinforcement is provided.

### **3.07 COLD AND HOT WEATHER CONCRETING**

- A. Follow recommendations of ACI 305R when concreting during hot weather.
- B. Follow recommendations of ACI 306R when concreting during cold weather.
- C. Do not place concrete when base surface temperature is less than 40 degrees F, or surface is wet or frozen.

### **3.08 PLACING CONCRETE**

- A. Mixing: If batch plant is within travel time not exceeding maximum limits, transit mix concrete in accordance with ASTM C94/C94M. If travel time exceeds limits, provide alternative means for mixing and submit for review and approval.
- B. Place concrete in accordance with ACI 304R.
- C. Do not place concrete when base surface is wet.
- D. Ensure reinforcement, inserts, embedded parts, formed joints are not disturbed during concrete placement.
- E. Place concrete continuously over the full width of the panel and between predetermined construction joints. Do not break or interrupt successive pours such that cold joints occur.
- F. Use internal vibration to consolidate concrete around reinforcing per industry guidelines.

### **3.09 JOINTS**

- A. Align curb, gutter, and sidewalk joints.
- B. Place 1/2 inch wide expansion joints as indicated on Drawings (if not indicated provide at 20 foot intervals) and to separate paving from vertical surfaces and other components and in pattern indicated.
  - 1. Place in all concrete walks, other exterior flatwork and concrete curbs and gutters.
  - 2. If expansion joints are not indicated, comply with standard details and specifications of authorities having jurisdiction, including Standard Details for Public Works Construction and Standard Specification for Public Works Construction, as applicable.
  - 3. Place expansion control filler to correct elevation and profile. Form joints with joint filler extending from bottom of pavement to within 1/2 inch of finished surface.
  - 4. Secure to resist movement by wet concrete.
  - 5. Coordinate locations to align expansion joints in adjoining concrete walks, curbs, gutters and other exterior flatwork.
  - 6. Provide expansion joints also at beginning and end of all curved segments.
  - 7. Provide expansion joints also at intersections of concrete curbs and gutters and building footing.
  - 8. Provide expansion joints also at intersections of concrete paving and building footing.

9. Lay out expansion joint locations to occur where possible at penetrations such as handrail posts and columns.
  10. Place expansion control filler to correct elevation and profile.
- C. Provide scored joints:
1. As indicated on Drawings. If not indicated, locate joints in compliance with Standard Details and as indicated below.
  2. Evenly spaced at maximum 5 feet intervals for vehicular paving and 5 feet for pedestrian paving.
  3. Between sidewalks and curbs.
  4. Between curbs and pavement.
  5. Lay out control joint locations to occur at penetrations such as handrail posts and columns and where shown on Drawings.
  6. Refer to Architectural, Landscape and Civil Drawings for additional information and joint locations.
- D. Provide keyed joints as indicated.
- E. Saw cut contraction joints 1/8 inch wide at an optimum time after finishing. Cut 1/3 into depth of slab.

### 3.10 FINISHING

- A. Sidewalk Paving: As indicated on Drawings, minimum equal to Light broom, texture perpendicular to direction of travel with troweled and radiused edge 1/4 inch radius.
1. Broomed: Pull broom across freshly floated concrete to produce medium texture in straight lines perpendicular to main line of traffic. Do not dampen brooms.
  2. Tooled Joints: 1-inch deep by 3/16-inch wide tooled joints with 1/8-inch radius corners.
- B. Specific Finishes: Where indicated on Drawings.
1. Concrete Paving Finish: 28 CFR 35, two-step trowel finish, followed after surface has achieved initial set by flooding of surface and light rubbing with bristle brush so that concrete fines are exposed slightly.
    - a. Finish surface less than 6 percent shall receive medium broom finish resembling medium grit sandpaper. CBC 11B-403 and 11B-302.1.
    - b. Finish surface greater than 6 percent shall receive heavy broom finish. CBC 11B-403 and 11B-302.1.
    - c. Surfaces shall have static coefficients of friction of 1.3 to 1.6 (dry) and 1.2 to 1.4 (wet) when field tested in accordance with ASTM D2047.
- C. Curing and Sealing:
1. Place curing compound on exposed concrete surfaces immediately after finishing. Apply in accordance with manufacturer's instructions.
  2. Integrally Colored Concrete: Apply curing compound for integrally colored concrete according to manufacturer's instructions using manufacturer's recommended application techniques. Apply curing and sealing compound at consistent time for each pour to maintain close color consistency.

- a. Curing compound shall be same color as the colored concrete and supplied by same manufacturer of the colored admixture.
3. Precautions shall be taken in hot weather to prevent plastic cracking resulting from excessively rapid drying at surface as described in CIP 5 Plastic Shrinkage Cracking published by the National Ready Mixed Concrete Association.
4. Do not cover concrete with plastic sheeting.

### **3.11 JOINT SEALING**

- A. See Section 3948 - 3948 for joint sealer requirements.

### **3.12 TOLERANCES**

- A. 28 CFR 35, Class B, except paving in public rights-of-way shall comply with the Standard Specifications.
- B. Maximum Variation of Surface Flatness: 1/4 inch in 10 ft.
- C. Maximum Variation From True Position: 1/4 inch.
- D. Control-joint grooves and other conspicuous lines:
  1. 1/4 inch maximum in any 20 feet.
  2. 1/2 inch maximum in any 40 feet.
- E. Variation in Cross-Sectional Thickness of Slabs:
  1. Minus 1/4 inch.
  2. Plus 1/2 inch.
- F. Variation in Radii
  1. In radii of less than 10 feet:
    - a. 1/8 inch in any 5 feet.
    - b. 1/4 inch in any 10 feet.
  2. In radii of 20 feet:
    - a. 1/4 inch in any 10 feet.
    - b. 3/8 inch in any 20 feet
  3. In radii of 30 feet or more:
    - a. 1/2 inch in any 20 feet.
    - b. 1 inch in any 30 feet.
- G. Coefficient of Friction for Finish Surface:
  1. Pedestrian Vehicular Finish Surface: Minimum 0.6 static coefficient of friction is required for all concrete paving finish surface. All concrete paving surfaces to be broom finish.
  2. Ramps: Minimum 0.8 static coefficient of friction is required for all concrete paving finish surfaces on ramps. All concrete paving surfaces on ramps to be broom finish.

### **3.13 FIELD QUALITY CONTROL**

- A. An independent testing agency will perform field quality control tests, as specified in Section 01 45 00 - Quality Control.

1. Provide free access to concrete operations at project site and cooperate with appointed firm.
  2. Submit proposed mix design of each class of concrete to inspection and testing firm for review prior to commencement of concrete operations.
  3. Tests of concrete and concrete materials may be performed at any time to ensure compliance with specified requirements.
- B. Compressive Strength Tests: ASTM C39/C39M. For each test, mold and cure three concrete test cylinders. Obtain test samples for every 75 cu yd or less of each class of concrete placed each day.
1. Take one additional test cylinder during cold weather concreting, cured on job site under same conditions as concrete it represents.
  2. Perform one slump test for each set of test cylinders taken.
- C. Maintain records of placed concrete items. Record date, location of pour, quantity, air temperature, and test samples taken.

### **3.14 PROTECTION**

- A. Immediately after placement, protect pavement from premature drying, excessive hot or cold temperatures, and mechanical injury.
- B. Do not permit pedestrian traffic over pavement until 75 percent design strength of concrete has been achieved.

**END OF SECTION**

**SECTION 32 17 23.13**  
**PAINTED PAVEMENT MARKINGS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Parking lot markings, including parking bays, crosswalks, accessibility symbols, and curb markings.
- B. "No Parking" curb painting.
- C. Existing Striping: Confirm compliance at all accessible parking spaces on site and path of travel with California Building Code and Access requirements.
  - 1. Remove non-compliant and provide all striping and modifications necessary for compliance.

**1.02 REFERENCE STANDARDS**

- A. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- B. FED-STD-595C - Colors Used in Government Procurement (Fan Deck); 2008 (Chg Notice 1).
- C. FS TT-B-1325 - Beads (Glass Spheres); Retro-Reflective; 2007d (Validated 2017).
- D. FS TT-P-1952 - Paint, Traffic Black, and Airfield Marking, Waterborne; 2015f.
- E. SAE AMS-STD-595 - Colors Used in Government Procurement; 2017a.
- F. MPI (APL) - Master Painters Institute Approved Products List; Master Painters and Decorators Association; Current Edition.
- G. FHWA MUTCD - Manual on Uniform Traffic Control Devices for Streets and Highways; U.S. Department of Transportation, Federal Highway Administration; Current Edition.
- H. SCAQMD 1113 - Architectural Coatings; 1977 (Amended 2016).

**1.03 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
  - 1. Preparation instructions and recommendations.
  - 2. Storage and handling requirements and recommendations.
  - 3. Installation methods.
- C. Certificates: Submit for each batch of paint and glass beads stating compliance with specified requirements.
- D. Maintenance Materials: Furnish the following for District's use in maintenance of project.
  - 1. See Section 01 63 00 - Product Substitution Procedures, for additional provisions.
  - 2. Extra Paint: 2 containers, 1 gallon size, of each type and color.

**1.04 QUALITY ASSURANCE**

- A. Regulatory Requirements:
  - 1. See restrictions regarding CalGreen requirements.



- a. Comply at time of installation with Air Quality standards of:
  - 1) South Coast Air Quality Management District, SCAQMD 1113.
  - 2) California Air Resources Board (CARB).
- 2. For accessibility markings see Part 3 Article "Installation".
- 3. Where reference is made to Standard Specifications, the following shall apply.
  - a. Perform on-site Work as indicated and referenced on the Contract Drawings and as specified herein.
- B. Applicator Qualifications: Company regularly engaged in pavement marking, well-experienced in use of machine-applied painted stripes and other markings, with three years of verifiable experience.

### **1.05 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver paint in containers of at least 5 gallons accompanied by batch certificate.
- B. Deliver glass beads in containers suitable for handling and strong enough to prevent loss during shipment accompanied by batch certificate.
- C. Store products in manufacturer's unopened packaging until ready for installation.
- D. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

### **1.06 FIELD CONDITIONS**

- A. Do not install products under environmental conditions outside paint manufacturer's absolute limits.
  - 1. Do not apply marking paint when weather is foggy or rainy, or when ambient or pavement temperatures are below 40 degrees F., or when such conditions are anticipated within eight hours of application.
- B. Do not apply marking paint when wind velocity causes uncontrollable overspray or excessively rapid drying.
- C. Sequence and Schedule: Apply pavement markings after asphaltic concrete and portland cement concrete and interlocking concrete paving Work are complete and properly cured and, if applicable, sealer has been applied to asphaltic concrete and landscaping Work is complete.

## **PART 2 PRODUCTS**

### **2.01 MATERIALS**

- A. General: Provide standard factory-mixed, quick drying and non-bleeding colors, conforming to Standard Specifications, as amended and adopted by the AHJ, City, and County, as applicable.
- B. Line and Zone Marking Paint: MPI (APL) No. 97 Latex Traffic Marking Paint; color(s) as indicated.
  - 1. Parking Lots: Fast-dry type. If required by authorities having jurisdiction for Work in public rights-of-way, include reflective material in paint. Paint for marking curbs shall not require reflective material. See Color Schedule in Part 3.

2. Accessibility Symbols: Blue shall conform to Color No. 15090, FED-STD-595C. (SAE AMS-STD-595)
- C. Paint For Obliterating Existing Markings: FS TT-P-1952; black for bituminous pavements, gray for portland cement pavements.
- D. Reflective Glass Beads: FS TT-B-1325, Type I (low index of refraction), Gradation A (coarse, drop-on); with silicone or other suitable waterproofing coating to ensure free flow.
  1. Comply with CALTRANS State Specification No. 8010-51J-22, Type II, and CBC Section 11B-502.6 Identification.
- E. Temporary Marking Tape: Preformed, reflective, pressure sensitive adhesive tape in color(s) required; Contractor is responsible for selection of material of sufficient durability as to perform satisfactorily during period for which its use is required.

### **PART 3 EXECUTION**

#### **3.01 EXAMINATION**

- A. Do not begin installation until substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

#### **3.02 PREPARATION**

- A. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- B. Clean surfaces thoroughly prior to installation.
  1. Remove dust, dirt, and other granular surface deposits by sweeping, blowing with compressed air, rinsing with water, or a combination of these methods.
- C. Where oil or grease are present, scrub affected areas with several applications of trisodium phosphate solution or other approved detergent or degreaser, and rinse thoroughly after each application; after cleaning, seal oil-soaked areas with cut shellac to prevent bleeding through the new paint.
- D. Establish survey control points to determine locations and dimensions of markings; provide templates to control paint application by type and color at necessary intervals.
  1. Lay out markings as shown on Drawings. Use guide lines, templates and forms for precise edges and spacings.
    - a. At off-site and on-site public rights-of-way, obtain review and approval of layout by authorities having jurisdiction.
- E. Temporary Pavement Markings: When required or directed by Architect, apply temporary markings of the color(s), width(s) and length(s) as indicated or directed.
  1. After temporary marking has served its purpose, remove temporary marking by carefully controlled sandblasting, approved grinding equipment, or other approved method so that surface to which the marking was applied will not be damaged.
  2. At Contractor's option, temporary marking tape may used in lieu of temporary painted marking; remove unsatisfactory tape and replace with painted markings at no additional cost to District.

### 3.03 INSTALLATION

#### A. Regulatory Accessibility Requirements for Installation:

1. Pavement markings for disability requirements shall meet requirements of California Building Code (CBC), Title 24, Part 2, Chapter 11B and ADA Accessibility Guidelines for Buildings and Facilities, per latest amendments.
  - a. Accessible parking spaces serving a particular building or facility shall be located, and dispersed if serving more than one accessible entrance, on the shortest accessible route to an entrance or to multiple accessible entrances. CBC Sections 11B-208.3.1
  - b. Accessible parking spaces in a parking facility not serving a particular building or facility shall be located on the shortest accessible route to an accessible pedestrian entrance of the parking facility. CBC Sections 11B-208.3.1
  - c. Minimum number of required accessible parking spaces shall be provided in accordance with CBC Table 11B-208.2 for each parking facility provided.
  - d. For every six or fraction of six accessible parking spaces, at least one shall be an accessible van parking space. CBC Section 11B-208.2.4
  - e. Accessible parking spaces and access aisles shall comply with CBC Section 11B-502 and shall be dimensioned to the centerline of the marked lines as follows:
    - 1) Parking spaces and access aisles shall be marked according to CBC Figures 11B-502.2, 11B-502.3, and 11B-502.3.3.
      - (a) Their surfaces shall comply with CBC Section 11B-302 and shall be at the same level with slopes not steeper than 1:48 in any direction. CBC Section 11B-502.4.
    - 2) Parking spaces shall be 9 x 18 feet minimum and van parking spaces shall be 12 x 18 feet minimum with an adjacent access aisle of 5 x 18 feet minimum.
      - (a) Access aisles shall be placed on either side of the parking spaces except be located on the passenger side for van parking spaces.
      - (b) Van parking spaces shall be permitted to be 9 x 18 feet minimum where the access aisle is 8 x 18 feet minimum.
    - 3) Access aisles shall be marked by a blue painted borderline around their perimeter.
      - (a) The area within the blue borderlines shall be marked with hatched lines a maximum of 36 inches on center in a color contrasting with that of the aisle surface, preferably blue or white.
      - (b) Access aisle markings may extend beyond the minimum required length. CBC Section 11B-502.3.3
      - (c) At drive aisle provide minimum 12 inch high white letters with the text "NO PARKING" per CBC Figure 11B-502.3.3.
    - 4) Access aisles (parking spaces as well- similar application) shall not overlap the vehicular way. CBC Section 11B-502.3.4
    - 5) A vertical clearance of 98 inches minimum shall be provided for accessible parking spaces, access aisles, and vehicular routes serving them. CBC Section 11B-502.5

- B. General: Using proper masking, stencils and application equipment, apply marking paint at rate recommended by paint manufacturer or approximately one gallon per 150 square feet

(equivalent to approximately one gallon for 450 lineal feet of 4-inch wide stripe), whichever is greater.

1. Equipment shall be capable of operating at 125 psi air pressure, agitate paint constantly and hold exactly to the alignment.
  2. Equipment used for applying reflectorized striping shall be equipped with a bead dispenser capable of applying beads at the specified rate.
- C. Begin pavement marking as soon as practicable after surface has been cleaned and dried.
- D. Do not apply paint if temperature of surface to be painted or the atmosphere is less than 50 degrees F or more than 95 degrees F.
- E. Apply in accordance with manufacturer's instructions using an experienced technician that is thoroughly familiar with equipment, materials, and marking layouts.
- F. Comply with FHWA MUTCD manual (<http://mutcd.fhwa.dot.gov>) for details not shown.
- G. Apply markings in locations determined by measurement from survey control points; preserve control points until after markings have been accepted.
- H. Apply uniformly painted markings of color(s), lengths, and widths as indicated on drawings true, sharp edges and ends.
1. Apply paint in one coat only.
  2. Wet Film Thickness: 0.015 inch, minimum.
  3. Length Tolerance: Plus or minus 3 inches.
  4. Width Tolerance: Plus or minus 1/8 inch.
- I. Curbs: Paint full vertical face and first 6-inches of horizontal plane at top of curb or combination curb/paving. Provide minimum 2 coats paint.
1. Provide stenciled text in the height, spacing and typeface as indicated on Drawings.
- J. Parking Lots: Apply parking space lines, entrance and exit arrows, painted curbs, and other markings indicated on drawings.
1. Mark the International Symbol of Accessibility at indicated parking spaces.
    - a. Accessibility Logo: Provide minimum of 2 coats paint.
      - 1) Comply with CBC Figure 11B-703.7.2.1.
    - b. Stall Marking:
      - 1) Use single-line style striping between parking stalls, unless otherwise indicated.
      - 2) Comply with local agency regulatory requirements.
      - 3) Accessible Stalls: Comply with ADA Standards and local agency regulatory requirements.
        - (a) Painted lines and markings on pavement shall be minimum 3 inches wide, color as indicated on Drawings
        - (b) Tactile warning lines shall comply with CBC Section 11B-705.1.2.5 Hazardous Vehicular Areas.
        - (c) Tactile warning devices shall comply with CBC, see Section 32 17 26 - Tactile Warning Surfacing.
    - c. Hatching: Provide hatching in parking areas, including accessible parking stalls, as indicated on Contract Drawings or as required by Standard Details. Should Contract Drawings and Standard Details conflict, comply with the more stringent.

- 2. Hand application by pneumatic spray is acceptable.
- K. Symbols: Use a suitable template that will provide a pavement marking with true, sharp edges and ends, of the design and size indicated.

**3.04 DRYING, PROTECTION, AND REPLACEMENT**

- A. Protect newly painted markings so that paint is not picked up by tires, smeared, or tracked.
  - 1. Prevent construction activities over completed markings, except light vehicular and pedestrian traffic.
- B. Provide barricades, warning signs, and flags as necessary to prevent traffic crossing newly painted markings.
- C. Allow paint to dry at least the minimum time specified by the applicable paint standard and not less than that recommended by the manufacturer.
- D. Touch-up paint as required to provide clean, straight lines and full coverage of surfaces.
- E. Remove and replace markings that are applied at less than minimum material rates; deviate from true alignment; exceed length and width tolerances; or show light spots, smears, or other deficiencies or irregularities.
- F. Remove markings in manner to avoid damage to the surface to which the marking was applied, using carefully controlled sand blasting, approved grinding equipment, or other approved method.
- G. Replace removed markings at no additional cost to District.
  - 1. Clean up all oil, paint splatters and other stains from surfaces in preparation for Substantial Completion review.

**3.05 COLOR SCHEDULE**

- A. Parking and On-Site Roadways

| <u>Location</u>  | <u>Color</u>   | <u>Reflectance**</u> |
|--|--|----------------------|
| Driving lane striping  | White  | 82%                  |
| Parking space striping   | White  | 82%                  |
| Accessible Parking, ISA, and zone markings                             | Blue No. 15090 per FED-STD-595C (SAE AMS-STD-595)                              | 52%                  |
| Accessible loading and cross-hatching                                  | A. White with Blue perimeter at Asphalt Paving.<br>B. Blue at Concrete Paving* | 82% / 52%<br>52%     |
| 12 inch high Text: "NO PARKING", "LOADING ZONE", and "FIRE LANE", etc. | White  | 82%                  |
| Firelanes / No Parking zone markings Special Use Markings              | Red No. 31350 per FED-STD-595C (SAE AMS-STD-595)                               | 52%                  |
| Loading zone markings  | Orange Yellow No. 33538 per FED-STD-595C (SAE AMS-STD-595)                     | 52%                  |
| Directional arrows   | White  | 82%                  |

|   |  |     |
|---|--|-----|
| Speed Bumps   | Orange Yellow No. 33538 per FED-STD-595C (SAE AMS-STD-595) | 52% |
| Black special-use pavement markings, if indicated on Drawings | Black No. 37038 per FED-STD-595C (SAE AMS-STD-595)         | NA  |

\*Contrasting color per CBC.

a. See also Division of the State Architect IR 11B-7.

\*\*Daylight directional reflectance (without glass beads) , when tested in accordance with Federal Test Method Standard 141A, Method 612.

**END OF SECTION**



**SECTION 32 17 26**  
**TACTILE WARNING SURFACING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Plastic tactile and detectable warning tiles for pedestrian walking surfaces. (if required)

**1.02 RELATED REQUIREMENTS**

- A. Section 32 13 13 - Concrete Paving: Concrete sidewalks.
- B. Section 32 17 23.13 - Painted Pavement Markings: Crosswalk and curb markings.

**1.03 REFERENCE STANDARDS**

- A. 49 CFR 37 - Transportation Services for Individuals with Disabilities (ADA); current edition.
- B. ASTM D2047 - Standard Test Method for Static Coefficient of Friction of Polish-Coated Flooring Surfaces as Measured by the James Machine; 2011.
- C. ADA Standards - Americans with Disabilities Act (ADA) Standards for Accessible Design; 2010.
- D. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2015.
- E. ASTM B117 - Standard Practice for Operating Salt Spray (Fog) Apparatus; 2018.
- F. ASTM C501 - Standard Test Method for Relative Resistance to Wear of Unglazed Ceramic Tile by the Taber Abraser; 1984 (Reapproved 2015).
- G. ASTM C903 - Standard Practice for Preparing Refractory Specimens by Cold Gunning; 2015, with Editorial Revision (2016).
- H. ASTM D543 - Standard Practices for Evaluating the Resistance of Plastics to Chemical Reagents; 2014.
- I. ASTM D570 - Standard Test Method for Water Absorption of Plastics; 1998 (Reapproved 2010).
- J. ASTM D638 - Standard Test Method for Tensile Properties of Plastics; 2014.
- K. ASTM D695 - Standard Test Method for Compressive Properties of Rigid Plastics; 2015.
- L. ASTM D790 - Standard Test Methods for Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials; 2016.
- M. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2018b.
- N. ASTM G155 - Standard Practice for Operating Xenon Arc Light Apparatus for Exposure of Nonmetallic Materials; 2013.
- O. ATBCB PROWAG - Proposed Accessibility Guidelines for Pedestrian Facilities in the Public Right-of-Way; 2011.
- P. SAE AMS-STD-595 - Colors Used in Government Procurement; 2017a.
- Q. California Department of General Services, Division of the State Architect, Interpretation of Regulations Document:



1. IR A-5 - Acceptance of Products, Materials and Evaluation Reports; Revised 1/27/17.

#### **1.04 SUBMITTALS**

- A. See Section 01 33 00 - Submittal Procedures, for submittal procedures.
- B. Product Data: Submit manufacturer's product data, standard details, details specific to this project; written installation and maintenance instructions.
- C. Samples: For each product specified provide two samples, 8 inches square, minimum; show actual product, color, and patterns.
- D. Shop Drawings: Submit plan and detail drawings. Indicate:
  1. Locations on project site. Demonstrate compliance with referenced accessibility standards.
  2. Sizes and layout.
  3. Pattern spacing and orientation.
  4. Attachment and fastener details, if applicable
- E. Warranty: Submit manufacturer warranty; complete forms in District's name and register with manufacturer.
- F. Certification: Manufacturers certification that product meets ADA for tactile warning surfaces.

#### **1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than five years documented experience.
- B. Installer Qualifications: Company certified in writing by product manufacturer as having successfully completed work substantially similar to the work of this section.

#### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver to project site in manufacturer's protective wrapping and in manufacturer's unopened packaging.
- B. Store covered and elevated above grade and in manufacturer's unopened packaging until ready for installation. Maintain at ambient temperature between 40 and 90 degrees F.

#### **1.07 WARRANTY**

- A. See Section 01 77 00 - Closeout Procedures, for additional warranty requirements.
- B. Provide manufacturer's standard five year warranty against manufacturing defects, breakage or deformation.
  1. Provide minimum 5 year warranty per DSA Bulletin 10/31/02, revised 04/09/08.

## **PART 2 PRODUCTS**

### **2.01 REGULATORY REQUIREMENTS**

- A. Detectable warnings shall comply with California Building Code (CBC) Section 11B-705.1 requirements, Section 11B-705.1.2 Locations and 11B-705.1.2.5 Hazardous Vehicular Areas, for special warnings for disabled persons.
- B. Nominal dimensions meeting Section 11B-705.1.2 Locations.
- C. Color contrast requirements meeting Section 11B-705.1.1.3 Contrast.
- D. Detectable warning surfaces at transit boarding platform edges, bus tops, hazardous vehicle areas, reflecting pools, and track crossings shall be yellow and approximate Federal Color No. 33538 as shown in SAE AMS-STD-595 (Table IV of Federal Standard No. 595C).
  - 1. Detectable warning surfaces at other locations shall be either the aforementioned yellow or a color providing a 70 percent minimum visual contrast with that of adjacent walking surfaces.
  - 2. The materials used to provide visual contrast shall be an integral part of the surface. CBC Section 11B-705.1.1.3.
- E. Detectable warning surfaces shall differ from adjoining surfaces in resiliency or sound-on-cane contact. Such constraint shall not be required for detectable warning surfaces at curb ramps, islands, or cut-through medians. CBC Section 11B-705.1.1.4 Resiliency.
- F. Color yellow for detectable warning surface is required at all hazardous vehicle locations and shall conform to Federal Color No. 33538 as shown in Table IV of Federal Standard No. 595C. CBC Sections 11B-705.1.1.3 Color and Contrast.
  - 1. Except for locations at curb ramps, islands, or cut-through medians where color used shall contrast visually with that of adjacent walking surfaces, either light-on-dark, or dark on-light. CBC Sections 11B-705.1.1.3 Contrast and 11B-705.1.1.5 Color.
- G. Truncated dome pattern in-line, not staggered.

### **2.02 MANUFACTURERS**

- A. Plastic Tactile and Detectable Warning Surface Tiles:
  - 1. Access Tile, a brand of Access Products, Inc: [www.accesstile.com](http://www.accesstile.com).
  - 2. ADA Solutions, Inc: [www.adatale.com/#sle](http://www.adatale.com/#sle).
  - 3. Answer Industries: [www.answerindustries.com](http://www.answerindustries.com).
  - 4. Armor-Tile, a brand of Engineered Plastics, Inc: [www.armortiletransit.com/#sle](http://www.armortiletransit.com/#sle).
  - 5. Safety StepTD, Inc.; SSTD-Traditional Mat System: [www.safetystepTD.com](http://www.safetystepTD.com)
  - 6. Transpo Industries, Inc.: [www.transpo.com](http://www.transpo.com)
  - 7. Van-Duerr Industries, Inc.: [safepathproducts.com](http://safepathproducts.com).
  - 8. Substitutions: See Section 01 63 00 - Product Substitution Procedures.

### **2.03 TACTILE AND DETECTABLE WARNING TILES**

- A. Plastic Tactile and Detectable Warning Tiles: ADA Standards compliant, glass fiber and carbon fiber reinforced, exterior grade, matte finish polyester sheet with truncated dome pattern,

solid color throughout, internal reinforcing of sheet and of truncated domes, integral radius cut lines on back face of tile; with factory applied removable protective sheeting.

1. Material Properties:
  - a. Water Absorption: 0.20 percent, maximum, when tested in accordance with ASTM D570.
  - b. Slip Resistance: 0.50 minimum dry static coefficient of friction, when tested in accordance with ASTM D2047.
  - c. Compressive Strength: 25,000 pounds per square inch, minimum, when tested in accordance with ASTM D695.
  - d. Tensile Strength: 10,000 pounds per square inch, minimum, when tested in accordance with ASTM D638.
  - e. Flexural Strength: 25,000 pounds per square inch minimum, when tested in accordance with ASTM D790.
  - f. Chemical Stain Resistance: No reaction to 1 percent hydrochloric acid, motor oil, calcium chloride, gum, soap solution, bleach, or antifreeze, when tested in accordance with ASTM D543.
  - g. Abrasion Resistance: 300, minimum, when tested in accordance with ASTM C501.
  - h. Flame Spread Index: 25, maximum, when tested in accordance with ASTM E84.
  - i. Accelerated Weathering: Delta-E of less than 5.0 at 2,000 hours exposure, when tested in accordance with ASTM G155.
  - j. Adhesion: No delamination of tile prior to board failure in a temperature range of 20 to 180 degrees F, when tested in accordance with ASTM C903.
  - k. Loading: No damage when tested according to 29 CFR 1910.132-138 test method HS20.
  - l. Salt and Spray Performance: No deterioration or other defect after 200 hours of exposure, when tested in accordance with ASTM B117.
2. Installation Method: Surface applied.
3. Shape: Rectangular.
4. Dimensions: 24 inches by 36 inches.
  - a. Curb Ramp: Cover entire width of the ramp surface, minimum 36 inches along path of travel.
  - b. Drive Aisle: 36 inches along path of travel.
5. Dome Spacing: 2.3 to 2.4 inches per CBC Section 11B-705.1.1.2.
6. Pattern: In-line pattern of truncated domes complying with ADA Standards.
7. Edge: ADAAG compliant bevel.
8. Joint: Butt.
9. Color: SAE AMS-STD-595, Table IV, Federal Yellow No. 33538.
10. Basis of Design Product: SSTD Traditional Mat System as manufactured by Safety Step TD; [www.safetysteptd.com](http://www.safetysteptd.com), or approved equal.

## **2.04 ACCESSORIES**

- A. Fasteners: ASTM A666, Type 304 stainless steel

1. Type: Countersunk, color matched composite sleeve anchors
  2. Size: 1/4 inch diameter and 1-1/2 inches long.
- B. Adhesive: Type recommended and approved by surfacing tile manufacturer.
- C. Sealant: Elastomeric sealant of color to match adjacent surfaces; approved by surfacing tile manufacturer.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. When installation location is near site boundary or property line, verify required location using property survey.
- B. Verify that work area is ready to receive work:
1. If existing conditions are not as required to properly complete the work of this section, notify Architect.
  2. Do not proceed with installation until deficiencies in existing conditions have been corrected.
- C. Verify that dimensions, tolerances, and attachment methods for work in this section are properly coordinated with other work on site.

### **3.02 INSTALLATION, GENERAL**

- A. Install in accordance with manufacturer's written instructions.
1. Do not install damaged, warped, bowed, dented, abraded, or otherwise defective units.
  2. Do not install when ambient or substrate temperature has been below 40 degrees F during the preceding 8 daylight hours.
- B. Field Adjustment:
1. Cut units to size and configuration shown on drawings.
  2. Do not cut tiles to less than 9 inches wide in any direction.
  3. Locate relative to curb line in compliance with ATBCB PROWAG, Sections 304 and 305.
  4. Orient so dome pattern is aligned with the direction of ramp.
  5. Align truncated dome pattern between adjacent units.
- C. Install units fully seated to substrate, square to straight edges and flat to required slope.
- D. Align units so that tops of adjacent units are flush and joints between units are uniform in width.

### **3.03 INSTALLATION, PRECAST TILES**

- A. Concrete Substrate:
1. See Section 32 13 13 - Concrete Paving.
  2. Slump: 4 to 7 percent.
- B. When installing multiple adjacent units, leave a 3/16 inch gap between units to allow for expansion.

- C. Tamp and vibrate units as recommended by manufacturer.
- D. Place and position weights on units while concrete cures as recommended by manufacturer. Ensure no voids or air pockets exist between top surface of concrete and underside of units.

### **3.04 INSTALLATION, CAST IN PLACE PLASTIC TILES**

- A. Concrete:
  - 1. See Section 32 13 13 - Concrete Paving.
  - 2. Slump: 4 to 7 percent.
- B. When installing multiple adjacent units, leave a 3/16 inch gap between units to allow for expansion.
- C. Tamp and vibrate units as recommended by manufacturer.
- D. Place and position weights on units while concrete cures as recommended by manufacturer. Ensure no voids or air pockets exist between top surface of concrete and underside of units.

### **3.05 INSTALLATION, SURFACE APPLIED PLASTIC TILES**

- A. Cure concrete surfaces for a minimum of 4 days before installing units.
- B. Verify substrate is clean and dry; free of voids, projections and loose material. Remove dust, oil, grease, curing compounds, sealers and other substances that may interfere with adhesive bond or sealant adhesion.
- C. Mechanically roughen surface as required to remove contaminants and prepare surface for adhesive and sealant application.
- D. When installing multiple adjacent units, leave a 1/8 inch gap between tiles to allow for expansion.
- E. Drill fastener holes straight, true and to depth recommended by manufacturer.
- F. Apply adhesive to back of unit as recommended by manufacturer.
- G. Mechanically fasten to substrate. Avoid striking or damaging the unit itself during installation.
- H. Apply sealant to edges in cove profile.

### **3.06 PROTECTION**

- A. Protect installed units from traffic, subsequent construction operations or other imposed loads until concrete is fully cured.
- B. Touch-up, repair or replace damaged products prior to Date of Substantial Completion.

**END OF SECTION**